

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 95080
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 27/01/2026
Contact: Michelle Davis
Phone:

Asset Register - 06.1A Fire Resistant Doorsets Service Record							
Asset ID	Building - Location	Equipment Number		Install # / Sub	Date	Service	Pass / Fail
93522	Entire Site	-		-	27/01/2026	3 Monthly	Fail
Test Readings	Work Order Number: JAN 26 SM		Site Attendance Record Number:: 106706		--- TABLE 12.4.3.2 THREE-MONTHLY AND SIX-MONTHLY SERVICE SCHEDULE HORIZONTAL SLIDING DOORS FIRE-RESISTANT DOORSETS: 2026-01-27		
	---THREE-MONTHLY 2.1 Frictional forces, operation and self-closing ability SIMULATE a full operational test (mechanically and electronically) as appropriate to ensure correct automatic closing of the door is achieved. CHECK operation to ensure the door fully closes from the fully open position and from one intermediary position.: Fail		Have all previously reported defects been rectified: No		Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - Maintenance complies with QDC, MP6.1:: No		
	Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - System is in proper working order:: No						
Failure Points	Performed 3 Monthly Testing and Maintenance - Issues Found - Refer to Assets for Defects / Failures and/or Recommendations. - 12.4.3.2						
Notes	Faults as reported and failures present.						

Asset Register - 06.1 Passive Fire and Smoke Systems - Fire Resistant Doorsets - AS1851.2012									
Asset ID	Location	Equipment Number	Door Number	Building Number	Door Type	Tag Number	Date	Service	Pass / Fail
96779	GF Shopping Centre to East Entry Foyer	1706	1706	Shopping Centre	Sliding Fire Door	Unable to see	27/01/2026	3 Monthly	Fail
Test Readings	Attendance Record No. (If Applicable):								
Failure Points	2.1 - other - 12.4.3.2								
Notes	As previously reported Unable to test as manual release facility is inaccessible/not installed.								
96780	GF Shopping Centre to Hotel Lobby	1707	1707	Shopping Centre	Sliding Door	.	27/01/2026	3 Monthly	Fail
Test Readings	Attendance Record No. (If Applicable):								
Failure Points	2.1 - other - 12.4.3.2								

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 95080
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 27/01/2026
Contact: Michelle Davis
Phone:

Notes	As previously reported Unable to test as manual release facility is inaccessible/not installed.								
119901	L1 Kitchen	290	.	Ramp between kitchen and pool	Sliding Fire door	6990077	27/01/2026	3 Monthly	Pass
Test Readings	Attendance Record No. (If Applicable):								
119900	L1 kitchen	289	.	Walkway between kitchen and pool	Automatic sliding	6990077	27/01/2026	3 Monthly	Pass
Test Readings	Attendance Record No. (If Applicable):								

Description Of Work

Asset ID 93522 - Asset Type 06.1A Fire Resistant Doorsets Service Record - Service Level 3 Monthly - Service Due Date 01/01/2026

Comments / Recommendations

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Aaron Nixon

Licence No.

1250392

Customer (Print Name):

Technician (Signature):



Customer (Signature):