

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.6 Portable Fire Equipment Service Record - AS1851.2012									
Asset ID	Building Location	Extinguishers	Fire Blankets	Hose Reels	Form 72 No. - if applicable	Date	Service	Pass / Fail	
93646	Entire Site	Yes	Yes	Yes		09/04/2025	Yearly	Fail	
Test Readings	Asset Type: Fire Extinguisher, Fire Hose Reel, Fire Blanket			Work Order Number: APR 25 SM PORT A		Site Attendance Record Number:: A 106670			
	Table 10.4.1 6 MONTHLY ROUTINE SERVICE SCHEDULE - FIRE EXTINGUISHERS: 2025-04-09			--- 1.1 Accessibility - CHECK the extinguisher is conspicuous, readily accessible and in its assigned location. All Extinguisher types : Fail		--- 1.2 Anti-tamper device -CHECK that the anti tamper device is intact. All Extinguisher types : Pass			
	--- 1.3 Exterior and operating instructions - CHECK that the extinguisher is clean and the operating instructions are legible. All extinguisher types : Pass			--- 1.4 Servcie tag or label -- CHECK that the service tag or label is firmly attached to the extinguisher. All Extinguisher types : Pass		--- 1.5 External damage - CHECK that the extinguisher , including any attachments, is not damaged (see AS 2337.1) All Extinguisher types : Pass			
	--- 1.6 External corrosion - CHECK that the exterior of the extinguisher is not pitted or otherwise damaged by corrosion (see Clause 10.2.5 and AS 2337.1) All extinguisher types : Pass			--- 1.7 Outlet hose assembly - CHECK that the hose is securely fitted, the nozzle is securely attached and the assembly is free from obstruction, and the hose shows no cracking, or other signs of damage or deterioration. All extinguisher types : Pass		--- 1.8 Pressure Indicator - Where fitted, CHECK that the pressure indicator is legible, and registering within operable range. All extinguisher types : Pass			
	--- 1.9 Contents - WEIGH the extinguisher to determine that it is fully charged. All extinguisher types : Pass			--- 1.10 Signage - CHECK that the location sign is visible. All extinguisher types: Fail		--- 1.11 Support Bracket - CHECK that the appropriate support bracket is securely attached to wall or other suitable feature. All extinguisher types : Pass			
	--- 1.12 Discharge Nozzle - CHECK that the appropriate discharge nozzle is fitted and is not blocked or damaged. All extinguisher types : Pass			--- 1.13 Discharge nozzle and control valve - CHECK that the discharge nozzle is not blocked and that the control valve is functional. All wheeled extinguishers : N/A		--- 1.14 Carriage Assembly - CHECK that the carriage assembly is functional and free form corrosion. All wheeled extinguishers : N/A			
	--- 1.15 Powder- Portable extinguishers - INVERT the extinguisher and ensure that the powder remains free flowing. Powder (stored pressure), powder (gas container) : Fail			--- 1.16 Compressed gas container - DETERMINE that the compressed gas container is the correct type and size, in good condition, fully charged, and subjected to service as per AS 2030.5. All gas container extinguishers : Pass		--- 1.17 Actuating device - DETERMINE where possible and without discharging any contents, that the actuating device is free of corrosion, moves freely and is undamaged. Water(stored pressure),wet chemical, foam(stored pressure),powder(stored pressure), Carbon Dioxide, vaporizing liquid : Pass			
	--- 1.18 Internal components - DETERMINE that the internal discharge tube and strainer (where fitted) provide clear passage and are securely attached. Water (gas container), foam (gas container) : N/A			--- 1.19 Tyres - DETERMINE that pneumatic tyres, where fitted, are pressurised to the recommended pressure. All wheeled extinguishers : N/A		--- 1.20 Wheel - LUBRICATE wheel bearings (where applicable). All wheeled extinguishers : N/A			
	--- 1.21 Mobility - CHECK that the extinguisher moves readily on its wheels by rolling it for a distance of al least 5 meters. All wheeled extinguishers : N/A			Table 10.4.2 AUSTRALIA STANDARD YEARLY ROUTINE SERVICE SCHEDULE - FIRE EXTINGUISHERS: 2025-04-09		--- 2.1 Six-monthly service - COMPLETE all six-monthly activities, as listed in Table 10.4.1: Pass			
	--- 2.2 Operating head or cap - CHECK that the threads on operating head or cap are not damaged, vent(s) is (are) not blocked, and any strainer or expansion device is unobstructed. For heads with no screw thread, determine that security locking device is undamaged and operational. Water (gas container), foam (gas container), water with additive (stored pressure), foam (stored pressure), powder (stored pressure): N/A			--- 2.3 Discharge - CHECK that the extinguisher functions in accordance with the operating instructions and that the discharge is satisfactory. Recharge in accordance with Item 2.8. - (a) Water with additive (stored pressure), foam (stored pressure) : N/A		--- 2.3 Discharge - CHECK that the extinguisher functions in accordance with the operating instructions and that the discharge is satisfactory. Recharge in accordance with Item 2.8. - (b) *Water with corrosion inhibitors or freezing point depressants (stored pressure). (*To be discharged on a three-yearly frequency): N/A			
	--- 2.4 Actuating device - CHECK that the actuating device is free of corrosion, moves freely, and is undamaged: any cutting edge is sharp:			--- 2.5 Internal components - (a) CHECK that the internal discharge tube, strainer and anti-overfill tube (where fitted) provide clear		--- 2.5 Internal components - (b) Check that the internal discharge tube, or gas inlet tube or ports, provide clear passage and are			

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

and all sealing gaskets are in good condition. Water (gas container), foam (gas container), foam (stored pressure), powder (gas container): N/A	passage and are securely attached, and that the anti-overfill device is undamaged. Water with additive (stored pressure), foam (stored pressure) : N/A	correctly installed, and that the powder is free flowing. Powder (gas container): N/A
--- 2.6 Internal condition-Portable extinguishers - CHECK that the interior of the cylinder is clean , is not pitted by corrosion (see AS2337.1), and any internal lining is in good condition. Water (gas container), water with additive (stored pressure), foam (gas container), foam (stored pressure), powder (gas container): N/A	--- 2.7 Internal condition - wheeled extinguishers - CHECK that the interior of the cylinder is clean. Water (gas container), foam (gas container), foam (stored pressure): N/A	--- 2.8 Extinguishing agent replacement - RECHARGE the extinguisher with fresh extinguisher agent in accordance with the manufacturer's instructions. Water with additive (stored pressure), foam (gas container), foam (stored pressure) - Upon completion of recharging stored pressure type extinguishers, perform a leak test as per item 2.10.: N/A
--- 2.9 Seals - CHECK that the operating head or cap seal is in good condition. Water (gas container), water with additive (stored pressure), foam (gas container), foam (stored pressure), powder (gas container): N/A	--- 2.10 Leak detection - CHECK if there are any leaks at the joints and seals that were renewed or disturbed during recharging. Water with additive (stored pressure), foam (stored pressure): N/A	--- 2.11 Fire hazard - CHECK that the fire hazard/risk to be protected has not changed. All extinguisher types : Pass
--- 2.12 Suitability - CHECK that the extinguisher is correct type, class, size and /or rating for the hazard to be protected. All extinguisher types. : Pass	--- 2.13 Obstructions - (a) CHECK that no alterations have been made to the building that may impede access to the extinguisher or increase the travel distances to more than those specified in AS2444 or the approved design. All portable extinguishers : Pass	--- 2.13 Obstructions - (b) CHECK that no alterations have been made to the building that may impede access to , or restrict the movement of the extinguisher. All wheeled extinguishers : Pass
TABL 11.4 SIX-MONTHLY SERVICE SCHEDULE - FIRE BLANKETS: 2025-04-09	--- 1.1 Accessibility - CHECK that the fire blanket is: - (a) Conspicuous.: Pass	--- 1.1 Accessibility - CHECK that the fire blanket is: - (b) In its assigned location.: Pass
--- 1.1 Accessibility - CHECK that the fire blanket is: - (c) Readily accessible.: Pass	--- 1.1 Accessibility - CHECK that the fire blanket is: - (d) Installed in accordance with AS 2444.: Pass	--- 1.2 Signage - CHECK that the location sign is visible and correct.: Pass
--- 1.3 Blanket container - CHECK that the fire blanket container: - (a) Is securely and correctly supported.: Pass	--- 1.3 Blanket container - CHECK that the fire blanket container: - (b) Is clean and free from damage.: Pass	--- 1.3 Blanket container - CHECK that the fire blanket container: - (c) Has clear and legible instructions thereon.: Pass
--- 1.3 Blanket container - CHECK that the fire blanket container: - (d) Has a service record tag/label attached.: Pass	--- 1.4 Fire blanket - REMOVE the fire blanket from the container and check: - (a) For any damage or contamination to the fire blanket (refer also Clause 11.2.4): Fail	--- 1.4 Fire blanket - REMOVE the fire blanket from the container and check: - (b) For unsecured or damaged hand-holding devices.: Pass
--- 1.4 Fire blanket - REMOVE the fire blanket from the container and check: - (c) That the fire blanket is correctly folded. Where the fire blanket conforms to the above, REPACK the blanket into the container as recommended by the manufacturer. NOTE: It is important that fire blankets are always folded in the manner prescribed by the manufacturer in order that they can be removed from the container quickly (see AS/NZS 3504): Pass	TABLE 9.4.1 SIX-MONTHLY SERVICE SCHEDULE FIRE HOSE REELS: 2025-04-09	--- 1.1 Accessibility - CHECK that the hose reel is readily accessible with no obstacles restricting its access. Where a hose reel is installed in a recess or cabinet, CHECK that the clearances around the hose reel comply with the requirements of AS 2441.: Fail
--- 1.2 Signage - Where a location sign is required by AS 2441, CHECK that it is correctly located and visible.: Pass	--- 1.3 Operating instructions - CHECK that the operating instructions are legible.: Pass	--- 1.4 Damage - CHECK for any damage or corrosion of components that could adversely affect the operation of the hose reel.: Fail
--- 1.5 Cabinet - CHECK that any hose reel cabinet is accessible, clear of extraneous materials, clearly and correctly marked and in good repair.: Pass	--- 1.6 Nozzle interlock - CHECK that the nozzle is retained in the nozzle interlock.: Pass	--- 1.7 * Swing arm Where fitted, TEST the swing arm to ensure it operates correctly and allows the hose to be run off in its intended direction.: N/A
--- 1.8 * Unwind With the nozzle closed and stop valve open, TEST that the hose reel can be unwound freely in its intended direction by unwinding at least 5 m of hose.: Pass	--- 1.9 * Leakage With the nozzle closed, pressurize the reel by opening the stop valve. DETERMINE if there are any leaks from the reels waterway, including glands, nozzle, stop valve, hose or any fittings. NOTE: In order to check that there is no leakage of water from any part of the reel waterway, it is recommended that the hose be completely unwound off the reel, so that all parts of the waterway can be examined.: Fail	--- 1.10 * Flow TEST water to ensure it is able to flow through the reel by opening and closing the nozzle.: Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	--- 1.11 * Service tag or label CHECK that the service tag or label is firmly attached to the hose reel.: Pass --- 2.1 Six monthly service - COMPLETE all six-monthly service activities, as listed in Table 9.4.1.: Pass --- 2.4 Hose fittings - CHECK that all hose fittings and connections are tight.: Fail --- 2.6 Flow rate - Minimum acceptable flow rates: - (a) 0.33 L/s for reels with 19 mm hose. (15 seconds = 4.95 litres): PASS --- 2.8 Ancillary equipment - CHECK that any foam branch pipe or other equipment is in good repair and maintained in accordance with the manufacturer's instructions.: Pass Have all previously reported defects been rectified: No	* After completing these actions, the nozzle shall be re-installed in the nozzle interlock and the hose depressurized (see Clause 9.2.6): Pass --- 2.2 Anchor points - CHECK that the hose reel is securely mounted and that the anchor points are tight.: Pass --- 2.5 Bearings - CHECK that the hose reel bearings are not damaged or excessively worn.: Pass --- 2.6 Flow rate - Minimum acceptable flow rates: - (b) 0.41 L/s for reels with 25 mm hose. (15 seconds = 6.15 litres): Pass --- 2.9 Fire hazard - CHECK that the hose reel is appropriate protection for the fire hazard/risk.: Pass Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - Maintenance complies with QDC, MP6.1.: Yes	TABLE 9.4.2 YEARLY SERVICE SCHEDULE FIRE HOSE REELS: 2025-04-09 --- 2.3 Hose guide - CHECK that any hose guide fixed to the hose reel supply pipe is not able to move upwards and cause the hose to jamb.: Pass --- 2.6 Flow rate - With the stop valve and nozzle fully opened, MEASURE the water flow rate from the most disadvantaged hose reel.: Pass --- 2.7 Hose - CHECK hose for kinking, excessive damage or wear, or collapse.: Pass --- 2.10 Obstructions - CHECK that no alterations have been made to the building, which impede access to the hose reel or restrict the running out of the hose, and that the hose can reach the fire hazard/risk in accordance with AS 2441.: Pass Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - System is in proper working order: Yes
Failure Points	Performed 12 Monthly Testing and Maintenance - Issues Found - Refer to Assets for Defects / Failures and/or Recommendations. - 9.4.2 & 10.4.2 & 11.4.1		
Notes	Refer to individual assets for failure points. NOTE: Extinguishers in FHR cupboards on floors with rooms on it require signage on all cupboards to be visible from 20m		

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93795	79321	Outside front deck	Left of underground car park ent	36	Wormwald	79321	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93796	79313	Underground Carpark	Carpark left side of boom gate as you enter	36m	Quell	79313	01/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation:								

Lewie Fire Protection

4 Schmid Street

Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151**Shangri-La Hotel - Pierpoint Road Cairns**

Pierpoint Road

Cairns QLD 4870

Inspection Date: 09/04/2025**Contact:** Michelle Davis**Phone:**

	* Non-Critical: Hose Reel leaking		
Notes	Annual testing completed		
	Hose reel leaking from hub. Requires replacement		

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93797	79314	Underground carpark	Left of boomgate as you enter carpark	9.0Kg ABE	79314	01/2022	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93798	79315	Underground Carpark	Adj pump room	36m	BFI	79315	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93799	79316	Underground Carpark	Inside Pump Room	4.5Kg ABE		01/2023	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93800	79317	Underground Carpark	West Wall North Of Pump Room	36m	Quell		01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Notes	Annual testing completed								
93802	79318	Underground Carpark	North Wall, Back Left Of Carpark	36	Wormwald	79318	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93899	79325	Ground Floor shopping	Adj Coffee Beach	4.5Kg ABE		09/2023	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93906	79326	Ground Floor Shopping	Next To Howling Jays Signage Opposite Toilet	4.5Kg ABE		18/2021	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93909	79333	Ground Floor Shopping	Next To Howlin Jays Signage, Adj Toilets	36m	Chubb		01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93914	79327	Ground Floor Outside	Outside East Entrance, Next To Marinades Resturant	36m	Wormwald		01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93923	79328	Ground Floor Shopping	Next To Cairns Koalas RHS	36m	Quell		01/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation:								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

	* Non-Critical: Hose Reel leaking								
Notes	Annual testing completed Leaking from hub Requires replacement								
93935	86721	Ground Floor Outside	Outside Entrance Adj D Finger Wharf And Big Marlin	36m	Fireater	86721	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93960	79343	Mezzanine Above Shopping	Mezzanine Down Hallway Next To HP Accounting	36m	Quell		03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93961	79345	Mezzanine Above Shopping	In Hallway Next To HP Accounting In Locked Room Next To Fire Hose Reel	4.5Kg ABE		02/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93962	79344	Mezzanine Above Shopping	Adj Stairs And Lift Through Brown Double Doors	36M	Quell		03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93963	83435	Mezzanine Above	Adj Stairs And Lift	4.5Kg ABE		10/2022	03/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
		Shopping	Through Brown Double Doors						
Test Readings	Attendance Record Number (if applicable):								
93964	79336	Ground Floor Shopping	Pole With Tvs, infront Of Stairs To Carpark	4.5Kg ABE		05/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93966	79347	Ground Floor Shopping	Main Entrance At Crossing	36m	Quell		01/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	2.5 - Hose reel bearings physically damaged or excessively worn - 9.4.2 Recommendation: * Non-Critical: Hose reel bearings physically damaged or excessively worn								
Notes	Annual testing completed Drum is loose on the bearings requires replacing								
93971	79346	Bin Room	Bin Rom Next To Fire Exit Door	36m	Wormald		03/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1								
Notes	Base of nozzle leaks under pressure. Requires new nozzle								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93999	83451	Bin Area	Bin Area Next To Fire Exit Door	2.0Kg ABE DCP		12/2022	03/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Extinguisher not readily accessible or in incorrect location (all extinguishers) - 10.4.1 Recommendation:								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

	* Non-Critical defect: Extinguisher not readily accessible or in incorrect location (all extinguishers)		
Notes	Extinguisher is mounted at 1590mm. Requires relocation		

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93974	79337	Ground Floor Shangri-la	Behind Reception Adj Toilets & Safe deposit Room	36m	FlameStop		03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94407	79339	Plant Room Roof	Inside Plant Room Next To Door, Stairs 10. Sth Tower	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94408	83431	Plant Room Roof	Lift Motor Room, Stairs 10. Sth Tower	4.5Kg ABE		05/2024	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94481	79350	Level 4 South Tower	Adj Fire Stairs & Room 4007,	36M	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94482	79348	Level 3 South Tower	Level 3 South Tower Adj Lift & Fire Stair	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94483	83559	Level 3 South Tower	Adj Lift And Fire Stairs	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94484	83495	Plant Room Top Stairs 7	North Tower	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94485	83444	Plant Room Top Stairs 7	Motor Room Above Plant Room	4.5Kg ABE		05/2024	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94486	83461	Level 4 North Tower	Level 4 Adj Lift & 4003	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94487	83413	Level 4 North Tower	Adj Lift & Room 4003	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94488	83471	Level 3 North Tower	Adj Fire Door Exit & Room 3003	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94489	83481	Level 3 North Tower	Adj Fire door Exit & Room 3003	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94490	83452	Level 2 North End	Adj Lift & room 2065 In FHR Cupboard	2.0Kg ABE DCP		08/2023	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires angled location sign								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94492	83462	Level 2 North End	Adj Lift & Room 2065 In FHR Cupboard	36m	Quell		07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Notes	- Nozzle Leaks When Under Pressure. Requires Replacing
-------	---

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94493	83482	Level 2 Ocean Side	Adj Room 2083 In FHR Cupboard	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires angled location sign								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94494	83472	Level 2 Ocean Side	Adj Room 2083 In FHR Cupboard	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94495	83492	Level 2 Ocean Side	Adj Room 2097 In FHR Cupboard	2.0Kg ABE DCP		08/2023	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires angled location sign								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94496	83453	Level 2 Ocean	Adj Room 2097 In	36m	Quell		07/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
		Side	FHR Cupboard						
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94497	83463	Level 2 South End	Adj Lift, Near Room 2107	2.0Kg ABE DCP		02/2024	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94498	83473	Level 2 South End	Adj Lift, Near Room 2107	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94499	83483	Projection Room	Adj Plant Room Top Of Stairs 11	3.5kg Co2		01/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94500	83422	Lift Motor Room 5	Between Stairs 11 and Stairs 9 behind Back Wall In Plant	4.5Kg ABE		9/2023	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94501	83493	Plant Room	Top Of Stairs 9 Inside Plant Room	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
---------------	---	--	--

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94502	83474	Plant Room	Top Of Stairs 9 Inside Plant Room	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94503	83484	Plant Room	Top Of Stair 8 Inside Plant Room	4.5Kg ABE		01/2023	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94504	83494	Plant Room	Top Of Stairs 8, Inside Plant Room	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94505	83464	Plant Room	Top Of Stairs 6, Inside Plant Room	4.5Kg ABE		05/2024	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94506	83454	Plant Room	Top Of Stair 6, Inside Plant Room	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94507	83455	Plant Room	Top of Stairs 5 Inside Plant Room	2.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94508	83421	Plant Room	Top Of Stair 5 Inside Plant Room	36	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94509	83465	Plant Room	Top of Stairs 5 Left Side Of Wall In Plant Room	4.5Kg ABE		01/2023	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94510	83560	Plant Room	Top of Stair 4 inside plant room stand alone extinguisher	4.5Kg ABE		01/2023	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94511	83581	Plant Room	Top of stair 4 inside plant room with FHR and hydrant	2.5Kg ABE		09/2021	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94512	83592	Plant room	Top of stair 4	36m	Quell		07/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
			inside plant room with hydrant and extinguisher						
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94513	83475	Outdoor rooftop	Top of stair 3 outside	4.5Kg ABE		09/2023	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	No location signage see photo attached								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94514	83510	Outside rooftop	Top of stair 3 outside	36m	Wormald		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	No defects identified with new test, valve operates as it should								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94515	83485	Plant room	Top of stair 2 in plant room	4.5Kg ABE		09/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94516	83456	Plant room	Top of stair 2 inside plant room next to FHR	2.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94517	83466	Plant room	Top of stair 2 next to extinguisher	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94518	83520	Lift motor room	Lift motor room adj stair 2	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94519	83476	Plant Room	Near stair 2, next to fire door and hot water room	9.0Kg ABE		04/2023	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94520	83486	Level 2	adj conference rooms next to kitchen entry in cupboard	2.5Kg ABE		09/2021	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires one flat location sign on front of door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94521	83501	Level 2	Adj conference rooms, next to kitchen entry in cupboard	36m	Quell		09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94522	83496	Level 2 City Side	In Cupboard Adj Room 2003	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1										
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number		Date	Service	Pass / Fail
94523	83509	Level 2 City Side	Adj room 2003 in cupboard	36m	Quell			07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):									
Failure Points	1.1 - Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441 - 9.4.1 Recommendation: * Non-Critical: Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441									
Notes	FHR does not have minimum 100mm clearance around drum. See photo attached to asset									

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94524	83457	Level 2 City Side	Adj room 2014 in FHR cupboard	2.0Kg ABE DCP		09/2021	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires one angled sign on FHR door								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94525	83467	Level 2 City Side	Adj room 2014 in FHR cupboard	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94526	83477	Level 2 City Side	Adj room 2029 in Cupboard	2.5Kg ABE		01/2023	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires on angled sign								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94527	83487	Level 2 City Side	Adj room 2029	36m	Quell		07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441 - 9.4.1 Recommendation: * Non-Critical: Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441								
Notes	Hose reel does not have minimum 100mm clearance on all sides. Photo attached to asset								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94528	83497	Level 2 North face	Adj room 2044	2.0Kg ABE DCP		12/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection

4 Schmid Street

Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151**Shangri-La Hotel - Pierpoint Road Cairns**

Pierpoint Road

Cairns QLD 4870

Inspection Date: 09/04/2025**Contact:** Michelle Davis**Phone:**

Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)		
Notes	Requires on angled sign		

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94529	83458	Level 2 North Face	Adj Room 2044	36	Quell		09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94530	83478	Level 2 North Face	Adj room 2056	2.5Kg ABE		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires one flat location sign								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94531	83468	Level 2 North Face	Adj room 2056	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94532	83488	Outdoor pool area	Adj level 1 entry to pool room 1080 in locked room	3.5kg Co2		02/2023	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94533	83498	Level 1 Ocean Side	Adj room 1080	4.5Kg ABE		10/2023	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94534	83459	Level 1 Ocean Side	Adj room 1080	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94535	83469	Level 1 Ocean Side	Adj Elevator Next To Room 1062	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94536	83504	Level 1 Ocean Side	Adj Elevator Next to Room 1062	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94537	83479	Level 1 North Face	Adj Room 1053	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one flat sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94538	83506	Level 1 North Face	Adj Room 1053	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94539	83489	Level 1 City Side	Adj Room 1041	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94540	83540	Level 1 City Side	Adj Room 1041	36m	BFI		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94541	83499	Level 1 South Face	Adj Room 1026	2.5Kg ABE		01/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1										
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number		Date	Service	Pass / Fail
94542	83550	Level 1 South Face	Adj Room 1026	36	Quell			07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):									
Failure Points	1.1 - Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441 - 9.4.1 Recommendation: * Non-Critical: Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441									
Notes	As per last result. FHR needs to be relocated to the centre by 40mm at a minimum									

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94543	83460	Level 1 South Face	Adj Room 1011	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94544	83470	Level 1 South Face	Adj Room 1011	36m	Quell		07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1								
Notes	Hose reel does not shut off the valve. - water does not stop when spindle is closed fully. - requires replacement / investigation								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94545	83480	Level 1 South Face	Adj Room 1003	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled signage on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94546	83511	Level 1 South Face	Adj Room 1003	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94547	83490	Level 1 South Face	Next to fire door behind sitting area over looking reception	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
94548	83500	Level 1 South Face	Next to single lift near government office	2.0Kg ABE DCP		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94549	83442	Level 1 South Face	Next to single lift near government office	36	BFI		09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94550	83580	Level 1 Kitchen Entry	Hallway between Kitchen and pool next to FHR	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94552	83531	Level 1 Kitchen entry	Hallway between kitchen and pool	36m	Wormald		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94553	83517	Level 1 kitchen entry	Next to door leading from pool to kitchen hallway	4.5Kg ABE		05/2024	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Notes	Noted that extinguisher is mounted to high. HOWEVER due to food trolleys moving through location this is the only realistic location								
94554	83590	Level 1 Ocean side	Adj room 1089	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on front of FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94555	83527	Level 1 Ocean Side	Adj Room 1089	36m	FlameStop		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94556	83599	Level 1 Ocean Side	Adj Room 1093	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on front of FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94557	83505	Level 1 Ocean side	Adj 1093	36m	Quell		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94558	83551	Level 2 Kitchen	Next to Maintenance Elevator	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94559	83569	Level 2 Kitchen	1.2 x 1.8		Wormald	Adj Chemical Storage & Coolroom	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94560	83579	Level 2 Kitchen	Next To Sinks, Adj Coolroom	4.5Kg ABE		05/2024	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Extinguisher not readily accessible or in incorrect location (all extinguishers) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher not readily accessible or in incorrect location (all extinguishers)								
Notes	Extinguisher is mounted 1540mm high. Requires relocation to appropriate height. NOTE: Wall is tiled. Photo attached for reference								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94561	83561	Level 1 Kitchen	1.2 x 1.2		FlameStop	Adj Lift, Next To Switchboard	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94562	83552	Level 1 Kitchen	Adj Lift, Next To Switchboard	7.0Lt Wet Chem		10/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Location sign is impeded, requires new signage above door See photo								
94563	83572	Level 1 Kitchen	Between Fire Door & Ice Machine	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94564	86722	Level 1 Kitchen	1.8 x 1.2		Lewie	Next To Fire Door & Ice Machine	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								
94565	83522	Level 1 Kitchen	1.8 x 1.8		Wormald	Next To Ansul & Stoves	09/04/2025	Yearly	Fail
Test Readings	Log Book Entry Number:								
Failure Points	0.0 - Other - 11.4								
Notes	- Fireblanket beginning to fray - Will require remounting with screws into stainless steel								
94567	86725	Level 1 Kitchen	1.2 x 1.8		Lewie	Adj Deep Fryer & Exhaust Fan Switch	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94569	83541	Level 1 Kitchen	Next To Coolroom, Adj Prep Area	4.5Kg ABE		09/2021	09/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
94571	83537	Level 1 Kitchen	Inside Office, Next to Coolroom	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94573	86709	Level 1 Kitchen	1.2 x 1.8		Lewie	Adj Storage Area, Next To Toilets	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94577	83548	Level 1 Kitchen	Adj Toilets, Near Storage Area	2.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94580	83562	Mezzanine Level BOH	Inside Plant Room Next To Lift	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94581	83582	Mezzanine Workshop	Workshop office near sign in	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94582	83526	Mezzanine Workshop	Adj Workshop Bench	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94584	83553	Mezzanine BOH	Hallway Next to Workshop Adj Food Storage	2.5Kg ABE		02/2022	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one flat loc sign								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94585	83514	Mezzanine BOH	Hallway next to workshop adj food storage	36m	Quell		09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	No signs of leakage present as reported on last test. No defects identified								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94588	83563	Mezzanine level rooms	Adj Room 10	4.5Kg ABE		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- requires one flat loc sign								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1										
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number		Date	Service	Pass / Fail
94589	83573	Mezzanine level rooms	Adj room 10	36m	Chubb			07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):									
Failure Points	2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty									
Notes	- nozzle damaged, water pressure inadequate - Requires replacement of nozzle									

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94592	79349	Mezzanine level	Hallway adj room	4.5Kg ABE		02/2022	07/04/2025	Yearly	Fail

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
		rooms	21						
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94595	83546	Mezzanine level rooms	Hallway adj room 21	36m	Wormald		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94600	83554	Mezzanine level rooms	Hallway adj room 28	4.5Kg ABE		05/2024	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94602	83512	Mezzanine level rooms	Hallway adj room 28	36m	Chubb		07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94611	83564	Mezzanine level rooms	Hallway adj room 35	4.5Kg ABE		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one angled sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1										
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number		Date	Service	Pass / Fail
94614	83524	Mezzanine level rooms	Hallway adj room 35	36m	Chubb			07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):									
Failure Points	2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty									
Notes	Plastic nozzle leaks, requires replacing									

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94620	83583	Mezzanine level rooms	Hallway adj room 38	4.5Kg ABE		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one flat loc sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94624	83544	Mezzanine level	Hallway adj room	36m	Chubb		07/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
		rooms	38						
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94628	83568	Mezzanine level rooms	Next to room 45, infront of fire door	4.5Kg ABE		05/2024	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	- Requires one flat location sign on FHR door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94630	83536	Mezzanine level rooms	Next to room 45, infront of fire door	36m	Chubb		07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty								
Notes	- Plastic nozzle leaks and requires replacing								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94633	83578	Mezzanine to shopping	Second door on left down hallway next to HP accounting	3.5kg Co2		08/2023	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94637	83542	Shangrila executive centre	Above pier shopping	3.5kg Co2		01/2022	03/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
94641	83534	Shangrila Executive centre	Above pier shopping	3.5kg Co2		01/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94646	83555	shangrila Executive centre	Above pier shopping	4.5Kg ABE		02/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94649	83565	Shangrila executive centre	1.2 x 1.8		FireWorld	Above shopping in kitchen	03/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94479	79340	Level 4	Adj Fire Door Exit & Room 4007, South Tower	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93977	79338	Ground Floor Shangri-la	Behind Reception Adj Toilets & Safe Deposit Room	2.0Kg ABE DCP		02/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93949	79334	Mezzanine To Shopping	Mezzanine Adj lift In Staff Only Door	36	Quell		07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty								

Lewie Fire Protection

4 Schmid Street

Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151**Shangri-La Hotel - Pierpoint Road Cairns**

Pierpoint Road

Cairns QLD 4870

Inspection Date: 09/04/2025**Contact:** Michelle Davis**Phone:**

Notes	Plastic nozzle leaks / difficult to open. Requires new nozzle
-------	--

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93946	79335	Mezzanine Of Shopping	Staff Door To Messanine Adj Lift	4.5Kg ABE		02/2022	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires one flat loc sign above door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93938	79330	Ground Floor Shopping	Adj Priceless Gems in Black Cabinet	36m	Quell		03/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation: * Non-Critical: Hose Reel leaking								
Notes	Annual testing completed Defects existing - Hose reel incorrect height, needs to be 1000mm minimum, currently at 600mm - leaking from Hub - leaking from valve. Needs replacement Photo attached to show bracket and mounted height								
93939	79342	Ground floor Shopping	Inside Fire Exit Opposite Oiled Massage	36m	Dixon		03/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.6 - Nozzle not retained in interlock - 9.4.1 Recommendation: * Non-Critical: Nozzle not retained in interlock								

Lewie Fire Protection

4 Schmid Street

Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151**Shangri-La Hotel - Pierpoint Road Cairns**

Pierpoint Road

Cairns QLD 4870

Inspection Date: 09/04/2025**Contact:** Michelle Davis**Phone:**

Notes	Annual testing completed								
	Defects - Due to pipe underneath hose reel, hose does not go into interlock Recommend changing to figure 8 which will require new nozzle								
93894	79324	Ground Floor	GF Centre Shopping Adj Himalayan Dreams (Black Cab)	36m	Chubb		01/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.6 - Nozzle not retained in interlock - 9.4.1 Recommendation: * Non-Critical: Nozzle not retained in interlock								
Notes	Annual testing completed								
	Requires new figure 8 and nozzle.								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93888	79332	Underground Carpark	Entrance to stairwell	4.5Kg ABE		09/2021	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93889	83408	Underground Carpark	Infront Of Door To Stairwell	36m	Wormwald		01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93886	83449	Underground Carpark	Near Lifts	36m	Quell		01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93882	79322	Underground Carpark	Back Wall Behind Carpark 2	36m	Quell		01/04/2025	Yearly	Fail

Lewie Fire Protection

4 Schmid Street

Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151**Shangri-La Hotel - Pierpoint Road Cairns**

Pierpoint Road

Cairns QLD 4870

Inspection Date: 09/04/2025**Contact:** Michelle Davis**Phone:**

Test Readings	Attendance Record Number (if applicable):		
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1	1.6 - Nozzle not retained in interlock - 9.4.1 Recommendation: * Non-Critical: Nozzle not retained in interlock	1.8 - Hose reel not easily unwound - 9.4.1 Recommendation: * Non-Critical: Hose reel not easily unwound
	1.9 - Hose Reel leaking - 9.4.1 Recommendation: * Non-Critical: Hose Reel leaking		
Notes	Annual testing completed Defects - Leaking from valve - Hose deteriorating - No interlock Needs replacing		

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93868	79323	Underground Carpark	Between Park 64 & 65 Far Wall Opposite Boom gate	4.5Kg ABE		05/2024	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
93877	79319	Underground Carpark	Mounted On Wall Left Of Carpark 1	4.5Kg ABE		05/2024	01/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 10.4.1								
Notes	Annual testing completed								
	Extinguisher cabinet damaged Lock no longer works								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93875	83450	Underground Carpark	Inside Cupboard between Carpark 40 & 101 (Rear Of Carpark)	36m	FlameStop		01/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
Notes	Annual testing completed		

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93873	79320	Underground Carpark	In Cupboard Between Carpark 40 & 101 (Rear Of Park)	4.5Kg ABE		02/2022	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93871	83430	Underground Carpark	In Cupboard Next to Carpark 90	36m	FlameStop		01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
93869	83419	Underground Carpark	Far Area Opposite car Park 68	4.5Kg ABE		02/2022	01/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Annual testing completed								
94660	83543	Mezzanine	Plant room near loading dock	4.5Kg ABE	83543	09/2023	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94667	83594	Mezzanine	Main switch room behind plant room	5.0Kg Co2	83594	05/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94672	83584	Mezzanine	Main electrical switch room	9.0Kg ABE	83584	11/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94678	83574	Mezzanine	Outside PABX Room	36m	BFI	83574	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94676	83595	Plant room Mezzanine	Next to pabx room, plant room behind loading dock	4.5Kg ABE		06/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94668	83585	Plant room mezzanine level	Behind loading dock next to electrixal substation	2.0Kg ABE DCP		09/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94664	83574	main plant room on Mezzanine	Behind loading dock and behnd executive centre (main)	9.0Kg ABE		05/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94739	82951	Mezzanine	Laundry infront of dryers	4.5Kg ABE	82951	02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Noted that extinguisher is mounted to high but due to the use of the area this is the most practical height								
94695	83588	Mezzanine events area	Outside stair 5 fire door	4.5Kg ABE		02/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94699	83598	Mezzanine events area	Outside of stairs 5 fire door	36m	Quell		03/04/2025	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
---------------	---	--	--

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94705	83557	Mezzanine events area	Trinity room 2 next to stairs 4	4.5Kg ABE		02/2022	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								
Notes	Requires location sign on door								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94711	83558	Mezzanine events area	Trinity room 2 next to stairs 4	36m	Quell		09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94714	83556	Mezzanine events kitchen	Kitchen adj sink and prep bench	4.5Kg ABE		06/2021	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94717	83566	Mezzanine events area kitchen	Kitchen, in store room	3.5kg Co2		08/2024	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94721	83404	Mezzanine events kitchen	1.8 x 1.8		FlameStop	Kitchen adj sink and prep	03/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94722	83576	Events front entrance	Main entrance door next to pier bar, facing lagoon	4.5Kg ABE		02/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94723	83405	Events main entrance	Events main door next to pier bar, facing lagoon	36m	Wormald		03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94732	83567	Mezzanine loading dock	Plant Room 2	4.5Kg ABE		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94733	83432	Mezzanine loading dock	Chemical room	4.5Kg ABE		02/2022	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Extinguisher not readily accessible or in incorrect location (all extinguishers) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher not readily accessible or in incorrect location (all extinguishers)								
Notes	Extinguisher is not present in assigned location. Requires new extinguisher Photo attached								
94734	83587	Mezzanine loading dock	FHR cupboard in loading dock	4.5Kg ABE		02/2022	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94735	82968	Mezzanine loading dock	FHR cupboard	36m	Quell		03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94736	82969	Mezzanine loading dock	Left side of FHR cupboard	4.5Kg ABE		05/2024	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94737	82970	Mezzanine laundry area	Next to service lift	4.5Kg ABE		08/2021	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94740	83000	Mezzanine laundry	Next to chemical storage adj sink	5.0Kg Co2		01/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94742	82961	Mezzanine	Adjacent staff lunch room	36	BFI	82961	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
94743	82999	Mezzanine staff area	Adj staff lunch room	2.0Kg ABE DCP		02/2022	09/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.10 - Extinguisher location not visible (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher location not visible (all extinguisher types)								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Notes	- Requires one flat loc sign								
94744	82971	Mezzanine behind laundry	Electrical and communications room adj female change	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94741	82978	Mezzanine laundry	Next to chemical storage adj sink	9.0Kg ABE		01/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94738	82958	Mezzanine loading dock	Adjacent office before hallway	9.0Kg ABE		01/2023	03/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94745	82981	Mezzanine horizon club	Kitchen area of horizon club buffet	2.0Kg ABE DCP		02/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
Notes	Noted extinguisher is mounted to high but no alternative location due to trolleys / bins moving through area								
94757	82979	Mezzanine horizon club	Horizon club, backside next to saphire system	3.5kg Co2		01/2022	07/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94758	83586	Pool area Bar	Inside bar area by the pool	2.0Kg ABE DCP		08/2023	07/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Extinguisher not readily accessible or in incorrect location (all extinguishers) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher not readily accessible or in incorrect location (all extinguishers)								
Notes	Extinguisher is mounted to high. Requires relocation to <1200 (brick wall)								
94759	82960	Ground floor reception	Office behind reception next to printer	4.5Kg ABE		10/2022	03/04/2025	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Extinguisher not readily accessible or in incorrect location (all extinguishers) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher not readily accessible or in incorrect location (all extinguishers)								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83151
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

Notes	Extinguisher is mounted 1310mm height at current. Requires relocation								
94760	83596	Backyard kitchen	Next to coldroom adj fire door	4.5Kg ABE		09/2023	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94761	82980	Backyard Kitchen	Adj stoves and door to ocean side	7.0Lt Wet Chem		03/2023	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94762	83597	Backyard Kitchen	1.2 x 1.8		FlameStop	Adj stoves and door to ocean side	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								
Notes	Blanket container is cleaned and instructions are legible								
94763	86726	Baxkyard Kitchen	1.2 x 1.8		Lewie	Centre wall adj stoves in kitchen	09/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								
102704	86707	Mezzanine workshop	1.2m x 1.2m	86707	FlameStop	Wall before workshop entry at sign in	07/04/2025	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	Equipment Size Type	LFP Equipment Number	Manufacture Date	Date	Service	Pass / Fail
102707	85957	Backyard Kitchen	Adj stoves	4.5Kg ABE		02/2022	09/04/2025	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Description Of Work

Asset ID 93646 - Asset Type 01.6 Portable Fire Equipment Service Record - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
 Asset ID 93795 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
 Asset ID 93796 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
 Asset ID 93797 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
 Asset ID 93798 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025

Lewie Fire Protection

4 Schmid Street
Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 09/04/2025

Contact: Michelle Davis

Phone:

Asset ID 93799 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93800 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93802 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93899 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93906 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93909 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93914 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93923 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93935 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93960 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93961 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93962 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93963 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93964 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93966 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93971 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93999 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93974 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94407 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94408 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94480 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94481 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94482 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94483 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94484 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94485 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94486 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94487 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94488 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94489 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94490 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94492 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94493 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94494 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94495 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025

4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622 Fax:
ABN 18 146 907 511

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

[illegible]

4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622 Fax:
ABN 18 146 907 511

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 09/04/2025
Contact: Michelle Davis
Phone:

[illegible]

Lewie Fire Protection

4 Schmid Street
Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 09/04/2025

Contact: Michelle Davis

Phone:

Asset ID 94569 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94571 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94573 - Asset Type 01.1 Fire Blankets - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94577 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94580 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94581 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94582 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94584 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94585 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94588 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94589 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94592 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94595 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94600 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94602 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94611 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94614 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94620 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94624 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94628 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94630 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94633 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94637 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94641 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94646 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94649 - Asset Type 01.1 Fire Blankets - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94551 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94491 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94479 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93977 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93949 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93946 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93938 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93939 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93894 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025

Lewie Fire Protection

4 Schmid Street
Garbutt, 4814

Ph: 07 4728 3622 Fax:

ABN 18 146 907 511

Asset Record - Job No. 83151

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 09/04/2025

Contact: Michelle Davis

Phone:

Asset ID 93888 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93889 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93886 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93882 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93868 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93877 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93875 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93873 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93871 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 93869 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94660 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94667 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94672 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94678 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94676 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94668 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94664 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94739 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94695 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94699 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94705 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94711 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94714 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94717 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94721 - Asset Type 01.1 Fire Blankets - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94722 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94723 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94732 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94733 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94734 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94735 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94736 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94737 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94740 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94742 - Asset Type 01.2 Fire Hose Reels - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025

Lewie Fire Protection

4 Schmid Street
Garbutt, 4814

Ph: 07 4728 3622 Fax:
ABN 18 146 907 511

Asset Record - Job No. 83151

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 09/04/2025

Contact: Michelle Davis

Phone:

Asset ID 94743 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94744 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94741 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94738 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94745 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94757 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94758 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94759 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94760 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94761 - Asset Type 01 Portable and Wheeled Fire Extinguishers - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94762 - Asset Type 01.1 Fire Blankets - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025
Asset ID 94763 - Asset Type 01.1 Fire Blankets - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025

Comments / Recommendations

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Thomas Elliott

Licence No.

Customer (Print Name):

Technician (Signature):



Customer (Signature):