No.	Status	Date
LNDE-JSA-20140902-024	Issued	2014-09-18

Job Safety Analysis - UT Thickness Survey - ATU-100 Rich Amine (Pre-MOC)

Administrative Data

Document No: LNDE-JSA-20140902-024

Date: 2014-09-18

Location: Hamilton Plant, ATU-100

Author: Marcus Chen (SNT-TC-1A UT Level II)

Scope of Work

Activity: UT thickness survey per QSCP-NDT-001 Rev 2

Primary Subjects: 4-RA-101, 4-RA-102, 6-RA-103, 4-RA-104

Objective: Pre-MOC thickness verification

Technical Parameters

4-RA-101: A106 Gr.B, OD 114.3 mm, t_nom 8.56 mm, t-min 3.81 mm, Design 862 kPa(g), 82 °C

4-RA-102: A106 Gr.B, OD 114.3 mm, t_nom 8.56 mm, t-min 3.81 mm, Design 862 kPa(g), 82 °C

6-RA-103: A106 Gr.B, OD 168.3 mm, t_nom 10.97 mm, t-min 4.57 mm, Design 862 kPa(g), 82 °C

4-RA-104: A106 Gr.B, OD 114.3 mm, t_nom 8.56 mm, t-min 3.81 mm, Design 862 kPa(g), 127 °C

Procedural Requirements

Methodology: Ultrasonic Thickness Measurement per QSCP-NDT-001 Rev 2

CUI Program: Profile radiography, insulation removal/reinstatement, and inspection-port requirements as specified

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT Level II	2014-09-18	_____