Larkhall NDE Services Inc. **Job Safety Analysis**

Site: Hamilton Plant

No.	Status	Date
LNDE-JSA-20220906-033	Issued	2022-09-15

Job Safety Analysis - UT Thickness Survey - ATU-100 Sour Gas, Regenerator Overhead, Rich Amine

Administrative Data

Document No: LNDE-JSA-20220906-033

Date: 2022-09-15

Location: Hamilton Plant, ATU-100

Author: Marcus Chen, Lead UT Technician (SNT-TC-1A UT Level II), Larkhall NDE Services Inc.

Governing Procedure: QSCP-NDT-001 Rev 2

Scope of Work: Sour Gas & Regenerator Overhead

6-SG-101: A106 Gr.B, OD 168.3 mm, t_nom 7.11 mm, t-min 3.56 mm, Design 1965 kPa(g), 66 °C

6-SG-102: A106 Gr.B, OD 168.3 mm, t_nom 7.11 mm, t-min 3.56 mm, Design 1965 kPa(g), 66 °C

3-RV-101: A106 Gr.B, OD 88.9 mm, t_nom 7.62 mm, t-min 3.56 mm, Design 345 kPa(g), 121 °C

2-RV-102: A106 Gr.B, OD 60.3 mm, t_nom 5.54 mm, t-min 2.79 mm, Design 345 kPa(g), 121 °C

Scope of Work: Rich Amine

4-RA-101: A106 Gr.B, OD 114.3 mm, t_nom 8.56 mm, t-min 3.81 mm, Design 862 kPa(g), 82 °C

4-RA-102: A106 Gr.B, OD 114.3 mm, t_nom 8.56 mm, t-min 3.81 mm, Design 862 kPa(g), 82 °C

6-RA-103: A106 Gr.B, OD 168.3 mm, t_nom 10.97 mm, t-min 4.57 mm, Design 862 kPa(g), 82 °C

4-RA-104: A106 Gr.B, OD 114.3 mm, t_nom 8.56 mm, t-min 3.81 mm, Design 862 kPa(g), 127 °C

Hazard Controls & Requirements

CUI Program: Insulation removal, reinstatement, and inspection-port requirements per QSCP-NDT-001 Rev 2

Material: A106 Gr.B carbon steel

Acceptance: Readings below t-min recorded as NCR

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT Level II; CAN/CGSB-48.9712 UT Level II	2022-09-15	_____