Halward Inspection Services Ltd.

Inspection Report

Site: Hamilton Plant

No.	Status	Date
HIS-2006-0412-DS-3-CW-101	Issued	2006-02-24

UT Thickness Data Sheet - 3-CW-101

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for line 3-CW-101, an Amine cooler CW line located within the ATU-100. The inspection was conducted as part of the 10-year full-unit survey detailed in HIS-2006-0412.

Kevin Doucette, acting as the lead UT technician (SNT-TC-1A UT Level II) for Halward Inspection Services Ltd., is responsible for the execution of the measurements and the recording of the thickness data.

Technical Specifications

Line 3-CW-101 is constructed from A106 Gr.B with an outer diameter of 88.9 mm and a nominal thickness of 5.49 mm. The design limits for this line are 517 kPa(g) and 49 ?C.

The minimum allowable thickness (t-min) for this asset is 2.79 mm. Any reading recorded below this retirement thickness shall be processed as an NCR.

Procedural Compliance

All thickness measurements were performed in accordance with the site NDE procedure QSCP-NDT-001 Rev 0 for the ATU-100, as well as the HIS-UT-002 Rev 1 procedure submitted by Halward Inspection Services Ltd. for QSCP acceptance.

The ultrasonic testing methodology and calibration requirements were conducted in accordance with the ASTM E797 standard, edition 05.

Asset Integrity Assessment

The remaining life of 3-CW-101 is calculated as (t - t-min) / rate. The corrosion rate is determined by the larger of the long-term rate since the first reading or the short-term rate over the latest pair of readings at least 3 years apart.

As a cooling water line, 3-CW-101 is designated as Class 3, with a maximum thickness and external visual inspection interval of 10 / 10 years. The next thickness reading is due at no more than half the remaining life, not to exceed the class maximum.

Thickness readings, measured 2006-02-24

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2001-03-02	6.82	6.59	0.053	0.046	>50	2011-02-24	
6-SG-101-02	7.11	3.56	2001-03-02	6.71	6.51	0.054	0.040	>50	2011-02-24	
6-SG-101-03	7.11	3.56	2001-03-02	6.74	6.42	0.066	0.064	43.2	2011-02-24	
6-SG-101-04	7.11	3.56	2001-03-02	6.73	6.28	0.081	0.090	30.1	2011-02-24	
6-SG-101-05	7.11	3.56	2001-03-02	6.68	6.22	0.092	0.092	28.8	2011-02-24	
6-SG-101-06	7.11	3.56	2001-03-02	6.87	6.49	0.058	0.076	38.4	2011-02-24	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2001-03-02	6.72	6.26	0.088	0.092	29.2	2011-02-24	
6-SG-102-02	7.11	3.56	2001-03-02	6.72	6.25	0.086	0.094	28.5	2011-02-24	
6-SG-102-03	7.11	3.56	2001-03-02	6.69	6.26	0.078	0.086	31.3	2011-02-24	
6-SG-102-04	7.11	3.56	2001-03-02	6.64	6.22	0.077	0.084	31.6	2011-02-24	
6-SG-102-05	7.11	3.56	2001-03-02	6.93	6.72	0.041	0.042	>50	2011-02-24	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	1996-03-08	8.20	7.89	0.031	0.031	>50	2016-02-24	
8-TG-101-02	8.18	4.06	1996-03-08	8.20	7.75	0.045	0.045	>50	2016-02-24	
8-TG-101-03	8.18	4.06	1996-03-08	8.23	7.79	0.044	0.044	>50	2016-02-24	
8-TG-101-04	8.18	4.06	1996-03-08	8.10	7.76	0.034	0.034	>50	2016-02-24	
8-TG-101-05	8.18	4.06	1996-03-08	8.22	7.95	0.027	0.027	>50	2016-02-24	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	1996-03-08	5.99	5.51	0.048	0.048	48.4	2016-02-24	
4-LA-101-02	6.02	3.18	1996-03-08	6.01	5.76	0.025	0.025	>50	2016-02-24	
4-LA-101-03	6.02	3.18	1996-03-08	5.96	5.76	0.020	0.020	>50	2016-02-24	
4-LA-101-04	6.02	3.18	1996-03-08	6.07	5.78	0.029	0.029	>50	2016-02-24	
4-LA-101-05	6.02	3.18	1996-03-08	6.01	5.81	0.020	0.020	>50	2016-02-24	
4-LA-101-06	6.02	3.18	1996-03-08	6.06	5.64	0.042	0.042	>50	2016-02-24	
4-LA-101-07	6.02	3.18	1996-03-08	5.99	5.57	0.042	0.042	>50	2016-02-24	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	1996-03-08	6.02	5.63	0.039	0.039	>50	2016-02-24	
4-LA-102-02	6.02	3.18	1996-03-08	6.07	5.67	0.040	0.040	>50	2016-02-24	
4-LA-102-03	6.02	3.18	1996-03-08	6.07	5.55	0.052	0.052	45.4	2016-02-24	
4-LA-102-04	6.02	3.18	1996-03-08	5.99	5.34	0.065	0.065	33.1	2016-02-24	
4-LA-102-05	6.02	3.18	1996-03-08	6.00	5.62	0.038	0.038	>50	2016-02-24	
4-LA-102-06	6.02	3.18	1996-03-08	6.00	5.83	0.017	0.017	>50	2016-02-24	
4-LA-102-07	6.02	3.18	1996-03-08	6.00	5.63	0.037	0.037	>50	2016-02-24	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	1996-03-08	7.02	6.75	0.027	0.027	>50	2016-02-24	
6-LA-103-02	7.11	3.56	1996-03-08	7.19	6.87	0.032	0.032	>50	2016-02-24	
6-LA-103-03	7.11	3.56	1996-03-08	7.08	6.65	0.043	0.043	>50	2016-02-24	
6-LA-103-04	7.11	3.56	1996-03-08	7.17	6.52	0.065	0.065	45.4	2016-02-24	
6-LA-103-05	7.11	3.56	1996-03-08	7.19	6.49	0.070	0.070	41.7	2016-02-24	
6-LA-103-06	7.11	3.56	1996-03-08	7.16	6.42	0.074	0.074	38.5	2016-02-24	
6-LA-103-07	7.11	3.56	1996-03-08	7.18	6.76	0.042	0.042	>50	2016-02-24	
6-LA-103-08	7.11	3.56	1996-03-08	7.04	6.79	0.025	0.025	>50	2016-02-24	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2001-03-02	8.39	8.27	0.025	0.024	>50	2016-02-24	
4-RA-101-02	8.56	3.81	2001-03-02	8.45	8.27	0.027	0.036	>50	2016-02-24	
4-RA-101-03	8.56	3.81	2001-03-02	8.42	8.10	0.051	0.064	>50	2016-02-24	
4-RA-101-04	8.56	3.81	2001-03-02	8.37	8.34	0.029	0.006	>50	2016-02-24	
4-RA-101-05	8.56	3.81	2001-03-02	8.42	8.29	0.031	0.026	>50	2016-02-24	
4-RA-101-07	8.56	3.81	2001-03-02	8.51	8.30	0.030	0.042	>50	2016-02-24	
4-RA-101-08	8.56	3.81	2001-03-02	8.30	8.07	0.061	0.046	>50	2016-02-24	
4-RA-101-09	8.56	3.81	2001-03-02	8.43	8.43	0.014	0.000	>50	2016-02-24	
4-RA-101-10	8.56	3.81	2001-03-02	8.48	8.27	0.040	0.042	>50	2016-02-24	
4-RA-101-11	8.56	3.81	2001-03-02	8.39	8.14	0.054	0.050	>50	2016-02-24	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2001-03-02	8.48	8.41	0.013	0.014	>50	2016-02-24	
4-RA-102-02	8.56	3.81	2001-03-02	8.50	8.15	0.042	0.070	>50	2016-02-24	
4-RA-102-03	8.56	3.81	2001-03-02	8.37	8.27	0.029	0.020	>50	2016-02-24	
4-RA-102-04	8.56	3.81	2001-03-02	8.35	8.24	0.030	0.022	>50	2016-02-24	
4-RA-102-05	8.56	3.81	2001-03-02	8.36	8.19	0.036	0.034	>50	2016-02-24	
4-RA-102-06	8.56	3.81	2001-03-02	8.38	8.15	0.036	0.046	>50	2016-02-24	
4-RA-102-07	8.56	3.81	2001-03-02	8.49	8.29	0.029	0.040	>50	2016-02-24	
4-RA-102-08	8.56	3.81	2001-03-02	8.36	8.05	0.044	0.062	>50	2016-02-24	
4-RA-102-09	8.56	3.81	2001-03-02	8.35	8.18	0.037	0.034	>50	2016-02-24	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2001-03-02	10.82	10.76	0.024	0.012	>50	2016-02-24	
6-RA-103-02	10.97	4.57	2001-03-02	10.69	10.50	0.059	0.038	>50	2016-02-24	
6-RA-103-03	10.97	4.57	2001-03-02	10.84	10.67	0.032	0.034	>50	2016-02-24	
6-RA-103-04	10.97	4.57	2001-03-02	10.59	10.40	0.058	0.038	>50	2016-02-24	
6-RA-103-05	10.97	4.57	2001-03-02	10.61	10.34	0.061	0.054	>50	2016-02-24	
6-RA-103-06	10.97	4.57	2001-03-02	10.86	10.74	0.027	0.024	>50	2016-02-24	
6-RA-103-07	10.97	4.57	2001-03-02	10.79	10.66	0.033	0.026	>50	2016-02-24	
6-RA-103-08	10.97	4.57	2001-03-02	10.83	10.58	0.039	0.050	>50	2016-02-24	
6-RA-103-09	10.97	4.57	2001-03-02	10.85	10.67	0.034	0.036	>50	2016-02-24	
6-RA-103-10	10.97	4.57	2001-03-02	10.78	10.27	0.075	0.102	>50	2016-02-24	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2001-03-02	7.26	6.98	0.061	0.056	>50	2011-02-24	
3-RV-101-02	7.62	3.56	2001-03-02	7.31	6.93	0.064	0.076	44.2	2011-02-24	
3-RV-101-03	7.62	3.56	2001-03-02	7.15	6.57	0.095	0.116	25.9	2011-02-24	
3-RV-101-04	7.62	3.56	2001-03-02	7.18	6.65	0.094	0.106	29.1	2011-02-24	
3-RV-101-05	7.62	3.56	2001-03-02	7.25	7.01	0.066	0.048	>50	2011-02-24	
3-RV-101-06	7.62	3.56	2001-03-02	7.20	6.74	0.085	0.092	34.4	2011-02-24	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2001-03-02	5.29	4.85	0.068	0.088	23.3	2011-02-24	
2-RV-102-02	5.54	2.79	2001-03-02	5.12	4.84	0.075	0.056	27.2	2011-02-24	
2-RV-102-03	5.54	2.79	2001-03-02	5.24	5.14	0.034	0.020	>50	2011-02-24	
2-RV-102-04	5.54	2.79	2001-03-02	5.33	5.07	0.051	0.052	43.7	2011-02-24	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	1996-03-08	5.48	5.48	0.000	0.000	>50	2016-02-24	
3-RF-101-02	5.49	2.41	1996-03-08	5.45	5.37	0.008	0.008	>50	2016-02-24	
3-RF-101-03	5.49	2.41	1996-03-08	5.45	5.45	0.000	0.000	>50	2016-02-24	
3-RF-101-04	5.49	2.41	1996-03-08	5.46	5.33	0.013	0.013	>50	2016-02-24	
3-RF-101-05	5.49	2.41	1996-03-08	5.45	5.40	0.005	0.005	>50	2016-02-24	
3-RF-101-06	5.49	2.41	1996-03-08	5.52	5.40	0.012	0.012	>50	2016-02-24	
3-RF-101-07	5.49	2.41	1996-03-08	5.42	5.35	0.007	0.007	>50	2016-02-24	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	1996-03-08	3.92	3.85	0.007	0.007	>50	2016-02-24	
2-RF-102-02	3.91	2.16	1996-03-08	3.88	3.88	0.000	0.000	>50	2016-02-24	
2-RF-102-03	3.91	2.16	1996-03-08	3.93	3.80	0.013	0.013	>50	2016-02-24	
2-RF-102-04	3.91	2.16	1996-03-08	3.87	3.81	0.006	0.006	>50	2016-02-24	
2-RF-102-07	3.91	2.16	1996-03-08	3.96	3.85	0.011	0.011	>50	2016-02-24	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	1996-03-08	6.07	5.75	0.032	0.032	>50	2016-02-24	
4-LA-104-02	6.02	3.18	1996-03-08	6.03	5.56	0.047	0.047	>50	2016-02-24	
4-LA-104-03	6.02	3.18	1996-03-08	5.96	5.74	0.022	0.022	>50	2016-02-24	
4-LA-104-04	6.02	3.18	1996-03-08	6.06	5.86	0.020	0.020	>50	2016-02-24	
4-LA-104-05	6.02	3.18	1996-03-08	6.04	5.51	0.053	0.053	43.8	2016-02-24	
4-LA-104-06	6.02	3.18	1996-03-08	6.10	5.83	0.027	0.027	>50	2016-02-24	
4-LA-104-07	6.02	3.18	1996-03-08	6.01	5.62	0.039	0.039	>50	2016-02-24	
4-LA-104-08	6.02	3.18	1996-03-08	5.94	5.50	0.044	0.044	>50	2016-02-24	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2001-03-02	8.40	8.16	0.035	0.048	>50	2016-02-24	
4-RA-104-02	8.56	3.81	2001-03-02	8.41	8.23	0.032	0.036	>50	2016-02-24	
4-RA-104-03	8.56	3.81	2001-03-02	8.46	8.30	0.024	0.032	>50	2016-02-24	
4-RA-104-04	8.56	3.81	2001-03-02	8.35	8.21	0.038	0.028	>50	2016-02-24	
4-RA-104-05	8.56	3.81	2001-03-02	8.29	8.14	0.046	0.030	>50	2016-02-24	
4-RA-104-06	8.56	3.81	2001-03-02	8.39	8.09	0.050	0.060	>50	2016-02-24	
4-RA-104-07	8.56	3.81	2001-03-02	8.29	7.97	0.062	0.064	>50	2016-02-24	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	1996-03-08	3.93	3.64	0.029	0.029	46.4	2016-02-24	
2-ST-101-02	3.91	2.29	1996-03-08	3.90	3.67	0.023	0.023	>50	2016-02-24	
2-ST-101-03	3.91	2.29	1996-03-08	3.94	3.82	0.012	0.012	>50	2016-02-24	
2-ST-101-04	3.91	2.29	1996-03-08	3.82	3.77	0.005	0.005	>50	2016-02-24	
2-ST-101-05	3.91	2.29	1996-03-08	3.91	3.72	0.019	0.019	>50	2016-02-24	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	1996-03-08	5.42	5.13	0.029	0.029	>50	2016-02-24	
3-CW-101-02	5.49	2.79	1996-03-08	5.41	5.20	0.021	0.021	>50	2016-02-24	
3-CW-101-03	5.49	2.79	1996-03-08	5.53	5.08	0.045	0.045	>50	2016-02-24	
3-CW-101-04	5.49	2.79	1996-03-08	5.46	5.38	0.008	0.008	>50	2016-02-24	
3-CW-101-05	5.49	2.79	1996-03-08	5.48	5.33	0.015	0.015	>50	2016-02-24	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	1996-03-08	5.50	5.20	0.030	0.030	>50	2016-02-24	
3-CW-102-02	5.49	2.79	1996-03-08	5.51	5.02	0.049	0.049	45.4	2016-02-24	
3-CW-102-03	5.49	2.79	1996-03-08	5.53	5.07	0.046	0.046	49.4	2016-02-24	
3-CW-102-04	5.49	2.79	1996-03-08	5.51	5.03	0.048	0.048	46.5	2016-02-24	

Sign-off	Name	Function	Date	Signature
Prepared	Kevin Doucette	lead UT technician, SNT-TC-1A UT Level II	2006-02-24	_____