No.	Status	Date
HIS-2006-0412-DS-3-RF-101	Issued	2006-02-24

UT Thickness Data Sheet - 3-RF-101

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurement results for line 3-RF-101 within the ATU-100. The scope of work is defined by the 10-year full-unit survey detailed in HIS-2006-0412.

Kevin Doucette, acting as lead UT technician and SNT-TC-1A UT Level II for Halward Inspection Services Ltd., is responsible for the execution of the measurements and the recording of the data.

Technical Specifications

Line 3-RF-101 is a Reflux line constructed from A312 TP316. The design parameters are 517 kPa(g) and 104 °C.

The line has an outer diameter of 88.9 mm and a nominal thickness of 5.49 mm. The minimum allowable thickness (t-min) is 2.41 mm.

Procedural Compliance

Thickness measurements were performed under the site NDE procedure QSCP-NDT-001 Rev 0, which governs pre-startup and in-service NDE for the ATU-100.

The inspection was further conducted in accordance with the Halward Inspection Services Ltd. procedure HIS-UT-002 Rev 1 and the requirements of ASTM E797.

Evaluation Criteria

Acceptance is based on the retirement thickness, defined as the t-min of 2.41 mm. Any reading below this value shall be raised as an NCR.

The corrosion rate is determined by the larger of the long-term rate or the short-term rate over the latest pair of readings at least 3 years apart.

Service Life and Scheduling

Remaining life is calculated as (t - t-min) / rate. The next thickness reading is due at no more than half the remaining life, subject to class maximums.

As a reflux line, 3-RF-101 is designated as Class 2, with a maximum thickness and external visual inspection interval of 10 / 5 years.

Thickness readings, measured 2006-02-24

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2001-03-02	6.82	6.59	0.053	0.046	>50	2011-02-24	
6-SG-101-02	7.11	3.56	2001-03-02	6.71	6.51	0.054	0.040	>50	2011-02-24	
6-SG-101-03	7.11	3.56	2001-03-02	6.74	6.42	0.066	0.064	43.2	2011-02-24	
6-SG-101-04	7.11	3.56	2001-03-02	6.73	6.28	0.081	0.090	30.1	2011-02-24	
6-SG-101-05	7.11	3.56	2001-03-02	6.68	6.22	0.092	0.092	28.8	2011-02-24	
6-SG-101-06	7.11	3.56	2001-03-02	6.87	6.49	0.058	0.076	38.4	2011-02-24	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2001-03-02	6.72	6.26	0.088	0.092	29.2	2011-02-24	
6-SG-102-02	7.11	3.56	2001-03-02	6.72	6.25	0.086	0.094	28.5	2011-02-24	
6-SG-102-03	7.11	3.56	2001-03-02	6.69	6.26	0.078	0.086	31.3	2011-02-24	
6-SG-102-04	7.11	3.56	2001-03-02	6.64	6.22	0.077	0.084	31.6	2011-02-24	
6-SG-102-05	7.11	3.56	2001-03-02	6.93	6.72	0.041	0.042	>50	2011-02-24	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	1996-03-08	8.20	7.89	0.031	0.031	>50	2016-02-24	
8-TG-101-02	8.18	4.06	1996-03-08	8.20	7.75	0.045	0.045	>50	2016-02-24	
8-TG-101-03	8.18	4.06	1996-03-08	8.23	7.79	0.044	0.044	>50	2016-02-24	
8-TG-101-04	8.18	4.06	1996-03-08	8.10	7.76	0.034	0.034	>50	2016-02-24	
8-TG-101-05	8.18	4.06	1996-03-08	8.22	7.95	0.027	0.027	>50	2016-02-24	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	1996-03-08	5.99	5.51	0.048	0.048	48.4	2016-02-24	
4-LA-101-02	6.02	3.18	1996-03-08	6.01	5.76	0.025	0.025	>50	2016-02-24	
4-LA-101-03	6.02	3.18	1996-03-08	5.96	5.76	0.020	0.020	>50	2016-02-24	
4-LA-101-04	6.02	3.18	1996-03-08	6.07	5.78	0.029	0.029	>50	2016-02-24	
4-LA-101-05	6.02	3.18	1996-03-08	6.01	5.81	0.020	0.020	>50	2016-02-24	
4-LA-101-06	6.02	3.18	1996-03-08	6.06	5.64	0.042	0.042	>50	2016-02-24	
4-LA-101-07	6.02	3.18	1996-03-08	5.99	5.57	0.042	0.042	>50	2016-02-24	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	1996-03-08	6.02	5.63	0.039	0.039	>50	2016-02-24	
4-LA-102-02	6.02	3.18	1996-03-08	6.07	5.67	0.040	0.040	>50	2016-02-24	
4-LA-102-03	6.02	3.18	1996-03-08	6.07	5.55	0.052	0.052	45.4	2016-02-24	
4-LA-102-04	6.02	3.18	1996-03-08	5.99	5.34	0.065	0.065	33.1	2016-02-24	
4-LA-102-05	6.02	3.18	1996-03-08	6.00	5.62	0.038	0.038	>50	2016-02-24	
4-LA-102-06	6.02	3.18	1996-03-08	6.00	5.83	0.017	0.017	>50	2016-02-24	
4-LA-102-07	6.02	3.18	1996-03-08	6.00	5.63	0.037	0.037	>50	2016-02-24	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	1996-03-08	7.02	6.75	0.027	0.027	>50	2016-02-24	
6-LA-103-02	7.11	3.56	1996-03-08	7.19	6.87	0.032	0.032	>50	2016-02-24	
6-LA-103-03	7.11	3.56	1996-03-08	7.08	6.65	0.043	0.043	>50	2016-02-24	
6-LA-103-04	7.11	3.56	1996-03-08	7.17	6.52	0.065	0.065	45.4	2016-02-24	
6-LA-103-05	7.11	3.56	1996-03-08	7.19	6.49	0.070	0.070	41.7	2016-02-24	
6-LA-103-06	7.11	3.56	1996-03-08	7.16	6.42	0.074	0.074	38.5	2016-02-24	
6-LA-103-07	7.11	3.56	1996-03-08	7.18	6.76	0.042	0.042	>50	2016-02-24	
6-LA-103-08	7.11	3.56	1996-03-08	7.04	6.79	0.025	0.025	>50	2016-02-24	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2001-03-02	8.39	8.27	0.025	0.024	>50	2016-02-24	
4-RA-101-02	8.56	3.81	2001-03-02	8.45	8.27	0.027	0.036	>50	2016-02-24	
4-RA-101-03	8.56	3.81	2001-03-02	8.42	8.10	0.051	0.064	>50	2016-02-24	
4-RA-101-04	8.56	3.81	2001-03-02	8.37	8.34	0.029	0.006	>50	2016-02-24	
4-RA-101-05	8.56	3.81	2001-03-02	8.42	8.29	0.031	0.026	>50	2016-02-24	
4-RA-101-07	8.56	3.81	2001-03-02	8.51	8.30	0.030	0.042	>50	2016-02-24	
4-RA-101-08	8.56	3.81	2001-03-02	8.30	8.07	0.061	0.046	>50	2016-02-24	
4-RA-101-09	8.56	3.81	2001-03-02	8.43	8.43	0.014	0.000	>50	2016-02-24	
4-RA-101-10	8.56	3.81	2001-03-02	8.48	8.27	0.040	0.042	>50	2016-02-24	
4-RA-101-11	8.56	3.81	2001-03-02	8.39	8.14	0.054	0.050	>50	2016-02-24	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2001-03-02	8.48	8.41	0.013	0.014	>50	2016-02-24	
4-RA-102-02	8.56	3.81	2001-03-02	8.50	8.15	0.042	0.070	>50	2016-02-24	
4-RA-102-03	8.56	3.81	2001-03-02	8.37	8.27	0.029	0.020	>50	2016-02-24	
4-RA-102-04	8.56	3.81	2001-03-02	8.35	8.24	0.030	0.022	>50	2016-02-24	
4-RA-102-05	8.56	3.81	2001-03-02	8.36	8.19	0.036	0.034	>50	2016-02-24	
4-RA-102-06	8.56	3.81	2001-03-02	8.38	8.15	0.036	0.046	>50	2016-02-24	
4-RA-102-07	8.56	3.81	2001-03-02	8.49	8.29	0.029	0.040	>50	2016-02-24	
4-RA-102-08	8.56	3.81	2001-03-02	8.36	8.05	0.044	0.062	>50	2016-02-24	
4-RA-102-09	8.56	3.81	2001-03-02	8.35	8.18	0.037	0.034	>50	2016-02-24	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2001-03-02	10.82	10.76	0.024	0.012	>50	2016-02-24	
6-RA-103-02	10.97	4.57	2001-03-02	10.69	10.50	0.059	0.038	>50	2016-02-24	
6-RA-103-03	10.97	4.57	2001-03-02	10.84	10.67	0.032	0.034	>50	2016-02-24	
6-RA-103-04	10.97	4.57	2001-03-02	10.59	10.40	0.058	0.038	>50	2016-02-24	
6-RA-103-05	10.97	4.57	2001-03-02	10.61	10.34	0.061	0.054	>50	2016-02-24	
6-RA-103-06	10.97	4.57	2001-03-02	10.86	10.74	0.027	0.024	>50	2016-02-24	
6-RA-103-07	10.97	4.57	2001-03-02	10.79	10.66	0.033	0.026	>50	2016-02-24	
6-RA-103-08	10.97	4.57	2001-03-02	10.83	10.58	0.039	0.050	>50	2016-02-24	
6-RA-103-09	10.97	4.57	2001-03-02	10.85	10.67	0.034	0.036	>50	2016-02-24	
6-RA-103-10	10.97	4.57	2001-03-02	10.78	10.27	0.075	0.102	>50	2016-02-24	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2001-03-02	7.26	6.98	0.061	0.056	>50	2011-02-24	
3-RV-101-02	7.62	3.56	2001-03-02	7.31	6.93	0.064	0.076	44.2	2011-02-24	
3-RV-101-03	7.62	3.56	2001-03-02	7.15	6.57	0.095	0.116	25.9	2011-02-24	
3-RV-101-04	7.62	3.56	2001-03-02	7.18	6.65	0.094	0.106	29.1	2011-02-24	
3-RV-101-05	7.62	3.56	2001-03-02	7.25	7.01	0.066	0.048	>50	2011-02-24	
3-RV-101-06	7.62	3.56	2001-03-02	7.20	6.74	0.085	0.092	34.4	2011-02-24	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2001-03-02	5.29	4.85	0.068	0.088	23.3	2011-02-24	
2-RV-102-02	5.54	2.79	2001-03-02	5.12	4.84	0.075	0.056	27.2	2011-02-24	
2-RV-102-03	5.54	2.79	2001-03-02	5.24	5.14	0.034	0.020	>50	2011-02-24	
2-RV-102-04	5.54	2.79	2001-03-02	5.33	5.07	0.051	0.052	43.7	2011-02-24	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	1996-03-08	5.48	5.48	0.000	0.000	>50	2016-02-24	
3-RF-101-02	5.49	2.41	1996-03-08	5.45	5.37	0.008	0.008	>50	2016-02-24	
3-RF-101-03	5.49	2.41	1996-03-08	5.45	5.45	0.000	0.000	>50	2016-02-24	
3-RF-101-04	5.49	2.41	1996-03-08	5.46	5.33	0.013	0.013	>50	2016-02-24	
3-RF-101-05	5.49	2.41	1996-03-08	5.45	5.40	0.005	0.005	>50	2016-02-24	
3-RF-101-06	5.49	2.41	1996-03-08	5.52	5.40	0.012	0.012	>50	2016-02-24	
3-RF-101-07	5.49	2.41	1996-03-08	5.42	5.35	0.007	0.007	>50	2016-02-24	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	1996-03-08	3.92	3.85	0.007	0.007	>50	2016-02-24	
2-RF-102-02	3.91	2.16	1996-03-08	3.88	3.88	0.000	0.000	>50	2016-02-24	
2-RF-102-03	3.91	2.16	1996-03-08	3.93	3.80	0.013	0.013	>50	2016-02-24	
2-RF-102-04	3.91	2.16	1996-03-08	3.87	3.81	0.006	0.006	>50	2016-02-24	
2-RF-102-07	3.91	2.16	1996-03-08	3.96	3.85	0.011	0.011	>50	2016-02-24	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	1996-03-08	6.07	5.75	0.032	0.032	>50	2016-02-24	
4-LA-104-02	6.02	3.18	1996-03-08	6.03	5.56	0.047	0.047	>50	2016-02-24	
4-LA-104-03	6.02	3.18	1996-03-08	5.96	5.74	0.022	0.022	>50	2016-02-24	
4-LA-104-04	6.02	3.18	1996-03-08	6.06	5.86	0.020	0.020	>50	2016-02-24	
4-LA-104-05	6.02	3.18	1996-03-08	6.04	5.51	0.053	0.053	43.8	2016-02-24	
4-LA-104-06	6.02	3.18	1996-03-08	6.10	5.83	0.027	0.027	>50	2016-02-24	
4-LA-104-07	6.02	3.18	1996-03-08	6.01	5.62	0.039	0.039	>50	2016-02-24	
4-LA-104-08	6.02	3.18	1996-03-08	5.94	5.50	0.044	0.044	>50	2016-02-24	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2001-03-02	8.40	8.16	0.035	0.048	>50	2016-02-24	
4-RA-104-02	8.56	3.81	2001-03-02	8.41	8.23	0.032	0.036	>50	2016-02-24	
4-RA-104-03	8.56	3.81	2001-03-02	8.46	8.30	0.024	0.032	>50	2016-02-24	
4-RA-104-04	8.56	3.81	2001-03-02	8.35	8.21	0.038	0.028	>50	2016-02-24	
4-RA-104-05	8.56	3.81	2001-03-02	8.29	8.14	0.046	0.030	>50	2016-02-24	
4-RA-104-06	8.56	3.81	2001-03-02	8.39	8.09	0.050	0.060	>50	2016-02-24	
4-RA-104-07	8.56	3.81	2001-03-02	8.29	7.97	0.062	0.064	>50	2016-02-24	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	1996-03-08	3.93	3.64	0.029	0.029	46.4	2016-02-24	
2-ST-101-02	3.91	2.29	1996-03-08	3.90	3.67	0.023	0.023	>50	2016-02-24	
2-ST-101-03	3.91	2.29	1996-03-08	3.94	3.82	0.012	0.012	>50	2016-02-24	
2-ST-101-04	3.91	2.29	1996-03-08	3.82	3.77	0.005	0.005	>50	2016-02-24	
2-ST-101-05	3.91	2.29	1996-03-08	3.91	3.72	0.019	0.019	>50	2016-02-24	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	1996-03-08	5.42	5.13	0.029	0.029	>50	2016-02-24	
3-CW-101-02	5.49	2.79	1996-03-08	5.41	5.20	0.021	0.021	>50	2016-02-24	
3-CW-101-03	5.49	2.79	1996-03-08	5.53	5.08	0.045	0.045	>50	2016-02-24	
3-CW-101-04	5.49	2.79	1996-03-08	5.46	5.38	0.008	0.008	>50	2016-02-24	
3-CW-101-05	5.49	2.79	1996-03-08	5.48	5.33	0.015	0.015	>50	2016-02-24	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	1996-03-08	5.50	5.20	0.030	0.030	>50	2016-02-24	
3-CW-102-02	5.49	2.79	1996-03-08	5.51	5.02	0.049	0.049	45.4	2016-02-24	
3-CW-102-03	5.49	2.79	1996-03-08	5.53	5.07	0.046	0.046	49.4	2016-02-24	
3-CW-102-04	5.49	2.79	1996-03-08	5.51	5.03	0.048	0.048	46.5	2016-02-24	

Sign-off	Name	Function	Date	Signature
Prepared	Kevin Doucette	lead UT technician, SNT-TC-1A UT Level II	2006-02-24	_____