Halward Inspection Services Ltd.

Inspection Report

Site: Hamilton Plant

No.	Status	Date
HIS-2006-0412-DS-4-LA-104	Issued	2006-02-24

UT Thickness Data Sheet - 4-LA-104

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurement results for line 4-LA-104, located within the ATU-100. The inspection was conducted as part of the 10-year full-unit survey detailed in HIS-2006-0412.

Kevin Doucette, acting as the lead UT technician, is responsible for the execution of the measurements and the recording of the thickness data. All activities were performed in accordance with the requirements of the Hamilton Plant asset integrity program.

Technical Specifications

Line 4-LA-104 is an A106 Gr.B L/R exchanger lean side pipe with an outer diameter of 114.3 mm and a nominal thickness of 6.02 mm. The design pressure is 2758 kPa(g) and the design temperature is 138 °C.

The minimum allowable thickness (t-min) for this line is 3.18 mm. Any measured thickness falling below this value is subject to the issuance of an NCR per site rules.

Procedural Basis

Thickness measurements were performed under the site NDE procedure QSCP-NDT-001 Rev 0 for the ATU-100. The specific methodology for data acquisition followed HIS-UT-002 Rev 1, which was submitted for QSCP acceptance.

The inspection process and equipment calibration adhered to the requirements of ASTM E797.

Thickness readings, measured 2006-02-24

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2001-03-02	6.82	6.59	0.053	0.046	>50	2011-02-24	
6-SG-101-02	7.11	3.56	2001-03-02	6.71	6.51	0.054	0.040	>50	2011-02-24	
6-SG-101-03	7.11	3.56	2001-03-02	6.74	6.42	0.066	0.064	43.2	2011-02-24	
6-SG-101-04	7.11	3.56	2001-03-02	6.73	6.28	0.081	0.090	30.1	2011-02-24	
6-SG-101-05	7.11	3.56	2001-03-02	6.68	6.22	0.092	0.092	28.8	2011-02-24	
6-SG-101-06	7.11	3.56	2001-03-02	6.87	6.49	0.058	0.076	38.4	2011-02-24	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2001-03-02	6.72	6.26	0.088	0.092	29.2	2011-02-24	
6-SG-102-02	7.11	3.56	2001-03-02	6.72	6.25	0.086	0.094	28.5	2011-02-24	
6-SG-102-03	7.11	3.56	2001-03-02	6.69	6.26	0.078	0.086	31.3	2011-02-24	
6-SG-102-04	7.11	3.56	2001-03-02	6.64	6.22	0.077	0.084	31.6	2011-02-24	
6-SG-102-05	7.11	3.56	2001-03-02	6.93	6.72	0.041	0.042	>50	2011-02-24	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	1996-03-08	8.20	7.89	0.031	0.031	>50	2016-02-24	
8-TG-101-02	8.18	4.06	1996-03-08	8.20	7.75	0.045	0.045	>50	2016-02-24	
8-TG-101-03	8.18	4.06	1996-03-08	8.23	7.79	0.044	0.044	>50	2016-02-24	
8-TG-101-04	8.18	4.06	1996-03-08	8.10	7.76	0.034	0.034	>50	2016-02-24	
8-TG-101-05	8.18	4.06	1996-03-08	8.22	7.95	0.027	0.027	>50	2016-02-24	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	1996-03-08	5.99	5.51	0.048	0.048	48.4	2016-02-24	
4-LA-101-02	6.02	3.18	1996-03-08	6.01	5.76	0.025	0.025	>50	2016-02-24	
4-LA-101-03	6.02	3.18	1996-03-08	5.96	5.76	0.020	0.020	>50	2016-02-24	
4-LA-101-04	6.02	3.18	1996-03-08	6.07	5.78	0.029	0.029	>50	2016-02-24	
4-LA-101-05	6.02	3.18	1996-03-08	6.01	5.81	0.020	0.020	>50	2016-02-24	
4-LA-101-06	6.02	3.18	1996-03-08	6.06	5.64	0.042	0.042	>50	2016-02-24	
4-LA-101-07	6.02	3.18	1996-03-08	5.99	5.57	0.042	0.042	>50	2016-02-24	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	1996-03-08	6.02	5.63	0.039	0.039	>50	2016-02-24	
4-LA-102-02	6.02	3.18	1996-03-08	6.07	5.67	0.040	0.040	>50	2016-02-24	
4-LA-102-03	6.02	3.18	1996-03-08	6.07	5.55	0.052	0.052	45.4	2016-02-24	
4-LA-102-04	6.02	3.18	1996-03-08	5.99	5.34	0.065	0.065	33.1	2016-02-24	
4-LA-102-05	6.02	3.18	1996-03-08	6.00	5.62	0.038	0.038	>50	2016-02-24	
4-LA-102-06	6.02	3.18	1996-03-08	6.00	5.83	0.017	0.017	>50	2016-02-24	
4-LA-102-07	6.02	3.18	1996-03-08	6.00	5.63	0.037	0.037	>50	2016-02-24	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	1996-03-08	7.02	6.75	0.027	0.027	>50	2016-02-24	
6-LA-103-02	7.11	3.56	1996-03-08	7.19	6.87	0.032	0.032	>50	2016-02-24	
6-LA-103-03	7.11	3.56	1996-03-08	7.08	6.65	0.043	0.043	>50	2016-02-24	
6-LA-103-04	7.11	3.56	1996-03-08	7.17	6.52	0.065	0.065	45.4	2016-02-24	
6-LA-103-05	7.11	3.56	1996-03-08	7.19	6.49	0.070	0.070	41.7	2016-02-24	
6-LA-103-06	7.11	3.56	1996-03-08	7.16	6.42	0.074	0.074	38.5	2016-02-24	
6-LA-103-07	7.11	3.56	1996-03-08	7.18	6.76	0.042	0.042	>50	2016-02-24	
6-LA-103-08	7.11	3.56	1996-03-08	7.04	6.79	0.025	0.025	>50	2016-02-24	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2001-03-02	8.39	8.27	0.025	0.024	>50	2016-02-24	
4-RA-101-02	8.56	3.81	2001-03-02	8.45	8.27	0.027	0.036	>50	2016-02-24	
4-RA-101-03	8.56	3.81	2001-03-02	8.42	8.10	0.051	0.064	>50	2016-02-24	
4-RA-101-04	8.56	3.81	2001-03-02	8.37	8.34	0.029	0.006	>50	2016-02-24	
4-RA-101-05	8.56	3.81	2001-03-02	8.42	8.29	0.031	0.026	>50	2016-02-24	
4-RA-101-07	8.56	3.81	2001-03-02	8.51	8.30	0.030	0.042	>50	2016-02-24	
4-RA-101-08	8.56	3.81	2001-03-02	8.30	8.07	0.061	0.046	>50	2016-02-24	
4-RA-101-09	8.56	3.81	2001-03-02	8.43	8.43	0.014	0.000	>50	2016-02-24	
4-RA-101-10	8.56	3.81	2001-03-02	8.48	8.27	0.040	0.042	>50	2016-02-24	
4-RA-101-11	8.56	3.81	2001-03-02	8.39	8.14	0.054	0.050	>50	2016-02-24	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2001-03-02	8.48	8.41	0.013	0.014	>50	2016-02-24	
4-RA-102-02	8.56	3.81	2001-03-02	8.50	8.15	0.042	0.070	>50	2016-02-24	
4-RA-102-03	8.56	3.81	2001-03-02	8.37	8.27	0.029	0.020	>50	2016-02-24	
4-RA-102-04	8.56	3.81	2001-03-02	8.35	8.24	0.030	0.022	>50	2016-02-24	
4-RA-102-05	8.56	3.81	2001-03-02	8.36	8.19	0.036	0.034	>50	2016-02-24	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-06	8.56	3.81	2001-03-02	8.38	8.15	0.036	0.046	>50	2016-02-24	
4-RA-102-07	8.56	3.81	2001-03-02	8.49	8.29	0.029	0.040	>50	2016-02-24	
4-RA-102-08	8.56	3.81	2001-03-02	8.36	8.05	0.044	0.062	>50	2016-02-24	
4-RA-102-09	8.56	3.81	2001-03-02	8.35	8.18	0.037	0.034	>50	2016-02-24	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2001-03-02	10.82	10.76	0.024	0.012	>50	2016-02-24	
6-RA-103-02	10.97	4.57	2001-03-02	10.69	10.50	0.059	0.038	>50	2016-02-24	
6-RA-103-03	10.97	4.57	2001-03-02	10.84	10.67	0.032	0.034	>50	2016-02-24	
6-RA-103-04	10.97	4.57	2001-03-02	10.59	10.40	0.058	0.038	>50	2016-02-24	
6-RA-103-05	10.97	4.57	2001-03-02	10.61	10.34	0.061	0.054	>50	2016-02-24	
6-RA-103-06	10.97	4.57	2001-03-02	10.86	10.74	0.027	0.024	>50	2016-02-24	
6-RA-103-07	10.97	4.57	2001-03-02	10.79	10.66	0.033	0.026	>50	2016-02-24	
6-RA-103-08	10.97	4.57	2001-03-02	10.83	10.58	0.039	0.050	>50	2016-02-24	
6-RA-103-09	10.97	4.57	2001-03-02	10.85	10.67	0.034	0.036	>50	2016-02-24	
6-RA-103-10	10.97	4.57	2001-03-02	10.78	10.27	0.075	0.102	>50	2016-02-24	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2001-03-02	7.26	6.98	0.061	0.056	>50	2011-02-24	
3-RV-101-02	7.62	3.56	2001-03-02	7.31	6.93	0.064	0.076	44.2	2011-02-24	
3-RV-101-03	7.62	3.56	2001-03-02	7.15	6.57	0.095	0.116	25.9	2011-02-24	
3-RV-101-04	7.62	3.56	2001-03-02	7.18	6.65	0.094	0.106	29.1	2011-02-24	
3-RV-101-05	7.62	3.56	2001-03-02	7.25	7.01	0.066	0.048	>50	2011-02-24	
3-RV-101-06	7.62	3.56	2001-03-02	7.20	6.74	0.085	0.092	34.4	2011-02-24	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2001-03-02	5.29	4.85	0.068	0.088	23.3	2011-02-24	
2-RV-102-02	5.54	2.79	2001-03-02	5.12	4.84	0.075	0.056	27.2	2011-02-24	
2-RV-102-03	5.54	2.79	2001-03-02	5.24	5.14	0.034	0.020	>50	2011-02-24	
2-RV-102-04	5.54	2.79	2001-03-02	5.33	5.07	0.051	0.052	43.7	2011-02-24	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	1996-03-08	5.48	5.48	0.000	0.000	>50	2016-02-24	
3-RF-101-02	5.49	2.41	1996-03-08	5.45	5.37	0.008	0.008	>50	2016-02-24	
3-RF-101-03	5.49	2.41	1996-03-08	5.45	5.45	0.000	0.000	>50	2016-02-24	
3-RF-101-04	5.49	2.41	1996-03-08	5.46	5.33	0.013	0.013	>50	2016-02-24	
3-RF-101-05	5.49	2.41	1996-03-08	5.45	5.40	0.005	0.005	>50	2016-02-24	
3-RF-101-06	5.49	2.41	1996-03-08	5.52	5.40	0.012	0.012	>50	2016-02-24	
3-RF-101-07	5.49	2.41	1996-03-08	5.42	5.35	0.007	0.007	>50	2016-02-24	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	1996-03-08	3.92	3.85	0.007	0.007	>50	2016-02-24	
2-RF-102-02	3.91	2.16	1996-03-08	3.88	3.88	0.000	0.000	>50	2016-02-24	
2-RF-102-03	3.91	2.16	1996-03-08	3.93	3.80	0.013	0.013	>50	2016-02-24	
2-RF-102-04	3.91	2.16	1996-03-08	3.87	3.81	0.006	0.006	>50	2016-02-24	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-07	3.91	2.16	1996-03-08	3.96	3.85	0.011	0.011	>50	2016-02-24	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	1996-03-08	6.07	5.75	0.032	0.032	>50	2016-02-24	
4-LA-104-02	6.02	3.18	1996-03-08	6.03	5.56	0.047	0.047	>50	2016-02-24	
4-LA-104-03	6.02	3.18	1996-03-08	5.96	5.74	0.022	0.022	>50	2016-02-24	
4-LA-104-04	6.02	3.18	1996-03-08	6.06	5.86	0.020	0.020	>50	2016-02-24	
4-LA-104-05	6.02	3.18	1996-03-08	6.04	5.51	0.053	0.053	43.8	2016-02-24	
4-LA-104-06	6.02	3.18	1996-03-08	6.10	5.83	0.027	0.027	>50	2016-02-24	
4-LA-104-07	6.02	3.18	1996-03-08	6.01	5.62	0.039	0.039	>50	2016-02-24	
4-LA-104-08	6.02	3.18	1996-03-08	5.94	5.50	0.044	0.044	>50	2016-02-24	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2001-03-02	8.40	8.16	0.035	0.048	>50	2016-02-24	
4-RA-104-02	8.56	3.81	2001-03-02	8.41	8.23	0.032	0.036	>50	2016-02-24	
4-RA-104-03	8.56	3.81	2001-03-02	8.46	8.30	0.024	0.032	>50	2016-02-24	
4-RA-104-04	8.56	3.81	2001-03-02	8.35	8.21	0.038	0.028	>50	2016-02-24	
4-RA-104-05	8.56	3.81	2001-03-02	8.29	8.14	0.046	0.030	>50	2016-02-24	
4-RA-104-06	8.56	3.81	2001-03-02	8.39	8.09	0.050	0.060	>50	2016-02-24	
4-RA-104-07	8.56	3.81	2001-03-02	8.29	7.97	0.062	0.064	>50	2016-02-24	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	1996-03-08	3.93	3.64	0.029	0.029	46.4	2016-02-24	
2-ST-101-02	3.91	2.29	1996-03-08	3.90	3.67	0.023	0.023	>50	2016-02-24	
2-ST-101-03	3.91	2.29	1996-03-08	3.94	3.82	0.012	0.012	>50	2016-02-24	
2-ST-101-04	3.91	2.29	1996-03-08	3.82	3.77	0.005	0.005	>50	2016-02-24	
2-ST-101-05	3.91	2.29	1996-03-08	3.91	3.72	0.019	0.019	>50	2016-02-24	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	1996-03-08	5.42	5.13	0.029	0.029	>50	2016-02-24	
3-CW-101-02	5.49	2.79	1996-03-08	5.41	5.20	0.021	0.021	>50	2016-02-24	
3-CW-101-03	5.49	2.79	1996-03-08	5.53	5.08	0.045	0.045	>50	2016-02-24	
3-CW-101-04	5.49	2.79	1996-03-08	5.46	5.38	0.008	0.008	>50	2016-02-24	
3-CW-101-05	5.49	2.79	1996-03-08	5.48	5.33	0.015	0.015	>50	2016-02-24	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	1996-03-08	5.50	5.20	0.030	0.030	>50	2016-02-24	
3-CW-102-02	5.49	2.79	1996-03-08	5.51	5.02	0.049	0.049	45.4	2016-02-24	
3-CW-102-03	5.49	2.79	1996-03-08	5.53	5.07	0.046	0.046	49.4	2016-02-24	
3-CW-102-04	5.49	2.79	1996-03-08	5.51	5.03	0.048	0.048	46.5	2016-02-24	

Sign-off	Name	Function	Date	Signature
Prepared	Kevin Doucette	lead UT technician, SNT-TC-1A UT Level II	2006-02-24	_____