No.	Status	Date
HIS-2006-0412-DS-6-SG-102	Issued	2006-02-24

UT Thickness Data Sheet - 6-SG-102

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurement results for line 6-SG-102, a sour gas inlet within the ATU-100. The inspection was conducted as part of the 10-year full-unit survey detailed in HIS-2006-0412.

Kevin Doucette, acting as the lead UT technician (SNT-TC-1A UT Level II) for Halward Inspection Services Ltd., performed the measurements and is responsible for the accuracy of the recorded data.

Technical Basis and Procedures

Thickness measurements were performed in accordance with the site NDE procedure QSCP-NDT-001 Rev 0 and the HIS-UT-002 Rev 1 procedure submitted for QSCP acceptance.

The inspection methodology and equipment calibration were executed according to the requirements of ASTM E797.

Component Design Data

Line 6-SG-102 is constructed from A106 Gr.B with an outside diameter of 168.3 mm and a nominal wall thickness of 7.11 mm. The design pressure is 1965 kPa(g) and the design temperature is 66 °C.

The minimum allowable thickness (t-min) for this line is 3.56 mm. Any reading below this retirement thickness shall be raised as an NCR.

Integrity Assessment

Corrosion rates are determined by the larger of the long-term rate since the first reading or the short-term rate over the latest pair of readings at least 3 years apart. Remaining life is calculated as (t - t-min) / rate.

The next thickness reading is due at no more than half the remaining life, subject to the class maxima. For the ATU-100, Class 2 and Class 3 intervals are 10 years, while Class 1 is 5 years.

Thickness readings, measured 2006-02-24

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2001-03-02	6.82	6.59	0.053	0.046	>50	2011-02-24	
6-SG-101-02	7.11	3.56	2001-03-02	6.71	6.51	0.054	0.040	>50	2011-02-24	
6-SG-101-03	7.11	3.56	2001-03-02	6.74	6.42	0.066	0.064	43.2	2011-02-24	
6-SG-101-04	7.11	3.56	2001-03-02	6.73	6.28	0.081	0.090	30.1	2011-02-24	
6-SG-101-05	7.11	3.56	2001-03-02	6.68	6.22	0.092	0.092	28.8	2011-02-24	
6-SG-101-06	7.11	3.56	2001-03-02	6.87	6.49	0.058	0.076	38.4	2011-02-24	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2001-03-02	6.72	6.26	0.088	0.092	29.2	2011-02-24	
6-SG-102-02	7.11	3.56	2001-03-02	6.72	6.25	0.086	0.094	28.5	2011-02-24	
6-SG-102-03	7.11	3.56	2001-03-02	6.69	6.26	0.078	0.086	31.3	2011-02-24	
6-SG-102-04	7.11	3.56	2001-03-02	6.64	6.22	0.077	0.084	31.6	2011-02-24	
6-SG-102-05	7.11	3.56	2001-03-02	6.93	6.72	0.041	0.042	>50	2011-02-24	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	1996-03-08	8.20	7.89	0.031	0.031	>50	2016-02-24	
8-TG-101-02	8.18	4.06	1996-03-08	8.20	7.75	0.045	0.045	>50	2016-02-24	
8-TG-101-03	8.18	4.06	1996-03-08	8.23	7.79	0.044	0.044	>50	2016-02-24	
8-TG-101-04	8.18	4.06	1996-03-08	8.10	7.76	0.034	0.034	>50	2016-02-24	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-05	8.18	4.06	1996-03-08	8.22	7.95	0.027	0.027	>50	2016-02-24	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	1996-03-08	5.99	5.51	0.048	0.048	48.4	2016-02-24	
4-LA-101-02	6.02	3.18	1996-03-08	6.01	5.76	0.025	0.025	>50	2016-02-24	
4-LA-101-03	6.02	3.18	1996-03-08	5.96	5.76	0.020	0.020	>50	2016-02-24	
4-LA-101-04	6.02	3.18	1996-03-08	6.07	5.78	0.029	0.029	>50	2016-02-24	
4-LA-101-05	6.02	3.18	1996-03-08	6.01	5.81	0.020	0.020	>50	2016-02-24	
4-LA-101-06	6.02	3.18	1996-03-08	6.06	5.64	0.042	0.042	>50	2016-02-24	
4-LA-101-07	6.02	3.18	1996-03-08	5.99	5.57	0.042	0.042	>50	2016-02-24	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	1996-03-08	6.02	5.63	0.039	0.039	>50	2016-02-24	
4-LA-102-02	6.02	3.18	1996-03-08	6.07	5.67	0.040	0.040	>50	2016-02-24	
4-LA-102-03	6.02	3.18	1996-03-08	6.07	5.55	0.052	0.052	45.4	2016-02-24	
4-LA-102-04	6.02	3.18	1996-03-08	5.99	5.34	0.065	0.065	33.1	2016-02-24	
4-LA-102-05	6.02	3.18	1996-03-08	6.00	5.62	0.038	0.038	>50	2016-02-24	
4-LA-102-06	6.02	3.18	1996-03-08	6.00	5.83	0.017	0.017	>50	2016-02-24	
4-LA-102-07	6.02	3.18	1996-03-08	6.00	5.63	0.037	0.037	>50	2016-02-24	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	1996-03-08	7.02	6.75	0.027	0.027	>50	2016-02-24	
6-LA-103-02	7.11	3.56	1996-03-08	7.19	6.87	0.032	0.032	>50	2016-02-24	
6-LA-103-03	7.11	3.56	1996-03-08	7.08	6.65	0.043	0.043	>50	2016-02-24	
6-LA-103-04	7.11	3.56	1996-03-08	7.17	6.52	0.065	0.065	45.4	2016-02-24	
6-LA-103-05	7.11	3.56	1996-03-08	7.19	6.49	0.070	0.070	41.7	2016-02-24	
6-LA-103-06	7.11	3.56	1996-03-08	7.16	6.42	0.074	0.074	38.5	2016-02-24	
6-LA-103-07	7.11	3.56	1996-03-08	7.18	6.76	0.042	0.042	>50	2016-02-24	
6-LA-103-08	7.11	3.56	1996-03-08	7.04	6.79	0.025	0.025	>50	2016-02-24	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2001-03-02	8.39	8.27	0.025	0.024	>50	2016-02-24	
4-RA-101-02	8.56	3.81	2001-03-02	8.45	8.27	0.027	0.036	>50	2016-02-24	
4-RA-101-03	8.56	3.81	2001-03-02	8.42	8.10	0.051	0.064	>50	2016-02-24	
4-RA-101-04	8.56	3.81	2001-03-02	8.37	8.34	0.029	0.006	>50	2016-02-24	
4-RA-101-05	8.56	3.81	2001-03-02	8.42	8.29	0.031	0.026	>50	2016-02-24	
4-RA-101-07	8.56	3.81	2001-03-02	8.51	8.30	0.030	0.042	>50	2016-02-24	
4-RA-101-08	8.56	3.81	2001-03-02	8.30	8.07	0.061	0.046	>50	2016-02-24	
4-RA-101-09	8.56	3.81	2001-03-02	8.43	8.43	0.014	0.000	>50	2016-02-24	
4-RA-101-10	8.56	3.81	2001-03-02	8.48	8.27	0.040	0.042	>50	2016-02-24	
4-RA-101-11	8.56	3.81	2001-03-02	8.39	8.14	0.054	0.050	>50	2016-02-24	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2001-03-02	8.48	8.41	0.013	0.014	>50	2016-02-24	
4-RA-102-02	8.56	3.81	2001-03-02	8.50	8.15	0.042	0.070	>50	2016-02-24	
4-RA-102-03	8.56	3.81	2001-03-02	8.37	8.27	0.029	0.020	>50	2016-02-24	
4-RA-102-04	8.56	3.81	2001-03-02	8.35	8.24	0.030	0.022	>50	2016-02-24	
4-RA-102-05	8.56	3.81	2001-03-02	8.36	8.19	0.036	0.034	>50	2016-02-24	
4-RA-102-06	8.56	3.81	2001-03-02	8.38	8.15	0.036	0.046	>50	2016-02-24	
4-RA-102-07	8.56	3.81	2001-03-02	8.49	8.29	0.029	0.040	>50	2016-02-24	
4-RA-102-08	8.56	3.81	2001-03-02	8.36	8.05	0.044	0.062	>50	2016-02-24	
4-RA-102-09	8.56	3.81	2001-03-02	8.35	8.18	0.037	0.034	>50	2016-02-24	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2001-03-02	10.82	10.76	0.024	0.012	>50	2016-02-24	
6-RA-103-02	10.97	4.57	2001-03-02	10.69	10.50	0.059	0.038	>50	2016-02-24	
6-RA-103-03	10.97	4.57	2001-03-02	10.84	10.67	0.032	0.034	>50	2016-02-24	
6-RA-103-04	10.97	4.57	2001-03-02	10.59	10.40	0.058	0.038	>50	2016-02-24	
6-RA-103-05	10.97	4.57	2001-03-02	10.61	10.34	0.061	0.054	>50	2016-02-24	
6-RA-103-06	10.97	4.57	2001-03-02	10.86	10.74	0.027	0.024	>50	2016-02-24	
6-RA-103-07	10.97	4.57	2001-03-02	10.79	10.66	0.033	0.026	>50	2016-02-24	
6-RA-103-08	10.97	4.57	2001-03-02	10.83	10.58	0.039	0.050	>50	2016-02-24	
6-RA-103-09	10.97	4.57	2001-03-02	10.85	10.67	0.034	0.036	>50	2016-02-24	
6-RA-103-10	10.97	4.57	2001-03-02	10.78	10.27	0.075	0.102	>50	2016-02-24	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2001-03-02	7.26	6.98	0.061	0.056	>50	2011-02-24	
3-RV-101-02	7.62	3.56	2001-03-02	7.31	6.93	0.064	0.076	44.2	2011-02-24	
3-RV-101-03	7.62	3.56	2001-03-02	7.15	6.57	0.095	0.116	25.9	2011-02-24	
3-RV-101-04	7.62	3.56	2001-03-02	7.18	6.65	0.094	0.106	29.1	2011-02-24	
3-RV-101-05	7.62	3.56	2001-03-02	7.25	7.01	0.066	0.048	>50	2011-02-24	
3-RV-101-06	7.62	3.56	2001-03-02	7.20	6.74	0.085	0.092	34.4	2011-02-24	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2001-03-02	5.29	4.85	0.068	0.088	23.3	2011-02-24	
2-RV-102-02	5.54	2.79	2001-03-02	5.12	4.84	0.075	0.056	27.2	2011-02-24	
2-RV-102-03	5.54	2.79	2001-03-02	5.24	5.14	0.034	0.020	>50	2011-02-24	
2-RV-102-04	5.54	2.79	2001-03-02	5.33	5.07	0.051	0.052	43.7	2011-02-24	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	1996-03-08	5.48	5.48	0.000	0.000	>50	2016-02-24	
3-RF-101-02	5.49	2.41	1996-03-08	5.45	5.37	0.008	0.008	>50	2016-02-24	
3-RF-101-03	5.49	2.41	1996-03-08	5.45	5.45	0.000	0.000	>50	2016-02-24	
3-RF-101-04	5.49	2.41	1996-03-08	5.46	5.33	0.013	0.013	>50	2016-02-24	
3-RF-101-05	5.49	2.41	1996-03-08	5.45	5.40	0.005	0.005	>50	2016-02-24	
3-RF-101-06	5.49	2.41	1996-03-08	5.52	5.40	0.012	0.012	>50	2016-02-24	
3-RF-101-07	5.49	2.41	1996-03-08	5.42	5.35	0.007	0.007	>50	2016-02-24	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	1996-03-08	3.92	3.85	0.007	0.007	>50	2016-02-24	
2-RF-102-02	3.91	2.16	1996-03-08	3.88	3.88	0.000	0.000	>50	2016-02-24	
2-RF-102-03	3.91	2.16	1996-03-08	3.93	3.80	0.013	0.013	>50	2016-02-24	
2-RF-102-04	3.91	2.16	1996-03-08	3.87	3.81	0.006	0.006	>50	2016-02-24	
2-RF-102-07	3.91	2.16	1996-03-08	3.96	3.85	0.011	0.011	>50	2016-02-24	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	1996-03-08	6.07	5.75	0.032	0.032	>50	2016-02-24	
4-LA-104-02	6.02	3.18	1996-03-08	6.03	5.56	0.047	0.047	>50	2016-02-24	
4-LA-104-03	6.02	3.18	1996-03-08	5.96	5.74	0.022	0.022	>50	2016-02-24	
4-LA-104-04	6.02	3.18	1996-03-08	6.06	5.86	0.020	0.020	>50	2016-02-24	
4-LA-104-05	6.02	3.18	1996-03-08	6.04	5.51	0.053	0.053	43.8	2016-02-24	
4-LA-104-06	6.02	3.18	1996-03-08	6.10	5.83	0.027	0.027	>50	2016-02-24	
4-LA-104-07	6.02	3.18	1996-03-08	6.01	5.62	0.039	0.039	>50	2016-02-24	
4-LA-104-08	6.02	3.18	1996-03-08	5.94	5.50	0.044	0.044	>50	2016-02-24	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2001-03-02	8.40	8.16	0.035	0.048	>50	2016-02-24	
4-RA-104-02	8.56	3.81	2001-03-02	8.41	8.23	0.032	0.036	>50	2016-02-24	
4-RA-104-03	8.56	3.81	2001-03-02	8.46	8.30	0.024	0.032	>50	2016-02-24	
4-RA-104-04	8.56	3.81	2001-03-02	8.35	8.21	0.038	0.028	>50	2016-02-24	
4-RA-104-05	8.56	3.81	2001-03-02	8.29	8.14	0.046	0.030	>50	2016-02-24	
4-RA-104-06	8.56	3.81	2001-03-02	8.39	8.09	0.050	0.060	>50	2016-02-24	
4-RA-104-07	8.56	3.81	2001-03-02	8.29	7.97	0.062	0.064	>50	2016-02-24	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	1996-03-08	3.93	3.64	0.029	0.029	46.4	2016-02-24	
2-ST-101-02	3.91	2.29	1996-03-08	3.90	3.67	0.023	0.023	>50	2016-02-24	
2-ST-101-03	3.91	2.29	1996-03-08	3.94	3.82	0.012	0.012	>50	2016-02-24	
2-ST-101-04	3.91	2.29	1996-03-08	3.82	3.77	0.005	0.005	>50	2016-02-24	
2-ST-101-05	3.91	2.29	1996-03-08	3.91	3.72	0.019	0.019	>50	2016-02-24	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	1996-03-08	5.42	5.13	0.029	0.029	>50	2016-02-24	
3-CW-101-02	5.49	2.79	1996-03-08	5.41	5.20	0.021	0.021	>50	2016-02-24	
3-CW-101-03	5.49	2.79	1996-03-08	5.53	5.08	0.045	0.045	>50	2016-02-24	
3-CW-101-04	5.49	2.79	1996-03-08	5.46	5.38	0.008	0.008	>50	2016-02-24	
3-CW-101-05	5.49	2.79	1996-03-08	5.48	5.33	0.015	0.015	>50	2016-02-24	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	1996-03-08	5.50	5.20	0.030	0.030	>50	2016-02-24	
3-CW-102-02	5.49	2.79	1996-03-08	5.51	5.02	0.049	0.049	45.4	2016-02-24	
3-CW-102-03	5.49	2.79	1996-03-08	5.53	5.07	0.046	0.046	49.4	2016-02-24	
3-CW-102-04	5.49	2.79	1996-03-08	5.51	5.03	0.048	0.048	46.5	2016-02-24	

Sign-off	Name	Function	Date	Signature
Prepared	Kevin Doucette	lead UT technician, SNT-TC-1A UT Level II	2006-02-24	_____