No.	Status	Date
LNDE-FN-20241025-031-DFR-2	Issued	2024-11-05

Daily Field Report 2 - Field Notes - ATU-100 UT Thickness Survey, WO-20241025-031

Scope and Responsibilities

This report covers the second day of the five-year UT thickness survey within the ATU-100. The primary objective is the measurement of 150 CMLs as authorized under QSCP-WP-2024-11021.

Marcus Chen, acting as lead UT technician, is responsible for the execution of the measurements and the verification of data integrity. All field activities are performed in accordance with the safety requirements established in LNDE-JSA-20241025-031.

Technical Basis and Standards

All ultrasonic thickness measurements are performed under QSCP-NDT-001 Rev 3. The inspection methodology and equipment operation comply with the requirements of ASTM E797.

The survey utilizes the digital export and CML-id format specified in the revised procedure to ensure alignment with corporate asset integrity standards.

Equipment and Calibration

Measurements were conducted using two Olympus 38DL PLUS units. The first unit is covered by LNDE-CAL-2024-0847 and the second unit is covered by LNDE-CAL-2024-0848.

Field calibration was verified using LNDE-CS-001, a 4-step carbon steel calibration block ranging from 0.100 to 0.400 in. Calibration intervals were maintained as per the procedure table.

Field Execution - Lean Amine and Rich Amine Lines

Thickness data was collected for the lean amine header 6-LA-103 (A106 Gr.B, OD 168.3 mm). Readings were compared against the t-min of 3.56 mm.

Survey work continued on the rich amine lines 4-RA-101 and 4-RA-102 (A106 Gr.B, OD 114.3 mm), both with a t-min of 3.81 mm. The rich amine header 6-RA-103 (A106 Gr.B, OD 168.3 mm) was also measured against its t-min of 4.57 mm.

Observations and Data Recording

All readings were recorded digitally. In accordance with QSCP-NDT-001 Rev 3, any reading falling below the alert level requires a photo of the gauge display to be captured.

The current survey progress is being tracked against the 150 CMLs listed in QSCP-WP-2024-11021 to ensure full coverage of the ATU-100 survey area.

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT/VT Level II; CAN/CGSB-48.9712 UT Level II	2024-11-05	_____