No.	Status	Date
LNDE-FN-20241025-031-DFR-4	Issued	2024-11-07

Daily Field Report 4 - Field Notes - ATU-100 UT Thickness Survey, WO-20241025-031

Scope and Responsibilities

Marcus Chen, acting as lead UT technician, performed ultrasonic thickness measurements on piping within the ATU-100. The scope of work was executed in accordance with the requirements of QSCP-WP-2024-11021 and the safety protocols established in LNDE-JSA-20241025-031.

All thickness data collection was performed under the guidelines of QSCP-NDT-001 Rev 3 and the standard requirements of ASTM E797.

Equipment and Calibration

Measurements were obtained using an Olympus 38DL PLUS 2847193 and an Olympus 38DL PLUS 2901456. The calibration and validity of these instruments are documented in LNDE-CAL-2024-0847 and LNDE-CAL-2024-0848 respectively.

Instrument verification and calibration were performed using the LNDE-CS-001 4-step carbon steel calibration block, covering the range of 0.100-0.400 in.

Field Activities - Exchanger Piping

Thickness surveys were completed on the lean side of the L/R exchanger, line 4-LA-104, and the rich side of the L/R exchanger, line 4-RA-104.

Data was recorded at the designated CMLs for these A106 Gr.B lines to evaluate current wall thickness against the specified t-min values.

Field Activities - Utility Piping

UT measurements were conducted on the reboiler steam line 2-ST-101 and the amine cooler CW lines 3-CW-101 and 3-CW-102.

All measurements on these A106 Gr.B lines were performed per the digital export and CML-id format requirements specified in QSCP-NDT-001 Rev 3.

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT/VT Level II; CAN/CGSB-48.9712 UT Level II	2024-11-07	_____