No.	Status	Date
LNDE-RPT-01-037-DS-4-RA-102	Issued	2001-03-02

UT Thickness Data Sheet - 4-RA-102

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for line 4-RA-102 located within the ATU-100. The inspection was conducted by Grace Okafor to support the 5-year Class 1 survey and rich amine piping assessment.

The technician is responsible for the accurate acquisition of thickness data and the identification of any readings falling below the minimum allowable thickness. All measurements were performed in accordance with the requirements of the site NDE procedure.

Technical Basis

The thickness measurements were performed under QSCP-NDT-001 Rev 0 and in accordance with the standard ASTM E797. These activities are detailed in the report LNDE-RPT-01-037.

The inspection focused on the rich amine service of 4-RA-102 to determine current wall thickness and evaluate the asset integrity of the piping within the ATU-100.

Line Specifications

Line 4-RA-102 is constructed from A106 Gr.B with an outer diameter of 114.3 mm and a nominal thickness of 8.56 mm. The design pressure is 862 kPa(g) and the design temperature is 82 °C.

The minimum allowable thickness (t-min) for this line is 3.81 mm. Any reading below this threshold is subject to an NCR.

Evaluation Criteria

Corrosion rates are calculated based on the larger of the long-term rate since the first reading or the short-term rate from the latest pair of readings at least 3 years apart.

Remaining life is determined by the formula (t - t-min) / rate. The next inspection interval is set at no more than half the remaining life, subject to the class maximum for amine service.

Inspection Results

The UT thickness data for 4-RA-102 was collected by Grace Okafor as part of the survey documented in LNDE-RPT-01-037.

The measured values are compared against the t-min of 3.81 mm to ensure the line maintains its design integrity for the rich amine service.

Thickness readings, measured 2001-03-02

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	1996-03-08	7.12	6.82	0.060	0.060	>50	2006-03-02	
6-SG-101-02	7.11	3.56	1996-03-08	7.05	6.71	0.068	0.068	46.2	2006-03-02	
6-SG-101-03	7.11	3.56	1996-03-08	7.08	6.74	0.068	0.068	46.6	2006-03-02	
6-SG-101-04	7.11	3.56	1996-03-08	7.09	6.73	0.072	0.072	43.9	2006-03-02	
6-SG-101-05	7.11	3.56	1996-03-08	7.14	6.68	0.092	0.092	33.8	2006-03-02	
6-SG-101-06	7.11	3.56	1996-03-08	7.07	6.87	0.040	0.040	>50	2006-03-02	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	1996-03-08	7.14	6.72	0.084	0.084	37.5	2006-03-02	
6-SG-102-02	7.11	3.56	1996-03-08	7.11	6.72	0.078	0.078	40.4	2006-03-02	
6-SG-102-03	7.11	3.56	1996-03-08	7.04	6.69	0.070	0.070	44.6	2006-03-02	
6-SG-102-04	7.11	3.56	1996-03-08	6.99	6.64	0.070	0.070	43.8	2006-03-02	
6-SG-102-05	7.11	3.56	1996-03-08	7.13	6.93	0.040	0.040	>50	2006-03-02	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	1996-03-08	8.52	8.39	0.026	0.026	>50	2011-03-02	
4-RA-101-02	8.56	3.81	1996-03-08	8.54	8.45	0.018	0.018	>50	2011-03-02	
4-RA-101-03	8.56	3.81	1996-03-08	8.61	8.42	0.038	0.038	>50	2011-03-02	
4-RA-101-04	8.56	3.81	1996-03-08	8.63	8.37	0.052	0.052	>50	2011-03-02	
4-RA-101-05	8.56	3.81	1996-03-08	8.60	8.42	0.036	0.036	>50	2011-03-02	
4-RA-101-07	8.56	3.81	1996-03-08	8.60	8.51	0.018	0.018	>50	2011-03-02	
4-RA-101-08	8.56	3.81	1996-03-08	8.68	8.30	0.076	0.076	>50	2011-03-02	
4-RA-101-09	8.56	3.81	1996-03-08	8.57	8.43	0.028	0.028	>50	2011-03-02	
4-RA-101-10	8.56	3.81	1996-03-08	8.67	8.48	0.038	0.038	>50	2011-03-02	
4-RA-101-11	8.56	3.81	1996-03-08	8.68	8.39	0.058	0.058	>50	2011-03-02	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	1996-03-08	8.54	8.48	0.012	0.012	>50	2011-03-02	
4-RA-102-02	8.56	3.81	1996-03-08	8.57	8.50	0.014	0.014	>50	2011-03-02	
4-RA-102-03	8.56	3.81	1996-03-08	8.56	8.37	0.038	0.038	>50	2011-03-02	
4-RA-102-04	8.56	3.81	1996-03-08	8.54	8.35	0.038	0.038	>50	2011-03-02	
4-RA-102-05	8.56	3.81	1996-03-08	8.55	8.36	0.038	0.038	>50	2011-03-02	
4-RA-102-06	8.56	3.81	1996-03-08	8.51	8.38	0.026	0.026	>50	2011-03-02	
4-RA-102-07	8.56	3.81	1996-03-08	8.58	8.49	0.018	0.018	>50	2011-03-02	
4-RA-102-08	8.56	3.81	1996-03-08	8.49	8.36	0.026	0.026	>50	2011-03-02	
4-RA-102-09	8.56	3.81	1996-03-08	8.55	8.35	0.040	0.040	>50	2011-03-02	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	1996-03-08	11.00	10.82	0.036	0.036	>50	2011-03-02	
6-RA-103-02	10.97	4.57	1996-03-08	11.09	10.69	0.080	0.080	>50	2011-03-02	
6-RA-103-03	10.97	4.57	1996-03-08	10.99	10.84	0.030	0.030	>50	2011-03-02	
6-RA-103-04	10.97	4.57	1996-03-08	10.98	10.59	0.078	0.078	>50	2011-03-02	
6-RA-103-05	10.97	4.57	1996-03-08	10.95	10.61	0.068	0.068	>50	2011-03-02	
6-RA-103-06	10.97	4.57	1996-03-08	11.01	10.86	0.030	0.030	>50	2011-03-02	
6-RA-103-07	10.97	4.57	1996-03-08	10.99	10.79	0.040	0.040	>50	2011-03-02	
6-RA-103-08	10.97	4.57	1996-03-08	10.97	10.83	0.028	0.028	>50	2011-03-02	
6-RA-103-09	10.97	4.57	1996-03-08	11.01	10.85	0.032	0.032	>50	2011-03-02	
6-RA-103-10	10.97	4.57	1996-03-08	11.02	10.78	0.048	0.048	>50	2011-03-02	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	1996-03-08	7.59	7.26	0.066	0.066	>50	2006-03-02	
3-RV-101-02	7.62	3.56	1996-03-08	7.57	7.31	0.052	0.052	>50	2006-03-02	
3-RV-101-03	7.62	3.56	1996-03-08	7.52	7.15	0.074	0.074	48.3	2006-03-02	
3-RV-101-04	7.62	3.56	1996-03-08	7.59	7.18	0.082	0.082	44.0	2006-03-02	
3-RV-101-05	7.62	3.56	1996-03-08	7.67	7.25	0.084	0.084	43.8	2006-03-02	
3-RV-101-06	7.62	3.56	1996-03-08	7.59	7.20	0.078	0.078	46.5	2006-03-02	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	1996-03-08	5.53	5.29	0.048	0.048	>50	2006-03-02	
2-RV-102-02	5.54	2.79	1996-03-08	5.59	5.12	0.094	0.094	24.7	2006-03-02	
2-RV-102-03	5.54	2.79	1996-03-08	5.48	5.24	0.048	0.048	>50	2006-03-02	
2-RV-102-04	5.54	2.79	1996-03-08	5.58	5.33	0.050	0.050	>50	2006-03-02	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	1996-03-08	8.51	8.40	0.022	0.022	>50	2011-03-02	
4-RA-104-02	8.56	3.81	1996-03-08	8.55	8.41	0.028	0.028	>50	2011-03-02	
4-RA-104-03	8.56	3.81	1996-03-08	8.54	8.46	0.016	0.016	>50	2011-03-02	
4-RA-104-04	8.56	3.81	1996-03-08	8.59	8.35	0.048	0.048	>50	2011-03-02	
4-RA-104-05	8.56	3.81	1996-03-08	8.60	8.29	0.062	0.062	>50	2011-03-02	
4-RA-104-06	8.56	3.81	1996-03-08	8.59	8.39	0.040	0.040	>50	2011-03-02	
4-RA-104-07	8.56	3.81	1996-03-08	8.59	8.29	0.060	0.060	>50	2011-03-02	

Sign-off	Name	Function	Date	Signature
Prepared	Grace Okafor	UT technician, SNT-TC-1A UT Level II	2001-03-02	_____