No.	Status	Date
LNDE-RPT-01-037-DS-6-SG-102	Issued	2001-03-02

UT Thickness Data Sheet - 6-SG-102

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurement results for line 6-SG-102 located within the ATU-100. The scope of work involves the assessment of wall thickness to monitor degradation in sour gas service.

Grace Okafor, acting as the UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., is responsible for the execution of the measurements and the recording of the data presented herein.

Technical Basis

The thickness measurements were performed under the requirements of QSCP-NDT-001 Rev 0. All ultrasonic testing was conducted in accordance with the guidelines specified in ASTM E797.

The data collected for this line is integrated into the broader 5-year Class 1 survey detailed in LNDE-RPT-01-037, which covers sour gas, regenerator overhead, and rich amine piping.

Line Specifications

The subject line, 6-SG-102, is a sour gas inlet constructed from A106 Gr.B. The nominal dimensions are 168.3 mm OD by 7.11 mm wall thickness.

The design limits for this line are 1965 kPa(g) and 66 °C. The minimum allowable thickness (t-min) is established at 3.56 mm.

Evaluation Criteria

Acceptance is based on the retirement thickness, which is equal to the t-min of 3.56 mm. Any reading falling below this value shall be raised as an NCR.

Corrosion rates are determined by the larger of the long-term rate or the short-term rate over the latest pair of readings at least 3 years apart. Remaining life is calculated as (t - t-min) / rate.

Inspection Interval

The next thickness reading is due at no more than half the remaining life, subject to the class maximum. For Class 1 sour gas and regenerator overhead service, the maximum interval for thickness and external visual inspection is 5 years.

Thickness readings, measured 2001-03-02

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	1996-03-08	7.12	6.82	0.060	0.060	>50	2006-03-02	
6-SG-101-02	7.11	3.56	1996-03-08	7.05	6.71	0.068	0.068	46.2	2006-03-02	
6-SG-101-03	7.11	3.56	1996-03-08	7.08	6.74	0.068	0.068	46.6	2006-03-02	
6-SG-101-04	7.11	3.56	1996-03-08	7.09	6.73	0.072	0.072	43.9	2006-03-02	
6-SG-101-05	7.11	3.56	1996-03-08	7.14	6.68	0.092	0.092	33.8	2006-03-02	
6-SG-101-06	7.11	3.56	1996-03-08	7.07	6.87	0.040	0.040	>50	2006-03-02	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	1996-03-08	7.14	6.72	0.084	0.084	37.5	2006-03-02	
6-SG-102-02	7.11	3.56	1996-03-08	7.11	6.72	0.078	0.078	40.4	2006-03-02	
6-SG-102-03	7.11	3.56	1996-03-08	7.04	6.69	0.070	0.070	44.6	2006-03-02	
6-SG-102-04	7.11	3.56	1996-03-08	6.99	6.64	0.070	0.070	43.8	2006-03-02	
6-SG-102-05	7.11	3.56	1996-03-08	7.13	6.93	0.040	0.040	>50	2006-03-02	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	1996-03-08	8.52	8.39	0.026	0.026	>50	2011-03-02	
4-RA-101-02	8.56	3.81	1996-03-08	8.54	8.45	0.018	0.018	>50	2011-03-02	
4-RA-101-03	8.56	3.81	1996-03-08	8.61	8.42	0.038	0.038	>50	2011-03-02	
4-RA-101-04	8.56	3.81	1996-03-08	8.63	8.37	0.052	0.052	>50	2011-03-02	
4-RA-101-05	8.56	3.81	1996-03-08	8.60	8.42	0.036	0.036	>50	2011-03-02	
4-RA-101-07	8.56	3.81	1996-03-08	8.60	8.51	0.018	0.018	>50	2011-03-02	
4-RA-101-08	8.56	3.81	1996-03-08	8.68	8.30	0.076	0.076	>50	2011-03-02	
4-RA-101-09	8.56	3.81	1996-03-08	8.57	8.43	0.028	0.028	>50	2011-03-02	
4-RA-101-10	8.56	3.81	1996-03-08	8.67	8.48	0.038	0.038	>50	2011-03-02	
4-RA-101-11	8.56	3.81	1996-03-08	8.68	8.39	0.058	0.058	>50	2011-03-02	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	1996-03-08	8.54	8.48	0.012	0.012	>50	2011-03-02	
4-RA-102-02	8.56	3.81	1996-03-08	8.57	8.50	0.014	0.014	>50	2011-03-02	
4-RA-102-03	8.56	3.81	1996-03-08	8.56	8.37	0.038	0.038	>50	2011-03-02	
4-RA-102-04	8.56	3.81	1996-03-08	8.54	8.35	0.038	0.038	>50	2011-03-02	
4-RA-102-05	8.56	3.81	1996-03-08	8.55	8.36	0.038	0.038	>50	2011-03-02	
4-RA-102-06	8.56	3.81	1996-03-08	8.51	8.38	0.026	0.026	>50	2011-03-02	
4-RA-102-07	8.56	3.81	1996-03-08	8.58	8.49	0.018	0.018	>50	2011-03-02	
4-RA-102-08	8.56	3.81	1996-03-08	8.49	8.36	0.026	0.026	>50	2011-03-02	
4-RA-102-09	8.56	3.81	1996-03-08	8.55	8.35	0.040	0.040	>50	2011-03-02	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	1996-03-08	11.00	10.82	0.036	0.036	>50	2011-03-02	
6-RA-103-02	10.97	4.57	1996-03-08	11.09	10.69	0.080	0.080	>50	2011-03-02	
6-RA-103-03	10.97	4.57	1996-03-08	10.99	10.84	0.030	0.030	>50	2011-03-02	
6-RA-103-04	10.97	4.57	1996-03-08	10.98	10.59	0.078	0.078	>50	2011-03-02	
6-RA-103-05	10.97	4.57	1996-03-08	10.95	10.61	0.068	0.068	>50	2011-03-02	
6-RA-103-06	10.97	4.57	1996-03-08	11.01	10.86	0.030	0.030	>50	2011-03-02	
6-RA-103-07	10.97	4.57	1996-03-08	10.99	10.79	0.040	0.040	>50	2011-03-02	
6-RA-103-08	10.97	4.57	1996-03-08	10.97	10.83	0.028	0.028	>50	2011-03-02	
6-RA-103-09	10.97	4.57	1996-03-08	11.01	10.85	0.032	0.032	>50	2011-03-02	
6-RA-103-10	10.97	4.57	1996-03-08	11.02	10.78	0.048	0.048	>50	2011-03-02	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	1996-03-08	7.59	7.26	0.066	0.066	>50	2006-03-02	
3-RV-101-02	7.62	3.56	1996-03-08	7.57	7.31	0.052	0.052	>50	2006-03-02	
3-RV-101-03	7.62	3.56	1996-03-08	7.52	7.15	0.074	0.074	48.3	2006-03-02	
3-RV-101-04	7.62	3.56	1996-03-08	7.59	7.18	0.082	0.082	44.0	2006-03-02	
3-RV-101-05	7.62	3.56	1996-03-08	7.67	7.25	0.084	0.084	43.8	2006-03-02	
3-RV-101-06	7.62	3.56	1996-03-08	7.59	7.20	0.078	0.078	46.5	2006-03-02	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	1996-03-08	5.53	5.29	0.048	0.048	>50	2006-03-02	
2-RV-102-02	5.54	2.79	1996-03-08	5.59	5.12	0.094	0.094	24.7	2006-03-02	
2-RV-102-03	5.54	2.79	1996-03-08	5.48	5.24	0.048	0.048	>50	2006-03-02	
2-RV-102-04	5.54	2.79	1996-03-08	5.58	5.33	0.050	0.050	>50	2006-03-02	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	1996-03-08	8.51	8.40	0.022	0.022	>50	2011-03-02	
4-RA-104-02	8.56	3.81	1996-03-08	8.55	8.41	0.028	0.028	>50	2011-03-02	
4-RA-104-03	8.56	3.81	1996-03-08	8.54	8.46	0.016	0.016	>50	2011-03-02	
4-RA-104-04	8.56	3.81	1996-03-08	8.59	8.35	0.048	0.048	>50	2011-03-02	
4-RA-104-05	8.56	3.81	1996-03-08	8.60	8.29	0.062	0.062	>50	2011-03-02	
4-RA-104-06	8.56	3.81	1996-03-08	8.59	8.39	0.040	0.040	>50	2011-03-02	
4-RA-104-07	8.56	3.81	1996-03-08	8.59	8.29	0.060	0.060	>50	2011-03-02	

Sign-off	Name	Function	Date	Signature
Prepared	Grace Okafor	UT technician, SNT-TC-1A UT Level II	2001-03-02	_____