Larkhall NDE Services Inc.

Inspection Report

Site: Hamilton Plant

No.	Status	Date
LNDE-RPT-20160118-004-DFR-1	Issued	2016-02-12

Daily Field Report 1 - UT Thickness Survey - ATU-100 Full Unit

Scope and Responsibilities

Marcus Chen, acting as lead UT technician, performed a UT thickness survey on 18 lines within the ATU-100. The scope of work was executed in accordance with the requirements of QSCP-NDT-001 Rev 2 and the guidelines set forth in ASTM E797.

All field activities were conducted under the authority of permit QSCP-WP-2016-02126. Safety compliance was maintained as per the requirements detailed in LNDE-JSA-20160118-004.

Equipment and Calibration

Thickness measurements were performed using an Olympus 37DL PLUS 0611452. The instrument's annual calibration is verified by LNDE-CAL-2016-0042.

Field calibration and verification were performed using LNDE-CS-001 for carbon steel components and LNDE-SS-003 for stainless steel components.

Inspection Summary - Gas and Amine Services

UT thickness measurements were collected for the sour gas inlet lines 6-SG-101 and 6-SG-102, and the treated gas line 8-TG-101. Lean amine supply and header lines 4-LA-101, 4-LA-102, and 6-LA-103 were also surveyed.

Measurements were completed for the rich amine circuit, including lines 4-RA-101, 4-RA-102, and 6-RA-103.

Inspection Summary - Regenerator and Exchanger Services

The regenerator overhead circuit was surveyed on lines 3-RV-101 and 2-RV-102. Reflux lines 3-RF-101 and 2-RF-102 were measured using the stainless-steel velocity setting.

Thickness data was acquired for the L/R exchanger lean side 4-LA-104 and rich side 4-RA-104.

Inspection Summary - Utility Services

The survey included the reboiler steam line 2-ST-101.

Thickness measurements were also recorded for the amine cooler CW lines 3-CW-101 and 3-CW-102.

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT Level II; CAN/CGSB-48.9712 UT Level II	2016-02-12	_____