Larkhall NDE Services Inc.

Inspection Report

Site: Hamilton Plant

No.	Status	Date
LNDE-RPT-20160118-004-DS-3-CW-102	Issued	2016-02-12

UT Thickness Data Sheet - 3-CW-102

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurement results for line 3-CW-102, located within the ATU-100. The scope of work involves the recording of wall thickness to monitor asset integrity and determine remaining life based on site retirement limits.

Marcus Chen, acting as the lead UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., performed the measurements and is responsible for the accuracy of the data recorded herein.

Technical Basis and Procedures

All thickness measurements were performed under the requirements of QSCP-NDT-001 Rev 2. This procedure includes specific mandates for insulation removal, reinstatement, and the use of inspection ports to facilitate access for the CUI program.

The measurement techniques and equipment calibration were conducted in accordance with ASTM E797.

Line Specifications

The subject line, 3-CW-102, is an Amine cooler CW constructed from A106 Gr.B. The line has an outer diameter of 88.9 mm and a nominal wall thickness of 5.49 mm.

Design parameters for the line are established at a maximum allowable pressure of 517 kPa(g) and a maximum allowable temperature of 49 °C. The minimum allowable thickness (t-min) is 2.79 mm.

Inspection Context

The data presented in this sheet is part of the broader survey detailed in LNDE-RPT-20160118-004-R0. This survey covers the ATU-100 full unit, including Class 1 5-year, Class 2 10-year, and specific 3-year intervals for rich amine and regenerator overhead circuits.

The current assessment for 3-CW-102 is conducted within the framework of the site's asset integrity rules regarding corrosion rate calculations and remaining life projections.

Thickness readings, measured 2016-02-12

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2011-02-18	6.39	6.17	0.048	0.044	>50	2021-02-12	
6-SG-101-02	7.11	3.56	2011-02-18	6.14	5.76	0.065	0.076	28.8	2021-02-12	
6-SG-101-03	7.11	3.56	2011-02-18	6.17	5.87	0.061	0.060	38.1	2021-02-12	
6-SG-101-04	7.11	3.56	2011-02-18	6.05	5.58	0.076	0.094	21.4	2021-02-12	
6-SG-101-05	7.11	3.56	2011-02-18	5.87	5.38	0.088	0.098	18.5	2021-02-12	
6-SG-101-06	7.11	3.56	2011-02-18	6.27	5.88	0.060	0.078	29.6	2021-02-12	
6-SG-101-08	7.11	3.56	2011-02-18	6.33	6.00	0.066	0.066	36.8	2021-02-12	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2011-02-18	5.75	5.42	0.086	0.066	21.6	2021-02-12	
6-SG-102-02	7.11	3.56	2011-02-18	5.80	5.43	0.084	0.074	22.2	2021-02-12	
6-SG-102-03	7.11	3.56	2011-02-18	5.80	5.22	0.091	0.116	14.3	2021-02-12	
6-SG-102-04	7.11	3.56	2011-02-18	5.73	5.18	0.091	0.110	14.7	2021-02-12	
6-SG-102-05	7.11	3.56	2011-02-18	6.46	6.19	0.047	0.054	48.5	2021-02-12	
6-SG-102-06	7.11	3.56	2011-02-18	6.41	6.06	0.070	0.070	35.6	2021-02-12	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	2006-02-24	7.89	7.76	0.022	0.013	>50	2026-02-12	
8-TG-101-02	8.18	4.06	2006-02-24	7.75	7.46	0.037	0.029	>50	2026-02-12	
8-TG-101-03	8.18	4.06	2006-02-24	7.79	7.54	0.035	0.025	>50	2026-02-12	
8-TG-101-04	8.18	4.06	2006-02-24	7.76	7.51	0.030	0.025	>50	2026-02-12	
8-TG-101-05	8.18	4.06	2006-02-24	7.95	7.73	0.025	0.022	>50	2026-02-12	
8-TG-101-07	8.18	4.06	—	—	7.39	—	—	—	2026-02-12	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	2006-02-24	5.51	5.02	0.049	0.049	37.4	2026-02-12	
4-LA-101-02	6.02	3.18	2006-02-24	5.76	5.45	0.028	0.031	>50	2026-02-12	
4-LA-101-03	6.02	3.18	2006-02-24	5.76	5.45	0.026	0.031	>50	2026-02-12	
4-LA-101-04	6.02	3.18	2006-02-24	5.78	5.48	0.030	0.030	>50	2026-02-12	
4-LA-101-05	6.02	3.18	2006-02-24	5.81	5.54	0.024	0.027	>50	2026-02-12	
4-LA-101-06	6.02	3.18	2006-02-24	5.64	5.30	0.038	0.034	>50	2026-02-12	
4-LA-101-07	6.02	3.18	2006-02-24	5.57	4.87	0.056	0.070	24.1	2026-02-12	
4-LA-101-09	6.02	3.18	—	—	5.00	—	—	—	2026-02-12	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	2006-02-24	5.63	5.25	0.039	0.038	>50	2026-02-12	
4-LA-102-02	6.02	3.18	2006-02-24	5.67	5.36	0.036	0.031	>50	2026-02-12	
4-LA-102-03	6.02	3.18	2006-02-24	5.55	5.28	0.040	0.027	>50	2026-02-12	
4-LA-102-04	6.02	3.18	2006-02-24	5.34	4.90	0.055	0.044	31.5	2026-02-12	
4-LA-102-05	6.02	3.18	2006-02-24	5.62	5.34	0.033	0.028	>50	2026-02-12	
4-LA-102-06	6.02	3.18	2006-02-24	5.83	5.60	0.020	0.023	>50	2026-02-12	
4-LA-102-07	6.02	3.18	2006-02-24	5.63	5.40	0.030	0.023	>50	2026-02-12	
4-LA-102-08	6.02	3.18	—	—	5.70	—	—	—	2026-02-12	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	2006-02-24	6.75	6.44	0.029	0.031	>50	2026-02-12	
6-LA-103-02	7.11	3.56	2006-02-24	6.87	6.53	0.033	0.034	>50	2026-02-12	
6-LA-103-03	7.11	3.56	2006-02-24	6.65	6.28	0.040	0.037	>50	2026-02-12	
6-LA-103-04	7.11	3.56	2006-02-24	6.52	6.15	0.051	0.037	>50	2026-02-12	
6-LA-103-05	7.11	3.56	2006-02-24	6.49	5.98	0.061	0.051	39.9	2026-02-12	
6-LA-103-06	7.11	3.56	2006-02-24	6.42	5.82	0.067	0.060	33.6	2026-02-12	
6-LA-103-07	7.11	3.56	2006-02-24	6.76	6.12	0.053	0.064	39.9	2026-02-12	
6-LA-103-08	7.11	3.56	2006-02-24	6.79	6.49	0.028	0.030	>50	2026-02-12	
6-LA-103-10	7.11	3.56	—	—	6.30	—	—	—	2026-02-12	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2014-09-19	8.07	7.83	0.035	0.098	40.9	2019-02-12	
4-RA-101-02	8.56	3.81	2014-09-19	8.02	7.94	0.030	0.052	>50	2019-02-12	
4-RA-101-03	8.56	3.81	2014-09-19	7.88	7.65	0.048	0.066	>50	2019-02-12	
4-RA-101-04	8.56	3.81	2014-09-19	8.18	8.00	0.032	0.042	>50	2019-02-12	
4-RA-101-05	8.56	3.81	2014-09-19	7.98	7.82	0.039	0.068	>50	2019-02-12	
4-RA-101-06	8.56	3.81	2014-09-19	7.91	7.87	0.029	0.029	>50	2019-02-12	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-07	8.56	3.81	2014-09-19	8.22	8.14	0.023	0.032	>50	2019-02-12	
4-RA-101-08	8.56	3.81	2014-09-19	7.71	7.31	0.069	0.142	24.6	2019-02-12	
4-RA-101-09	8.56	3.81	2014-09-19	8.27	8.13	0.022	0.038	>50	2019-02-12	
4-RA-101-10	8.56	3.81	2014-09-19	8.21	8.02	0.033	0.052	>50	2019-02-12	
4-RA-101-11	8.56	3.81	2014-09-19	7.88	7.60	0.054	0.088	42.9	2019-02-12	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2014-09-19	8.25	8.02	0.026	0.062	>50	2019-02-12	
4-RA-102-02	8.56	3.81	2014-09-19	7.89	7.64	0.047	0.070	>50	2019-02-12	
4-RA-102-03	8.56	3.81	2014-09-19	7.95	7.55	0.051	0.098	38.0	2019-02-12	
4-RA-102-04	8.56	3.81	2014-09-19	7.93	7.72	0.041	0.048	>50	2019-02-12	
4-RA-102-05	8.56	3.81	2014-09-19	7.84	7.67	0.044	0.080	48.1	2019-02-12	
4-RA-102-06	8.56	3.81	2014-09-19	7.95	7.73	0.039	0.056	>50	2019-02-12	
4-RA-102-07	8.56	3.81	2014-09-19	7.98	7.78	0.040	0.064	>50	2019-02-12	
4-RA-102-08	8.56	3.81	2014-09-19	7.58	7.35	0.057	0.106	33.3	2019-02-12	
4-RA-102-09	8.56	3.81	2014-09-19	7.84	7.54	0.051	0.088	42.2	2019-02-12	
4-RA-102-11	8.56	3.81	2014-09-19	8.12	7.96	0.046	0.046	>50	2019-02-12	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2014-09-19	10.62	10.29	0.036	0.036	>50	2019-02-12	
6-RA-103-02	10.97	4.57	2014-09-19	10.06	9.69	0.070	0.108	47.2	2019-02-12	
6-RA-103-03	10.97	4.57	2014-09-19	10.39	10.06	0.047	0.072	>50	2019-02-12	
6-RA-103-04	10.97	4.57	2014-09-19	9.79	9.31	0.084	0.132	35.8	2019-02-12	
6-RA-103-05	10.97	4.57	2014-09-19	9.81	9.48	0.074	0.124	39.5	2019-02-12	
6-RA-103-06	10.97	4.57	2014-09-19	10.43	10.32	0.035	0.048	>50	2019-02-12	
6-RA-103-07	10.97	4.57	2014-09-19	10.37	10.20	0.040	0.070	>50	2019-02-12	
6-RA-103-08	10.97	4.57	2014-09-19	10.49	10.33	0.032	0.022	>50	2019-02-12	
6-RA-103-09	10.97	4.57	2014-09-19	10.39	10.33	0.034	0.046	>50	2019-02-12	
6-RA-103-10	10.97	4.57	2014-09-19	9.93	9.49	0.077	0.112	43.8	2019-02-12	
6-RA-103-11	10.97	4.57	2014-09-19	10.10	9.77	0.236	0.236	22.0	2019-02-12	
6-RA-103-13	10.97	4.57	2014-09-19	10.38	10.15	0.060	0.060	>50	2019-02-12	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2013-09-09	6.49	6.34	0.063	0.081	34.2	2019-02-12	
3-RV-101-02	7.62	3.56	2013-09-09	6.44	6.31	0.063	0.052	43.5	2019-02-12	
3-RV-101-03	7.62	3.56	2013-09-09	5.80	5.63	0.095	0.098	21.2	2019-02-12	
3-RV-101-04	7.62	3.56	2013-09-09	6.13	5.88	0.086	0.102	22.8	2019-02-12	
3-RV-101-05	7.62	3.56	2013-09-09	6.48	6.36	0.066	0.050	42.6	2019-02-12	
3-RV-101-06	7.62	3.56	2013-09-09	6.11	5.96	0.082	0.087	27.7	2019-02-12	
3-RV-101-07	7.62	3.56	2013-09-09	5.73	5.54	0.122	0.122	16.2	2019-02-12	
3-RV-101-08	7.62	3.56	2013-09-09	6.36	6.31	0.074	0.074	37.2	2019-02-12	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2013-09-09	4.49	4.35	0.059	0.037	26.4	2019-02-12	
2-RV-102-02	5.54	2.79	2013-09-09	4.29	4.01	0.079	0.109	11.2	2019-02-12	
2-RV-102-03	5.54	2.79	2013-09-09	4.68	4.64	0.042	0.037	43.9	2019-02-12	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-04	5.54	2.79	2013-09-09	4.81	4.73	0.043	0.020	45.5	2019-02-12	
2-RV-102-05	5.54	2.79	2013-09-09	4.96	4.97	0.013	0.013	>50	2019-02-12	
2-RV-102-06	5.54	2.79	2013-09-09	4.55	4.27	0.102	0.102	14.6	2019-02-12	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	2013-12-09	5.37	5.31	0.009	0.017	>50	2026-02-12	
3-RF-101-02	5.49	2.41	2013-12-09	5.40	5.34	0.006	0.003	>50	2026-02-12	
3-RF-101-03	5.49	2.41	2013-12-09	5.37	5.33	0.006	0.012	>50	2026-02-12	
3-RF-101-04	5.49	2.41	2013-12-09	5.41	5.35	0.006	-0.002	>50	2026-02-12	
3-RF-101-05	5.49	2.41	2013-12-09	5.32	5.33	0.006	0.007	>50	2026-02-12	
3-RF-101-06	5.49	2.41	2013-12-09	5.17	5.23	0.015	0.017	>50	2026-02-12	
3-RF-101-07	5.49	2.41	2013-12-09	5.48	5.37	0.003	-0.002	>50	2026-02-12	
3-RF-101-09	5.49	2.41	2013-12-09	5.26	5.19	-0.029	-0.029	>50	2026-02-12	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	2013-12-09	3.60	3.76	0.008	0.009	>50	2026-02-12	
2-RF-102-02	3.91	2.16	2013-12-09	3.70	3.64	0.012	0.024	>50	2026-02-12	
2-RF-102-03	3.91	2.16	2013-12-09	3.79	3.75	0.009	0.005	>50	2026-02-12	
2-RF-102-04	3.91	2.16	2013-12-09	3.82	3.38	0.025	0.043	28.3	2026-02-12	
2-RF-102-05	3.91	2.16	2013-12-09	3.67	3.49	0.082	0.082	16.1	2024-03-06	
2-RF-102-06	3.91	2.16	2013-12-09	3.67	3.47	0.099	0.099	13.2	2022-09-26	
2-RF-102-07	3.91	2.16	2013-12-09	3.72	3.57	0.020	0.028	>50	2026-02-12	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	2006-02-24	5.75	5.31	0.038	0.044	48.2	2026-02-12	
4-LA-104-02	6.02	3.18	2006-02-24	5.56	5.00	0.052	0.056	32.4	2026-02-12	
4-LA-104-03	6.02	3.18	2006-02-24	5.74	5.42	0.027	0.032	>50	2026-02-12	
4-LA-104-04	6.02	3.18	2006-02-24	5.86	5.63	0.022	0.023	>50	2026-02-12	
4-LA-104-05	6.02	3.18	2006-02-24	5.51	4.88	0.058	0.063	26.9	2026-02-12	
4-LA-104-06	6.02	3.18	2006-02-24	5.83	5.55	0.028	0.028	>50	2026-02-12	
4-LA-104-07	6.02	3.18	2006-02-24	5.62	5.28	0.037	0.034	>50	2026-02-12	
4-LA-104-08	6.02	3.18	2006-02-24	5.50	5.11	0.042	0.039	46.3	2026-02-12	
4-LA-104-10	6.02	3.18	—	—	4.84	—	—	—	2026-02-12	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2014-09-19	7.84	7.71	0.040	0.048	>50	2019-02-12	
4-RA-104-02	8.56	3.81	2014-09-19	8.09	7.85	0.035	0.058	>50	2019-02-12	
4-RA-104-03	8.56	3.81	2014-09-19	8.46	8.28	0.057	0.056	>50	2019-02-12	
4-RA-104-04	8.56	3.81	2014-09-19	8.49	8.18	0.063	0.084	>50	2019-02-12	
4-RA-104-05	8.56	3.81	2014-09-19	8.37	8.16	0.050	0.082	>50	2019-02-12	
4-RA-104-06	8.56	3.81	2014-09-19	7.91	7.61	0.049	0.074	>50	2019-02-12	
4-RA-104-07	8.56	3.81	2014-09-19	7.61	7.32	0.064	0.092	38.0	2019-02-12	
4-RA-104-08	8.56	3.81	2014-09-19	8.00	7.81	0.074	0.074	>50	2019-02-12	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	2006-02-24	3.64	3.61	0.016	0.003	>50	2026-02-12	
2-ST-101-02	3.91	2.29	2006-02-24	3.67	3.55	0.018	0.012	>50	2026-02-12	
2-ST-101-03	3.91	2.29	2006-02-24	3.82	3.55	0.020	0.027	46.5	2026-02-12	
2-ST-101-04	3.91	2.29	2006-02-24	3.77	3.68	0.007	0.009	>50	2026-02-12	
2-ST-101-05	3.91	2.29	2006-02-24	3.72	3.50	0.021	0.022	>50	2026-02-12	
2-ST-101-06	3.91	2.29	—	—	3.63	—	—	—	2026-02-12	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	2006-02-24	5.13	5.03	0.020	0.010	>50	2026-02-12	
3-CW-101-02	5.49	2.79	2006-02-24	5.20	5.01	0.020	0.019	>50	2026-02-12	
3-CW-101-03	5.49	2.79	2006-02-24	5.08	4.93	0.030	0.015	>50	2026-02-12	
3-CW-101-04	5.49	2.79	2006-02-24	5.38	5.26	0.010	0.012	>50	2026-02-12	
3-CW-101-05	5.49	2.79	2006-02-24	5.33	5.35	0.007	-0.002	>50	2026-02-12	
3-CW-101-06	5.49	2.79	—	—	5.08	—	—	—	2026-02-12	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	2006-02-24	5.20	5.06	0.022	0.014	>50	2026-02-12	
3-CW-102-02	5.49	2.79	2006-02-24	5.02	4.37	0.057	0.065	24.2	2026-02-12	
3-CW-102-03	5.49	2.79	2006-02-24	5.07	4.54	0.050	0.053	32.9	2026-02-12	
3-CW-102-04	5.49	2.79	2006-02-24	5.03	4.69	0.041	0.034	46.2	2026-02-12	
3-CW-102-05	5.49	2.79	—	—	4.66	—	—	—	2026-02-12	

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT Level II; CAN/CGSB-48.9712 UT Level II	2016-02-12	_____