No.	Status	Date
LNDE-RPT-20160118-004-DS-8-TG-101	Issued	2016-02-12

UT Thickness Data Sheet - 8-TG-101

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for line 8-TG-101 located within the ATU-100. The scope of work is limited to the thickness data collection for this specific line as part of the broader unit survey.

Marcus Chen, acting as the lead UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., is responsible for the execution of the measurements and the recording of the data presented herein.

Technical References

The thickness measurements were performed in accordance with the requirements of QSCP-NDT-001 Rev 2. This procedure includes specific mandates for insulation removal and reinstatement, inspection-port requirements, and profile radiography to support the CUI program.

The measurement techniques and equipment calibration are based on the standard ASTM E797. All results are consolidated into the primary survey report LNDE-RPT-20160118-004-R0.

Component Design Data

Line 8-TG-101 is constructed from A106 Gr.B with a nominal outside diameter of 219.1 mm and a nominal wall thickness of 8.18 mm. The design pressure is 1896 kPa(g) and the design temperature is 60 °C.

The minimum allowable wall thickness (t-min) for this line is 4.06 mm. Any reading recorded below this value is subject to an NCR per site integrity rules.

Inspection Interval and Classification

Line 8-TG-101 is classified as Class 2 (treated gas), which dictates a maximum thickness measurement interval of 10 years and an external visual inspection interval of 5 years.

The current survey, as detailed in LNDE-RPT-20160118-004-R0, represents the 10-year Class 2 interval since 2006.

Thickness readings, measured 2016-02-12

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2011-02-18	6.39	6.17	0.048	0.044	>50	2021-02-12	
6-SG-101-02	7.11	3.56	2011-02-18	6.14	5.76	0.065	0.076	28.8	2021-02-12	
6-SG-101-03	7.11	3.56	2011-02-18	6.17	5.87	0.061	0.060	38.1	2021-02-12	
6-SG-101-04	7.11	3.56	2011-02-18	6.05	5.58	0.076	0.094	21.4	2021-02-12	
6-SG-101-05	7.11	3.56	2011-02-18	5.87	5.38	0.088	0.098	18.5	2021-02-12	
6-SG-101-06	7.11	3.56	2011-02-18	6.27	5.88	0.060	0.078	29.6	2021-02-12	
6-SG-101-08	7.11	3.56	2011-02-18	6.33	6.00	0.066	0.066	36.8	2021-02-12	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2011-02-18	5.75	5.42	0.086	0.066	21.6	2021-02-12	
6-SG-102-02	7.11	3.56	2011-02-18	5.80	5.43	0.084	0.074	22.2	2021-02-12	
6-SG-102-03	7.11	3.56	2011-02-18	5.80	5.22	0.091	0.116	14.3	2021-02-12	
6-SG-102-04	7.11	3.56	2011-02-18	5.73	5.18	0.091	0.110	14.7	2021-02-12	
6-SG-102-05	7.11	3.56	2011-02-18	6.46	6.19	0.047	0.054	48.5	2021-02-12	
6-SG-102-06	7.11	3.56	2011-02-18	6.41	6.06	0.070	0.070	35.6	2021-02-12	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	2006-02-24	7.89	7.76	0.022	0.013	>50	2026-02-12	
8-TG-101-02	8.18	4.06	2006-02-24	7.75	7.46	0.037	0.029	>50	2026-02-12	
8-TG-101-03	8.18	4.06	2006-02-24	7.79	7.54	0.035	0.025	>50	2026-02-12	
8-TG-101-04	8.18	4.06	2006-02-24	7.76	7.51	0.030	0.025	>50	2026-02-12	
8-TG-101-05	8.18	4.06	2006-02-24	7.95	7.73	0.025	0.022	>50	2026-02-12	
8-TG-101-07	8.18	4.06	—	—	7.39	—	—	—	2026-02-12	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	2006-02-24	5.51	5.02	0.049	0.049	37.4	2026-02-12	
4-LA-101-02	6.02	3.18	2006-02-24	5.76	5.45	0.028	0.031	>50	2026-02-12	
4-LA-101-03	6.02	3.18	2006-02-24	5.76	5.45	0.026	0.031	>50	2026-02-12	
4-LA-101-04	6.02	3.18	2006-02-24	5.78	5.48	0.030	0.030	>50	2026-02-12	
4-LA-101-05	6.02	3.18	2006-02-24	5.81	5.54	0.024	0.027	>50	2026-02-12	
4-LA-101-06	6.02	3.18	2006-02-24	5.64	5.30	0.038	0.034	>50	2026-02-12	
4-LA-101-07	6.02	3.18	2006-02-24	5.57	4.87	0.056	0.070	24.1	2026-02-12	
4-LA-101-09	6.02	3.18	—	—	5.00	—	—	—	2026-02-12	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	2006-02-24	5.63	5.25	0.039	0.038	>50	2026-02-12	
4-LA-102-02	6.02	3.18	2006-02-24	5.67	5.36	0.036	0.031	>50	2026-02-12	
4-LA-102-03	6.02	3.18	2006-02-24	5.55	5.28	0.040	0.027	>50	2026-02-12	
4-LA-102-04	6.02	3.18	2006-02-24	5.34	4.90	0.055	0.044	31.5	2026-02-12	
4-LA-102-05	6.02	3.18	2006-02-24	5.62	5.34	0.033	0.028	>50	2026-02-12	
4-LA-102-06	6.02	3.18	2006-02-24	5.83	5.60	0.020	0.023	>50	2026-02-12	
4-LA-102-07	6.02	3.18	2006-02-24	5.63	5.40	0.030	0.023	>50	2026-02-12	
4-LA-102-08	6.02	3.18	—	—	5.70	—	—	—	2026-02-12	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	2006-02-24	6.75	6.44	0.029	0.031	>50	2026-02-12	
6-LA-103-02	7.11	3.56	2006-02-24	6.87	6.53	0.033	0.034	>50	2026-02-12	
6-LA-103-03	7.11	3.56	2006-02-24	6.65	6.28	0.040	0.037	>50	2026-02-12	
6-LA-103-04	7.11	3.56	2006-02-24	6.52	6.15	0.051	0.037	>50	2026-02-12	
6-LA-103-05	7.11	3.56	2006-02-24	6.49	5.98	0.061	0.051	39.9	2026-02-12	
6-LA-103-06	7.11	3.56	2006-02-24	6.42	5.82	0.067	0.060	33.6	2026-02-12	
6-LA-103-07	7.11	3.56	2006-02-24	6.76	6.12	0.053	0.064	39.9	2026-02-12	
6-LA-103-08	7.11	3.56	2006-02-24	6.79	6.49	0.028	0.030	>50	2026-02-12	
6-LA-103-10	7.11	3.56	—	—	6.30	—	—	—	2026-02-12	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2014-09-19	8.07	7.83	0.035	0.098	40.9	2019-02-12	
4-RA-101-02	8.56	3.81	2014-09-19	8.02	7.94	0.030	0.052	>50	2019-02-12	
4-RA-101-03	8.56	3.81	2014-09-19	7.88	7.65	0.048	0.066	>50	2019-02-12	
4-RA-101-04	8.56	3.81	2014-09-19	8.18	8.00	0.032	0.042	>50	2019-02-12	
4-RA-101-05	8.56	3.81	2014-09-19	7.98	7.82	0.039	0.068	>50	2019-02-12	
4-RA-101-06	8.56	3.81	2014-09-19	7.91	7.87	0.029	0.029	>50	2019-02-12	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-07	8.56	3.81	2014-09-19	8.22	8.14	0.023	0.032	>50	2019-02-12	
4-RA-101-08	8.56	3.81	2014-09-19	7.71	7.31	0.069	0.142	24.6	2019-02-12	
4-RA-101-09	8.56	3.81	2014-09-19	8.27	8.13	0.022	0.038	>50	2019-02-12	
4-RA-101-10	8.56	3.81	2014-09-19	8.21	8.02	0.033	0.052	>50	2019-02-12	
4-RA-101-11	8.56	3.81	2014-09-19	7.88	7.60	0.054	0.088	42.9	2019-02-12	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2014-09-19	8.25	8.02	0.026	0.062	>50	2019-02-12	
4-RA-102-02	8.56	3.81	2014-09-19	7.89	7.64	0.047	0.070	>50	2019-02-12	
4-RA-102-03	8.56	3.81	2014-09-19	7.95	7.55	0.051	0.098	38.0	2019-02-12	
4-RA-102-04	8.56	3.81	2014-09-19	7.93	7.72	0.041	0.048	>50	2019-02-12	
4-RA-102-05	8.56	3.81	2014-09-19	7.84	7.67	0.044	0.080	48.1	2019-02-12	
4-RA-102-06	8.56	3.81	2014-09-19	7.95	7.73	0.039	0.056	>50	2019-02-12	
4-RA-102-07	8.56	3.81	2014-09-19	7.98	7.78	0.040	0.064	>50	2019-02-12	
4-RA-102-08	8.56	3.81	2014-09-19	7.58	7.35	0.057	0.106	33.3	2019-02-12	
4-RA-102-09	8.56	3.81	2014-09-19	7.84	7.54	0.051	0.088	42.2	2019-02-12	
4-RA-102-11	8.56	3.81	2014-09-19	8.12	7.96	0.046	0.046	>50	2019-02-12	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2014-09-19	10.62	10.29	0.036	0.036	>50	2019-02-12	
6-RA-103-02	10.97	4.57	2014-09-19	10.06	9.69	0.070	0.108	47.2	2019-02-12	
6-RA-103-03	10.97	4.57	2014-09-19	10.39	10.06	0.047	0.072	>50	2019-02-12	
6-RA-103-04	10.97	4.57	2014-09-19	9.79	9.31	0.084	0.132	35.8	2019-02-12	
6-RA-103-05	10.97	4.57	2014-09-19	9.81	9.48	0.074	0.124	39.5	2019-02-12	
6-RA-103-06	10.97	4.57	2014-09-19	10.43	10.32	0.035	0.048	>50	2019-02-12	
6-RA-103-07	10.97	4.57	2014-09-19	10.37	10.20	0.040	0.070	>50	2019-02-12	
6-RA-103-08	10.97	4.57	2014-09-19	10.49	10.33	0.032	0.022	>50	2019-02-12	
6-RA-103-09	10.97	4.57	2014-09-19	10.39	10.33	0.034	0.046	>50	2019-02-12	
6-RA-103-10	10.97	4.57	2014-09-19	9.93	9.49	0.077	0.112	43.8	2019-02-12	
6-RA-103-11	10.97	4.57	2014-09-19	10.10	9.77	0.236	0.236	22.0	2019-02-12	
6-RA-103-13	10.97	4.57	2014-09-19	10.38	10.15	0.060	0.060	>50	2019-02-12	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2013-09-09	6.49	6.34	0.063	0.081	34.2	2019-02-12	
3-RV-101-02	7.62	3.56	2013-09-09	6.44	6.31	0.063	0.052	43.5	2019-02-12	
3-RV-101-03	7.62	3.56	2013-09-09	5.80	5.63	0.095	0.098	21.2	2019-02-12	
3-RV-101-04	7.62	3.56	2013-09-09	6.13	5.88	0.086	0.102	22.8	2019-02-12	
3-RV-101-05	7.62	3.56	2013-09-09	6.48	6.36	0.066	0.050	42.6	2019-02-12	
3-RV-101-06	7.62	3.56	2013-09-09	6.11	5.96	0.082	0.087	27.7	2019-02-12	
3-RV-101-07	7.62	3.56	2013-09-09	5.73	5.54	0.122	0.122	16.2	2019-02-12	
3-RV-101-08	7.62	3.56	2013-09-09	6.36	6.31	0.074	0.074	37.2	2019-02-12	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2013-09-09	4.49	4.35	0.059	0.037	26.4	2019-02-12	
2-RV-102-02	5.54	2.79	2013-09-09	4.29	4.01	0.079	0.109	11.2	2019-02-12	
2-RV-102-03	5.54	2.79	2013-09-09	4.68	4.64	0.042	0.037	43.9	2019-02-12	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-04	5.54	2.79	2013-09-09	4.81	4.73	0.043	0.020	45.5	2019-02-12	
2-RV-102-05	5.54	2.79	2013-09-09	4.96	4.97	0.013	0.013	>50	2019-02-12	
2-RV-102-06	5.54	2.79	2013-09-09	4.55	4.27	0.102	0.102	14.6	2019-02-12	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	2013-12-09	5.37	5.31	0.009	0.017	>50	2026-02-12	
3-RF-101-02	5.49	2.41	2013-12-09	5.40	5.34	0.006	0.003	>50	2026-02-12	
3-RF-101-03	5.49	2.41	2013-12-09	5.37	5.33	0.006	0.012	>50	2026-02-12	
3-RF-101-04	5.49	2.41	2013-12-09	5.41	5.35	0.006	-0.002	>50	2026-02-12	
3-RF-101-05	5.49	2.41	2013-12-09	5.32	5.33	0.006	0.007	>50	2026-02-12	
3-RF-101-06	5.49	2.41	2013-12-09	5.17	5.23	0.015	0.017	>50	2026-02-12	
3-RF-101-07	5.49	2.41	2013-12-09	5.48	5.37	0.003	-0.002	>50	2026-02-12	
3-RF-101-09	5.49	2.41	2013-12-09	5.26	5.19	-0.029	-0.029	>50	2026-02-12	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	2013-12-09	3.60	3.76	0.008	0.009	>50	2026-02-12	
2-RF-102-02	3.91	2.16	2013-12-09	3.70	3.64	0.012	0.024	>50	2026-02-12	
2-RF-102-03	3.91	2.16	2013-12-09	3.79	3.75	0.009	0.005	>50	2026-02-12	
2-RF-102-04	3.91	2.16	2013-12-09	3.82	3.38	0.025	0.043	28.3	2026-02-12	
2-RF-102-05	3.91	2.16	2013-12-09	3.67	3.49	0.082	0.082	16.1	2024-03-06	
2-RF-102-06	3.91	2.16	2013-12-09	3.67	3.47	0.099	0.099	13.2	2022-09-26	
2-RF-102-07	3.91	2.16	2013-12-09	3.72	3.57	0.020	0.028	>50	2026-02-12	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	2006-02-24	5.75	5.31	0.038	0.044	48.2	2026-02-12	
4-LA-104-02	6.02	3.18	2006-02-24	5.56	5.00	0.052	0.056	32.4	2026-02-12	
4-LA-104-03	6.02	3.18	2006-02-24	5.74	5.42	0.027	0.032	>50	2026-02-12	
4-LA-104-04	6.02	3.18	2006-02-24	5.86	5.63	0.022	0.023	>50	2026-02-12	
4-LA-104-05	6.02	3.18	2006-02-24	5.51	4.88	0.058	0.063	26.9	2026-02-12	
4-LA-104-06	6.02	3.18	2006-02-24	5.83	5.55	0.028	0.028	>50	2026-02-12	
4-LA-104-07	6.02	3.18	2006-02-24	5.62	5.28	0.037	0.034	>50	2026-02-12	
4-LA-104-08	6.02	3.18	2006-02-24	5.50	5.11	0.042	0.039	46.3	2026-02-12	
4-LA-104-10	6.02	3.18	—	—	4.84	—	—	—	2026-02-12	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2014-09-19	7.84	7.71	0.040	0.048	>50	2019-02-12	
4-RA-104-02	8.56	3.81	2014-09-19	8.09	7.85	0.035	0.058	>50	2019-02-12	
4-RA-104-03	8.56	3.81	2014-09-19	8.46	8.28	0.057	0.056	>50	2019-02-12	
4-RA-104-04	8.56	3.81	2014-09-19	8.49	8.18	0.063	0.084	>50	2019-02-12	
4-RA-104-05	8.56	3.81	2014-09-19	8.37	8.16	0.050	0.082	>50	2019-02-12	
4-RA-104-06	8.56	3.81	2014-09-19	7.91	7.61	0.049	0.074	>50	2019-02-12	
4-RA-104-07	8.56	3.81	2014-09-19	7.61	7.32	0.064	0.092	38.0	2019-02-12	
4-RA-104-08	8.56	3.81	2014-09-19	8.00	7.81	0.074	0.074	>50	2019-02-12	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	2006-02-24	3.64	3.61	0.016	0.003	>50	2026-02-12	
2-ST-101-02	3.91	2.29	2006-02-24	3.67	3.55	0.018	0.012	>50	2026-02-12	
2-ST-101-03	3.91	2.29	2006-02-24	3.82	3.55	0.020	0.027	46.5	2026-02-12	
2-ST-101-04	3.91	2.29	2006-02-24	3.77	3.68	0.007	0.009	>50	2026-02-12	
2-ST-101-05	3.91	2.29	2006-02-24	3.72	3.50	0.021	0.022	>50	2026-02-12	
2-ST-101-06	3.91	2.29	—	—	3.63	—	—	—	2026-02-12	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	2006-02-24	5.13	5.03	0.020	0.010	>50	2026-02-12	
3-CW-101-02	5.49	2.79	2006-02-24	5.20	5.01	0.020	0.019	>50	2026-02-12	
3-CW-101-03	5.49	2.79	2006-02-24	5.08	4.93	0.030	0.015	>50	2026-02-12	
3-CW-101-04	5.49	2.79	2006-02-24	5.38	5.26	0.010	0.012	>50	2026-02-12	
3-CW-101-05	5.49	2.79	2006-02-24	5.33	5.35	0.007	-0.002	>50	2026-02-12	
3-CW-101-06	5.49	2.79	—	—	5.08	—	—	—	2026-02-12	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	2006-02-24	5.20	5.06	0.022	0.014	>50	2026-02-12	
3-CW-102-02	5.49	2.79	2006-02-24	5.02	4.37	0.057	0.065	24.2	2026-02-12	
3-CW-102-03	5.49	2.79	2006-02-24	5.07	4.54	0.050	0.053	32.9	2026-02-12	
3-CW-102-04	5.49	2.79	2006-02-24	5.03	4.69	0.041	0.034	46.2	2026-02-12	
3-CW-102-05	5.49	2.79	—	—	4.66	—	—	—	2026-02-12	

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT Level II; CAN/CGSB-48.9712 UT Level II	2016-02-12	_____