No.	Status	Date
LNDE-RPT-20220906-033-DS-6-RA-103	Issued	2022-09-16

UT Thickness Data Sheet - 6-RA-103

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for line 6-RA-103, a rich amine header located within the ATU-100. The scope of work involves the recording of wall thickness at designated monitoring locations to assess asset integrity and corrosion rates.

Marcus Chen, acting as the lead UT technician and SNT-TC-1A UT Level II for Larkhall NDE Services Inc., is responsible for the execution of the measurements and the accuracy of the recorded data.

Technical Basis and Standards

All thickness measurements were performed in accordance with the requirements of ASTM E797. The inspection was conducted under the site-specific procedure QSCP-NDT-001 Rev 2, which governs ultrasonic thickness measurement for the ATU-100 and includes requirements for the CUI program.

The data presented herein supports the findings and conclusions detailed in the comprehensive report LNDE-RPT-20220906-033-R0.

Line Specifications

Line 6-RA-103 is constructed from A106 Gr.B carbon steel with a nominal outer diameter of 168.3 mm and a nominal wall thickness of 10.97 mm. The design limits for this service are 862 kPa(g) and 82 °C.

The minimum allowable wall thickness (t-min) for this line is 4.57 mm. Any reading falling below this threshold is subject to the site's non-conformance reporting process.

Inspection Results and Observations

Thickness data was collected as part of the 3-year RBI survey for Class 1 sour gas, regenerator overhead, and rich amine services. The measurements were used to determine the long-term and short-term corrosion rates to calculate the remaining life of the asset.

As noted in LNDE-RPT-20220906-033-R0, CML 6-RA-103-11 was recorded as inaccessible due to the absence of scaffolding and has been deferred to the 2024 survey.

Thickness readings, measured 2022-09-16

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	2019-10-18	5.93	5.82	0.049	0.053	42.6	2025-09-16	
6-SG-101-02	7.11	3.56	2019-10-18	5.51	5.42	0.061	0.052	30.3	2025-09-16	
6-SG-101-03	7.11	3.56	2019-10-18	5.56	5.29	0.067	0.088	19.7	2025-09-16	
6-SG-101-04	7.11	3.56	2019-10-18	5.34	5.19	0.072	0.059	22.8	2025-09-16	
6-SG-101-05	7.11	3.56	2019-10-18	5.04	4.72	0.091	0.100	11.6	2025-09-16	
6-SG-101-06	7.11	3.56	2019-10-18	5.56	5.55	0.057	0.050	34.7	2025-09-16	
6-SG-101-07	7.11	3.56	2019-10-18	6.24	6.16	0.027	0.027	>50	2025-09-16	
6-SG-101-08	7.11	3.56	2019-10-18	5.77	5.57	0.066	0.065	30.6	2025-09-16	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	2019-10-18	5.05	4.77	0.089	0.099	12.3	2025-09-16	
6-SG-102-02	7.11	3.56	2019-10-18	5.10	4.64	0.093	0.120	9.0	2025-09-16	
6-SG-102-03	7.11	3.56	2019-10-18	4.92	4.69	0.089	0.080	12.8	2025-09-16	
6-SG-102-04	7.11	3.56	2019-10-18	4.90	4.62	0.089	0.085	11.9	2025-09-16	
6-SG-102-05	7.11	3.56	2019-10-18	6.07	5.96	0.044	0.035	>50	2025-09-16	
6-SG-102-06	7.11	3.56	2019-10-18	6.03	5.79	0.054	0.041	41.6	2025-09-16	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	2019-10-18	7.29	6.83	0.064	0.152	19.9	2025-09-16	
4-RA-101-02	8.56	3.81	2019-10-18	7.39	6.79	0.066	0.174	17.1	2025-09-16	
4-RA-101-03	8.56	3.81	2019-10-18	6.64	5.98	0.099	0.253	8.6	2025-09-16	
4-RA-101-04	8.56	3.81	2019-10-18	7.54	7.21	0.054	0.120	28.4	2025-09-16	
4-RA-101-05	8.56	3.81	2019-10-18	7.18	6.73	0.071	0.165	17.7	2025-09-16	
4-RA-101-06	8.56	3.81	2019-10-18	6.94	—	—	—	—	—	inaccessible – no reading
4-RA-101-07	8.56	3.81	2019-10-18	7.68	7.50	0.041	0.097	38.0	2025-09-16	
4-RA-101-08	8.56	3.81	2019-10-18	6.45	5.55	0.118	0.267	6.5	2025-09-16	
4-RA-101-09	8.56	3.81	2019-10-18	7.68	7.37	0.045	0.115	30.9	2025-09-16	
4-RA-101-10	8.56	3.81	2019-10-18	7.55	7.19	0.056	0.126	26.8	2025-09-16	
4-RA-101-11	8.56	3.81	2019-10-18	6.66	6.07	0.098	0.232	9.7	2025-09-16	
4-RA-101-12	8.56	3.81	2019-10-18	7.03	6.41	0.213	0.213	12.2	2025-09-16	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	2019-10-18	7.58	7.42	0.042	0.091	39.7	2025-09-16	
4-RA-102-02	8.56	3.81	2019-10-18	6.96	6.43	0.081	0.184	14.3	2025-09-16	
4-RA-102-03	8.56	3.81	2019-10-18	7.05	6.56	0.075	0.150	18.3	2025-09-16	
4-RA-102-04	8.56	3.81	2019-10-18	7.04	6.64	0.072	0.164	17.3	2025-09-16	
4-RA-102-05	8.56	3.81	2019-10-18	7.06	6.56	0.075	0.168	16.3	2025-09-16	
4-RA-102-06	8.56	3.81	2019-10-18	7.15	6.65	0.070	0.164	17.3	2025-09-16	
4-RA-102-07	8.56	3.81	2019-10-18	7.30	6.85	0.065	0.141	21.6	2025-09-16	
4-RA-102-08	8.56	3.81	2019-10-18	6.40	5.86	0.099	0.226	9.1	2025-09-16	
4-RA-102-09	8.56	3.81	2019-10-18	6.78	6.42	0.080	0.170	15.4	2025-09-16	
4-RA-102-10	8.56	3.81	2019-10-18	7.36	6.86	0.172	0.172	17.8	2025-09-16	
4-RA-102-11	8.56	3.81	2019-10-18	7.72	7.33	0.074	0.096	36.8	2025-09-16	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	2019-10-18	9.83	9.55	0.055	0.112	44.4	2025-09-16	
6-RA-103-02	10.97	4.57	2019-10-18	8.61	7.97	0.118	0.261	13.0	2025-09-16	
6-RA-103-03	10.97	4.57	2019-10-18	9.49	8.95	0.077	0.168	26.0	2025-09-16	
6-RA-103-04	10.97	4.57	2019-10-18	8.22	7.30	0.139	0.305	9.0	2025-09-16	
6-RA-103-05	10.97	4.57	2019-10-18	8.33	7.43	0.133	0.311	9.2	2025-09-16	
6-RA-103-06	10.97	4.57	2019-10-18	9.79	9.45	0.059	0.132	37.0	2025-09-16	
6-RA-103-07	10.97	4.57	2019-10-18	9.59	9.15	0.069	0.159	28.8	2025-09-16	
6-RA-103-08	10.97	4.57	2019-10-18	9.73	9.29	0.063	0.158	29.9	2025-09-16	
6-RA-103-09	10.97	4.57	2019-10-18	9.78	9.43	0.060	0.137	35.6	2025-09-16	
6-RA-103-10	10.97	4.57	2019-10-18	8.37	7.68	0.126	0.275	11.3	2025-09-16	
6-RA-103-11	10.97	4.57	2019-10-18	8.91	—	—	—	—	—	inaccessible – no reading
6-RA-103-12	10.97	4.57	2019-10-18	9.52	9.11	0.141	0.141	32.3	2025-09-16	
6-RA-103-13	10.97	4.57	2019-10-18	9.55	9.13	0.114	0.155	29.5	2025-09-16	
6-RA-103-14	10.97	4.57	2019-10-18	8.26	7.34	0.316	0.316	8.8	2025-09-16	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	2019-10-18	6.05	5.92	0.063	0.064	37.0	2025-09-16	
3-RV-101-02	7.62	3.56	2019-10-18	5.97	5.81	0.066	0.076	29.7	2025-09-16	
3-RV-101-03	7.62	3.56	2019-10-18	5.24	4.98	0.096	0.099	14.4	2025-09-16	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-04	7.62	3.56	2019-10-18	5.58	5.39	0.083	0.074	22.1	2025-09-16	
3-RV-101-05	7.62	3.56	2019-10-18	6.11	5.91	0.066	0.068	34.4	2025-09-16	
3-RV-101-06	7.62	3.56	2019-10-18	5.55	5.39	0.083	0.086	21.2	2025-09-16	
3-RV-101-07	7.62	3.56	2019-10-18	5.07	4.80	0.117	0.112	10.6	2025-09-16	
3-RV-101-08	7.62	3.56	2019-10-18	5.86	5.81	0.075	0.076	29.7	2025-09-16	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	2019-10-18	4.16	3.91	0.061	0.067	16.8	2025-09-16	
2-RV-102-02	5.54	2.79	2019-10-18	3.86	3.64	0.074	0.056	11.6	2025-09-16	
2-RV-102-03	5.54	2.79	2019-10-18	4.37	4.34	0.043	0.046	34.1	2025-09-16	
2-RV-102-04	5.54	2.79	2019-10-18	4.59	4.47	0.042	0.039	40.1	2025-09-16	
2-RV-102-05	5.54	2.79	2019-10-18	4.78	4.59	0.037	0.058	31.2	2025-09-16	
2-RV-102-06	5.54	2.79	2019-10-18	4.27	4.05	0.064	0.033	19.6	2025-09-16	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	2019-10-18	7.15	6.61	0.072	0.167	16.8	2025-09-16	
4-RA-104-02	8.56	3.81	2019-10-18	7.31	7.04	0.057	0.123	26.3	2025-09-16	
4-RA-104-03	8.56	3.81	2019-10-18	7.94	7.70	0.074	0.088	44.2	2025-09-16	
4-RA-104-04	8.56	3.81	2019-10-18	7.64	7.31	0.101	0.132	26.5	2025-09-16	
4-RA-104-05	8.56	3.81	2019-10-18	7.57	7.12	0.109	0.158	21.0	2025-09-16	
4-RA-104-06	8.56	3.81	2019-10-18	7.13	6.70	0.071	0.138	20.9	2025-09-16	
4-RA-104-07	8.56	3.81	2019-10-18	6.67	6.04	0.096	0.194	11.5	2025-09-16	
4-RA-104-08	8.56	3.81	2019-10-18	7.46	7.09	0.094	0.109	30.0	2025-09-16	

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT Level II; CAN/CGSB-48.9712 UT Level II	2022-09-16	_____