No.	Status	Date
LNDE-RPT-20260209-006-DS-6-RA-103	Issued	2026-02-16

UT Thickness Data Sheet - 6-RA-103

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurement results for the rich amine header 6-RA-103 located within the ATU-100. The scope is limited to the 12-month re-measurement of 6-RA-103-11 as detailed in LNDE-RPT-20260209-006-R0.

Sarah Thompson, acting as the UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., is responsible for the data acquisition and recording of thickness values for this line.

Technical Basis

Thickness measurements were performed in accordance with QSCP-NDT-001 Rev 4, utilizing the ATU-100 site NDE procedure for ultrasonic thickness measurement. The inspection methodology adheres to the requirements of ASTM E797.

The line 6-RA-103 consists of A106 Gr.B material with a nominal thickness of 10.97 mm and an outer diameter of 168.3 mm. Design limits for the asset are 862 kPa(g) and 82 °C.

Measurement Results

The current readings for 6-RA-103-11 indicate thinning at approximately the line rate since the trim restoration. All recorded values remain above the t-min of 4.57 mm.

The measured thickness is within the FFS projection as cited in LNDE-RPT-20260209-006-R0.

Asset Integrity Evaluation

Evaluation of the 6-RA-103 thickness data is conducted against the retirement thickness of 4.57 mm. No readings below t-min were recorded; therefore, no NCR is required for this section.

The remaining life and next inspection interval are determined based on the larger of the long-term or short-term corrosion rates, consistent with the site rules for rich amine service.

Thickness readings, measured 2026-02-16

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-11	10.97	4.57	2024-12-10	5.82	5.53	0.400	0.534	1.8	2027-02-16	gauge photo attached

Sign-off	Name	Function	Date	Signature
Prepared	Sarah Thompson	UT technician, SNT-TC-1A UT Level II	2026-02-16	_____