No.	Status	Date
LNDE-RPT-96-014-DS-3-RF-101	Issued	1996-03-08

UT Thickness Data Sheet - 3-RF-101

Scope and Responsibility

This data sheet provides the ultrasonic thickness measurements for line 3-RF-101 located within the ATU-100. The scope of work involves the recording of baseline wall thickness to establish the initial condition of the asset prior to service.

Grace Okafor, acting as the UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., is responsible for the execution of the measurements and the accuracy of the recorded data.

Technical Basis

All thickness measurements were performed under the requirements of QSCP-NDT-001 Rev 0. The inspection methodology adheres to the guidelines specified in ASTM E797.

The data recorded herein forms part of the baseline survey detailed in LNDE-RPT-96-014, which covers 118 CMLs for the ATU-100 unit.

Component Specifications

The subject line, 3-RF-101, is a reflux line constructed from A312 TP316. The nominal dimensions are OD 88.9 mm with a nominal wall thickness of 5.49 mm.

The design parameters for this line are 517 kPa(g) and 104 °C. The minimum allowable thickness (t-min) is established at 2.41 mm.

Inspection Results

Baseline UT thickness readings were obtained for 3-RF-101. As the unit is not yet in service, these values serve as the initial reference for future corrosion rate calculations.

All measured thicknesses were compared against the t-min of 2.41 mm to ensure the line meets the required baseline integrity standards.

Thickness readings, measured 1996-03-08

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	—	—	7.12	—	—	—	2001-03-08	
6-SG-101-02	7.11	3.56	—	—	7.05	—	—	—	2001-03-08	
6-SG-101-03	7.11	3.56	—	—	7.08	—	—	—	2001-03-08	
6-SG-101-04	7.11	3.56	—	—	7.09	—	—	—	2001-03-08	
6-SG-101-05	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-101-06	7.11	3.56	—	—	7.07	—	—	—	2001-03-08	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-102-02	7.11	3.56	—	—	7.11	—	—	—	2001-03-08	
6-SG-102-03	7.11	3.56	—	—	7.04	—	—	—	2001-03-08	
6-SG-102-04	7.11	3.56	—	—	6.99	—	—	—	2001-03-08	
6-SG-102-05	7.11	3.56	—	—	7.13	—	—	—	2001-03-08	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-02	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-03	8.18	4.06	—	—	8.23	—	—	—	2006-03-08	
8-TG-101-04	8.18	4.06	—	—	8.10	—	—	—	2006-03-08	
8-TG-101-05	8.18	4.06	—	—	8.22	—	—	—	2006-03-08	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-101-02	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-101-04	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-101-05	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-06	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-101-07	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	—	—	6.02	—	—	—	2006-03-08	
4-LA-102-02	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-03	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-04	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-102-05	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-06	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-07	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	—	—	7.02	—	—	—	2006-03-08	
6-LA-103-02	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-03	7.11	3.56	—	—	7.08	—	—	—	2006-03-08	
6-LA-103-04	7.11	3.56	—	—	7.17	—	—	—	2006-03-08	
6-LA-103-05	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-06	7.11	3.56	—	—	7.16	—	—	—	2006-03-08	
6-LA-103-07	7.11	3.56	—	—	7.18	—	—	—	2006-03-08	
6-LA-103-08	7.11	3.56	—	—	7.04	—	—	—	2006-03-08	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	—	—	8.52	—	—	—	2006-03-08	
4-RA-101-02	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-101-03	8.56	3.81	—	—	8.61	—	—	—	2006-03-08	
4-RA-101-04	8.56	3.81	—	—	8.63	—	—	—	2006-03-08	
4-RA-101-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-07	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-08	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	
4-RA-101-09	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-101-10	8.56	3.81	—	—	8.67	—	—	—	2006-03-08	
4-RA-101-11	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-02	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-102-03	8.56	3.81	—	—	8.56	—	—	—	2006-03-08	
4-RA-102-04	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-05	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-102-06	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-102-07	8.56	3.81	—	—	8.58	—	—	—	2006-03-08	
4-RA-102-08	8.56	3.81	—	—	8.49	—	—	—	2006-03-08	
4-RA-102-09	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	—	—	11.00	—	—	—	2006-03-08	
6-RA-103-02	10.97	4.57	—	—	11.09	—	—	—	2006-03-08	
6-RA-103-03	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-04	10.97	4.57	—	—	10.98	—	—	—	2006-03-08	
6-RA-103-05	10.97	4.57	—	—	10.95	—	—	—	2006-03-08	
6-RA-103-06	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-07	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-08	10.97	4.57	—	—	10.97	—	—	—	2006-03-08	
6-RA-103-09	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-10	10.97	4.57	—	—	11.02	—	—	—	2006-03-08	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-02	7.62	3.56	—	—	7.57	—	—	—	2001-03-08	
3-RV-101-03	7.62	3.56	—	—	7.52	—	—	—	2001-03-08	
3-RV-101-04	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-05	7.62	3.56	—	—	7.67	—	—	—	2001-03-08	
3-RV-101-06	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	—	—	5.53	—	—	—	2001-03-08	
2-RV-102-02	5.54	2.79	—	—	5.59	—	—	—	2001-03-08	
2-RV-102-03	5.54	2.79	—	—	5.48	—	—	—	2001-03-08	
2-RV-102-04	5.54	2.79	—	—	5.58	—	—	—	2001-03-08	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	—	—	5.48	—	—	—	2006-03-08	
3-RF-101-02	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-03	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-04	5.49	2.41	—	—	5.46	—	—	—	2006-03-08	
3-RF-101-05	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-06	5.49	2.41	—	—	5.52	—	—	—	2006-03-08	
3-RF-101-07	5.49	2.41	—	—	5.42	—	—	—	2006-03-08	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	—	—	3.92	—	—	—	2006-03-08	
2-RF-102-02	3.91	2.16	—	—	3.88	—	—	—	2006-03-08	
2-RF-102-03	3.91	2.16	—	—	3.93	—	—	—	2006-03-08	
2-RF-102-04	3.91	2.16	—	—	3.87	—	—	—	2006-03-08	
2-RF-102-07	3.91	2.16	—	—	3.96	—	—	—	2006-03-08	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-104-02	6.02	3.18	—	—	6.03	—	—	—	2006-03-08	
4-LA-104-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-104-04	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-104-05	6.02	3.18	—	—	6.04	—	—	—	2006-03-08	
4-LA-104-06	6.02	3.18	—	—	6.10	—	—	—	2006-03-08	
4-LA-104-07	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-104-08	6.02	3.18	—	—	5.94	—	—	—	2006-03-08	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-104-02	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-104-03	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-104-04	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-104-06	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-07	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	—	—	3.93	—	—	—	2006-03-08	
2-ST-101-02	3.91	2.29	—	—	3.90	—	—	—	2006-03-08	
2-ST-101-03	3.91	2.29	—	—	3.94	—	—	—	2006-03-08	
2-ST-101-04	3.91	2.29	—	—	3.82	—	—	—	2006-03-08	
2-ST-101-05	3.91	2.29	—	—	3.91	—	—	—	2006-03-08	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	—	—	5.42	—	—	—	2006-03-08	
3-CW-101-02	5.49	2.79	—	—	5.41	—	—	—	2006-03-08	
3-CW-101-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-101-04	5.49	2.79	—	—	5.46	—	—	—	2006-03-08	
3-CW-101-05	5.49	2.79	—	—	5.48	—	—	—	2006-03-08	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	—	—	5.50	—	—	—	2006-03-08	
3-CW-102-02	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	
3-CW-102-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-102-04	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	

Sign-off	Name	Function	Date	Signature
Prepared	Grace Okafor	UT technician, SNT-TC-1A UT Level II	1996-03-08	_____