No.	Status	Date
LNDE-RPT-96-014-DS-3-RV-101	Issued	1996-03-08

UT Thickness Data Sheet - 3-RV-101

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for the 3-RV-101 regenerator overhead line within the ATU-100. The objective is to establish baseline wall thickness data for this specific line prior to the unit entering service.

Grace Okafor, acting as the UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., is responsible for the execution of the thickness measurements and the recording of the data presented herein.

Technical Basis and Standards

All thickness measurements were performed in accordance with the requirements of QSCP-NDT-001 Rev 0. This procedure governs the site NDE for pre-startup and in-service activities for the ATU-100.

The ultrasonic testing methodology and equipment application comply with the guidelines set forth in ASTM E797.

Component Specifications

The subject line, 3-RV-101, is constructed from A106 Gr.B with a nominal outer diameter of 88.9 mm and a nominal wall thickness of 7.62 mm. The design limits for this line are 345 kPa(g) and 121 °C.

The minimum allowable thickness (t-min) for this component is 3.56 mm. Any reading recorded below this threshold is subject to the site non-conformance reporting process.

Inspection Results

The data recorded in this sheet is a subset of the findings detailed in LNDE-RPT-96-014, which covers the baseline ultrasonic thickness survey of 118 CMLs for the ATU-100.

As the unit is not yet in service, these readings serve as the initial baseline for future corrosion rate calculations and remaining life assessments.

Thickness readings, measured 1996-03-08

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	—	—	7.12	—	—	—	2001-03-08	
6-SG-101-02	7.11	3.56	—	—	7.05	—	—	—	2001-03-08	
6-SG-101-03	7.11	3.56	—	—	7.08	—	—	—	2001-03-08	
6-SG-101-04	7.11	3.56	—	—	7.09	—	—	—	2001-03-08	
6-SG-101-05	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-101-06	7.11	3.56	—	—	7.07	—	—	—	2001-03-08	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-102-02	7.11	3.56	—	—	7.11	—	—	—	2001-03-08	
6-SG-102-03	7.11	3.56	—	—	7.04	—	—	—	2001-03-08	
6-SG-102-04	7.11	3.56	—	—	6.99	—	—	—	2001-03-08	
6-SG-102-05	7.11	3.56	—	—	7.13	—	—	—	2001-03-08	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-02	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-03	8.18	4.06	—	—	8.23	—	—	—	2006-03-08	
8-TG-101-04	8.18	4.06	—	—	8.10	—	—	—	2006-03-08	

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-05	8.18	4.06	—	—	8.22	—	—	—	2006-03-08	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-101-02	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-101-04	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-101-05	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-06	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-101-07	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	—	—	6.02	—	—	—	2006-03-08	
4-LA-102-02	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-03	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-04	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-102-05	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-06	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-07	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	—	—	7.02	—	—	—	2006-03-08	
6-LA-103-02	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-03	7.11	3.56	—	—	7.08	—	—	—	2006-03-08	
6-LA-103-04	7.11	3.56	—	—	7.17	—	—	—	2006-03-08	
6-LA-103-05	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-06	7.11	3.56	—	—	7.16	—	—	—	2006-03-08	
6-LA-103-07	7.11	3.56	—	—	7.18	—	—	—	2006-03-08	
6-LA-103-08	7.11	3.56	—	—	7.04	—	—	—	2006-03-08	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	—	—	8.52	—	—	—	2006-03-08	
4-RA-101-02	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-101-03	8.56	3.81	—	—	8.61	—	—	—	2006-03-08	
4-RA-101-04	8.56	3.81	—	—	8.63	—	—	—	2006-03-08	
4-RA-101-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-07	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-08	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	
4-RA-101-09	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-101-10	8.56	3.81	—	—	8.67	—	—	—	2006-03-08	
4-RA-101-11	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-02	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-102-03	8.56	3.81	—	—	8.56	—	—	—	2006-03-08	
4-RA-102-04	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-05	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-102-06	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-102-07	8.56	3.81	—	—	8.58	—	—	—	2006-03-08	
4-RA-102-08	8.56	3.81	—	—	8.49	—	—	—	2006-03-08	
4-RA-102-09	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	—	—	11.00	—	—	—	2006-03-08	
6-RA-103-02	10.97	4.57	—	—	11.09	—	—	—	2006-03-08	
6-RA-103-03	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-04	10.97	4.57	—	—	10.98	—	—	—	2006-03-08	
6-RA-103-05	10.97	4.57	—	—	10.95	—	—	—	2006-03-08	
6-RA-103-06	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-07	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-08	10.97	4.57	—	—	10.97	—	—	—	2006-03-08	
6-RA-103-09	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-10	10.97	4.57	—	—	11.02	—	—	—	2006-03-08	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-02	7.62	3.56	—	—	7.57	—	—	—	2001-03-08	
3-RV-101-03	7.62	3.56	—	—	7.52	—	—	—	2001-03-08	
3-RV-101-04	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-05	7.62	3.56	—	—	7.67	—	—	—	2001-03-08	
3-RV-101-06	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	—	—	5.53	—	—	—	2001-03-08	
2-RV-102-02	5.54	2.79	—	—	5.59	—	—	—	2001-03-08	
2-RV-102-03	5.54	2.79	—	—	5.48	—	—	—	2001-03-08	
2-RV-102-04	5.54	2.79	—	—	5.58	—	—	—	2001-03-08	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	—	—	5.48	—	—	—	2006-03-08	
3-RF-101-02	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-03	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-04	5.49	2.41	—	—	5.46	—	—	—	2006-03-08	
3-RF-101-05	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-06	5.49	2.41	—	—	5.52	—	—	—	2006-03-08	
3-RF-101-07	5.49	2.41	—	—	5.42	—	—	—	2006-03-08	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	—	—	3.92	—	—	—	2006-03-08	
2-RF-102-02	3.91	2.16	—	—	3.88	—	—	—	2006-03-08	
2-RF-102-03	3.91	2.16	—	—	3.93	—	—	—	2006-03-08	
2-RF-102-04	3.91	2.16	—	—	3.87	—	—	—	2006-03-08	
2-RF-102-07	3.91	2.16	—	—	3.96	—	—	—	2006-03-08	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-104-02	6.02	3.18	—	—	6.03	—	—	—	2006-03-08	
4-LA-104-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-104-04	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-104-05	6.02	3.18	—	—	6.04	—	—	—	2006-03-08	
4-LA-104-06	6.02	3.18	—	—	6.10	—	—	—	2006-03-08	
4-LA-104-07	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-104-08	6.02	3.18	—	—	5.94	—	—	—	2006-03-08	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-104-02	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-104-03	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-104-04	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-104-06	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-07	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	—	—	3.93	—	—	—	2006-03-08	
2-ST-101-02	3.91	2.29	—	—	3.90	—	—	—	2006-03-08	
2-ST-101-03	3.91	2.29	—	—	3.94	—	—	—	2006-03-08	
2-ST-101-04	3.91	2.29	—	—	3.82	—	—	—	2006-03-08	
2-ST-101-05	3.91	2.29	—	—	3.91	—	—	—	2006-03-08	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	—	—	5.42	—	—	—	2006-03-08	
3-CW-101-02	5.49	2.79	—	—	5.41	—	—	—	2006-03-08	
3-CW-101-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-101-04	5.49	2.79	—	—	5.46	—	—	—	2006-03-08	
3-CW-101-05	5.49	2.79	—	—	5.48	—	—	—	2006-03-08	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	—	—	5.50	—	—	—	2006-03-08	
3-CW-102-02	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	
3-CW-102-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-102-04	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	

Sign-off	Name	Function	Date	Signature
Prepared	Grace Okafor	UT technician, SNT-TC-1A UT Level II	1996-03-08	_____