No.	Status	Date
LNDE-RPT-96-014-DS-4-LA-101	Issued	1996-03-08

UT Thickness Data Sheet - 4-LA-101

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for the lean amine supply line 4-LA-101 within the ATU-100. The objective is to establish baseline wall thickness data for the asset prior to the unit entering service.

Grace Okafor, acting as the UT technician (SNT-TC-1A UT Level II) for Larkhall NDE Services Inc., performed the measurements and is responsible for the accuracy of the recorded data.

Technical Specifications

The subject line 4-LA-101 is constructed from A106 Gr.B with an outer diameter of 114.3 mm and a nominal thickness of 6.02 mm. The design pressure is 2413 kPa(g) and the design temperature is 93 °C.

The minimum allowable thickness (t-min) for this line is 3.18 mm. Any reading recorded below this value shall be processed as a non-conformance report.

Inspection Methodology

Thickness measurements were conducted in accordance with QSCP-NDT-001 Rev 0, the site NDE procedure issued for pre-startup and in-service inspections of the ATU-100.

The inspection was performed following the guidelines of ASTM E797 to ensure standardized ultrasonic thickness measurement practices.

Data Summary and Reporting

The measurements recorded on this data sheet form part of the larger baseline survey detailed in LNDE-RPT-96-014, which covers 118 CMLs for the unit.

As the unit is not yet in service, these readings serve as the initial baseline for future corrosion rate calculations and remaining life assessments.

Asset Integrity Classification

Line 4-LA-101 is categorized under Class 2 for amine service. This classification dictates a maximum thickness measurement interval of 10 years and an external visual inspection interval of 5 years.

Future inspection dates will be determined by the calculated corrosion rate and remaining life, ensuring the next reading occurs at no more than half the remaining life.

Thickness readings, measured 1996-03-08

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	—	—	7.12	—	—	—	2001-03-08	
6-SG-101-02	7.11	3.56	—	—	7.05	—	—	—	2001-03-08	
6-SG-101-03	7.11	3.56	—	—	7.08	—	—	—	2001-03-08	
6-SG-101-04	7.11	3.56	—	—	7.09	—	—	—	2001-03-08	
6-SG-101-05	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-101-06	7.11	3.56	—	—	7.07	—	—	—	2001-03-08	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-102-02	7.11	3.56	—	—	7.11	—	—	—	2001-03-08	
6-SG-102-03	7.11	3.56	—	—	7.04	—	—	—	2001-03-08	
6-SG-102-04	7.11	3.56	—	—	6.99	—	—	—	2001-03-08	
6-SG-102-05	7.11	3.56	—	—	7.13	—	—	—	2001-03-08	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-02	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-03	8.18	4.06	—	—	8.23	—	—	—	2006-03-08	
8-TG-101-04	8.18	4.06	—	—	8.10	—	—	—	2006-03-08	
8-TG-101-05	8.18	4.06	—	—	8.22	—	—	—	2006-03-08	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-101-02	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-101-04	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-101-05	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-06	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-101-07	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	—	—	6.02	—	—	—	2006-03-08	
4-LA-102-02	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-03	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-04	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-102-05	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-06	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-07	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	—	—	7.02	—	—	—	2006-03-08	
6-LA-103-02	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-03	7.11	3.56	—	—	7.08	—	—	—	2006-03-08	
6-LA-103-04	7.11	3.56	—	—	7.17	—	—	—	2006-03-08	
6-LA-103-05	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-06	7.11	3.56	—	—	7.16	—	—	—	2006-03-08	
6-LA-103-07	7.11	3.56	—	—	7.18	—	—	—	2006-03-08	
6-LA-103-08	7.11	3.56	—	—	7.04	—	—	—	2006-03-08	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	—	—	8.52	—	—	—	2006-03-08	
4-RA-101-02	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-101-03	8.56	3.81	—	—	8.61	—	—	—	2006-03-08	
4-RA-101-04	8.56	3.81	—	—	8.63	—	—	—	2006-03-08	
4-RA-101-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-07	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-08	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	
4-RA-101-09	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-101-10	8.56	3.81	—	—	8.67	—	—	—	2006-03-08	
4-RA-101-11	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-02	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-102-03	8.56	3.81	—	—	8.56	—	—	—	2006-03-08	
4-RA-102-04	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-05	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-102-06	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-102-07	8.56	3.81	—	—	8.58	—	—	—	2006-03-08	
4-RA-102-08	8.56	3.81	—	—	8.49	—	—	—	2006-03-08	
4-RA-102-09	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	—	—	11.00	—	—	—	2006-03-08	
6-RA-103-02	10.97	4.57	—	—	11.09	—	—	—	2006-03-08	
6-RA-103-03	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-04	10.97	4.57	—	—	10.98	—	—	—	2006-03-08	
6-RA-103-05	10.97	4.57	—	—	10.95	—	—	—	2006-03-08	
6-RA-103-06	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-07	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-08	10.97	4.57	—	—	10.97	—	—	—	2006-03-08	
6-RA-103-09	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-10	10.97	4.57	—	—	11.02	—	—	—	2006-03-08	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-02	7.62	3.56	—	—	7.57	—	—	—	2001-03-08	
3-RV-101-03	7.62	3.56	—	—	7.52	—	—	—	2001-03-08	
3-RV-101-04	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-05	7.62	3.56	—	—	7.67	—	—	—	2001-03-08	
3-RV-101-06	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	—	—	5.53	—	—	—	2001-03-08	
2-RV-102-02	5.54	2.79	—	—	5.59	—	—	—	2001-03-08	
2-RV-102-03	5.54	2.79	—	—	5.48	—	—	—	2001-03-08	
2-RV-102-04	5.54	2.79	—	—	5.58	—	—	—	2001-03-08	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	—	—	5.48	—	—	—	2006-03-08	
3-RF-101-02	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-03	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-04	5.49	2.41	—	—	5.46	—	—	—	2006-03-08	
3-RF-101-05	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-06	5.49	2.41	—	—	5.52	—	—	—	2006-03-08	
3-RF-101-07	5.49	2.41	—	—	5.42	—	—	—	2006-03-08	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	—	—	3.92	—	—	—	2006-03-08	
2-RF-102-02	3.91	2.16	—	—	3.88	—	—	—	2006-03-08	
2-RF-102-03	3.91	2.16	—	—	3.93	—	—	—	2006-03-08	
2-RF-102-04	3.91	2.16	—	—	3.87	—	—	—	2006-03-08	
2-RF-102-07	3.91	2.16	—	—	3.96	—	—	—	2006-03-08	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-104-02	6.02	3.18	—	—	6.03	—	—	—	2006-03-08	
4-LA-104-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-104-04	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-104-05	6.02	3.18	—	—	6.04	—	—	—	2006-03-08	
4-LA-104-06	6.02	3.18	—	—	6.10	—	—	—	2006-03-08	
4-LA-104-07	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-104-08	6.02	3.18	—	—	5.94	—	—	—	2006-03-08	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-104-02	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-104-03	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-104-04	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-104-06	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-07	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	—	—	3.93	—	—	—	2006-03-08	
2-ST-101-02	3.91	2.29	—	—	3.90	—	—	—	2006-03-08	
2-ST-101-03	3.91	2.29	—	—	3.94	—	—	—	2006-03-08	
2-ST-101-04	3.91	2.29	—	—	3.82	—	—	—	2006-03-08	
2-ST-101-05	3.91	2.29	—	—	3.91	—	—	—	2006-03-08	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	—	—	5.42	—	—	—	2006-03-08	
3-CW-101-02	5.49	2.79	—	—	5.41	—	—	—	2006-03-08	
3-CW-101-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-101-04	5.49	2.79	—	—	5.46	—	—	—	2006-03-08	
3-CW-101-05	5.49	2.79	—	—	5.48	—	—	—	2006-03-08	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	—	—	5.50	—	—	—	2006-03-08	
3-CW-102-02	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	
3-CW-102-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-102-04	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	

Sign-off	Name	Function	Date	Signature
Prepared	Grace Okafor	UT technician, SNT-TC-1A UT Level II	1996-03-08	_____