No.	Status	Date
LNDE-RPT-96-014-DS-4-RA-102	Issued	1996-03-08

UT Thickness Data Sheet - 4-RA-102

Scope and Responsibilities

This data sheet provides the ultrasonic thickness measurements for line 4-RA-102 within the ATU-100. The scope is limited to the baseline thickness recording of the rich amine piping to establish a reference for future asset integrity assessments.

Grace Okafor, acting as the UT technician, is responsible for the execution of the measurements and the recording of the data. All activities were performed in accordance with the requirements of the SNT-TC-1A UT Level II certification.

Technical Basis

The thickness measurements were performed under the requirements of QSCP-NDT-001 Rev 0. The methodology for the ultrasonic testing was conducted in accordance with the standard ASTM E797.

The data recorded herein forms part of the larger baseline survey detailed in LNDE-RPT-96-014, covering the pre-service condition of the ATU-100.

Component Specifications

Line 4-RA-102 is constructed from A106 Gr.B with an outside diameter of 114.3 mm and a nominal wall thickness of 8.56 mm. The design pressure is 862 kPa(g) and the design temperature is 82 °C.

The minimum allowable thickness (t-min) for this line is 3.81 mm. Any reading below this threshold is subject to the site non-conformance reporting process.

Inspection Results

Baseline thickness readings were obtained for the specified CMLs on 4-RA-102. As the unit is not yet in service, these values represent the initial state for the calculation of future corrosion rates.

The measured values are compared against the t-min of 3.81 mm to ensure the line meets the required baseline integrity standards prior to commissioning.

Integrity Assessment

The line is categorized under Class 2 for amine service, which dictates a maximum thickness measurement interval of 10 years and an external visual inspection interval of 5 years.

Remaining life and future inspection dates will be determined based on the long-term and short-term corrosion rates calculated from the baseline data provided in LNDE-RPT-96-014.

Thickness readings, measured 1996-03-08

Line 6-SG-101 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-101-01	7.11	3.56	—	—	7.12	—	—	—	2001-03-08	
6-SG-101-02	7.11	3.56	—	—	7.05	—	—	—	2001-03-08	
6-SG-101-03	7.11	3.56	—	—	7.08	—	—	—	2001-03-08	
6-SG-101-04	7.11	3.56	—	—	7.09	—	—	—	2001-03-08	
6-SG-101-05	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-101-06	7.11	3.56	—	—	7.07	—	—	—	2001-03-08	

Line 6-SG-102 | Sour gas inlet | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-SG-102-01	7.11	3.56	—	—	7.14	—	—	—	2001-03-08	
6-SG-102-02	7.11	3.56	—	—	7.11	—	—	—	2001-03-08	
6-SG-102-03	7.11	3.56	—	—	7.04	—	—	—	2001-03-08	
6-SG-102-04	7.11	3.56	—	—	6.99	—	—	—	2001-03-08	
6-SG-102-05	7.11	3.56	—	—	7.13	—	—	—	2001-03-08	

Line 8-TG-101 | Treated gas | A106 Gr.B | t_nom 8.18 mm | t-min 4.06 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
8-TG-101-01	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-02	8.18	4.06	—	—	8.20	—	—	—	2006-03-08	
8-TG-101-03	8.18	4.06	—	—	8.23	—	—	—	2006-03-08	
8-TG-101-04	8.18	4.06	—	—	8.10	—	—	—	2006-03-08	
8-TG-101-05	8.18	4.06	—	—	8.22	—	—	—	2006-03-08	

Line 4-LA-101 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-101-01	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-101-02	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-101-04	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-101-05	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-101-06	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-101-07	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	

Line 4-LA-102 | Lean amine supply | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-102-01	6.02	3.18	—	—	6.02	—	—	—	2006-03-08	
4-LA-102-02	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-03	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-102-04	6.02	3.18	—	—	5.99	—	—	—	2006-03-08	
4-LA-102-05	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-06	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	
4-LA-102-07	6.02	3.18	—	—	6.00	—	—	—	2006-03-08	

Line 6-LA-103 | Lean amine header | A106 Gr.B | t_nom 7.11 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-LA-103-01	7.11	3.56	—	—	7.02	—	—	—	2006-03-08	
6-LA-103-02	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-03	7.11	3.56	—	—	7.08	—	—	—	2006-03-08	
6-LA-103-04	7.11	3.56	—	—	7.17	—	—	—	2006-03-08	
6-LA-103-05	7.11	3.56	—	—	7.19	—	—	—	2006-03-08	
6-LA-103-06	7.11	3.56	—	—	7.16	—	—	—	2006-03-08	
6-LA-103-07	7.11	3.56	—	—	7.18	—	—	—	2006-03-08	
6-LA-103-08	7.11	3.56	—	—	7.04	—	—	—	2006-03-08	

Line 4-RA-101 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-101-01	8.56	3.81	—	—	8.52	—	—	—	2006-03-08	
4-RA-101-02	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-101-03	8.56	3.81	—	—	8.61	—	—	—	2006-03-08	
4-RA-101-04	8.56	3.81	—	—	8.63	—	—	—	2006-03-08	
4-RA-101-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-07	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-101-08	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	
4-RA-101-09	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-101-10	8.56	3.81	—	—	8.67	—	—	—	2006-03-08	
4-RA-101-11	8.56	3.81	—	—	8.68	—	—	—	2006-03-08	

Line 4-RA-102 | Rich amine | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-102-01	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-02	8.56	3.81	—	—	8.57	—	—	—	2006-03-08	
4-RA-102-03	8.56	3.81	—	—	8.56	—	—	—	2006-03-08	
4-RA-102-04	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-102-05	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-102-06	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-102-07	8.56	3.81	—	—	8.58	—	—	—	2006-03-08	
4-RA-102-08	8.56	3.81	—	—	8.49	—	—	—	2006-03-08	
4-RA-102-09	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	

Line 6-RA-103 | Rich amine header | A106 Gr.B | t_nom 10.97 mm | t-min 4.57 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
6-RA-103-01	10.97	4.57	—	—	11.00	—	—	—	2006-03-08	
6-RA-103-02	10.97	4.57	—	—	11.09	—	—	—	2006-03-08	
6-RA-103-03	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-04	10.97	4.57	—	—	10.98	—	—	—	2006-03-08	
6-RA-103-05	10.97	4.57	—	—	10.95	—	—	—	2006-03-08	
6-RA-103-06	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-07	10.97	4.57	—	—	10.99	—	—	—	2006-03-08	
6-RA-103-08	10.97	4.57	—	—	10.97	—	—	—	2006-03-08	
6-RA-103-09	10.97	4.57	—	—	11.01	—	—	—	2006-03-08	
6-RA-103-10	10.97	4.57	—	—	11.02	—	—	—	2006-03-08	

Line 3-RV-101 | Regenerator overhead | A106 Gr.B | t_nom 7.62 mm | t-min 3.56 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RV-101-01	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-02	7.62	3.56	—	—	7.57	—	—	—	2001-03-08	
3-RV-101-03	7.62	3.56	—	—	7.52	—	—	—	2001-03-08	
3-RV-101-04	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	
3-RV-101-05	7.62	3.56	—	—	7.67	—	—	—	2001-03-08	
3-RV-101-06	7.62	3.56	—	—	7.59	—	—	—	2001-03-08	

Line 2-RV-102 | Regenerator overhead | A106 Gr.B | t_nom 5.54 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RV-102-01	5.54	2.79	—	—	5.53	—	—	—	2001-03-08	
2-RV-102-02	5.54	2.79	—	—	5.59	—	—	—	2001-03-08	
2-RV-102-03	5.54	2.79	—	—	5.48	—	—	—	2001-03-08	
2-RV-102-04	5.54	2.79	—	—	5.58	—	—	—	2001-03-08	

Line 3-RF-101 | Reflux | A312 TP316 | t_nom 5.49 mm | t-min 2.41 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-RF-101-01	5.49	2.41	—	—	5.48	—	—	—	2006-03-08	
3-RF-101-02	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-03	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-04	5.49	2.41	—	—	5.46	—	—	—	2006-03-08	
3-RF-101-05	5.49	2.41	—	—	5.45	—	—	—	2006-03-08	
3-RF-101-06	5.49	2.41	—	—	5.52	—	—	—	2006-03-08	
3-RF-101-07	5.49	2.41	—	—	5.42	—	—	—	2006-03-08	

Line 2-RF-102 | Reflux | A312 TP316 | t_nom 3.91 mm | t-min 2.16 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-RF-102-01	3.91	2.16	—	—	3.92	—	—	—	2006-03-08	
2-RF-102-02	3.91	2.16	—	—	3.88	—	—	—	2006-03-08	
2-RF-102-03	3.91	2.16	—	—	3.93	—	—	—	2006-03-08	
2-RF-102-04	3.91	2.16	—	—	3.87	—	—	—	2006-03-08	
2-RF-102-07	3.91	2.16	—	—	3.96	—	—	—	2006-03-08	

Line 4-LA-104 | L/R exchanger, lean side | A106 Gr.B | t_nom 6.02 mm | t-min 3.18 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-LA-104-01	6.02	3.18	—	—	6.07	—	—	—	2006-03-08	
4-LA-104-02	6.02	3.18	—	—	6.03	—	—	—	2006-03-08	
4-LA-104-03	6.02	3.18	—	—	5.96	—	—	—	2006-03-08	
4-LA-104-04	6.02	3.18	—	—	6.06	—	—	—	2006-03-08	
4-LA-104-05	6.02	3.18	—	—	6.04	—	—	—	2006-03-08	
4-LA-104-06	6.02	3.18	—	—	6.10	—	—	—	2006-03-08	
4-LA-104-07	6.02	3.18	—	—	6.01	—	—	—	2006-03-08	
4-LA-104-08	6.02	3.18	—	—	5.94	—	—	—	2006-03-08	

Line 4-RA-104 | L/R exchanger, rich side | A106 Gr.B | t_nom 8.56 mm | t-min 3.81 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
4-RA-104-01	8.56	3.81	—	—	8.51	—	—	—	2006-03-08	
4-RA-104-02	8.56	3.81	—	—	8.55	—	—	—	2006-03-08	
4-RA-104-03	8.56	3.81	—	—	8.54	—	—	—	2006-03-08	
4-RA-104-04	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-05	8.56	3.81	—	—	8.60	—	—	—	2006-03-08	
4-RA-104-06	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	
4-RA-104-07	8.56	3.81	—	—	8.59	—	—	—	2006-03-08	

Line 2-ST-101 | Reboiler steam | A106 Gr.B | t_nom 3.91 mm | t-min 2.29 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
2-ST-101-01	3.91	2.29	—	—	3.93	—	—	—	2006-03-08	
2-ST-101-02	3.91	2.29	—	—	3.90	—	—	—	2006-03-08	
2-ST-101-03	3.91	2.29	—	—	3.94	—	—	—	2006-03-08	
2-ST-101-04	3.91	2.29	—	—	3.82	—	—	—	2006-03-08	
2-ST-101-05	3.91	2.29	—	—	3.91	—	—	—	2006-03-08	

Line 3-CW-101 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-101-01	5.49	2.79	—	—	5.42	—	—	—	2006-03-08	
3-CW-101-02	5.49	2.79	—	—	5.41	—	—	—	2006-03-08	
3-CW-101-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-101-04	5.49	2.79	—	—	5.46	—	—	—	2006-03-08	
3-CW-101-05	5.49	2.79	—	—	5.48	—	—	—	2006-03-08	

Line 3-CW-102 | Amine cooler CW | A106 Gr.B | t_nom 5.49 mm | t-min 2.79 mm

CML	t_nom (mm)	t-min (mm)	Prev. date	Prev. (mm)	Current (mm)	CR LT (mm/y)	CR ST (mm/y)	RL (y)	Next due	Remark
3-CW-102-01	5.49	2.79	—	—	5.50	—	—	—	2006-03-08	
3-CW-102-02	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	
3-CW-102-03	5.49	2.79	—	—	5.53	—	—	—	2006-03-08	
3-CW-102-04	5.49	2.79	—	—	5.51	—	—	—	2006-03-08	

Sign-off	Name	Function	Date	Signature
Prepared	Grace Okafor	UT technician, SNT-TC-1A UT Level II	1996-03-08	_____