No.	Status	Date
QSCP-CIS-001 Rev 0	Issued	2018-06-01

Corporate Integrity Standard - Piping Inspection and Integrity

Scope and Application

This standard establishes the mandatory requirements for piping inspection and integrity management across all QSCP sites. It defines the framework for maintaining the mechanical integrity of metallic and fiberglass-reinforced plastic piping systems in accordance with the principles established by Dr. Helen Marchetti. The requirements set forth in this document ensure a uniform approach to asset life extension and risk mitigation.

All site-level inspection programs must align with the mandates of API 570 to ensure compliance with recognized industry practices. This standard supersedes previous local procedures regarding inspection frequency and data management. The implementation of these requirements is mandatory for all facilities under the jurisdiction of QSCP Corporate Asset Integrity.

Responsibilities

Dr. Helen Marchetti is responsible for the technical governance of this standard and the oversight of its implementation across all corporate assets. The Corporate Asset Integrity department shall provide the necessary technical support to ensure that site-specific programs meet the minimum requirements for data quality and engineering analysis. Site management is responsible for providing the resources required to execute the re-baseline activities.

Site inspection personnel are responsible for the execution of inspection plans and the accurate recording of data within the corporate management system. Any deviations from the requirements of API 570 must be documented and approved by the Corporate Asset Integrity Manager. The responsibility for final integrity affirmations rests with the designated site lead in coordination with corporate engineering.

Inspection Planning and Intervals

Inspection intervals shall be determined using Risk-Based Inspection (RBI) methodologies. These intervals must be established within the maximum limits defined by API 570. The RBI process must account for active and potential damage mechanisms as identified through the application of API RP 571 to ensure all credible threats are addressed in the inspection scope.

A mandatory re-baseline of all Condition Monitoring Locations (CML) is required to ensure data integrity and consistency across the fleet. This re-baseline must capture essential data requirements for accurate corrosion rate modeling and remaining life calculations. The integration of API RP 571 damage mechanism screening is essential for the selection of appropriate non-destructive examination techniques.

Fitness-For-Service Assessment

When piping systems exhibit flaws, loss of containment, or thinning beyond original design margins, a formal assessment is required. All Fitness-For-Service evaluations must be performed in accordance with API 579-1/ASME FFS-1 to determine the suitability for continued operation. These assessments must consider the specific damage mechanisms and environmental factors affecting the asset.

Every assessment conducted under API 579-1/ASME FFS-1 must be performed by a qualified engineer. The results of these evaluations shall dictate the required mitigation, repair, or monitoring strategies. Documentation of these assessments must be maintained within the asset integrity record for the duration of the piping system's service life.

Sign-off	Name	Function	Date	Signature
Prepared	Dr. Helen Marchetti	Corporate Asset Integrity Manager, P.Eng.	2018-06-01	_____