Halward Inspection Services Ltd.

Transmittal

Site: Hamilton Plant

No.	Status	Date
HIS-TR-2011-019	Issued	2011-02-18

Transmittal - UT Survey Report HIS-2011-0207

Distribution Details

To: QSCP Hamilton Inspection Department

Attn: Chief Inspector

From: Halward Inspection Services Ltd.

Date: 2011-02-18

Site: Hamilton Plant

Enclosures

HIS-2011-0207: UT Thickness Survey - ATU-100 Sour Gas and Rich Amine

Purpose and Summary

Purpose: Submission for review and record.

Scope: 5-year Class 1 survey of ATU-100.

Findings: Rich amine circuit identified at half remaining life per site corrosion rate calculations.

Acknowledgement

Please acknowledge receipt by signing and returning a copy of this transmittal to Halward Inspection Services Ltd.