Larkhall NDE Services Inc.

Transmittal

Site: Hamilton Plant

No.	Status	Date
LNDE-TRN-2025-071	Issued	2025-11-03

Transmittal - Re-measurement Report LNDE-RPT-20251103-041-R0

Distribution Details

To: QSCP Hamilton Inspection Department

Attn: Department Lead

From: Larkhall NDE Services Inc.

Date: 2025-11-03

Site: Hamilton Plant

Enclosures

Document ID: LNDE-RPT-20251103-041-R0

Description: UT Re-measurement - 2-RF-102

Unit: ATU-100

Purpose and Summary

Purpose: For review and record.

Summary: 12-month re-measurement of 2-RF-102. Downstream CMLs recorded at 1.6 to 1.75 mm. Corrosion rate remains unchanged. Thickness remains above structural limit at projected turnaround date. Replacement scheduled for next turnaround remains valid.

Acknowledgement

Please acknowledge receipt of LNDE-RPT-20251103-041-R0 by signing and returning a copy of this transmittal.