No.	Status	Date
QSCP-RBI-ATU100-2023	Issued	2023-05-15

Risk-Based Inspection Review - ATU-100

Executive Summary

This CorpSummary, authored by Dr. Helen Marchetti and Jennifer Walsh, details the second RBI review for ATU-100. The review identifies a requirement to transition from QSCP-NDT-001 to QSCP-CIS-001 Rev 1 to address data-quality issues identified during the 2019 re-baseline survey. This transition ensures compliance with updated digital data protocols and CML-id naming conventions.

Historical Data and Quality Findings

LNDE-RPT-20191001-027-R0 documented a 150 CML re-baseline survey where mixed date formats and CML-id variants were observed. To mitigate these inconsistencies, QSCP-CIS-001 Rev 1 is now mandated, requiring PAUT for corrosion mapping and personnel certification to CAN/CGSB-48.9712 or EN ISO 9712. Damage mechanism assessment remains governed by API RP 571.

Inspection Status and Recommendations

LNDE-RPT-20220906-033-R0 recorded the 3-year RBI survey for Class 1 sour gas, regenerator overhead, and rich amine circuits. Due to lack of scaffolding, CMLs 4-RA-101-06 and 6-RA-103-11 were inaccessible and are deferred to the 2024 survey. Future inspections must adhere to the standardized reporting rules defined in the 2022-03-01 corporate integrity standard.

Sign-off	Name	Function	Date	Signature
Prepared	Dr. Helen Marchetti	Corporate Asset Integrity Manager, P.Eng.	2023-05-15	_____
Prepared	Jennifer Walsh	Inspection Coordinator, API 570 inspector	2023-05-15	_____