No.	Status	Date
LNDE-JSA-20160118-004	Issued	2016-02-12

Job Safety Analysis - ATU-100 UT Thickness Survey

General Information

Document ID: LNDE-JSA-20160118-004

Date: 2016-02-12

Location: Hamilton Plant

Unit: ATU-100

Author: Marcus Chen, lead UT technician, SNT-TC-1A UT Level II, Larkhall NDE Services Inc.

Scope of Work

Activity: Full-unit UT thickness survey.

Objective: Job safety analysis for the full-unit UT thickness survey.

Equipment: Ultrasonic thickness gauge.

Material Calibration: A312 TP316 lines measured at stainless-steel velocity setting.

Safety and Compliance Requirements

Acceptance Criteria: Retirement thickness defined as t-min. Readings below t-min require NCR issuance.

Interval Constraints: Regenerator overhead circuit and rich amine lines restricted to 3-year thickness intervals.

CUI Controls: Insulated lines in CUI range require profile RT or insulation windows every 5 years.

Class Maxima: Class 1 (5/5 years), Class 2 (10/5 years), Class 3 (10/10 years).

Hazard Mitigation

Access: Scaffolding or ladder access for CML locations.

Surface Prep: Removal of scale or loose coating for probe contact.

Remaining Life Calculation: (t - t-min) / rate. Next reading due at half remaining life or class maximum.

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT Level II; CAN/CGSB-48.9712 UT Level II	2016-02-12	_____