No.	Status	Date
LNDE-JSA-20191001-027	Issued	2019-10-18

Job Safety Analysis - ATU-100 Re-baseline UT Survey

Administrative Data

Document ID: LNDE-JSA-20191001-027

Date: 2019-10-18

Location: Hamilton Plant

Unit: ATU-100

Author: Trevor Nolan, Larkhall NDE Services Inc.

Scope of Work

Activity: Re-baseline UT survey for Amine Treating Unit piping.

Material: A312 TP316 stainless steel components.

Calibration: Ultrasonic equipment set to stainless-steel velocity for all measurements.

Safety and Compliance Requirements

Acceptance Criteria: Retirement thickness defined as line t-min; readings below t-min require immediate NCR.

Interval Management: Class 1 (sour gas, regenerator overhead) 5-year maximum; Class 2 (amine, reflux, treated gas) 10-year maximum.

RBI Constraints: 3-year interval for Class 1 sour gas and rich amine; 6-year interval for all other lines.

CUI Controls: Insulated lines in CUI range require profile RT or insulation windows every 5 years.

Hazard Mitigation

Personnel: Trevor Nolan to maintain UT Level II certification status.

Data Analysis: Remaining life calculated as (t - t-min) / rate; next inspection due at half remaining life.

Corrosion Monitoring: Rate determined by larger of long-term or short-term (minimum 3-year span) values.

Sign-off	Name	Function	Date	Signature
Prepared	Trevor Nolan	UT technician, SNT-TC-1A UT Level II	2019-10-18	_____