No.	Status	Date
LNDE-JSA-20241025-031	Issued	2024-10-29

Job Safety Analysis - ATU-100 Five-Year UT Survey

Administrative Data

Document ID: LNDE-JSA-20241025-031

Date: 2024-10-29

Location: Hamilton Plant

Unit: ATU-100

Author: Marcus Chen, SNT-TC-1A UT Level II, Larkhall NDE Services Inc.

Scope of Work

Activity: Job safety analysis for the 5-year survey.

Methodology: Ultrasonic thickness measurement of piping circuits.

Material Calibration: A312 TP316 lines calibrated to stainless-steel velocity setting.

Site Inspection Rules

Acceptance Criteria: Readings below t-min require NCR issuance.

Interval Calculation: Remaining life = (t - t-min) / rate. Next reading due at half remaining life or class maximum.

Class 1 (Sour Gas, Regenerator Overhead): 5 year thickness / 5 year external visual maximums.

Class 2 (Amine, Reflux, Treated Gas): 10 year thickness / 5 year external visual maximums.

RBI Intervals: 3 years for Class 1 sour gas, regenerator overhead, and rich amine; 6 years for other lines.

CUI Program: Profile RT or insulation windows every 5 years for insulated lines in CUI range.

Safety and Hazard Controls

Access: Scaffolding and ladder safety for elevated CML locations.

Thermal: Surface temperature monitoring for high-temperature amine and steam lines.

Chemical: PPE requirements for potential sour gas and amine exposure areas.

Sign-off	Name	Function	Date	Signature
Prepared	Marcus Chen	lead UT technician, SNT-TC-1A UT/MT/PT/VT Level II; CAN/CGSB-48.9712 UT Level II	2024-10-29	_____