No.	Status	Date
QSCP-RBI-NR21-2025	Issued	24.11.2025

Risk-Based Inspection Review - Anlage 21

Executive Summary

This document records the second RBI review of ANLAGE-21, following the initial assessment documented in QSCP-RBI-NR21-2018. The review, authored by Daniel Hartmann, evaluates the current integrity status of the solvent recovery unit based on updated inspection data and corporate compliance requirements.

Integrity Assessment and Compliance

All inspection activities and data management must adhere to QSCP-CIS-001 Rev 1, which mandates specific CML-id rules and the use of PAUT for corrosion mapping. Damage mechanism identification is performed in accordance with API RP 571. Recent surface examinations conducted under the hotspot program, as detailed in RLW-PB-2025-0277, confirmed no indications via penetrant testing.

Inspection Planning and Scheduling

The inspection strategy has been updated through NR-PFE-21-2024 and NR-PP-21 Rev 3. These documents reflect the re-issued interval workbook and prüfplan. Specifically, piping circuit NR-21-L-0207 is scheduled for re-measurement in February 2026 to maintain compliance with the updated prüffristenermittlung.

Sign-off	Name	Function	Date	Signature
Prepared	Daniel Hartmann	Integrity Engineer, QSCP Corporate Asset Integrity, based at Werk Niederrhein	24.11.2025	_____