

VAYU — AI Forecast Audit Brief

Generated: 06 May 2026, 03:53 IST | Issued by: VAYU Orchestrator Agent | Regulator-ready

1. Forecast Summary

Plant	P10 (MW)	P50 (MW)	P90 (MW)	Risk Score	Alert
Pavagada Solar	5	22	38	6.9/10	HIGH
Raichur Solar	6	20	35	8.7/10	CRITICAL
Chitradurga Wind	18	28	42	5.3/10	MEDIUM

2. Anomaly & Cascade Report

Alert Level: **CASCADE_CRITICAL** | Total Grid Drop: **63 MW** | Plants Flagged: **2**

3. Forecast Drivers (SHAP)

Based on the forecast, I'm indicating that the wind plant is expected to produce approximately 9.6 MW of power. The main factors contributing to this prediction are a moderate wind speed at 100 meters (12.86 meters per second), a favorable wind direction (101.69 degrees), and relatively clear skies with low cloud cover (45.33%).

4. Model Health & Learning Agent

Average MAPE (last 7 days): **5.32%** | Drift Alerts: **0** | Retrain Required: **False**

5. Operator Decision Record

This brief is auto-generated by VAYU for regulatory compliance. All forecasts include uncertainty bands (P10/P50/P90). Decisions made using this brief should be logged by the duty officer.