

Technical Guide: Carrier WeatherExpert 20-Ton Rooftop Unit (HVAC-01)

Asset ID: HVAC-01 | **Location:** Ground Floor Plant Room (Lobby Supply)

Model: Carrier 48LC WeatherExpert Packaged Rooftop Unit

Operating Parameters:

- **Supply Airflow:** 7,500 CFM
- **Refrigerant:** R-410A (Factory Charge: 22.0 lbs)
- **Cooling Supply Temp:** 55°F target

Maintenance Checklist:

- Replace MERV 11 filters every 90 days.
- Clean condensate drain pan and trap annually.