

REPORT- LV-M DOE-2.2 Units Conversion Table

WEATHER FILE- Los Angeles CA TMY2

	ENGLISH	MULTIPLIED BY	GIVES	METRIC	MULTIPLIED BY	GIVES	ENGLISH
1			1.000000			1.000000	
2			1.000000			1.000000	
3	BTU		0.293000	WH		3.412969	BTU
4	BTU/HR		0.293000	WATT		3.412969	BTU/HR
5	BTU/LB-F	4183.830078	J/KG-K			0.000239	BTU/LB-F
6	BTU/HR-SQFT-F		5.678260	W/M2-K		0.176110	BTU/HR-SQFT-F
7	DEGREES		1.000000	DEGREES		1.000000	DEGREES
9	SQFT		0.092903	M2		10.763915	SQFT
10	CUFT		0.028317	M3		35.314724	CUFT
11	LB/HR		0.453592	KG/HR		2.204624	LB/HR
12	LB/CUFT	16.018459	KG/M3			0.062428	LB/CUFT
13	MPH		0.447040	M/S		2.236936	MPH
14	BTU/HR-F		0.527178	W/K		1.896893	BTU/HR-F
15	FT		0.304800	M		3.280840	FT
16	BTU/HR-FT-F		1.730735	W/M-K		0.577789	BTU/HR-FT-F
17	BTU/HR- SQFT		3.152480	WATT /M2		0.317211	BTU/HR- SQFT
18	IN		2.540000	CM		0.393701	IN
19	UNITS/IN		0.393700	UNITS/CM		2.540005	UNITS/IN
20	UNITS		1.000000	UNITS		1.000000	UNITS
21	LB		0.453592	KG		2.204624	LB
22	FRAC.OR MULT.		1.000000	FRAC.OR MULT.		1.000000	FRAC.OR MULT.
23	HOURS		1.000000	HRS		1.000000	HOURS
24	PERCENT-RH		1.000000	PERCENT-RH		1.000000	PERCENT-RH
25	CFM		1.699010	M3/H		0.588578	CFM
26	IN-WATER	25.400000	MM-WATER			0.039370	IN-WATER
27	LB/SQFT		4.882400	KG/M2		0.204817	LB/SQFT
28	KW		1.000000	KW		1.000000	KW
29	W/SQFT	10.763920	W/M2			0.092903	W/SQFT
30	THERMS	25.000000	THERMIES			0.040000	THERMS
31	KNOTS		0.514440	M/SEC		1.943861	KNOTS
32	HR-SQFT-F /BTU		0.176228	M2-K /W		5.674467	HR-SQFT-F /BTU
33	\$DOLLARS		1.000000	\$DOLLARS		1.000000	\$DOLLARS
34	MBTU/HR		0.293000	MWATT		3.412969	MBTU/HR
35	YEARS		1.000000	YEARS		1.000000	YEARS
36	\$/HR		1.000000	\$/HR		1.000000	\$/HR
37	HRS/YEARS		1.000000	HRS/YEARS		1.000000	HRS/YEARS
38	PERCENT		1.000000	PERCENT		1.000000	PERCENT
39	\$/MONTH		1.000000	\$/MONTH		1.000000	\$/MONTH
40	GALLONS/MIN/TON		1.078000	LITERS/MIN/KW		0.927644	GALLONS/MIN/TON
41	BTU/LB		0.645683	WH/KG		1.548748	BTU/LB
42	LBS/SQIN-GAGE	68.947571	MBAR-GAGE			0.014504	LBS/SQIN-GAGE
43	\$/UNIT		1.000000	\$/UNIT		1.000000	\$/UNIT
44	BTU/HR/PERSON		0.293000	W/PERSON		3.412969	BTU/HR/PERSON
45	LBS/LB		1.000000	KGS/KG		1.000000	LBS/LB
46	BTU/BTU		1.000000	KWH/KWH		1.000000	BTU/BTU
47	LBS/KW		0.453590	KG/KW		2.204634	LBS/KW
48	REV/MIN		1.000000	REV/MIN		1.000000	REV/MIN
49	KW/TON		1.000000	KW/TON		1.000000	KW/TON
50	MBTU		0.293000	MWH		3.412969	MBTU
51	GAL		3.785410	LITER		0.264172	GAL
52	GAL/MIN		3.785410	LITERS/MIN		0.264172	GAL/MIN
53	BTU/F	1897.800049	J/K			0.000527	BTU/F
54	KWH		1.000000	KWH		1.000000	KWH
55	\$/UNIT-HR		1.000000	\$/UNIT-HR		1.000000	\$/UNIT-HR
56	KW/CFM		0.588500	KW/M3/HR		1.699235	KW/CFM
57	BTU/SQFT-F	20428.400391	J/M2-K			0.000049	BTU/SQFT-F
58	HR/HR		1.000000	HR/HR		1.000000	HR/HR
59	BTU/FT-F	6226.479980	J/M-K			0.000161	BTU/FT-F
60	R		0.555556	K		1.799999	R

61	INCH MER	33.863800	MBAR	0.029530	INCH MER
62	UNITS/GAL/MIN	0.264170	UNITS/LITER/MIN	3.785441	UNITS/GAL/MIN
63	(HR-SQFT-F/BTU) 2	0.031056	(M2-K /W) 2	32.199585	(HR-SQFT-F/BTU) 2
64	KBTU/HR	0.293000	KW	3.412969	KBTU/HR
65	KBTU	0.293000	KWH	3.412969	KBTU
66	CFM	0.471900	L/S	2.119093	CFM
67	CFM/SQFT	18.288000	M3/H-M2	0.054681	CFM/SQFT
68	1/R	1.799900	1/K	0.555586	1/R
69	1/KNOT	1.943860	SEC/M	0.514440	1/KNOT
70	FOOTCANDLES	10.763910	LUX	0.092903	FOOTCANDLES
71	FOOTLAMBERT	3.426259	CANDELA/M2	0.291864	FOOTLAMBERT
72	LUMEN / WATT	1.000000	LUMEN / WATT	1.000000	LUMEN / WATT
73	KBTU/SQFT-YR	3.152480	KWH/M2-YR	0.317211	KBTU/SQFT-YR
74	F (DELTA)	0.555556	C (DELTA)	1.799999	F (DELTA)
75	BTU/DAY	0.012202	WATT	81.953773	BTU/DAY
76	\$/YEAR	1.000000	\$/YEAR	1.000000	\$/YEAR
77	BTU/WATT	0.293000	WATT/WATT	3.412969	BTU/WATT
78	RADIANS	1.000000	RADIANS	1.000000	RADIANS
79	WATT/BTU	3.413000	WATT/WATT	0.292997	WATT/BTU
80	BTU	0.000293	KWH	3412.969482	BTU
81	WATT	1.000000	WATT	1.000000	WATT
82	LUMENS	1.000000	LUMENS	1.000000	LUMENS
83	BTU/HR-FT-R2	3.115335	W/M-K2	0.320993	BTU/HR-FT-R2
84	LB/FT-S	1.488163	KG/M-S	0.671969	LB/FT-S
85	LB/FT-S-R	2.678693	KG/M-S-K	0.373316	LB/FT-S-R
86	LB/CUFT-R	28.833212	KG/M3-K	0.034682	LB/CUFT-R
87	BTU/HR-FT-R	1.730741	W/M-K	0.577787	BTU/HR-FT-R
88	THERM	2.831700	M3	0.353145	THERM
89	THERM/HR	2.831700	M3/HR	0.353145	THERM/HR
90	TON	0.907180	TONNE	1.102317	TON
91	TON/HR	0.907180	TONNE/HR	1.102317	TON/HR
92	BTU/UNIT	1.000000	BTU/UNIT	1.000000	BTU/UNIT
93	\$	1.000000	\$	1.000000	\$
94	KW/GAL/MIN	0.264170	KW/LITER/MIN	3.785441	KW/GAL/MIN
95	CUFT/GAL	0.448831	M3-MIN/H-LITERS	2.228010	CUFT/GAL
96	MINUTES	1.000000	MINUTES	1.000000	MINUTES
97	UNUSED	1.000000	UNUSED	1.000000	UNUSED
98	UNUSED	1.000000	UNUSED	1.000000	UNUSED
99	UNUSED	1.000000	UNUSED	1.000000	UNUSED
100	UNUSED	1.000000	UNUSED	1.000000	UNUSED
101	UNUSED	1.000000	UNUSED	1.000000	UNUSED
102	UNUSED	1.000000	UNUSED	1.000000	UNUSED
103	UNUSED	1.000000	UNUSED	1.000000	UNUSED
104	UNUSED	1.000000	UNUSED	1.000000	UNUSED
105	UNUSED	1.000000	UNUSED	1.000000	UNUSED
106	UNUSED	1.000000	UNUSED	1.000000	UNUSED
107	UNUSED	1.000000	UNUSED	1.000000	UNUSED
108	UNUSED	1.000000	UNUSED	1.000000	UNUSED
109	UNUSED	1.000000	UNUSED	1.000000	UNUSED
110	UNUSED	1.000000	UNUSED	1.000000	UNUSED
111	UNUSED	1.000000	UNUSED	1.000000	UNUSED
112	UNUSED	1.000000	UNUSED	1.000000	UNUSED
113	BTU-F/BTU	0.555560	KWH-C/KWH	1.799986	BTU-F/BTU
114	UNUSED	1.000000	UNUSED	1.000000	UNUSED
115	VOLTS	1.000000	VOLTS	1.000000	VOLTS
116	C	1.000000	C	1.000000	C
117	AMPS	1.000000	AMPS	1.000000	AMPS
118	VOLTS/C	1.000000	VOLTS/C	1.000000	VOLTS/C
119	1/C	1.000000	1/C	1.000000	1/C
120	FT/MIN	0.005080	M/S	196.850388	FT/MIN
121	GAL/MIN	227.160004	LITERS/HR	0.004402	GAL/MIN
122	KW/CFM	588.500000	W/M3/HR	0.001699	KW/CFM
123	BTU/HR-F	0.000527	KW/C	1896.892578	BTU/HR-F
124	HP	0.102000	kW	9.803922	HP
125	CFM/TON	0.483200	(M3/H) /KW	2.069536	CFM/TON
126	UNUSED	1.000000	UNUSED	1.000000	UNUSED

127	UNUSED	1.000000	UNUSED	1.000000	UNUSED
128	UNUSED	1.000000	UNUSED	1.000000	UNUSED
129	UNUSED	1.000000	UNUSED	1.000000	UNUSED
130	1/VOLTS	1.000000	1/VOLTS	1.000000	1/VOLTS
131	(C-M2) /W	1.000000	(C-M2) /W	1.000000	(C-M2) /W
132	(C-M-SEC) /W	1.000000	(C-M-SEC) /W	1.000000	(C-M-SEC) /W
133	W/M2	1.000000	W/M2	1.000000	W/M2
134	TDV-MBTUH	0.293000	TDV-MW	3.412969	TDV-MBTUH
135	TDV-MBTU	0.293000	TDV-MWH	3.412969	TDV-MBTU
136	TDV-KBTU/KWH	0.293000	TDV-KWH/KWH	3.412969	TDV-KBTU/KWH
137	TDV-KBTU/THERM	0.010000	TDV-KWH/KWH	100.000000	TDV-KBTU/THERM
138	FT2/HR	0.092903	M2/SEC	10.763915	FT2/HR
139	GPM	0.063100	L/S	15.847859	GPM
140	FT/S	0.304800	M/S	3.280840	FT/S
141	HR-FT-F/BTU	0.577800	M-K/W	1.730703	HR-FT-F/BTU

WEATHER FILE- Los Angeles CA TMY2

East Perim Spc (.....	(153.2	148.4	0.0)										
Flr (B.E1.I1)	(-153.2	-148.4	-12.5)	(-153.2	-17.1	-12.5)	(-22.0	-17.2	-12.5)	(-22.0	-148.4	-12.5)	
Ceiling (B.E1.I2....	(-153.2	-148.4	-3.6)	(-22.0	-148.4	-3.6)	(-22.0	-17.2	-3.6)	(-153.2	-17.1	-3.6)	
Core Spc (B.C2)	(72.0	56.0	0.0)										
Flr (B.C2.I3)	(-72.0	-56.0	-12.5)	(-72.0	-106.0	-12.5)	(-104.0	-106.0	-12.5)	(-104.0	-56.0	-12.5)	
North Wall (B.C2....	(-72.0	-56.0	-3.6)	(-72.0	-56.0	-12.5)	(-104.0	-56.0	-12.5)	(-104.0	-56.0	-3.6)	
West Wall (B.C2....	(-104.0	-56.0	-3.6)	(-104.0	-56.0	-12.5)	(-104.0	-106.0	-12.5)	(-104.0	-106.0	-3.6)	
South Wall (B.C2....	(-104.0	-106.0	-3.6)	(-104.0	-106.0	-12.5)	(-72.0	-106.0	-12.5)	(-72.0	-106.0	-3.6)	
East Wall (B.C2....	(-72.0	-106.0	-3.6)	(-72.0	-106.0	-12.5)	(-72.0	-56.0	-12.5)	(-72.0	-56.0	-3.6)	
Ceiling (B.C2.I8....	(-72.0	-56.0	-3.6)	(-104.0	-56.0	-3.6)	(-104.0	-106.0	-3.6)	(-72.0	-106.0	-3.6)	
East Perim Plnm	(153.2	148.4	8.9)										
Ceiling (B.E1.I2....	(-153.2	-148.4	-3.6)	(-22.0	-148.4	-3.6)	(-22.0	-17.2	-3.6)	(-153.2	-17.1	-3.6)	
Flr (G.E5.I13)	(-153.2	-148.4	0.0)	(-153.2	-17.1	0.0)	(-22.0	-17.2	0.0)	(-22.0	-148.4	0.0)	
Core Plnm (B.C4).....	(72.0	56.0	8.9)										
Ceiling (B.C2.I8....	(-72.0	-56.0	-3.6)	(-104.0	-56.0	-3.6)	(-104.0	-106.0	-3.6)	(-72.0	-106.0	-3.6)	
North Wall (B.C4....	(-72.0	-56.0	0.0)	(-72.0	-56.0	-3.6)	(-104.0	-56.0	-3.6)	(-104.0	-56.0	0.0)	
West Wall (B.C4....	(-104.0	-56.0	0.0)	(-104.0	-56.0	-3.6)	(-104.0	-106.0	-3.6)	(-104.0	-106.0	0.0)	
South Wall (B.C4....	(-104.0	-106.0	0.0)	(-104.0	-106.0	-3.6)	(-72.0	-106.0	-3.6)	(-72.0	-106.0	0.0)	
East Wall (B.C4....	(-72.0	-106.0	0.0)	(-72.0	-106.0	-3.6)	(-72.0	-56.0	-3.6)	(-72.0	-56.0	0.0)	
Flr (G.C6.I15)	(-72.0	-56.0	0.0)	(-72.0	-106.0	0.0)	(-104.0	-106.0	0.0)	(-104.0	-56.0	0.0)	
East Perim Spc (.....	(153.2	148.4	0.0)										
South Wall (G.E5....	(-153.2	-148.4	8.9)	(-153.2	-148.4	0.0)	(-22.0	-148.4	0.0)	(-22.0	-148.4	8.9)	
South Win (G.E5....	(-152.1	-148.4	8.6)	(-152.1	-148.4	1.2)	(-148.6	-148.4	1.2)	(-148.6	-148.4	8.6)	
South Win (G.E5....	(-146.4	-148.4	8.6)	(-146.4	-148.4	1.2)	(-142.9	-148.4	1.2)	(-142.9	-148.4	8.6)	
South Win (G.E5....	(-140.7	-148.4	8.6)	(-140.7	-148.4	1.2)	(-137.2	-148.4	1.2)	(-137.2	-148.4	8.6)	
South Win (G.E5....	(-135.0	-148.4	8.6)	(-135.0	-148.4	1.2)	(-131.5	-148.4	1.2)	(-131.5	-148.4	8.6)	
South Win (G.E5....	(-129.3	-148.4	8.6)	(-129.3	-148.4	1.2)	(-125.8	-148.4	1.2)	(-125.8	-148.4	8.6)	
South Win (G.E5....	(-123.6	-148.4	8.6)	(-123.6	-148.4	1.2)	(-120.1	-148.4	1.2)	(-120.1	-148.4	8.6)	
South Win (G.E5....	(-117.8	-148.4	8.6)	(-117.8	-148.4	1.2)	(-114.4	-148.4	1.2)	(-114.4	-148.4	8.6)	
South Win (G.E5....	(-112.1	-148.4	8.6)	(-112.1	-148.4	1.2)	(-108.7	-148.4	1.2)	(-108.7	-148.4	8.6)	
South Win (G.E5....	(-106.4	-148.4	8.6)	(-106.4	-148.4	1.2)	(-103.0	-148.4	1.2)	(-103.0	-148.4	8.6)	
South Win (G.E5....	(-100.7	-148.4	8.6)	(-100.7	-148.4	1.2)	(-97.3	-148.4	1.2)	(-97.3	-148.4	8.6)	
South Win (G.E5....	(-77.9	-14											

East Win (G.E5.E (	-22.0	-67.4	8.6)	(	-22.0	-67.4	1.2)	(	-22.0	-63.9	1.2)	(	-22.0	-63.9	8.6)
East Win (G.E5.E (	-22.0	-61.7	8.6)	(	-22.0	-61.7	1.2)	(	-22.0	-58.2	1.2)	(	-22.0	-58.2	8.6)
East Win (G.E5.E (	-22.0	-56.0	8.6)	(	-22.0	-56.0	1.2)	(	-22.0	-52.5	1.2)	(	-22.0	-52.5	8.6)
East Win (G.E5.E (	-22.0	-50.3	8.6)	(	-22.0	-50.3	1.2)	(	-22.0	-46.8	1.2)	(	-22.0	-46.8	8.6)
East Win (G.E5.E (	-22.0	-44.6	8.6)	(	-22.0	-44.6	1.2)	(	-22.0	-41.1	1.2)	(	-22.0	-41.1	8.6)
East Win (G.E5.E (	-22.0	-38.8	8.6)	(	-22.0	-38.8	1.2)	(	-22.0	-35.4	1.2)	(	-22.0	-35.4	8.6)
East Win (G.E5.E (	-22.0	-33.1	8.6)	(	-22.0	-33.1	1.2)	(	-22.0	-29.7	1.2)	(	-22.0	-29.7	8.6)
East Win (G.E5.E (	-22.0	-27.4	8.6)	(	-22.0	-27.4	1.2)	(	-22.0	-24.0	1.2)	(	-22.0	-24.0	8.6)
East Win (G.E5.E (	-22.0	-21.7	8.6)	(	-22.0	-21.7	1.2)	(	-22.0	-18.3	1.2)	(	-22.0	-18.3	8.6)
East Win (G.E5.E (	-22.0	-90.2	8.6)	(	-22.0	-90.2	1.2)	(	-22.0	-86.8	1.2)	(	-22.0	-86.8	8.6)
East Win (G.E5.E (	-22.0	-78.7	8.6)	(	-22.0	-78.7	1.2)	(	-22.0	-75.3	1.2)	(	-22.0	-75.3	8.6)
East Door (G.E5. (	-22.0	-85.5	7.8)	(	-22.0	-85.5	0.3)	(	-22.0	-80.0	0.3)	(	-22.0	-80.0	7.8)
North Wall (G.E5.... (	-22.0	-17.2	8.9)	(	-22.0	-17.2	0.0)	(	-153.2	-17.1	0.0)	(	-153.2	-17.1	8.9)
North Win (G.E5. (	-23.1	-17.2	8.6)	(	-23.1	-17.2	1.2)	(	-26.6	-17.2	1.2)	(	-26.6	-17.2	8.6)
North Win (G.E5. (	-28.8	-17.2	8.6)	(	-28.8	-17.2	1.2)	(	-32.3	-17.2	1.2)	(	-32.3	-17.2	8.6)
North Win (G.E5. (	-34.5	-17.1	8.6)	(	-34.5	-17.1	1.2)	(	-38.0	-17.1	1.2)	(	-38.0	-17.1	8.6)
North Win (G.E5. (	-40.2	-17.1	8.6)	(	-40.2	-17.1	1.2)	(	-43.7	-17.1	1.2)	(	-43.7	-17.1	8.6)
North Win (G.E5. (	-45.9	-17.1	8.6)	(	-45.9	-17.1	1.2)	(	-49.4	-17.1	1.2)	(	-49.4	-17.1	8.6)
North Win (G.E5. (	-51.6	-17.1	8.6)	(	-51.6	-17.1	1.2)	(	-55.1	-17.1	1.2)	(	-55.1	-17.1	8.6)
North Win (G.E5. (	-57.4	-17.1	8.6)	(	-57.4	-17.1	1.2)	(	-60.8	-17.1	1.2)	(	-60.8	-17.1	8.6)
North Win (G.E5. (	-63.1	-17.1	8.6)	(	-63.1	-17.1	1.2)	(	-66.5	-17.1	1.2)	(	-66.5	-17.1	8.6)
North Win (G.E5. (	-68.8	-17.1	8.6)	(	-68.8	-17.1	1.2)	(	-72.2	-17.1	1.2)	(	-72.2	-17.1	8.6)
North Win (G.E5. (	-74.5	-17.1	8.6)	(	-74.5	-17.1	1.2)	(	-77.9	-17.1	1.2)	(	-77.9	-17.1	8.6)
North Win (G.E5. (	-97.3	-17.1	8.6)	(	-97.3	-17.1	1.2)	(	-100.7	-17.1	1.2)	(	-100.7	-17.1	8.6)
North Win (G.E5. (	-103.0	-17.1	8.6)	(	-103.0	-17.1	1.2)	(	-106.4	-17.1	1.2)	(	-106.4	-17.1	8.6)
North Win (G.E5. (	-108.7	-17.1	8.6)	(	-108.7	-17.1	1.2)	(	-112.1	-17.1	1.2)	(	-112.1	-17.1	8.6)
North Win (G.E5. (	-114.4	-17.1	8.6)	(	-114.4	-17.1	1.2)	(	-117.8	-17.1	1.2)	(	-117.8	-17.1	8.6)
North Win (G.E5. (	-120.1	-17.1	8.6)	(	-120.1	-17.1	1.2)	(	-123.6	-17.1	1.2)	(	-123.6	-17.1	8.6)
North Win (G.E5. (	-125.8	-17.1	8.6)	(	-125.8	-17.1	1.2)	(	-129.3	-17.1	1.2)	(	-129.3	-17.1	8.6)
North Win (G.E5. (	-131.5	-17.1	8.6)	(	-131.5	-17.1	1.2)	(	-135.0	-17.1	1.2)	(	-135.0	-17.1	8.6)
North Win (G.E5. (	-137.2	-17.1	8.6)	(	-137.2	-17.1	1.2)	(	-140.7	-17.1	1.2)	(	-140.7	-17.1	8.6)
North Win (G.E5. (	-142.9	-17.1	8.6)	(	-142.9	-17.1	1.2)	(	-146.4	-17.1	1.2)	(	-146.4	-17.1	8.6)
North Win (G.E5. (	-148.6	-17.1	8.6)	(	-148.6	-17.1	1.2)	(	-152.1	-17.1	1.2)	(	-152.1	-17.1	8.6)
North Win (G.E5. (	-80.2	-17.1	8.6)	(	-80.2	-17.1	1.2)	(	-83.6	-17.1	1.2)	(	-83.6	-17.1	8.6)
North Win (G.E5. (	-91.6	-17.1	8.6)	(	-91.6	-17.1	1.2)	(	-95.0	-17.1	1.2)	(	-95.0	-17.1	8.6)
North Door (G.E5 (	-84.8	-17.1	7.8)	(	-84.8	-17.1	0.3)	(	-90.3	-17.1	0.3)	(	-90.3	-17.1	7.8)
West Wall (G.E5.... (	-153.2	-17.1	8.9)	(	-153.2	-17.1	0.0)	(	-153.2	-148.4	0.0)	(	-153.2	-148.4	8.9)
West Win (G.E5.E (	-153.2	-18.3	8.6)	(	-153.2	-18.3	1.2)	(	-153.2	-21.7	1.2)	(	-153.2	-21.7	8.6)
West Win (G.E5.E (	-153.2	-24.0	8.6)	(	-153.2	-24.0	1.2)	(	-153.2	-27.4	1.2)	(	-153.2	-27.4	8.6)
West Win (G.E5.E (	-153.2	-29.7	8.6)	(	-153.2	-29.7	1.2)	(	-153.2	-33.1	1.2)	(	-153.2	-33.1	8.6)
West Win (G.E5.E (	-153.2	-35.4	8.6)	(	-153.2	-35.4	1.2)	(	-153.2	-38.8	1.2)	(	-153.2	-38.8	8.6)
West Win (G.E5.E (	-153.2	-41.1	8.6)	(	-153.2	-41.1	1.2)	(	-153.2	-44.6	1.2)	(	-153.2	-44.6	8.6)
West Win (G.E5.E (	-153.2	-46.8	8.6)	(	-153.2	-46.8	1.2)	(	-153.2	-50.3	1.2)	(	-153.2	-50.3	8.6)
West Win (G.E5.E (	-153.2	-52.5	8.6)	(	-153.2	-52.5	1.2)	(	-153.2	-56.0	1.2)	(	-153.2	-56.0	8.6)
West Win (G.E5.E (	-153.2	-58.2	8.6)	(	-153.2	-58.2	1.2)	(	-153.2	-61.7	1.2)	(	-153.2	-61.7	8.6)
West Win (G.E5.E (	-153.2	-63.9	8.6)	(	-153.2	-63.9	1.2)	(	-153.2	-67.4	1.2)	(	-153.2	-67.4	8.6)
West Win (G.E5.E (	-153.2	-69.6	8.6)	(	-153.2	-69.6	1.2)	(	-153.2	-73.1	1.2)	(	-153.2	-73.1	8.6)
West Win (G.E5.E (	-153.2	-92.5	8.6)	(	-153.2	-92.5	1.2)	(	-153.2	-95.9	1.2)	(	-153.2	-95.9	8.6)
West Win (G.E5.E (	-153.2	-98.2	8.6)	(	-153.2	-98.2	1.2)	(	-153.2	-101.6	1.2)	(	-153.2	-101.6	8.6)
West Win (G.E5.E (	-153.2	-103.9	8.6)	(	-153.2	-103.9	1.2)	(	-153.2	-107.3	1.2)	(	-153.2	-107.3	8.6)
West Win (G.E5.E (	-153.2	-109.6	8.6)	(	-153.2	-109.6	1.2)	(	-153.2	-113.0	1.2)	(	-153.2	-113.0	8.6)
West Win (G.E5.E (	-153.2	-115.3	8.6)	(	-153.2	-115.3	1.2)	(	-153.2	-118.7	1.2)	(	-153.2	-118.7	8.6)
West Win (G.E5.E (	-153.2	-121.0	8.6)	(	-153.2	-121.0	1.2)	(	-153.2	-124.4	1.2)	(	-153.2	-124.4	8.6)
West Win (G.E5.E (	-153.2	-126.7	8.6)	(	-153.2	-126.7	1.2)	(	-153.2	-130.2	1.2)	(	-153.2	-130.2	8.6)
West Win (G.E5.E (	-153.2	-132.4	8.6)	(	-153.2	-132.4	1.2)	(	-153.2	-135.9	1.2)	(	-153.2	-135.9	8.6)
West Win (G.E5.E (	-153.2	-138.1	8.6)	(	-153.2	-138.1	1.2)	(	-153.2	-141.6	1.2)	(	-153.2	-141.6	8.6)
West Win (G.E5.E (	-153.2	-143.8	8.6)	(	-153.2	-143.8	1.2)	(	-153.2	-147.3	1.2)	(	-153.2	-147.3	8.6)
West Win (G.E5.E (	-153.2	-75.3	8.6)	(	-153.2	-75.3	1.2)	(	-153.2	-78.7	1.2)	(	-153.2	-78.7	8.6)
West Win (G.E5.E (	-153.2	-86.8	8.6)	(	-153.2	-86.8	1.2)	(	-153.2	-90.2	1.2)	(	-153.2	-90.2	8.6)
West Door (G.E5. (	-153.2	-80.0	7.8)	(	-153.2	-80.0	0.3)	(	-153.2	-85.5	0.3)	(	-153.2	-85.5	7.8)
Flr (G.E5.I13) (	-153.2	-148.4	0.0)	(	-153.2	-17.1	0.0)	(	-22.0	-17.2	0.0)	(	-22.0	-148.4	0.0)
Ceiling (G.E5.I1.... (	-153.2	-148.4	8.9)	(	-22.0	-148.4	8.9)	(	-22.0	-17.2	8.9)	(	-153.2	-17.1	8.9)
Core Spc (G.C6) (	72.0	56.0	0.0)												
Flr (G.C6.I15) (	-72.0	-56.0	0.0)	(	-72.0	-106.0	0.0)	(	-104.0	-106.0	0.0)	(	-104.0	-56.0	0.0)
North Wall (G.C6.... (	-72.0	-56.0	8.9)	(	-72.0	-56.0	0.0)	(	-104.0	-56.0	0.0)	(	-104.0	-56.0	8.9)
West Wall (G.C6.... (	-104.0	-56.0	8.9)	(	-104.0	-56.0	0.0)	(	-104.0	-106.0	0.0)	(	-104.0	-106.0	8.9)

South Wall (G.C6....	(	-104.0	-106.0	8.9)	(	-104.0	-106.0	0.0)	(	-72.0	-106.0	0.0)	(	-72.0	-106.0	8.9)
East Wall (G.C6.....	(	-72.0	-106.0	8.9)	(	-72.0	-106.0	0.0)	(	-72.0	-56.0	0.0)	(	-72.0	-56.0	8.9)
Ceiling (G.C6.I2....	(	-72.0	-56.0	8.9)	(	-104.0	-56.0	8.9)	(	-104.0	-106.0	8.9)	(	-72.0	-106.0	8.9)
East Perim Plnm	(	153.2	148.4	8.9)												
South Wall (G.E7....	(	-153.2	-148.4	12.5)	(	-153.2	-148.4	8.9)	(	-22.0	-148.4	8.9)	(	-22.0	-148.4	12.5)
East Wall (G.E7.....	(	-22.0	-148.4	12.5)	(	-22.0	-148.4	8.9)	(	-22.0	-17.2	8.9)	(	-22.0	-17.2	12.5)
North Wall (G.E7....	(	-22.0	-17.2	12.5)	(	-22.0	-17.2	8.9)	(	-153.2	-17.1	8.9)	(	-153.2	-17.1	12.5)
West Wall (G.E7.....	(	-153.2	-17.1	12.5)	(	-153.2	-17.1	8.9)	(	-153.2	-148.4	8.9)	(	-153.2	-148.4	12.5)
Ceiling (G.E5.I1....	(	-153.2	-148.4	8.9)	(	-22.0	-148.4	8.9)	(	-22.0	-17.2	8.9)	(	-153.2	-17.1	8.9)
Flr (M.E9.I25)	(	-153.2	-148.4	12.5)	(	-153.2	-17.1	12.5)	(	-22.0	-17.2	12.5)	(	-22.0	-148.4	12.5)
Core Plnm (G.C8).....	(	72.0	56.0	8.9)												
Ceiling (G.C6.I2....	(	-72.0	-56.0	8.9)	(	-104.0	-56.0	8.9)	(	-104.0	-106.0	8.9)	(	-72.0	-106.0	8.9)
North Wall (G.C8....	(	-72.0	-56.0	12.5)	(	-72.0	-56.0	8.9)	(	-104.0	-56.0	8.9)	(	-104.0	-56.0	12.5)
West Wall (G.C8.....	(	-104.0	-56.0	12.5)	(	-104.0	-56.0	8.9)	(	-104.0	-106.0	8.9)	(	-104.0	-106.0	12.5)
South Wall (G.C8....	(	-104.0	-106.0	12.5)	(	-104.0	-106.0	8.9)	(	-72.0	-106.0	8.9)	(	-72.0	-106.0	12.5)
East Wall (G.C8.....	(	-72.0	-106.0	12.5)	(	-72.0	-106.0	8.9)	(	-72.0	-56.0	8.9)	(	-72.0	-56.0	12.5)
Flr (M.C10.I27)	(	-72.0	-56.0	12.5)	(	-72.0	-106.0	12.5)	(	-104.0	-106.0	12.5)	(	-104.0	-56.0	12.5)
East Perim Spc (.....	(	153.2	148.4	0.0)												
South Wall (M.E9....	(	-153.2	-148.4	21.4)	(	-153.2	-148.4	12.5)	(	-22.0	-148.4	12.5)	(	-22.0	-148.4	21.4)
South Win (M.E9....	(	-152.1	-148.4	21.1)	(	-152.1	-148.4	13.7)	(	-148.6	-148.4	13.7)	(	-148.6	-148.4	21.1)
South Win (M.E9....	(	-146.4	-148.4	21.1)	(	-146.4	-148.4	13.7)	(	-142.9	-148.4	13.7)	(	-142.9	-148.4	21.1)
South Win (M.E9....	(	-140.7	-148.4	21.1)	(	-140.7	-148.4	13.7)	(	-137.2	-148.4	13.7)	(	-137.2	-148.4	21.1)
South Win (M.E9....	(	-135.0	-148.4	21.1)	(	-135.0	-148.4	13.7)	(	-131.5	-148.4	13.7)	(	-131.5	-148.4	21.1)
South Win (M.E9....	(	-129.3	-148.4	21.1)	(	-129.3	-148.4	13.7)	(	-125.8	-148.4	13.7)	(	-125.8	-148.4	21.1)
South Win (M.E9....	(	-123.6	-148.4	21.1)	(	-123.6	-148.4	13.7)	(	-120.1	-148.4	13.7)	(	-120.1	-148.4	21.1)
South Win (M.E9....	(	-117.8	-148.4	21.1)	(	-117.8	-148.4	13.7)	(	-114.4	-148.4	13.7)	(	-114.4	-148.4	21.1)
South Win (M.E9....	(	-112.1	-148.4	21.1)	(	-112.1	-148.4	13.7)	(	-108.7	-148.4	13.7)	(	-108.7	-148.4	21.1)
South Win (M.E9....	(	-106.4	-148.4	21.1)	(	-106.4	-148.4	13.7)	(	-103.0	-148.4	13.7)	(	-103.0	-148.4	21.1)
South Win (M.E9....	(	-100.7	-148.4	21.1)	(	-100.7	-148.4	13.7)	(	-97.3	-148.4	13.7)	(	-97.3	-148.4	21.1)
South Win (M.E9....	(	-95.0	-148.4	21.1)	(	-95.0	-148.4	13.7)	(	-91.6	-148.4	13.7)	(	-91.6	-148.4	21.1)
South Win (M.E9....	(	-89.3	-148.4	21.1)	(	-89.3	-148.4	13.7)	(	-85.9	-148.4	13.7)	(	-85.9	-148.4	21.1)
South Win (M.E9....	(	-83.6	-148.4	21.1)	(	-83.6	-148.4	13.7)	(	-80.2	-148.4	13.7)	(	-80.2	-148.4	21.1)
South Win (M.E9....	(	-77.9	-148.4	21.1)	(	-77.9	-148.4	13.7)	(	-74.5	-148.4	13.7)	(	-74.5	-148.4	21.1)
South Win (M.E9....	(	-72.2	-148.4	21.1)	(	-72.2	-148.4	13.7)	(	-68.8	-148.4	13.7)	(	-68.8	-148.4	21.1)
South Win (M.E9....	(	-66.5	-148.4	21.1)	(	-66.5	-148.4	13.7)	(	-63.1	-148.4	13.7)	(	-63.1	-148.4	21.1)
South Win (M.E9....	(	-60.8	-148.4	21.1)	(	-60.8	-148.4	13.7)	(	-57.4	-148.4	13.7)	(	-57.4	-148.4	21.1)
South Win (M.E9....	(	-55.1	-148.4	21.1)	(	-55.1	-148.4	13.7)	(	-51.6	-148.4	13.7)	(	-51.6	-148.4	21.1)
South Win (M.E9....	(	-49.4	-148.4	21.1)	(	-49.4	-148.4	13.7)	(	-45.9	-148.4	13.7)	(	-45.9	-148.4	21.1)
South Win (M.E9....	(	-43.7	-148.4	21.1)	(	-43.7	-148.4	13.7)	(	-40.2	-148.4	13.7)	(	-40.2	-148.4	21.1)
South Win (M.E9....	(	-38.0	-148.4	21.1)	(	-38.0	-148.4	13.7)	(	-34.5	-148.4	13.7)	(	-34.5	-148.4	21.1)
South Win (M.E9....	(	-32.3	-148.4	21.1)	(	-32.3	-148.4	13.7)	(	-28.8	-148.4	13.7)	(	-28.8	-148.4	21.1)
South Win (M.E9....	(	-26.6	-148.4	21.1)	(	-26.6	-148.4	13.7)	(	-23.1	-148.4	13.7)	(	-23.1	-148.4	21.1)
East Wall (M.E9.....	(	-22.0	-148.4	21.4)	(	-22.0	-148.4	12.5)	(	-22.0	-17.2	12.5)	(	-22.0	-17.2	21.4)
East Win (M.E9.E....	(	-22.0	-147.3	21.1)	(	-22.0	-147.3	13.7)	(	-22.0	-143.8	13.7)	(	-22.0	-143.8	21.1)
East Win (M.E9.E....	(	-22.0	-141.6	21.1)	(	-22.0	-141.6	13.7)	(	-22.0	-138.1	13.7)	(	-22.0	-138.1	21.1)
East Win (M.E9.E....	(	-22.0	-135.9	21.1)	(	-22.0	-135.9	13.7)	(	-22.0	-132.4	13.7)	(	-22.0	-132.4	21.1)
East Win (M.E9.E....	(	-22.0	-130.2	21.1)	(	-22.0	-130.2	13.7)	(	-22.0	-126.7	13.7)	(	-22.0	-126.7	21.1)
East Win (M.E9.E....	(	-22.0	-124.4	21.1)	(	-22.0	-124.4	13.7)	(	-22.0	-121.0	13.7)	(	-22.0	-121.0	21.1)
East Win (M.E9.E....	(	-22.0	-118.7	21.1)	(	-22.0	-118.7	13.7)	(	-22.0	-115.3	13.7)	(	-22.0	-115.3	21.1)
East Win (M.E9.E....	(	-22.0	-113.0	21.1)	(	-22.0	-113.0	13.7)	(	-22.0	-109.6	13.7)	(	-22.0	-109.6	21.1)
East Win (M.E9.E....	(	-22.0	-107.3	21.1)	(	-22.0	-107.3	13.7)	(	-22.0	-103.9	13.7)	(	-22.0	-103.9	21.1)
East Win (M.E9.E....	(	-22.0	-101.6	21.1)	(	-22.0	-101.6	13.7)	(	-22.0	-98.2	13.7)	(	-22.0	-98.2	21.1)
East Win (M.E9.E....	(	-22.0	-95.9	21.1)	(	-22.0	-95.9	13.7)	(	-22.0	-92.5	13.7)	(	-22.0	-92.5	21.1)
East Win (M.E9.E....	(	-22.0	-90.2	21.1)	(	-22.0	-90.2	13.7)	(	-22.0	-86.8	13.7)	(	-22.0	-86.8	21.1)
East Win (M.E9.E....	(	-22.0	-84.5	21.1)	(	-22.0	-84.5	13.7)	(	-22.0	-81.1	13.7)	(	-22.0	-81.1	21.1)
East Win (M.E9.E....	(	-22.0	-78.8	21.1)	(	-22.0	-78.8	13.7)	(	-22.0	-75.3	13.7)	(	-22.0	-75.3	21.1)
East Win (M.E9.E....	(	-22.0	-73.1	21.1)	(	-22.0	-73.1	13.7)	(	-22.0	-69.6	13.7)	(	-22.0	-69.6	21.1)
East Win (M.E9.E....	(	-22.0	-67.4	21.1)	(	-22.0	-67.4	13.7)	(	-22.0	-63.9	13.7)	(	-22.0	-63.9	21.1)
East Win (M.E9.E....	(	-22.0	-61.7	21.1)	(	-22.0	-61.7	13.7)	(	-22.0	-58.2	13.7)	(	-22.0	-58.2	21.1)
East Win (M.E9.E....	(	-22.0	-56.0	21.1)	(	-22.0	-56.0	13.7)	(	-22.0	-52.5	13.7)	(	-22.0	-52.5	21.1)
East Win (M.E9.E....	(	-22.0	-50.3	21.1)	(	-22.0	-50.3	13.7)	(	-22.0	-46.8	13.7)	(	-22.0	-46.8	21.1)
East Win (M.E9.E....	(	-22.0	-44.6	21.1)	(	-22.0	-44.6	13.7)	(	-22.0	-41.1	13.7)	(	-22.0	-41.1	21.1)
East Win (M.E9.E....	(	-22.0	-38.8	21.1)	(	-22.0	-38.8	13.7)	(	-22.0	-35.4	13.7)	(	-22.0	-35.4	21.1)
East Win (M.E9.E....	(	-22.0	-33.1	21.1)	(	-22.0	-33.1	13.7)	(	-22.0	-29.7	13.7)	(	-22.0	-29.7	21.1)
East Win (M.E9.E....	(	-22.0	-27.4	21.1)	(	-22.0	-27.4	13.7)	(	-22.0	-24.0	13.7)	(	-22.0	-24.0	21.1)
East Win (M.E9.E....	(	-22.0	-21.7	21.1)	(	-22.0	-21.7	13.7)	(	-22.0	-18.3	13.7)	(	-22.0	-18.3	21.1)

North Wall (M.E9....	(	-22.0	-17.2	21.4)	(	-22.0	-17.2	12.5)	(	-153.2	-17.1	12.5)	(	-153.2	-17.1	21.4)
North Win (M.E9.	(	-23.1	-17.2	21.1)	(	-23.1	-17.2	13.7)	(	-26.6	-17.2	13.7)	(	-26.6	-17.2	21.1)
North Win (M.E9.	(	-28.8	-17.2	21.1)	(	-28.8	-17.2	13.7)	(	-32.3	-17.2	13.7)	(	-32.3	-17.2	21.1)
North Win (M.E9.	(	-34.5	-17.1	21.1)	(	-34.5	-17.1	13.7)	(	-38.0	-17.1	13.7)	(	-38.0	-17.1	21.1)
North Win (M.E9.	(	-40.2	-17.1	21.1)	(	-40.2	-17.1	13.7)	(	-43.7	-17.1	13.7)	(	-43.7	-17.1	21.1)
North Win (M.E9.	(	-45.9	-17.1	21.1)	(	-45.9	-17.1	13.7)	(	-49.4	-17.1	13.7)	(	-49.4	-17.1	21.1)
North Win (M.E9.	(	-51.6	-17.1	21.1)	(	-51.6	-17.1	13.7)	(	-55.1	-17.1	13.7)	(	-55.1	-17.1	21.1)
North Win (M.E9.	(	-57.4	-17.1	21.1)	(	-57.4	-17.1	13.7)	(	-60.8	-17.1	13.7)	(	-60.8	-17.1	21.1)
North Win (M.E9.	(	-63.1	-17.1	21.1)	(	-63.1	-17.1	13.7)	(	-66.5	-17.1	13.7)	(	-66.5	-17.1	21.1)
North Win (M.E9.	(	-68.8	-17.1	21.1)	(	-68.8	-17.1	13.7)	(	-72.2	-17.1	13.7)	(	-72.2	-17.1	21.1)
North Win (M.E9.	(	-74.5	-17.1	21.1)	(	-74.5	-17.1	13.7)	(	-77.9	-17.1	13.7)	(	-77.9	-17.1	21.1)
North Win (M.E9.	(	-80.2	-17.1	21.1)	(	-80.2	-17.1	13.7)	(	-83.6	-17.1	13.7)	(	-83.6	-17.1	21.1)
North Win (M.E9.	(	-85.9	-17.1	21.1)	(	-85.9	-17.1	13.7)	(	-89.3	-17.1	13.7)	(	-89.3	-17.1	21.1)
North Win (M.E9.	(	-91.6	-17.1	21.1)	(	-91.6	-17.1	13.7)	(	-95.0	-17.1	13.7)	(	-95.0	-17.1	21.1)
North Win (M.E9.	(	-97.3	-17.1	21.1)	(	-97.3	-17.1	13.7)	(	-100.7	-17.1	13.7)	(	-100.7	-17.1	21.1)
North Win (M.E9.	(	-103.0	-17.1	21.1)	(	-103.0	-17.1	13.7)	(	-106.4	-17.1	13.7)	(	-106.4	-17.1	21.1)
North Win (M.E9.	(	-108.7	-17.1	21.1)	(	-108.7	-17.1	13.7)	(	-112.1	-17.1	13.7)	(	-112.1	-17.1	21.1)
North Win (M.E9.	(	-114.4	-17.1	21.1)	(	-114.4	-17.1	13.7)	(	-117.8	-17.1	13.7)	(	-117.8	-17.1	21.1)
North Win (M.E9.	(	-120.1	-17.1	21.1)	(	-120.1	-17.1	13.7)	(	-123.6	-17.1	13.7)	(	-123.6	-17.1	21.1)
North Win (M.E9.	(	-125.8	-17.1	21.1)	(	-125.8	-17.1	13.7)	(	-129.3	-17.1	13.7)	(	-129.3	-17.1	21.1)
North Win (M.E9.	(	-131.5	-17.1	21.1)	(	-131.5	-17.1	13.7)	(	-135.0	-17.1	13.7)	(	-135.0	-17.1	21.1)
North Win (M.E9.	(	-137.2	-17.1	21.1)	(	-137.2	-17.1	13.7)	(	-140.7	-17.1	13.7)	(	-140.7	-17.1	21.1)
North Win (M.E9.	(	-142.9	-17.1	21.1)	(	-142.9	-17.1	13.7)	(	-146.4	-17.1	13.7)	(	-146.4	-17.1	21.1)
North Win (M.E9.	(	-148.6	-17.1	21.1)	(	-148.6	-17.1	13.7)	(	-152.1	-17.1	13.7)	(	-152.1	-17.1	21.1)
West Wall (M.E9.....	(	-153.2	-17.1	21.4)	(	-153.2	-17.1	12.5)	(	-153.2	-148.4	12.5)	(	-153.2	-148.4	21.4)
West Win (M.E9.E	(	-153.2	-18.3	21.1)	(	-153.2	-18.3	13.7)	(	-153.2	-21.7	13.7)	(	-153.2	-21.7	21.1)
West Win (M.E9.E	(	-153.2	-24.0	21.1)	(	-153.2	-24.0	13.7)	(	-153.2	-27.4	13.7)	(	-153.2	-27.4	21.1)
West Win (M.E9.E	(	-153.2	-29.7	21.1)	(	-153.2	-29.7	13.7)	(	-153.2	-33.1	13.7)	(	-153.2	-33.1	21.1)
West Win (M.E9.E	(	-153.2	-35.4	21.1)	(	-153.2	-35.4	13.7)	(	-153.2	-38.8	13.7)	(	-153.2	-38.8	21.1)
West Win (M.E9.E	(	-153.2	-41.1	21.1)	(	-153.2	-41.1	13.7)	(	-153.2	-44.6	13.7)	(	-153.2	-44.6	21.1)
West Win (M.E9.E	(	-153.2	-46.8	21.1)	(	-153.2	-46.8	13.7)	(	-153.2	-50.3	13.7)	(	-153.2	-50.3	21.1)
West Win (M.E9.E	(	-153.2	-52.5	21.1)	(	-153.2	-52.5	13.7)	(	-153.2	-56.0	13.7)	(	-153.2	-56.0	21.1)
West Win (M.E9.E	(	-153.2	-58.2	21.1)	(	-153.2	-58.2	13.7)	(	-153.2	-61.7	13.7)	(	-153.2	-61.7	21.1)
West Win (M.E9.E	(	-153.2	-63.9	21.1)	(	-153.2	-63.9	13.7)	(	-153.2	-67.4	13.7)	(	-153.2	-67.4	21.1)
West Win (M.E9.E	(	-153.2	-69.6	21.1)	(	-153.2	-69.6	13.7)	(	-153.2	-73.1	13.7)	(	-153.2	-73.1	21.1)
West Win (M.E9.E	(	-153.2	-75.3	21.1)	(	-153.2	-75.3	13.7)	(	-153.2	-78.8	13.7)	(	-153.2	-78.8	21.1)
West Win (M.E9.E	(	-153.2	-81.1	21.1)	(	-153.2	-81.1	13.7)	(	-153.2	-84.5	13.7)	(	-153.2	-84.5	21.1)
West Win (M.E9.E	(	-153.2	-86.8	21.1)	(	-153.2	-86.8	13.7)	(	-153.2	-90.2	13.7)	(	-153.2	-90.2	21.1)
West Win (M.E9.E	(	-153.2	-92.5	21.1)	(	-153.2	-92.5	13.7)	(	-153.2	-95.9	13.7)	(	-153.2	-95.9	21.1)
West Win (M.E9.E	(	-153.2	-98.2	21.1)	(	-153.2	-98.2	13.7)	(	-153.2	-101.6	13.7)	(	-153.2	-101.6	21.1)
West Win (M.E9.E	(	-153.2	-103.9	21.1)	(	-153.2	-103.9	13.7)	(	-153.2	-107.3	13.7)	(	-153.2	-107.3	21.1)
West Win (M.E9.E	(	-153.2	-109.6	21.1)	(	-153.2	-109.6	13.7)	(	-153.2	-113.0	13.7)	(	-153.2	-113.0	21.1)
West Win (M.E9.E	(	-153.2	-115.3	21.1)	(	-153.2	-115.3	13.7)	(	-153.2	-118.7	13.7)	(	-153.2	-118.7	21.1)
West Win (M.E9.E	(	-153.2	-121.0	21.1)	(	-153.2	-121.0	13.7)	(	-153.2	-124.4	13.7)	(	-153.2	-124.4	21.1)
West Win (M.E9.E	(	-153.2	-126.7	21.1)	(	-153.2	-126.7	13.7)	(	-153.2	-130.2	13.7)	(	-153.2	-130.2	21.1)
West Win (M.E9.E	(	-153.2	-132.4	21.1)	(	-153.2	-132.4	13.7)	(	-153.2	-135.9	13.7)	(	-153.2	-135.9	21.1)
West Win (M.E9.E	(	-153.2	-138.1	21.1)	(	-153.2	-138.1	13.7)	(	-153.2	-141.6	13.7)	(	-153.2	-141.6	21.1)
West Win (M.E9.E	(	-153.2	-143.8	21.1)	(	-153.2	-143.8	13.7)	(	-153.2	-147.3	13.7)	(	-153.2	-147.3	21.1)
Flr (M.E9.I25)	(	-153.2	-148.4	12.5)	(	-153.2	-17.1	12.5)	(	-22.0	-17.2	12.5)	(	-22.0	-148.4	12.5)
Ceiling (M.E9.I2....	(	-153.2	-148.4	21.4)	(	-22.0	-148.4	21.4)	(	-22.0	-17.2	21.4)	(	-153.2	-17.1	21.4)
Core Spc (M.C10).....	(	72.0	56.0	0.0)												
Flr (M.C10.I27)	(	-72.0	-56.0	12.5)	(	-72.0	-106.0	12.5)	(	-104.0	-106.0	12.5)	(	-104.0	-56.0	12.5)
North Wall (M.C1....	(	-72.0	-56.0	21.4)	(	-72.0	-56.0	12.5)	(	-104.0	-56.0	12.5)	(	-104.0	-56.0	21.4)
West Wall (M.C10....	(	-104.0	-56.0	21.4)	(	-104.0	-56.0	12.5)	(	-104.0	-106.0	12.5)	(	-104.0	-106.0	21.4)
South Wall (M.C1....	(	-104.0	-106.0	21.4)	(	-104.0	-106.0	12.5)	(	-72.0	-106.0	12.5)	(	-72.0	-106.0	21.4)
East Wall (M.C10....	(	-72.0	-106.0	21.4)	(	-72.0	-106.0	12.5)	(	-72.0	-56.0	12.5)	(	-72.0	-56.0	21.4)
Ceiling (M.C10.I....	(	-72.0	-56.0	21.4)	(	-104.0	-56.0	21.4)	(	-104.0	-106.0	21.4)	(	-72.0	-106.0	21.4)
East Perim Plnm	(	153.2	148.4	8.9)												
South Wall (M.E1....	(	-153.2	-148.4	25.0)	(	-153.2	-148.4	21.4)	(	-22.0	-148.4	21.4)	(	-22.0	-148.4	25.0)
East Wall (M.E11....	(	-22.0	-148.4	25.0)	(	-22.0	-148.4	21.4)	(	-22.0	-17.2	21.4)	(	-22.0	-17.2	25.0)
North Wall (M.E1....	(	-22.0	-17.2	25.0)	(	-22.0	-17.2	21.4)	(	-153.2	-17.1	21.4)	(	-153.2	-17.1	25.0)
West Wall (M.E11....	(	-153.2	-17.1	25.0)	(	-153.2	-17.1	21.4)	(	-153.2	-148.4	21.4)	(	-153.2	-148.4	25.0)
Ceiling (M.E9.I2....	(	-153.2	-148.4	21.4)	(	-22.0	-148.4	21.4)	(	-22.0	-17.2	21.4)	(	-153.2	-17.1	21.4)
Flr (T.E13.I37)	(	-153.2	-148.4	50.0)	(	-153.2	-17.1	50.0)	(	-22.0	-17.2	50.0)	(	-22.0	-148.4	50.0)
Core Plnm (M.C12.....	(	72.0	56.0	8.9)												
Ceiling (M.C10.I....	(	-72.0	-56.0	21.4)	(	-104.0	-56.0	21.4)	(	-104.0	-106.0	21.4)	(	-72.0	-106.0	21.4)

North Wall (M.C1....	(	-72.0	-56.0	25.0)	(	-72.0	-56.0	21.4)	(	-104.0	-56.0	21.4)	(	-104.0	-56.0	25.0)
West Wall (M.C12....	(	-104.0	-56.0	25.0)	(	-104.0	-56.0	21.4)	(	-104.0	-106.0	21.4)	(	-104.0	-106.0	25.0)
South Wall (M.C1....	(	-104.0	-106.0	25.0)	(	-104.0	-106.0	21.4)	(	-72.0	-106.0	21.4)	(	-72.0	-106.0	25.0)
East Wall (M.C12....	(	-72.0	-106.0	25.0)	(	-72.0	-106.0	21.4)	(	-72.0	-56.0	21.4)	(	-72.0	-56.0	25.0)
Flr (T.C14.I39)	(	-72.0	-56.0	50.0)	(	-72.0	-106.0	50.0)	(	-104.0	-106.0	50.0)	(	-104.0	-56.0	50.0)
East Perim Spc (.....	(	153.2	148.4	0.0)												
South Wall (T.E1.....	(	-153.2	-148.4	58.9)	(	-153.2	-148.4	50.0)	(	-22.0	-148.4	50.0)	(	-22.0	-148.4	58.9)
South Win (T.E13	(	-152.1	-148.4	58.6)	(	-152.1	-148.4	51.2)	(	-148.6	-148.4	51.2)	(	-148.6	-148.4	58.6)
South Win (T.E13	(	-146.4	-148.4	58.6)	(	-146.4	-148.4	51.2)	(	-142.9	-148.4	51.2)	(	-142.9	-148.4	58.6)
South Win (T.E13	(	-140.7	-148.4	58.6)	(	-140.7	-148.4	51.2)	(	-137.2	-148.4	51.2)	(	-137.2	-148.4	58.6)
South Win (T.E13	(	-135.0	-148.4	58.6)	(	-135.0	-148.4	51.2)	(	-131.5	-148.4	51.2)	(	-131.5	-148.4	58.6)
South Win (T.E13	(	-129.3	-148.4	58.6)	(	-129.3	-148.4	51.2)	(	-125.8	-148.4	51.2)	(	-125.8	-148.4	58.6)
South Win (T.E13	(	-123.6	-148.4	58.6)	(	-123.6	-148.4	51.2)	(	-120.1	-148.4	51.2)	(	-120.1	-148.4	58.6)
South Win (T.E13	(	-117.8	-148.4	58.6)	(	-117.8	-148.4	51.2)	(	-114.4	-148.4	51.2)	(	-114.4	-148.4	58.6)
South Win (T.E13	(	-112.1	-148.4	58.6)	(	-112.1	-148.4	51.2)	(	-108.7	-148.4	51.2)	(	-108.7	-148.4	58.6)
South Win (T.E13	(	-106.4	-148.4	58.6)	(	-106.4	-148.4	51.2)	(	-103.0	-148.4	51.2)	(	-103.0	-148.4	58.6)
South Win (T.E13	(	-100.7	-148.4	58.6)	(	-100.7	-148.4	51.2)	(	-97.3	-148.4	51.2)	(	-97.3	-148.4	58.6)
South Win (T.E13	(	-95.0	-148.4	58.6)	(	-95.0	-148.4	51.2)	(	-91.6	-148.4	51.2)	(	-91.6	-148.4	58.6)
South Win (T.E13	(	-89.3	-148.4	58.6)	(	-89.3	-148.4	51.2)	(	-85.9	-148.4	51.2)	(	-85.9	-148.4	58.6)
South Win (T.E13	(	-83.6	-148.4	58.6)	(	-83.6	-148.4	51.2)	(	-80.2	-148.4	51.2)	(	-80.2	-148.4	58.6)
South Win (T.E13	(	-77.9	-148.4	58.6)	(	-77.9	-148.4	51.2)	(	-74.5	-148.4	51.2)	(	-74.5	-148.4	58.6)
South Win (T.E13	(	-72.2	-148.4	58.6)	(	-72.2	-148.4	51.2)	(	-68.8	-148.4	51.2)	(	-68.8	-148.4	58.6)
South Win (T.E13	(	-66.5	-148.4	58.6)	(	-66.5	-148.4	51.2)	(	-63.1	-148.4	51.2)	(	-63.1	-148.4	58.6)
South Win (T.E13	(	-60.8	-148.4	58.6)	(	-60.8	-148.4	51.2)	(	-57.4	-148.4	51.2)	(	-57.4	-148.4	58.6)
South Win (T.E13	(	-55.1	-148.4	58.6)	(	-55.1	-148.4	51.2)	(	-51.6	-148.4	51.2)	(	-51.6	-148.4	58.6)
South Win (T.E13	(	-49.4	-148.4	58.6)	(	-49.4	-148.4	51.2)	(	-45.9	-148.4	51.2)	(	-45.9	-148.4	58.6)
South Win (T.E13	(	-43.7	-148.4	58.6)	(	-43.7	-148.4	51.2)	(	-40.2	-148.4	51.2)	(	-40.2	-148.4	58.6)
South Win (T.E13	(	-38.0	-148.4	58.6)	(	-38.0	-148.4	51.2)	(	-34.5	-148.4	51.2)	(	-34.5	-148.4	58.6)
South Win (T.E13	(	-32.3	-148.4	58.6)	(	-32.3	-148.4	51.2)	(	-28.8	-148.4	51.2)	(	-28.8	-148.4	58.6)
South Win (T.E13	(	-26.6	-148.4	58.6)	(	-26.6	-148.4	51.2)	(	-23.1	-148.4	51.2)	(	-23.1	-148.4	58.6)
East Wall (T.E13....	(	-22.0	-148.4	58.9)	(	-22.0	-148.4	50.0)	(	-22.0	-17.2	50.0)	(	-22.0	-17.2	58.9)
East Win (T.E13.	(	-22.0	-147.3	58.6)	(	-22.0	-147.3	51.2)	(	-22.0	-143.8	51.2)	(	-22.0	-143.8	58.6)
East Win (T.E13.	(	-22.0	-141.6	58.6)	(	-22.0	-141.6	51.2)	(	-22.0	-138.1	51.2)	(	-22.0	-138.1	58.6)
East Win (T.E13.	(	-22.0	-135.9	58.6)	(	-22.0	-135.9	51.2)	(	-22.0	-132.4	51.2)	(	-22.0	-132.4	58.6)
East Win (T.E13.	(	-22.0	-130.2	58.6)	(	-22.0	-130.2	51.2)	(	-22.0	-126.7	51.2)	(	-22.0	-126.7	58.6)
East Win (T.E13.	(	-22.0	-124.4	58.6)	(	-22.0	-124.4	51.2)	(	-22.0	-121.0	51.2)	(	-22.0	-121.0	58.6)
East Win (T.E13.	(	-22.0	-118.7	58.6)	(	-22.0	-118.7	51.2)	(	-22.0	-115.3	51.2)	(	-22.0	-115.3	58.6)
East Win (T.E13.	(	-22.0	-113.0	58.6)	(	-22.0	-113.0	51.2)	(	-22.0	-109.6	51.2)	(	-22.0	-109.6	58.6)
East Win (T.E13.	(	-22.0	-107.3	58.6)	(	-22.0	-107.3	51.2)	(	-22.0	-103.9	51.2)	(	-22.0	-103.9	58.6)
East Win (T.E13.	(	-22.0	-101.6	58.6)	(	-22.0	-101.6	51.2)	(	-22.0	-98.2	51.2)	(	-22.0	-98.2	58.6)
East Win (T.E13.	(	-22.0	-95.9	58.6)	(	-22.0	-95.9	51.2)	(	-22.0	-92.5	51.2)	(	-22.0	-92.5	58.6)
East Win (T.E13.	(	-22.0	-90.2	58.6)	(	-22.0	-90.2	51.2)	(	-22.0	-86.8	51.2)	(	-22.0	-86.8	58.6)
East Win (T.E13.	(	-22.0	-84.5	58.6)	(	-22.0	-84.5	51.2)	(	-22.0	-81.1	51.2)	(	-22.0	-81.1	58.6)
East Win (T.E13.	(	-22.0	-78.8	58.6)	(	-22.0	-78.8	51.2)	(	-22.0	-75.3	51.2)	(	-22.0	-75.3	58.6)
East Win (T.E13.	(	-22.0	-73.1	58.6)	(	-22.0	-73.1	51.2)	(	-22.0	-69.6	51.2)	(	-22.0	-69.6	58.6)
East Win (T.E13.	(	-22.0	-67.4	58.6)	(	-22.0	-67.4	51.2)	(	-22.0	-63.9	51.2)	(	-22.0	-63.9	58.6)
East Win (T.E13.	(	-22.0	-61.7	58.6)	(	-22.0	-61.7	51.2)	(	-22.0	-58.2	51.2)	(	-22.0	-58.2	58.6)
East Win (T.E13.	(	-22.0	-56.0	58.6)	(	-22.0	-56.0	51.2)	(	-22.0	-52.5	51.2)	(	-22.0	-52.5	58.6)
East Win (T.E13.	(	-22.0	-50.3	58.6)	(	-22.0	-50.3	51.2)	(	-22.0	-46.8	51.2)	(	-22.0	-46.8	58.6)
East Win (T.E13.	(	-22.0	-44.6	58.6)	(	-22.0	-44.6	51.2)	(	-22.0	-41.1	51.2)	(	-22.0	-41.1	58.6)
East Win (T.E13.	(	-22.0	-38.8	58.6)	(	-22.0	-38.8	51.2)	(	-22.0	-35.4	51.2)	(	-22.0	-35.4	58.6)
East Win (T.E13.	(	-22.0	-33.1	58.6)	(	-22.0	-33.1	51.2)	(	-22.0	-29.7	51.2)	(	-22.0	-29.7	58.6)
East Win (T.E13.	(	-22.0	-27.4	58.6)	(	-22.0	-27.4	51.2)	(	-22.0	-24.0	51.2)	(	-22.0	-24.0	58.6)
East Win (T.E13.	(	-22.0	-21.7	58.6)	(	-22.0	-21.7	51.2)	(	-22.0	-18.3	51.2)	(	-22.0	-18.3	58.6)
North Wall (T.E1....	(	-22.0	-17.2	58.9)	(	-22.0	-17.2	50.0)	(	-153.2	-17.1	50.0)	(	-153.2	-17.1	58.9)
North Win (T.E13	(	-23.1	-17.2	58.6)	(	-23.1	-17.2	51.2)	(	-26.6	-17.2	51.2)	(	-26.6	-17.2	58.6)
North Win (T.E13	(	-28.8	-17.2	58.6)	(	-28.8	-17.2	51.2)	(	-32.3	-17.2	51.2)	(	-32.3	-17.2	58.6)
North Win (T.E13	(	-34.5	-17.1	58.6)	(	-34.5	-17.1	51.2)	(	-38.0	-17.1	51.2)	(	-38.0	-17.1	58.6)
North Win (T.E13	(	-40.2	-17.1	58.6)	(	-40.2	-17.1	51.2)	(	-43.7	-17.1	51.2)	(	-43.7	-17.1	58.6)
North Win (T.E13	(	-45.9	-17.1	58.6)	(	-45.9	-17.1	51.2)	(	-49.4	-17.1	51.2)	(	-49.4	-17.1	58.6)
North Win (T.E13	(	-51.6	-17.1	58.6)	(	-51.6	-17.1	51.2)	(	-55.1	-17.1	51.2)	(	-55.1	-17.1	58.6)
North Win (T.E13	(	-57.4	-17.1	58.6)	(	-57.4	-17.1	51.2)	(	-60.8	-17.1	51.2)	(	-60.8	-17.1	58.6)
North Win (T.E13	(	-63.1	-17.1	58.6)	(	-63.1	-17.1	51.2)	(	-66.5	-17.1	51.2)	(	-66.5	-17.1	58.6)
North Win (T.E13	(	-68.8	-17.1	58.6)	(	-68.8	-17.1	51.2)	(	-72.2	-17.1	51.2)	(	-72.2	-17.1	58.6)
North Win (T.E13	(	-74.5	-17.1	58.6)	(	-74.5	-17.1	51.2)	(	-77.9	-17.1	51.2)	(	-77.9	-17.1	58.6)
North Win (T.E13	(	-80.2	-17.1	58.6)	(	-80.2	-17.1	51.2)	(	-83.6	-17.1	51.2)	(	-83.6	-17.1	58.6)

North Win (T.E13 (	-85.9	-17.1	58.6)	(	-85.9	-17.1	51.2)	(	-89.3	-17.1	51.2)	(	-89.3	-17.1	58.6)
North Win (T.E13 (	-91.6	-17.1	58.6)	(	-91.6	-17.1	51.2)	(	-95.0	-17.1	51.2)	(	-95.0	-17.1	58.6)
North Win (T.E13 (	-97.3	-17.1	58.6)	(	-97.3	-17.1	51.2)	(	-100.7	-17.1	51.2)	(	-100.7	-17.1	58.6)
North Win (T.E13 (	-103.0	-17.1	58.6)	(	-103.0	-17.1	51.2)	(	-106.4	-17.1	51.2)	(	-106.4	-17.1	58.6)
North Win (T.E13 (	-108.7	-17.1	58.6)	(	-108.7	-17.1	51.2)	(	-112.1	-17.1	51.2)	(	-112.1	-17.1	58.6)
North Win (T.E13 (	-114.4	-17.1	58.6)	(	-114.4	-17.1	51.2)	(	-117.8	-17.1	51.2)	(	-117.8	-17.1	58.6)
North Win (T.E13 (	-120.1	-17.1	58.6)	(	-120.1	-17.1	51.2)	(	-123.6	-17.1	51.2)	(	-123.6	-17.1	58.6)
North Win (T.E13 (	-125.8	-17.1	58.6)	(	-125.8	-17.1	51.2)	(	-129.3	-17.1	51.2)	(	-129.3	-17.1	58.6)
North Win (T.E13 (	-131.5	-17.1	58.6)	(	-131.5	-17.1	51.2)	(	-135.0	-17.1	51.2)	(	-135.0	-17.1	58.6)
North Win (T.E13 (	-137.2	-17.1	58.6)	(	-137.2	-17.1	51.2)	(	-140.7	-17.1	51.2)	(	-140.7	-17.1	58.6)
North Win (T.E13 (	-142.9	-17.1	58.6)	(	-142.9	-17.1	51.2)	(	-146.4	-17.1	51.2)	(	-146.4	-17.1	58.6)
North Win (T.E13 (	-148.6	-17.1	58.6)	(	-148.6	-17.1	51.2)	(	-152.1	-17.1	51.2)	(	-152.1	-17.1	58.6)
West Wall (T.E13....	-153.2	-17.1	58.9)	(	-153.2	-17.1	50.0)	(	-153.2	-148.4	50.0)	(	-153.2	-148.4	58.9)
West Win (T.E13. (	-153.2	-18.3	58.6)	(	-153.2	-18.3	51.2)	(	-153.2	-21.7	51.2)	(	-153.2	-21.7	58.6)
West Win (T.E13. (	-153.2	-24.0	58.6)	(	-153.2	-24.0	51.2)	(	-153.2	-27.4	51.2)	(	-153.2	-27.4	58.6)
West Win (T.E13. (	-153.2	-29.7	58.6)	(	-153.2	-29.7	51.2)	(	-153.2	-33.1	51.2)	(	-153.2	-33.1	58.6)
West Win (T.E13. (	-153.2	-35.4	58.6)	(	-153.2	-35.4	51.2)	(	-153.2	-38.8	51.2)	(	-153.2	-38.8	58.6)
West Win (T.E13. (	-153.2	-41.1	58.6)	(	-153.2	-41.1	51.2)	(	-153.2	-44.6	51.2)	(	-153.2	-44.6	58.6)
West Win (T.E13. (	-153.2	-46.8	58.6)	(	-153.2	-46.8	51.2)	(	-153.2	-50.3	51.2)	(	-153.2	-50.3	58.6)
West Win (T.E13. (	-153.2	-52.5	58.6)	(	-153.2	-52.5	51.2)	(	-153.2	-56.0	51.2)	(	-153.2	-56.0	58.6)
West Win (T.E13. (	-153.2	-58.2	58.6)	(	-153.2	-58.2	51.2)	(	-153.2	-61.7	51.2)	(	-153.2	-61.7	58.6)
West Win (T.E13. (	-153.2	-63.9	58.6)	(	-153.2	-63.9	51.2)	(	-153.2	-67.4	51.2)	(	-153.2	-67.4	58.6)
West Win (T.E13. (	-153.2	-69.6	58.6)	(	-153.2	-69.6	51.2)	(	-153.2	-73.1	51.2)	(	-153.2	-73.1	58.6)
West Win (T.E13. (	-153.2	-75.3	58.6)	(	-153.2	-75.3	51.2)	(	-153.2	-78.8	51.2)	(	-153.2	-78.8	58.6)
West Win (T.E13. (	-153.2	-81.1	58.6)	(	-153.2	-81.1	51.2)	(	-153.2	-84.5	51.2)	(	-153.2	-84.5	58.6)
West Win (T.E13. (	-153.2	-86.8	58.6)	(	-153.2	-86.8	51.2)	(	-153.2	-90.2	51.2)	(	-153.2	-90.2	58.6)
West Win (T.E13. (	-153.2	-92.5	58.6)	(	-153.2	-92.5	51.2)	(	-153.2	-95.9	51.2)	(	-153.2	-95.9	58.6)
West Win (T.E13. (	-153.2	-98.2	58.6)	(	-153.2	-98.2	51.2)	(	-153.2	-101.6	51.2)	(	-153.2	-101.6	58.6)
West Win (T.E13. (	-153.2	-103.9	58.6)	(	-153.2	-103.9	51.2)	(	-153.2	-107.3	51.2)	(	-153.2	-107.3	58.6)
West Win (T.E13. (	-153.2	-109.6	58.6)	(	-153.2	-109.6	51.2)	(	-153.2	-113.0	51.2)	(	-153.2	-113.0	58.6)
West Win (T.E13. (	-153.2	-115.3	58.6)	(	-153.2	-115.3	51.2)	(	-153.2	-118.7	51.2)	(	-153.2	-118.7	58.6)
West Win (T.E13. (	-153.2	-121.0	58.6)	(	-153.2	-121.0	51.2)	(	-153.2	-124.4	51.2)	(	-153.2	-124.4	58.6)
West Win (T.E13. (	-153.2	-126.7	58.6)	(	-153.2	-126.7	51.2)	(	-153.2	-130.2	51.2)	(	-153.2	-130.2	58.6)
West Win (T.E13. (	-153.2	-132.4	58.6)	(	-153.2	-132.4	51.2)	(	-153.2	-135.9	51.2)	(	-153.2	-135.9	58.6)
West Win (T.E13. (	-153.2	-138.1	58.6)	(	-153.2	-138.1	51.2)	(	-153.2	-141.6	51.2)	(	-153.2	-141.6	58.6)
West Win (T.E13. (	-153.2	-143.8	58.6)	(	-153.2	-143.8	51.2)	(	-153.2	-147.3	51.2)	(	-153.2	-147.3	58.6)
Flr (T.E13.I37)	-153.2	-148.4	50.0)	(	-153.2	-17.1	50.0)	(	-22.0	-17.2	50.0)	(	-22.0	-148.4	50.0)
Ceiling (T.E13.I....	-153.2	-148.4	58.9)	(	-22.0	-148.4	58.9)	(	-22.0	-17.2	58.9)	(	-153.2	-17.1	58.9)
Core Spc (T.C14).....	72.0	56.0	0.0)												
Flr (T.C14.I39)	-72.0	-56.0	50.0)	(	-72.0	-106.0	50.0)	(	-104.0	-106.0	50.0)	(	-104.0	-56.0	50.0)
North Wall (T.C1....	-72.0	-56.0	58.9)	(	-72.0	-56.0	50.0)	(	-104.0	-56.0	50.0)	(	-104.0	-56.0	58.9)
West Wall (T.C14....	-104.0	-56.0	58.9)	(	-104.0	-56.0	50.0)	(	-104.0	-106.0	50.0)	(	-104.0	-106.0	58.9)
South Wall (T.C1....	-104.0	-106.0	58.9)	(	-104.0	-106.0	50.0)	(	-72.0	-106.0	50.0)	(	-72.0	-106.0	58.9)
East Wall (T.C14....	-72.0	-106.0	58.9)	(	-72.0	-106.0	50.0)	(	-72.0	-56.0	50.0)	(	-72.0	-56.0	58.9)
Ceiling (T.C14.I....	-72.0	-56.0	58.9)	(	-104.0	-56.0	58.9)	(	-104.0	-106.0	58.9)	(	-72.0	-106.0	58.9)
East Perim Plnm	153.2	148.4	8.9)												
South Wall (T.E1....	-153.2	-148.4	62.5)	(	-153.2	-148.4	58.9)	(	-22.0	-148.4	58.9)	(	-22.0	-148.4	62.5)
East Wall (T.E15....	-22.0	-148.4	62.5)	(	-22.0	-148.4	58.9)	(	-22.0	-17.2	58.9)	(	-22.0	-17.2	62.5)
North Wall (T.E1....	-22.0	-17.2	62.5)	(	-22.0	-17.2	58.9)	(	-153.2	-17.1	58.9)	(	-153.2	-17.1	62.5)
West Wall (T.E15....	-153.2	-17.1	62.5)	(	-153.2	-17.1	58.9)	(	-153.2	-148.4	58.9)	(	-153.2	-148.4	62.5)
Ceiling (T.E13.I....	-153.2	-148.4	58.9)	(	-22.0	-148.4	58.9)	(	-22.0	-17.2	58.9)	(	-153.2	-17.1	58.9)
UnderRf (T.E15.I....	-153.2	-148.4	62.5)	(	-22.0	-148.4	62.5)	(	-22.0	-17.2	62.5)	(	-153.2	-17.1	62.5)
Core Plnm (T.C16).....	72.0	56.0	8.9)												
Ceiling (T.C14.I....	-72.0	-56.0	58.9)	(	-104.0	-56.0	58.9)	(	-104.0	-106.0	58.9)	(	-72.0	-106.0	58.9)
North Wall (T.C1....	-72.0	-56.0	62.5)	(	-72.0	-56.0	58.9)	(	-104.0	-56.0	58.9)	(	-104.0	-56.0	62.5)
West Wall (T.C16....	-104.0	-56.0	62.5)	(	-104.0	-56.0	58.9)	(	-104.0	-106.0	58.9)	(	-104.0	-106.0	62.5)
South Wall (T.C1....	-104.0	-106.0	62.5)	(	-104.0	-106.0	58.9)	(	-72.0	-106.0	58.9)	(	-72.0	-106.0	62.5)
East Wall (T.C16....	-72.0	-106.0	62.5)	(	-72.0	-106.0	58.9)	(	-72.0	-56.0	58.9)	(	-72.0	-56.0	62.5)
UnderRf (T.C16.I....	-72.0	-56.0	62.5)	(	-104.0	-56.0	62.5)	(	-104.0	-106.0	62.5)	(	-72.0	-106.0	62.5)
Under Roof (T.15).....	0.0	0.0	12.5)												
Roof (T.15.E25)	-153.2	-148.4	62.5)	(	-22.0	-148.4	62.5)	(	-87.6	-82.8	80.1)				
Roof (T.15.E26)	-22.0	-148.4	62.5)	(	-22.0	-17.1	62.5)	(	-87.6	-82.8	80.1)				
Roof (T.15.E27)	-22.0	-17.1	62.5)	(	-153.2	-17.1	62.5)	(	-87.6	-82.8	80.1)				
Roof (T.15.E28)	-153.2	-17.1	62.5)	(	-153.2	-148.4	62.5)	(	-87.6	-82.8	80.1)				
UnderRf (T.E15.I....	-153.2	-148.4	62.5)	(	-22.0	-148.4	62.5)	(	-22.0	-17.2	62.5)	(	-153.2	-17.1	62.5)
UnderRf (T.C16.I....	-72.0	-56.0	62.5)	(	-104.0	-56.0	62.5)	(	-104.0	-106.0	62.5)	(	-72.0	-106.0	62.5)

PERIOD OF STUDY

STARTING DATE	ENDING DATE	NUMBER OF DAYS
---------------	-------------	----------------

1 JAN 2026	31 DEC 2026	365
------------	-------------	-----

SITE CHARACTERISTIC DATA

STATION NAME	LATITUDE (DEG)	LONGITUDE (DEG)	ALTITUDE (FT)	TIME ZONE	BUILDING AZIMUTH (DEG)
-----------------	-------------------	--------------------	------------------	--------------	------------------------------

Los Angeles CA TMY2	33.9	118.4	100.	8 PST	0.0
---------------------	------	-------	------	-------	-----

REPORT- LV-B Summary of Spaces

WEATHER FILE- Los Angeles CA TMY2

NUMBER OF SPACES 17 EXTERIOR 9 INTERIOR 8

SPACE	SPACE*FLOOR MULTIPLIER	SPACE TYPE	AZIM	LIGHTS (WATT / SQFT)	PEOPLE	EQUIP (WATT / SQFT)	INFILTRATION METHOD	ACH	AREA (SQFT)	VOLUME (CUFT)
Spaces on floor: Below-Grade Flr										
East Perim Spc (B.E1)	1.0	EXT	180.0	0.80	169.3	1.02	NO-INFILT.	0.00	17220.0	153258.0
Core Spc (B.C2)	1.0	EXT	0.0	0.80	15.7	1.02	NO-INFILT.	0.00	1600.0	14240.0
East Perim Plnm (B.E3)	1.0	INT	180.0	0.00	0.0	0.00	AIR-CHANGE	0.07	17220.0	61992.0
Core Plnm (B.C4)	1.0	INT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.02	1600.0	5760.0
Spaces on floor: Ground Flr										
East Perim Spc (G.E5)	1.0	EXT	180.0	1.09	183.2	2.00	AIR-CHANGE	0.07	17220.0	153258.0
Core Spc (G.C6)	1.0	INT	0.0	1.50	4.8	0.70	AIR-CHANGE	0.01	1600.0	14240.0
East Perim Plnm (G.E7)	1.0	EXT	180.0	0.00	0.0	0.00	AIR-CHANGE	0.07	17220.0	61992.0
Core Plnm (G.C8)	1.0	INT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.02	1600.0	5760.0
Spaces on floor: Above-Grade Flrs										
East Perim Spc (M.E9)	3.0	EXT	180.0	1.01	188.4	2.55	AIR-CHANGE	0.07	17220.0	153258.0
Core Spc (M.C10)	3.0	INT	0.0	0.80	15.7	1.02	AIR-CHANGE	0.01	1600.0	14240.0
East Perim Plnm (M.E11)	3.0	EXT	180.0	0.00	0.0	0.00	AIR-CHANGE	0.07	17220.0	61992.0
Core Plnm (M.C12)	3.0	INT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.02	1600.0	5760.0
Spaces on floor: Top Abv-Grade Flr										
East Perim Spc (T.E13)	1.0	EXT	180.0	1.01	188.4	2.55	AIR-CHANGE	0.07	17220.0	153258.0
Core Spc (T.C14)	1.0	INT	0.0	0.80	15.7	1.02	AIR-CHANGE	0.01	1600.0	14240.0
East Perim Plnm (T.E15)	1.0	EXT	180.0	0.00	0.0	0.00	AIR-CHANGE	0.07	17220.0	61992.0
Core Plnm (T.C16)	1.0	INT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.02	1600.0	5760.0
Under Roof (T.15)	1.0	EXT	0.0	0.00	0.0	0.00	AIR-CHANGE	5.00	17220.0	101021.0
BUILDING TOTALS					1189.5				243060.0	1512521.0

REPORT- LV-C Details of Space

East Perim Spc (B.E1)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Spc (B.E1) IN FLOOR Below-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

SPACE AZIMUTH (DEG)			SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
XB (FT)	YB (FT)	ZB (FT)				
153.20	148.40	0.00	180.00	1.0	8.90	17220.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	1	1	4	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	169.3	101.7	249.6	230.9

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	0.80	13.78	1.00

REPORT- LV-C Details of Space

East Perim Spc (B.E1)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.20	3.38	0.95	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	0.82	14.10	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (B.E1.I2)	17220.00	Ceily Construction	0.381
SURFACE	SURFACE-TYPE	ADJACENT SPACE	
Ceiling (B.E1.I2)	DELAYED STANDARD	East Perim Plnm (B.E3)	

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE			
Flr (B.E1.I1)	1.0	17220.00	GFlr Construction	0.701	DELAYED			
LOCATION OF ORIGIN IN BUILDING COORDINATES								
LOCATION OF ORIGIN IN SPACE COORDINATES								
SURFACE	AZIMUTH (DEG)	TILT (DEG)	XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
Flr (B.E1.I1)	90.0	180.0	-153.20	-17.15	-12.50	0.00	0.00	0.00

UNDERGROUND SURFACES (U-VALUE INCLUDES INSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
South Wall (B.E1.U1)	1.0	1167.68	UWCons (B.E1.U1)	0.22
East Wall (B.E1.U2)	1.0	1168.13	UWCons (B.E1.U1)	0.22
North Wall (B.E1.U3)	1.0	1167.68	UWCons (B.E1.U1)	0.22
West Wall (B.E1.U4)	1.0	1168.13	UWCons (B.E1.U1)	0.22

REPORT- LV-C Details of Space

Core Spc (B.C2)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (B.C2)

IN FLOOR

Below-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

SPACE AZIMUTH (DEG)			SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
XB (FT)	YB (FT)	ZB (FT)				
72.00	56.00	0.00	0.00	1.0	8.90	1600.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	1	5	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	15.7	101.7	249.6	230.9

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	0.80	1.28	1.00

REPORT- LV-C Details of Space

Core Spc (B.C2)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.20	0.31	0.95	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	0.82	1.31	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
North Wall (B.C2.I4)	284.80	IWall Construction	0.315
West Wall (B.C2.I5)	445.00	IWall Construction	0.315
South Wall (B.C2.I6)	284.80	IWall Construction	0.315
East Wall (B.C2.I7)	445.00	IWall Construction	0.315
Ceiling (B.C2.I8)	1600.00	Ceilg Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
North Wall (B.C2.I4)	DELAYED ADIABATIC	
West Wall (B.C2.I5)	DELAYED ADIABATIC	
South Wall (B.C2.I6)	DELAYED ADIABATIC	
East Wall (B.C2.I7)	DELAYED ADIABATIC	
Ceiling (B.C2.I8)	DELAYED STANDARD	Core Plnm (B.C4)

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
Flr (B.C2.I3)	1.0	1600.00	GFlr Construction	0.701	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
Flr (B.C2.I3)	90.0	180.0	-72.00	-106.00	-12.50	0.00	0.00	0.00

REPORT- LV-C Details of Space

East Perim Plnm (B.E3)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Plnm (B.E3) IN FLOOR Below-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	8.90	180.00	1.0	3.60	17220.00	61992.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	2	4	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.004	0.07

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (B.E1.I2)	17220.00	Ceigl Construction	0.381
Flr (G.E5.I13)	17220.00	IFlr Construction	0.286

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Ceiling (B.E1.I2)	DELAYED STANDARD	East Perim Spc (B.E1)
Flr (G.E5.I13)	DELAYED STANDARD	East Perim Spc (G.E5)

UNDERGROUND SURFACES (U-VALUE INCLUDES INSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
South Wall (B.E3.U5)	1.0	472.32	UWCons (B.E3.U5)	0.29
East Wall (B.E3.U6)	1.0	472.50	UWCons (B.E3.U5)	0.29
North Wall (B.E3.U7)	1.0	472.32	UWCons (B.E3.U5)	0.29
West Wall (B.E3.U8)	1.0	472.50	UWCons (B.E3.U5)	0.29

REPORT- LV-C Details of Space

Core Plnm (B.C4)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Plnm (B.C4) IN FLOOR Below-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	8.90	0.00	1.0	3.60	1600.00	5760.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.02

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (B.C2.I8)	1600.00	Ceilg Construction	0.381
North Wall (B.C4.I9)	115.20	IWall Construction	0.315
West Wall (B.C4.I10)	180.00	IWall Construction	0.315
South Wall (B.C4.I11)	115.20	IWall Construction	0.315
East Wall (B.C4.I12)	180.00	IWall Construction	0.315
Flr (G.C6.I15)	1600.00	IFlr Construction	0.286

REPORT- LV-C Details of Space

Core Plnm (B.C4)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Ceiling (B.C2.I8)	DELAYED STANDARD	Core Spc (B.C2)
North Wall (B.C4.I9)	DELAYED ADIABATIC	
West Wall (B.C4.I10)	DELAYED ADIABATIC	
South Wall (B.C4.I11)	DELAYED ADIABATIC	
East Wall (B.C4.I12)	DELAYED ADIABATIC	
Flr (G.C6.I15)	DELAYED STANDARD	Core Spc (G.C6)

REPORT- LV-C Details of Space

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Spc (G.E5) IN FLOOR Ground Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	0.00	180.00	1.0	8.90	17220.00	153258.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
92	92	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.010	0.07

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	183.2	94.0	249.5	210.8

REPORT- LV-C Details of Space

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	1.09	18.85	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.36	6.23	0.93	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	1.64	28.17	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Flr (G.E5.I13)	17220.00	IFlr Construction	0.286
Ceiling (G.E5.I14)	17220.00	Ceilg Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Flr (G.E5.I13)	DELAYED STANDARD	East Perim Plnm (B.E3)
Ceiling (G.E5.I14)	DELAYED STANDARD	East Perim Plnm (G.E7)

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
South Wall (G.E5.E1)	1.0	1167.68	EWall Construction	0.439	DELAYED
East Wall (G.E5.E2)	1.0	1168.13	EWall Construction	0.439	DELAYED
North Wall (G.E5.E3)	1.0	1167.68	EWall Construction	0.439	DELAYED
West Wall (G.E5.E4)	1.0	1168.13	EWall Construction	0.439	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
South Wall (G.E5.E1)	-180.0	90.0	-153.20	-148.40	0.00	0.00	0.00	0.00
East Wall (G.E5.E2)	-270.0	90.0	-22.00	-148.40	0.00	131.20	0.00	0.00
North Wall (G.E5.E3)	0.0	90.0	-22.00	-17.15	0.00	131.20	131.25	0.00
West Wall (G.E5.E4)	-90.0	90.0	-153.20	-17.15	0.00	0.00	131.25	0.00

REPORT- LV-C Details of Space

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (SQFT)	GLASS WIDTH (FT)	GLASS HEIGHT (FT)	SET- BACK (FT)	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS SHADING COEFF	GLASS VISIBLE TRANS	GLASS SOLAR TRANS
South Win (G.E5.E1.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W21)	1.0	25.05	3.39	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (G.E5.E1.W22)	1.0	25.05	3.39	7.38	0.00	1	0.983	0.84	0.810	0.680
South Door (G.E5.E1.D1)	1.0	41.25	5.50	7.50	0.00	1	0.983	0.95	0.881	0.775
East Win (G.E5.E2.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W21)	1.0	25.06	3.40	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (G.E5.E2.W22)	1.0	25.06	3.40	7.38	0.00	1	0.983	0.84	0.810	0.680
East Door (G.E5.E2.D1)	1.0	41.25	5.50	7.50	0.00	1	0.983	0.95	0.881	0.775
North Win (G.E5.E3.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680

REPORT- LV-C Details of Space

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (SQFT)	GLASS WIDTH (FT)	GLASS HEIGHT (FT)	SET- BACK (FT)	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS SHADING COEFF	GLASS VISIBLE TRANS	GLASS SOLAR TRANS
North Win (G.E5.E3.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W21)	1.0	25.05	3.39	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (G.E5.E3.W22)	1.0	25.05	3.39	7.38	0.00	1	0.983	0.84	0.810	0.680
North Door (G.E5.E3.D1)	1.0	41.25	5.50	7.50	0.00	1	0.983	0.95	0.881	0.775
West Win (G.E5.E4.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W21)	1.0	25.06	3.40	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (G.E5.E4.W22)	1.0	25.06	3.40	7.38	0.00	1	0.983	0.84	0.810	0.680
West Door (G.E5.E4.D1)	1.0	41.25	5.50	7.50	0.00	1	0.983	0.95	0.881	0.775

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
South Win (G.E5.E1.W1)	South Wall (G.E5.E1)	-152.07	-148.40	1.23	1.13	1.23
South Win (G.E5.E1.W2)	South Wall (G.E5.E1)	-146.37	-148.40	1.23	6.83	1.23
South Win (G.E5.E1.W3)	South Wall (G.E5.E1)	-140.66	-148.40	1.23	12.54	1.23
South Win (G.E5.E1.W4)	South Wall (G.E5.E1)	-134.96	-148.40	1.23	18.24	1.23
South Win (G.E5.E1.W5)	South Wall (G.E5.E1)	-129.25	-148.40	1.23	23.95	1.23

REPORT- LV-C Details of Space

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
South Win (G.E5.E1.W6)	South Wall (G.E5.E1)	-123.55	-148.40	1.23	29.65	1.23
South Win (G.E5.E1.W7)	South Wall (G.E5.E1)	-117.85	-148.40	1.23	35.35	1.23
South Win (G.E5.E1.W8)	South Wall (G.E5.E1)	-112.14	-148.40	1.23	41.06	1.23
South Win (G.E5.E1.W9)	South Wall (G.E5.E1)	-106.44	-148.40	1.23	46.76	1.23
South Win (G.E5.E1.W10)	South Wall (G.E5.E1)	-100.73	-148.40	1.23	52.47	1.23
South Win (G.E5.E1.W11)	South Wall (G.E5.E1)	-77.92	-148.40	1.23	75.28	1.23
South Win (G.E5.E1.W12)	South Wall (G.E5.E1)	-72.21	-148.40	1.23	80.99	1.23
South Win (G.E5.E1.W13)	South Wall (G.E5.E1)	-66.51	-148.40	1.23	86.69	1.23
South Win (G.E5.E1.W14)	South Wall (G.E5.E1)	-60.80	-148.40	1.23	92.40	1.23
South Win (G.E5.E1.W15)	South Wall (G.E5.E1)	-55.10	-148.40	1.23	98.10	1.23
South Win (G.E5.E1.W16)	South Wall (G.E5.E1)	-49.39	-148.40	1.23	103.81	1.23
South Win (G.E5.E1.W17)	South Wall (G.E5.E1)	-43.69	-148.40	1.23	109.51	1.23
South Win (G.E5.E1.W18)	South Wall (G.E5.E1)	-37.99	-148.40	1.23	115.21	1.23
South Win (G.E5.E1.W19)	South Wall (G.E5.E1)	-32.28	-148.40	1.23	120.92	1.23
South Win (G.E5.E1.W20)	South Wall (G.E5.E1)	-26.58	-148.40	1.23	126.62	1.23
South Win (G.E5.E1.W21)	South Wall (G.E5.E1)	-95.03	-148.40	1.23	58.17	1.23
South Win (G.E5.E1.W22)	South Wall (G.E5.E1)	-83.57	-148.40	1.23	69.63	1.23
South Door (G.E5.E1.D1)	South Wall (G.E5.E1)	-90.35	-148.40	0.25	62.85	0.25
East Win (G.E5.E2.W1)	East Wall (G.E5.E2)	-22.00	-147.27	1.23	1.13	1.23
East Win (G.E5.E2.W2)	East Wall (G.E5.E2)	-22.00	-141.56	1.23	6.84	1.23
East Win (G.E5.E2.W3)	East Wall (G.E5.E2)	-22.00	-135.86	1.23	12.54	1.23
East Win (G.E5.E2.W4)	East Wall (G.E5.E2)	-22.00	-130.15	1.23	18.25	1.23
East Win (G.E5.E2.W5)	East Wall (G.E5.E2)	-22.00	-124.44	1.23	23.96	1.23
East Win (G.E5.E2.W6)	East Wall (G.E5.E2)	-22.00	-118.74	1.23	29.66	1.23
East Win (G.E5.E2.W7)	East Wall (G.E5.E2)	-22.00	-113.03	1.23	35.37	1.23
East Win (G.E5.E2.W8)	East Wall (G.E5.E2)	-22.00	-107.33	1.23	41.07	1.23
East Win (G.E5.E2.W9)	East Wall (G.E5.E2)	-22.00	-101.62	1.23	46.78	1.23
East Win (G.E5.E2.W10)	East Wall (G.E5.E2)	-22.00	-95.91	1.23	52.49	1.23
East Win (G.E5.E2.W11)	East Wall (G.E5.E2)	-22.00	-73.09	1.23	75.31	1.23
East Win (G.E5.E2.W12)	East Wall (G.E5.E2)	-22.00	-67.38	1.23	81.02	1.23
East Win (G.E5.E2.W13)	East Wall (G.E5.E2)	-22.00	-61.67	1.23	86.73	1.23
East Win (G.E5.E2.W14)	East Wall (G.E5.E2)	-22.00	-55.97	1.23	92.43	1.23
East Win (G.E5.E2.W15)	East Wall (G.E5.E2)	-22.00	-50.26	1.23	98.14	1.23
East Win (G.E5.E2.W16)	East Wall (G.E5.E2)	-22.00	-44.55	1.23	103.85	1.23
East Win (G.E5.E2.W17)	East Wall (G.E5.E2)	-22.00	-38.85	1.23	109.55	1.23
East Win (G.E5.E2.W18)	East Wall (G.E5.E2)	-22.00	-33.14	1.23	115.26	1.23
East Win (G.E5.E2.W19)	East Wall (G.E5.E2)	-22.00	-27.43	1.23	120.97	1.23
East Win (G.E5.E2.W20)	East Wall (G.E5.E2)	-22.00	-21.73	1.23	126.67	1.23
East Win (G.E5.E2.W21)	East Wall (G.E5.E2)	-22.00	-90.21	1.23	58.19	1.23
East Win (G.E5.E2.W22)	East Wall (G.E5.E2)	-22.00	-78.74	1.23	69.66	1.23
East Door (G.E5.E2.D1)	East Wall (G.E5.E2)	-22.00	-85.53	0.25	62.88	0.25
North Win (G.E5.E3.W1)	North Wall (G.E5.E3)	-23.13	-17.15	1.23	1.13	1.23
North Win (G.E5.E3.W2)	North Wall (G.E5.E3)	-28.83	-17.15	1.23	6.83	1.23
North Win (G.E5.E3.W3)	North Wall (G.E5.E3)	-34.54	-17.15	1.23	12.54	1.23
North Win (G.E5.E3.W4)	North Wall (G.E5.E3)	-40.24	-17.15	1.23	18.24	1.23
North Win (G.E5.E3.W5)	North Wall (G.E5.E3)	-45.95	-17.15	1.23	23.95	1.23
North Win (G.E5.E3.W6)	North Wall (G.E5.E3)	-51.65	-17.15	1.23	29.65	1.23
North Win (G.E5.E3.W7)	North Wall (G.E5.E3)	-57.35	-17.15	1.23	35.35	1.23
North Win (G.E5.E3.W8)	North Wall (G.E5.E3)	-63.06	-17.15	1.23	41.06	1.23
North Win (G.E5.E3.W9)	North Wall (G.E5.E3)	-68.76	-17.15	1.23	46.76	1.23
North Win (G.E5.E3.W10)	North Wall (G.E5.E3)	-74.47	-17.15	1.23	52.47	1.23
North Win (G.E5.E3.W11)	North Wall (G.E5.E3)	-97.28	-17.15	1.23	75.28	1.23
North Win (G.E5.E3.W12)	North Wall (G.E5.E3)	-102.99	-17.15	1.23	80.99	1.23

REPORT- LV-C Details of Space

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
North Win (G.E5.E3.W13)	North Wall (G.E5.E3)	-108.69	-17.15	1.23	86.69	1.23
North Win (G.E5.E3.W14)	North Wall (G.E5.E3)	-114.40	-17.15	1.23	92.40	1.23
North Win (G.E5.E3.W15)	North Wall (G.E5.E3)	-120.10	-17.15	1.23	98.10	1.23
North Win (G.E5.E3.W16)	North Wall (G.E5.E3)	-125.81	-17.15	1.23	103.81	1.23
North Win (G.E5.E3.W17)	North Wall (G.E5.E3)	-131.51	-17.15	1.23	109.51	1.23
North Win (G.E5.E3.W18)	North Wall (G.E5.E3)	-137.21	-17.15	1.23	115.21	1.23
North Win (G.E5.E3.W19)	North Wall (G.E5.E3)	-142.92	-17.15	1.23	120.92	1.23
North Win (G.E5.E3.W20)	North Wall (G.E5.E3)	-148.62	-17.15	1.23	126.62	1.23
North Win (G.E5.E3.W21)	North Wall (G.E5.E3)	-80.17	-17.15	1.23	58.17	1.23
North Win (G.E5.E3.W22)	North Wall (G.E5.E3)	-91.63	-17.15	1.23	69.63	1.23
North Door (G.E5.E3.D1)	North Wall (G.E5.E3)	-84.85	-17.15	0.25	62.85	0.25
West Win (G.E5.E4.W1)	West Wall (G.E5.E4)	-153.20	-18.28	1.23	1.13	1.23
West Win (G.E5.E4.W2)	West Wall (G.E5.E4)	-153.20	-23.99	1.23	6.84	1.23
West Win (G.E5.E4.W3)	West Wall (G.E5.E4)	-153.20	-29.69	1.23	12.54	1.23
West Win (G.E5.E4.W4)	West Wall (G.E5.E4)	-153.20	-35.40	1.23	18.25	1.23
West Win (G.E5.E4.W5)	West Wall (G.E5.E4)	-153.20	-41.11	1.23	23.96	1.23
West Win (G.E5.E4.W6)	West Wall (G.E5.E4)	-153.20	-46.81	1.23	29.66	1.23
West Win (G.E5.E4.W7)	West Wall (G.E5.E4)	-153.20	-52.52	1.23	35.37	1.23
West Win (G.E5.E4.W8)	West Wall (G.E5.E4)	-153.20	-58.22	1.23	41.07	1.23
West Win (G.E5.E4.W9)	West Wall (G.E5.E4)	-153.20	-63.93	1.23	46.78	1.23
West Win (G.E5.E4.W10)	West Wall (G.E5.E4)	-153.20	-69.64	1.23	52.49	1.23
West Win (G.E5.E4.W11)	West Wall (G.E5.E4)	-153.20	-92.46	1.23	75.31	1.23
West Win (G.E5.E4.W12)	West Wall (G.E5.E4)	-153.20	-98.17	1.23	81.02	1.23
West Win (G.E5.E4.W13)	West Wall (G.E5.E4)	-153.20	-103.88	1.23	86.73	1.23
West Win (G.E5.E4.W14)	West Wall (G.E5.E4)	-153.20	-109.58	1.23	92.43	1.23
West Win (G.E5.E4.W15)	West Wall (G.E5.E4)	-153.20	-115.29	1.23	98.14	1.23
West Win (G.E5.E4.W16)	West Wall (G.E5.E4)	-153.20	-121.00	1.23	103.85	1.23
West Win (G.E5.E4.W17)	West Wall (G.E5.E4)	-153.20	-126.70	1.23	109.55	1.23
West Win (G.E5.E4.W18)	West Wall (G.E5.E4)	-153.20	-132.41	1.23	115.26	1.23
West Win (G.E5.E4.W19)	West Wall (G.E5.E4)	-153.20	-138.12	1.23	120.97	1.23
West Win (G.E5.E4.W20)	West Wall (G.E5.E4)	-153.20	-143.82	1.23	126.67	1.23
West Win (G.E5.E4.W21)	West Wall (G.E5.E4)	-153.20	-75.34	1.23	58.19	1.23
West Win (G.E5.E4.W22)	West Wall (G.E5.E4)	-153.20	-86.81	1.23	69.66	1.23
West Door (G.E5.E4.D1)	West Wall (G.E5.E4)	-153.20	-80.02	0.25	62.88	0.25

REPORT- LV-C Details of Space

Core Spc (G.C6)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (G.C6)

IN FLOOR

Ground Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	0.00	0.00	1.0	8.90	1600.00	14240.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.01

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	4.8	333.3	250.0	250.0

REPORT- LV-C Details of Space

Core Spc (G.C6)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	1.50	2.40	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.20	0.32	1.00	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	0.50	0.80	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Flr (G.C6.I15)	1600.00	IFlr Construction	0.286
North Wall (G.C6.I16)	284.80	IWall Construction	0.315
West Wall (G.C6.I17)	445.00	IWall Construction	0.315
South Wall (G.C6.I18)	284.80	IWall Construction	0.315
East Wall (G.C6.I19)	445.00	IWall Construction	0.315
Ceiling (G.C6.I20)	1600.00	Ceilg Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Flr (G.C6.I15)	DELAYED STANDARD	Core Plnm (B.C4)
North Wall (G.C6.I16)	DELAYED ADIABATIC	
West Wall (G.C6.I17)	DELAYED ADIABATIC	
South Wall (G.C6.I18)	DELAYED ADIABATIC	
East Wall (G.C6.I19)	DELAYED ADIABATIC	
Ceiling (G.C6.I20)	DELAYED STANDARD	Core Plnm (G.C8)

REPORT- LV-C Details of Space

East Perim Plnm (G.E7)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Plnm (G.E7) IN FLOOR Ground Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	8.90	180.00	1.0	3.60	17220.00	61992.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.004	0.07

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (G.E5.I14)	17220.00	Ceigl Construction	0.381
Flr (M.E9.I25)	17220.00	IFlr Construction	0.286
SURFACE	SURFACE-TYPE	ADJACENT SPACE	
Ceiling (G.E5.I14)	DELAYED STANDARD	East Perim Spc (G.E5)	
Flr (M.E9.I25)	DELAYED STANDARD	East Perim Spc (M.E9)	

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
South Wall (G.E7.E5)	1.0	472.32	EWall Construction	0.439	DELAYED
East Wall (G.E7.E6)	1.0	472.50	EWall Construction	0.439	DELAYED
North Wall (G.E7.E7)	1.0	472.32	EWall Construction	0.439	DELAYED
West Wall (G.E7.E8)	1.0	472.50	EWall Construction	0.439	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
South Wall (G.E7.E5)	-180.0	90.0	-153.20	-148.40	8.90	0.00	0.00	0.00
East Wall (G.E7.E6)	-270.0	90.0	-22.00	-148.40	8.90	131.20	0.00	0.00
North Wall (G.E7.E7)	0.0	90.0	-22.00	-17.15	8.90	131.20	131.25	0.00
West Wall (G.E7.E8)	-90.0	90.0	-153.20	-17.15	8.90	0.00	131.25	0.00

REPORT- LV-C Details of Space

Core Plnm (G.C8)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Plnm (G.C8) IN FLOOR Ground Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	8.90	0.00	1.0	3.60	1600.00	5760.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.02

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (G.C6.I20)	1600.00	Ceilg Construction	0.381
North Wall (G.C8.I21)	115.20	IWall Construction	0.315
West Wall (G.C8.I22)	180.00	IWall Construction	0.315
South Wall (G.C8.I23)	115.20	IWall Construction	0.315
East Wall (G.C8.I24)	180.00	IWall Construction	0.315
Flr (M.C10.I27)	1600.00	IFlr Construction	0.286

REPORT- LV-C Details of Space

Core Plnm (G.C8)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Ceiling (G.C6.I20)	DELAYED STANDARD	Core Spc (G.C6)
North Wall (G.C8.I21)	DELAYED ADIABATIC	
West Wall (G.C8.I22)	DELAYED ADIABATIC	
South Wall (G.C8.I23)	DELAYED ADIABATIC	
East Wall (G.C8.I24)	DELAYED ADIABATIC	
Flr (M.C10.I27)	DELAYED STANDARD	Core Spc (M.C10)

REPORT- LV-C Details of Space

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Spc (M.E9) IN FLOOR Above-Grade Flrs

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	0.00	180.00	3.0	8.90	17220.00	153258.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
92	92	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.010	0.07

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	188.4	91.4	249.2	193.6

REPORT- LV-C Details of Space

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	1.01	17.33	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.43	7.44	0.90	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	2.12	36.54	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Flr (M.E9.I25)	17220.00	IFlr Construction	0.286
Ceiling (M.E9.I26)	17220.00	Ceilg Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Flr (M.E9.I25)	DELAYED STANDARD	East Perim Plnm (G.E7)
Ceiling (M.E9.I26)	DELAYED STANDARD	East Perim Plnm (M.E11)

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
South Wall (M.E9.E9)	1.0	1167.68	EWall Construction	0.439	DELAYED
East Wall (M.E9.E10)	1.0	1168.13	EWall Construction	0.439	DELAYED
North Wall (M.E9.E11)	1.0	1167.68	EWall Construction	0.439	DELAYED
West Wall (M.E9.E12)	1.0	1168.13	EWall Construction	0.439	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
South Wall (M.E9.E9)	-180.0	90.0	-153.20	-148.40	12.50	0.00	0.00	0.00
East Wall (M.E9.E10)	-270.0	90.0	-22.00	-148.40	12.50	131.20	0.00	0.00
North Wall (M.E9.E11)	0.0	90.0	-22.00	-17.15	12.50	131.20	131.25	0.00
West Wall (M.E9.E12)	-90.0	90.0	-153.20	-17.15	12.50	0.00	131.25	0.00

REPORT- LV-C Details of Space

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (SQFT)	GLASS WIDTH (FT)	GLASS HEIGHT (FT)	SET- BACK (FT)	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS SHADING COEFF	GLASS VISIBLE TRANS	GLASS SOLAR TRANS
South Win (M.E9.E9.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (M.E9.E9.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (M.E9.E10.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680

REPORT- LV-C Details of Space

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (SQFT)	GLASS WIDTH (FT)	GLASS HEIGHT (FT)	SET- BACK (FT)	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS SHADING COEFF	GLASS VISIBLE TRANS	GLASS SOLAR TRANS
North Win (M.E9.E11.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (M.E9.E11.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (M.E9.E12.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
South Win (M.E9.E9.W1)	South Wall (M.E9.E9)	-152.07	-148.40	13.73	1.13	1.23
South Win (M.E9.E9.W2)	South Wall (M.E9.E9)	-146.37	-148.40	13.73	6.83	1.23
South Win (M.E9.E9.W3)	South Wall (M.E9.E9)	-140.66	-148.40	13.73	12.54	1.23
South Win (M.E9.E9.W4)	South Wall (M.E9.E9)	-134.96	-148.40	13.73	18.24	1.23
South Win (M.E9.E9.W5)	South Wall (M.E9.E9)	-129.25	-148.40	13.73	23.95	1.23

REPORT- LV-C Details of Space

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
South Win (M.E9.E9.W6)	South Wall (M.E9.E9)	-123.55	-148.40	13.73	29.65	1.23
South Win (M.E9.E9.W7)	South Wall (M.E9.E9)	-117.85	-148.40	13.73	35.35	1.23
South Win (M.E9.E9.W8)	South Wall (M.E9.E9)	-112.14	-148.40	13.73	41.06	1.23
South Win (M.E9.E9.W9)	South Wall (M.E9.E9)	-106.44	-148.40	13.73	46.76	1.23
South Win (M.E9.E9.W10)	South Wall (M.E9.E9)	-100.73	-148.40	13.73	52.47	1.23
South Win (M.E9.E9.W11)	South Wall (M.E9.E9)	-95.03	-148.40	13.73	58.17	1.23
South Win (M.E9.E9.W12)	South Wall (M.E9.E9)	-89.32	-148.40	13.73	63.88	1.23
South Win (M.E9.E9.W13)	South Wall (M.E9.E9)	-83.62	-148.40	13.73	69.58	1.23
South Win (M.E9.E9.W14)	South Wall (M.E9.E9)	-77.92	-148.40	13.73	75.28	1.23
South Win (M.E9.E9.W15)	South Wall (M.E9.E9)	-72.21	-148.40	13.73	80.99	1.23
South Win (M.E9.E9.W16)	South Wall (M.E9.E9)	-66.51	-148.40	13.73	86.69	1.23
South Win (M.E9.E9.W17)	South Wall (M.E9.E9)	-60.80	-148.40	13.73	92.40	1.23
South Win (M.E9.E9.W18)	South Wall (M.E9.E9)	-55.10	-148.40	13.73	98.10	1.23
South Win (M.E9.E9.W19)	South Wall (M.E9.E9)	-49.39	-148.40	13.73	103.81	1.23
South Win (M.E9.E9.W20)	South Wall (M.E9.E9)	-43.69	-148.40	13.73	109.51	1.23
South Win (M.E9.E9.W21)	South Wall (M.E9.E9)	-37.99	-148.40	13.73	115.21	1.23
South Win (M.E9.E9.W22)	South Wall (M.E9.E9)	-32.28	-148.40	13.73	120.92	1.23
South Win (M.E9.E9.W23)	South Wall (M.E9.E9)	-26.58	-148.40	13.73	126.62	1.23
East Win (M.E9.E10.W1)	East Wall (M.E9.E10)	-22.00	-147.27	13.73	1.13	1.23
East Win (M.E9.E10.W2)	East Wall (M.E9.E10)	-22.00	-141.56	13.73	6.84	1.23
East Win (M.E9.E10.W3)	East Wall (M.E9.E10)	-22.00	-135.86	13.73	12.54	1.23
East Win (M.E9.E10.W4)	East Wall (M.E9.E10)	-22.00	-130.15	13.73	18.25	1.23
East Win (M.E9.E10.W5)	East Wall (M.E9.E10)	-22.00	-124.44	13.73	23.96	1.23
East Win (M.E9.E10.W6)	East Wall (M.E9.E10)	-22.00	-118.74	13.73	29.66	1.23
East Win (M.E9.E10.W7)	East Wall (M.E9.E10)	-22.00	-113.03	13.73	35.37	1.23
East Win (M.E9.E10.W8)	East Wall (M.E9.E10)	-22.00	-107.33	13.73	41.07	1.23
East Win (M.E9.E10.W9)	East Wall (M.E9.E10)	-22.00	-101.62	13.73	46.78	1.23
East Win (M.E9.E10.W10)	East Wall (M.E9.E10)	-22.00	-95.91	13.73	52.49	1.23
East Win (M.E9.E10.W11)	East Wall (M.E9.E10)	-22.00	-90.21	13.73	58.19	1.23
East Win (M.E9.E10.W12)	East Wall (M.E9.E10)	-22.00	-84.50	13.73	63.90	1.23
East Win (M.E9.E10.W13)	East Wall (M.E9.E10)	-22.00	-78.79	13.73	69.61	1.23
East Win (M.E9.E10.W14)	East Wall (M.E9.E10)	-22.00	-73.09	13.73	75.31	1.23
East Win (M.E9.E10.W15)	East Wall (M.E9.E10)	-22.00	-67.38	13.73	81.02	1.23
East Win (M.E9.E10.W16)	East Wall (M.E9.E10)	-22.00	-61.67	13.73	86.73	1.23
East Win (M.E9.E10.W17)	East Wall (M.E9.E10)	-22.00	-55.97	13.73	92.43	1.23
East Win (M.E9.E10.W18)	East Wall (M.E9.E10)	-22.00	-50.26	13.73	98.14	1.23
East Win (M.E9.E10.W19)	East Wall (M.E9.E10)	-22.00	-44.55	13.73	103.85	1.23
East Win (M.E9.E10.W20)	East Wall (M.E9.E10)	-22.00	-38.85	13.73	109.55	1.23
East Win (M.E9.E10.W21)	East Wall (M.E9.E10)	-22.00	-33.14	13.73	115.26	1.23
East Win (M.E9.E10.W22)	East Wall (M.E9.E10)	-22.00	-27.43	13.73	120.97	1.23
East Win (M.E9.E10.W23)	East Wall (M.E9.E10)	-22.00	-21.73	13.73	126.67	1.23
North Win (M.E9.E11.W1)	North Wall (M.E9.E11)	-23.13	-17.15	13.73	1.13	1.23
North Win (M.E9.E11.W2)	North Wall (M.E9.E11)	-28.83	-17.15	13.73	6.83	1.23
North Win (M.E9.E11.W3)	North Wall (M.E9.E11)	-34.54	-17.15	13.73	12.54	1.23
North Win (M.E9.E11.W4)	North Wall (M.E9.E11)	-40.24	-17.15	13.73	18.24	1.23
North Win (M.E9.E11.W5)	North Wall (M.E9.E11)	-45.95	-17.15	13.73	23.95	1.23
North Win (M.E9.E11.W6)	North Wall (M.E9.E11)	-51.65	-17.15	13.73	29.65	1.23
North Win (M.E9.E11.W7)	North Wall (M.E9.E11)	-57.35	-17.15	13.73	35.35	1.23
North Win (M.E9.E11.W8)	North Wall (M.E9.E11)	-63.06	-17.15	13.73	41.06	1.23
North Win (M.E9.E11.W9)	North Wall (M.E9.E11)	-68.76	-17.15	13.73	46.76	1.23
North Win (M.E9.E11.W10)	North Wall (M.E9.E11)	-74.47	-17.15	13.73	52.47	1.23
North Win (M.E9.E11.W11)	North Wall (M.E9.E11)	-80.17	-17.15	13.73	58.17	1.23
North Win (M.E9.E11.W12)	North Wall (M.E9.E11)	-85.88	-17.15	13.73	63.88	1.23

REPORT- LV-C Details of Space

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
North Win (M.E9.E11.W13)	North Wall (M.E9.E11)	-91.58	-17.15	13.73	69.58	1.23
North Win (M.E9.E11.W14)	North Wall (M.E9.E11)	-97.28	-17.15	13.73	75.28	1.23
North Win (M.E9.E11.W15)	North Wall (M.E9.E11)	-102.99	-17.15	13.73	80.99	1.23
North Win (M.E9.E11.W16)	North Wall (M.E9.E11)	-108.69	-17.15	13.73	86.69	1.23
North Win (M.E9.E11.W17)	North Wall (M.E9.E11)	-114.40	-17.15	13.73	92.40	1.23
North Win (M.E9.E11.W18)	North Wall (M.E9.E11)	-120.10	-17.15	13.73	98.10	1.23
North Win (M.E9.E11.W19)	North Wall (M.E9.E11)	-125.81	-17.15	13.73	103.81	1.23
North Win (M.E9.E11.W20)	North Wall (M.E9.E11)	-131.51	-17.15	13.73	109.51	1.23
North Win (M.E9.E11.W21)	North Wall (M.E9.E11)	-137.21	-17.15	13.73	115.21	1.23
North Win (M.E9.E11.W22)	North Wall (M.E9.E11)	-142.92	-17.15	13.73	120.92	1.23
North Win (M.E9.E11.W23)	North Wall (M.E9.E11)	-148.62	-17.15	13.73	126.62	1.23
West Win (M.E9.E12.W1)	West Wall (M.E9.E12)	-153.20	-18.28	13.73	1.13	1.23
West Win (M.E9.E12.W2)	West Wall (M.E9.E12)	-153.20	-23.99	13.73	6.84	1.23
West Win (M.E9.E12.W3)	West Wall (M.E9.E12)	-153.20	-29.69	13.73	12.54	1.23
West Win (M.E9.E12.W4)	West Wall (M.E9.E12)	-153.20	-35.40	13.73	18.25	1.23
West Win (M.E9.E12.W5)	West Wall (M.E9.E12)	-153.20	-41.11	13.73	23.96	1.23
West Win (M.E9.E12.W6)	West Wall (M.E9.E12)	-153.20	-46.81	13.73	29.66	1.23
West Win (M.E9.E12.W7)	West Wall (M.E9.E12)	-153.20	-52.52	13.73	35.37	1.23
West Win (M.E9.E12.W8)	West Wall (M.E9.E12)	-153.20	-58.22	13.73	41.07	1.23
West Win (M.E9.E12.W9)	West Wall (M.E9.E12)	-153.20	-63.93	13.73	46.78	1.23
West Win (M.E9.E12.W10)	West Wall (M.E9.E12)	-153.20	-69.64	13.73	52.49	1.23
West Win (M.E9.E12.W11)	West Wall (M.E9.E12)	-153.20	-75.34	13.73	58.19	1.23
West Win (M.E9.E12.W12)	West Wall (M.E9.E12)	-153.20	-81.05	13.73	63.90	1.23
West Win (M.E9.E12.W13)	West Wall (M.E9.E12)	-153.20	-86.76	13.73	69.61	1.23
West Win (M.E9.E12.W14)	West Wall (M.E9.E12)	-153.20	-92.46	13.73	75.31	1.23
West Win (M.E9.E12.W15)	West Wall (M.E9.E12)	-153.20	-98.17	13.73	81.02	1.23
West Win (M.E9.E12.W16)	West Wall (M.E9.E12)	-153.20	-103.88	13.73	86.73	1.23
West Win (M.E9.E12.W17)	West Wall (M.E9.E12)	-153.20	-109.58	13.73	92.43	1.23
West Win (M.E9.E12.W18)	West Wall (M.E9.E12)	-153.20	-115.29	13.73	98.14	1.23
West Win (M.E9.E12.W19)	West Wall (M.E9.E12)	-153.20	-121.00	13.73	103.85	1.23
West Win (M.E9.E12.W20)	West Wall (M.E9.E12)	-153.20	-126.70	13.73	109.55	1.23
West Win (M.E9.E12.W21)	West Wall (M.E9.E12)	-153.20	-132.41	13.73	115.26	1.23
West Win (M.E9.E12.W22)	West Wall (M.E9.E12)	-153.20	-138.12	13.73	120.97	1.23
West Win (M.E9.E12.W23)	West Wall (M.E9.E12)	-153.20	-143.82	13.73	126.67	1.23

REPORT- LV-C Details of Space

Core Spc (M.C10)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (M.C10) IN FLOOR Above-Grade Flrs

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	0.00	0.00	3.0	8.90	1600.00	14240.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.01

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	15.7	101.7	249.6	230.9

REPORT- LV-C Details of Space

Core Spc (M.C10)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	0.80	1.28	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.20	0.31	0.95	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	0.82	1.31	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Flr (M.C10.I27)	1600.00	IFlr Construction	0.286
North Wall (M.C10.I28)	284.80	IWall Construction	0.315
West Wall (M.C10.I29)	445.00	IWall Construction	0.315
South Wall (M.C10.I30)	284.80	IWall Construction	0.315
East Wall (M.C10.I31)	445.00	IWall Construction	0.315
Ceiling (M.C10.I32)	1600.00	Ceilg Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Flr (M.C10.I27)	DELAYED STANDARD	Core Plnm (G.C8)
North Wall (M.C10.I28)	DELAYED ADIABATIC	
West Wall (M.C10.I29)	DELAYED ADIABATIC	
South Wall (M.C10.I30)	DELAYED ADIABATIC	
East Wall (M.C10.I31)	DELAYED ADIABATIC	
Ceiling (M.C10.I32)	DELAYED STANDARD	Core Plnm (M.C12)

REPORT- LV-C Details of Space

East Perim Plnm (M.E11)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Plnm (M.E11) IN FLOOR Above-Grade Flrs

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	8.90	180.00	3.0	3.60	17220.00	61992.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.004	0.07

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (M.E9.I26)	17220.00	Ceigl Construction	0.381
Flr (T.E13.I37)	17220.00	IFlr Construction	0.286
SURFACE	SURFACE-TYPE	ADJACENT SPACE	
Ceiling (M.E9.I26)	DELAYED STANDARD	East Perim Spc (M.E9)	
Flr (T.E13.I37)	DELAYED STANDARD	East Perim Spc (T.E13)	

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
South Wall (M.E11.E13)	1.0	472.32	EWall Construction	0.439	DELAYED
East Wall (M.E11.E14)	1.0	472.50	EWall Construction	0.439	DELAYED
North Wall (M.E11.E15)	1.0	472.32	EWall Construction	0.439	DELAYED
West Wall (M.E11.E16)	1.0	472.50	EWall Construction	0.439	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
South Wall (M.E11.E13)	-180.0	90.0	-153.20	-148.40	21.40	0.00	0.00	0.00
East Wall (M.E11.E14)	-270.0	90.0	-22.00	-148.40	21.40	131.20	0.00	0.00
North Wall (M.E11.E15)	0.0	90.0	-22.00	-17.15	21.40	131.20	131.25	0.00
West Wall (M.E11.E16)	-90.0	90.0	-153.20	-17.15	21.40	0.00	131.25	0.00

REPORT- LV-C Details of Space

Core Plnm (M.C12)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Plnm (M.C12) IN FLOOR Above-Grade Flrs

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	8.90	0.00	3.0	3.60	1600.00	5760.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.02

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (M.C10.I32)	1600.00	Ceilg Construction	0.381
North Wall (M.C12.I33)	115.20	IWall Construction	0.315
West Wall (M.C12.I34)	180.00	IWall Construction	0.315
South Wall (M.C12.I35)	115.20	IWall Construction	0.315
East Wall (M.C12.I36)	180.00	IWall Construction	0.315
Flr (T.C14.I39)	1600.00	IFlr Construction	0.286

REPORT- LV-C Details of Space

Core Plnm (M.C12)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Ceiling (M.C10.I32)	DELAYED STANDARD	Core Spc (M.C10)
North Wall (M.C12.I33)	DELAYED ADIABATIC	
West Wall (M.C12.I34)	DELAYED ADIABATIC	
South Wall (M.C12.I35)	DELAYED ADIABATIC	
East Wall (M.C12.I36)	DELAYED ADIABATIC	Core Spc (T.C14)
Flr (T.C14.I39)	DELAYED STANDARD	

REPORT- LV-C Details of Space

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Spc (T.E13) IN FLOOR Top Abv-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	0.00	180.00	1.0	8.90	17220.00	153258.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
92	92	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.010	0.07

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	188.4	91.4	249.2	193.6

REPORT- LV-C Details of Space

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	1.01	17.33	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.43	7.44	0.90	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	2.12	36.54	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Flr (T.E13.I37)	17220.00	IFlr Construction	0.286
Ceiling (T.E13.I38)	17220.00	Ceilig Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Flr (T.E13.I37)	DELAYED STANDARD	East Perim Plnm (M.E11)
Ceiling (T.E13.I38)	DELAYED STANDARD	East Perim Plnm (T.E15)

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
South Wall (T.E13.E17)	1.0	1167.68	EWall Construction	0.439	DELAYED
East Wall (T.E13.E18)	1.0	1168.13	EWall Construction	0.439	DELAYED
North Wall (T.E13.E19)	1.0	1167.68	EWall Construction	0.439	DELAYED
West Wall (T.E13.E20)	1.0	1168.13	EWall Construction	0.439	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
South Wall (T.E13.E17)	-180.0	90.0	-153.20	-148.40	50.00	0.00	0.00	0.00
East Wall (T.E13.E18)	-270.0	90.0	-22.00	-148.40	50.00	131.20	0.00	0.00
North Wall (T.E13.E19)	0.0	90.0	-22.00	-17.15	50.00	131.20	131.25	0.00
West Wall (T.E13.E20)	-90.0	90.0	-153.20	-17.15	50.00	0.00	131.25	0.00

REPORT- LV-C Details of Space

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (SQFT)	GLASS WIDTH (FT)	GLASS HEIGHT (FT)	SET- BACK (FT)	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS SHADING COEFF	GLASS VISIBLE TRANS	GLASS SOLAR TRANS
South Win (T.E13.E17.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
South Win (T.E13.E17.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
East Win (T.E13.E18.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680

REPORT- LV-C Details of Space

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (SQFT)	GLASS WIDTH (FT)	GLASS HEIGHT (FT)	SET- BACK (FT)	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS SHADING COEFF	GLASS VISIBLE TRANS	GLASS SOLAR TRANS
North Win (T.E13.E19.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
North Win (T.E13.E19.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W1)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W2)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W3)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W4)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W5)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W6)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W7)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W8)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W9)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W10)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W11)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W12)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W13)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W14)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W15)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W16)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W17)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W18)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W19)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W20)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W21)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W22)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680
West Win (T.E13.E20.W23)	1.0	25.44	3.45	7.38	0.00	1	0.983	0.84	0.810	0.680

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
South Win (T.E13.E17.W1)	South Wall (T.E13.E17)	-152.07	-148.40	51.23	1.13	1.23
South Win (T.E13.E17.W2)	South Wall (T.E13.E17)	-146.37	-148.40	51.23	6.83	1.23
South Win (T.E13.E17.W3)	South Wall (T.E13.E17)	-140.66	-148.40	51.23	12.54	1.23
South Win (T.E13.E17.W4)	South Wall (T.E13.E17)	-134.96	-148.40	51.23	18.24	1.23
South Win (T.E13.E17.W5)	South Wall (T.E13.E17)	-129.25	-148.40	51.23	23.95	1.23

REPORT- LV-C Details of Space

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
South Win (T.E13.E17.W6)	South Wall (T.E13.E17)	-123.55	-148.40	51.23	29.65	1.23
South Win (T.E13.E17.W7)	South Wall (T.E13.E17)	-117.85	-148.40	51.23	35.35	1.23
South Win (T.E13.E17.W8)	South Wall (T.E13.E17)	-112.14	-148.40	51.23	41.06	1.23
South Win (T.E13.E17.W9)	South Wall (T.E13.E17)	-106.44	-148.40	51.23	46.76	1.23
South Win (T.E13.E17.W10)	South Wall (T.E13.E17)	-100.73	-148.40	51.23	52.47	1.23
South Win (T.E13.E17.W11)	South Wall (T.E13.E17)	-95.03	-148.40	51.23	58.17	1.23
South Win (T.E13.E17.W12)	South Wall (T.E13.E17)	-89.32	-148.40	51.23	63.88	1.23
South Win (T.E13.E17.W13)	South Wall (T.E13.E17)	-83.62	-148.40	51.23	69.58	1.23
South Win (T.E13.E17.W14)	South Wall (T.E13.E17)	-77.92	-148.40	51.23	75.28	1.23
South Win (T.E13.E17.W15)	South Wall (T.E13.E17)	-72.21	-148.40	51.23	80.99	1.23
South Win (T.E13.E17.W16)	South Wall (T.E13.E17)	-66.51	-148.40	51.23	86.69	1.23
South Win (T.E13.E17.W17)	South Wall (T.E13.E17)	-60.80	-148.40	51.23	92.40	1.23
South Win (T.E13.E17.W18)	South Wall (T.E13.E17)	-55.10	-148.40	51.23	98.10	1.23
South Win (T.E13.E17.W19)	South Wall (T.E13.E17)	-49.39	-148.40	51.23	103.81	1.23
South Win (T.E13.E17.W20)	South Wall (T.E13.E17)	-43.69	-148.40	51.23	109.51	1.23
South Win (T.E13.E17.W21)	South Wall (T.E13.E17)	-37.99	-148.40	51.23	115.21	1.23
South Win (T.E13.E17.W22)	South Wall (T.E13.E17)	-32.28	-148.40	51.23	120.92	1.23
South Win (T.E13.E17.W23)	South Wall (T.E13.E17)	-26.58	-148.40	51.23	126.62	1.23
East Win (T.E13.E18.W1)	East Wall (T.E13.E18)	-22.00	-147.27	51.23	1.13	1.23
East Win (T.E13.E18.W2)	East Wall (T.E13.E18)	-22.00	-141.56	51.23	6.84	1.23
East Win (T.E13.E18.W3)	East Wall (T.E13.E18)	-22.00	-135.86	51.23	12.54	1.23
East Win (T.E13.E18.W4)	East Wall (T.E13.E18)	-22.00	-130.15	51.23	18.25	1.23
East Win (T.E13.E18.W5)	East Wall (T.E13.E18)	-22.00	-124.44	51.23	23.96	1.23
East Win (T.E13.E18.W6)	East Wall (T.E13.E18)	-22.00	-118.74	51.23	29.66	1.23
East Win (T.E13.E18.W7)	East Wall (T.E13.E18)	-22.00	-113.03	51.23	35.37	1.23
East Win (T.E13.E18.W8)	East Wall (T.E13.E18)	-22.00	-107.33	51.23	41.07	1.23
East Win (T.E13.E18.W9)	East Wall (T.E13.E18)	-22.00	-101.62	51.23	46.78	1.23
East Win (T.E13.E18.W10)	East Wall (T.E13.E18)	-22.00	-95.91	51.23	52.49	1.23
East Win (T.E13.E18.W11)	East Wall (T.E13.E18)	-22.00	-90.21	51.23	58.19	1.23
East Win (T.E13.E18.W12)	East Wall (T.E13.E18)	-22.00	-84.50	51.23	63.90	1.23
East Win (T.E13.E18.W13)	East Wall (T.E13.E18)	-22.00	-78.79	51.23	69.61	1.23
East Win (T.E13.E18.W14)	East Wall (T.E13.E18)	-22.00	-73.09	51.23	75.31	1.23
East Win (T.E13.E18.W15)	East Wall (T.E13.E18)	-22.00	-67.38	51.23	81.02	1.23
East Win (T.E13.E18.W16)	East Wall (T.E13.E18)	-22.00	-61.67	51.23	86.73	1.23
East Win (T.E13.E18.W17)	East Wall (T.E13.E18)	-22.00	-55.97	51.23	92.43	1.23
East Win (T.E13.E18.W18)	East Wall (T.E13.E18)	-22.00	-50.26	51.23	98.14	1.23
East Win (T.E13.E18.W19)	East Wall (T.E13.E18)	-22.00	-44.55	51.23	103.85	1.23
East Win (T.E13.E18.W20)	East Wall (T.E13.E18)	-22.00	-38.85	51.23	109.55	1.23
East Win (T.E13.E18.W21)	East Wall (T.E13.E18)	-22.00	-33.14	51.23	115.26	1.23
East Win (T.E13.E18.W22)	East Wall (T.E13.E18)	-22.00	-27.43	51.23	120.97	1.23
East Win (T.E13.E18.W23)	East Wall (T.E13.E18)	-22.00	-21.73	51.23	126.67	1.23
North Win (T.E13.E19.W1)	North Wall (T.E13.E19)	-23.13	-17.15	51.23	1.13	1.23
North Win (T.E13.E19.W2)	North Wall (T.E13.E19)	-28.83	-17.15	51.23	6.83	1.23
North Win (T.E13.E19.W3)	North Wall (T.E13.E19)	-34.54	-17.15	51.23	12.54	1.23
North Win (T.E13.E19.W4)	North Wall (T.E13.E19)	-40.24	-17.15	51.23	18.24	1.23
North Win (T.E13.E19.W5)	North Wall (T.E13.E19)	-45.95	-17.15	51.23	23.95	1.23
North Win (T.E13.E19.W6)	North Wall (T.E13.E19)	-51.65	-17.15	51.23	29.65	1.23
North Win (T.E13.E19.W7)	North Wall (T.E13.E19)	-57.35	-17.15	51.23	35.35	1.23
North Win (T.E13.E19.W8)	North Wall (T.E13.E19)	-63.06	-17.15	51.23	41.06	1.23
North Win (T.E13.E19.W9)	North Wall (T.E13.E19)	-68.76	-17.15	51.23	46.76	1.23
North Win (T.E13.E19.W10)	North Wall (T.E13.E19)	-74.47	-17.15	51.23	52.47	1.23
North Win (T.E13.E19.W11)	North Wall (T.E13.E19)	-80.17	-17.15	51.23	58.17	1.23
North Win (T.E13.E19.W12)	North Wall (T.E13.E19)	-85.88	-17.15	51.23	63.88	1.23

REPORT- LV-C Details of Space

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)
North Win (T.E13.E19.W13)	North Wall (T.E13.E19)	-91.58	-17.15	51.23	69.58	1.23
North Win (T.E13.E19.W14)	North Wall (T.E13.E19)	-97.28	-17.15	51.23	75.28	1.23
North Win (T.E13.E19.W15)	North Wall (T.E13.E19)	-102.99	-17.15	51.23	80.99	1.23
North Win (T.E13.E19.W16)	North Wall (T.E13.E19)	-108.69	-17.15	51.23	86.69	1.23
North Win (T.E13.E19.W17)	North Wall (T.E13.E19)	-114.40	-17.15	51.23	92.40	1.23
North Win (T.E13.E19.W18)	North Wall (T.E13.E19)	-120.10	-17.15	51.23	98.10	1.23
North Win (T.E13.E19.W19)	North Wall (T.E13.E19)	-125.81	-17.15	51.23	103.81	1.23
North Win (T.E13.E19.W20)	North Wall (T.E13.E19)	-131.51	-17.15	51.23	109.51	1.23
North Win (T.E13.E19.W21)	North Wall (T.E13.E19)	-137.21	-17.15	51.23	115.21	1.23
North Win (T.E13.E19.W22)	North Wall (T.E13.E19)	-142.92	-17.15	51.23	120.92	1.23
North Win (T.E13.E19.W23)	North Wall (T.E13.E19)	-148.62	-17.15	51.23	126.62	1.23
West Win (T.E13.E20.W1)	West Wall (T.E13.E20)	-153.20	-18.28	51.23	1.13	1.23
West Win (T.E13.E20.W2)	West Wall (T.E13.E20)	-153.20	-23.99	51.23	6.84	1.23
West Win (T.E13.E20.W3)	West Wall (T.E13.E20)	-153.20	-29.69	51.23	12.54	1.23
West Win (T.E13.E20.W4)	West Wall (T.E13.E20)	-153.20	-35.40	51.23	18.25	1.23
West Win (T.E13.E20.W5)	West Wall (T.E13.E20)	-153.20	-41.11	51.23	23.96	1.23
West Win (T.E13.E20.W6)	West Wall (T.E13.E20)	-153.20	-46.81	51.23	29.66	1.23
West Win (T.E13.E20.W7)	West Wall (T.E13.E20)	-153.20	-52.52	51.23	35.37	1.23
West Win (T.E13.E20.W8)	West Wall (T.E13.E20)	-153.20	-58.22	51.23	41.07	1.23
West Win (T.E13.E20.W9)	West Wall (T.E13.E20)	-153.20	-63.93	51.23	46.78	1.23
West Win (T.E13.E20.W10)	West Wall (T.E13.E20)	-153.20	-69.64	51.23	52.49	1.23
West Win (T.E13.E20.W11)	West Wall (T.E13.E20)	-153.20	-75.34	51.23	58.19	1.23
West Win (T.E13.E20.W12)	West Wall (T.E13.E20)	-153.20	-81.05	51.23	63.90	1.23
West Win (T.E13.E20.W13)	West Wall (T.E13.E20)	-153.20	-86.76	51.23	69.61	1.23
West Win (T.E13.E20.W14)	West Wall (T.E13.E20)	-153.20	-92.46	51.23	75.31	1.23
West Win (T.E13.E20.W15)	West Wall (T.E13.E20)	-153.20	-98.17	51.23	81.02	1.23
West Win (T.E13.E20.W16)	West Wall (T.E13.E20)	-153.20	-103.88	51.23	86.73	1.23
West Win (T.E13.E20.W17)	West Wall (T.E13.E20)	-153.20	-109.58	51.23	92.43	1.23
West Win (T.E13.E20.W18)	West Wall (T.E13.E20)	-153.20	-115.29	51.23	98.14	1.23
West Win (T.E13.E20.W19)	West Wall (T.E13.E20)	-153.20	-121.00	51.23	103.85	1.23
West Win (T.E13.E20.W20)	West Wall (T.E13.E20)	-153.20	-126.70	51.23	109.55	1.23
West Win (T.E13.E20.W21)	West Wall (T.E13.E20)	-153.20	-132.41	51.23	115.26	1.23
West Win (T.E13.E20.W22)	West Wall (T.E13.E20)	-153.20	-138.12	51.23	120.97	1.23
West Win (T.E13.E20.W23)	West Wall (T.E13.E20)	-153.20	-143.82	51.23	126.67	1.23

REPORT- LV-C Details of Space

Core Spc (T.C14)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (T.C14) IN FLOOR Top Abv-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	0.00	0.00	1.0	8.90	1600.00	14240.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.01

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (SQFT)	PEOPLE SENSIBLE (BTU/HR)	PEOPLE LATENT (BTU/HR)
Bldg Occup Sch	15.7	101.7	249.6	230.9

REPORT- LV-C Details of Space

Core Spc (T.C14)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ SQFT)	LOAD (KW)	FRACTION OF LOAD TO SPACE
Bldg InsLt Sch	SUS-FLUOR	0.80	1.28	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ SQFT)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
Bldg Misc Sch	0.20	0.31	0.95	0.00
Bldg OffEq Sch	0.00	0.00	1.00	0.00
Bldg OffEq Sch	0.82	1.31	1.00	0.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Flr (T.C14.I39)	1600.00	IFlr Construction	0.286
North Wall (T.C14.I40)	284.80	IWall Construction	0.315
West Wall (T.C14.I41)	445.00	IWall Construction	0.315
South Wall (T.C14.I42)	284.80	IWall Construction	0.315
East Wall (T.C14.I43)	445.00	IWall Construction	0.315
Ceiling (T.C14.I44)	1600.00	Ceilg Construction	0.381

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Flr (T.C14.I39)	DELAYED STANDARD	Core Plnm (M.C12)
North Wall (T.C14.I40)	DELAYED ADIABATIC	
West Wall (T.C14.I41)	DELAYED ADIABATIC	
South Wall (T.C14.I42)	DELAYED ADIABATIC	
East Wall (T.C14.I43)	DELAYED ADIABATIC	
Ceiling (T.C14.I44)	DELAYED STANDARD	Core Plnm (T.C16)

REPORT- LV-C Details of Space

East Perim Plnm (T.E15)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Plnm (T.E15) IN FLOOR Top Abv-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
153.20	148.40	8.90	180.00	1.0	3.60	17220.00	61992.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) P-Inf Sch	AIR-CHANGE	0.004	0.07

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (T.E13.I38)	17220.00	Ceigl Construction	0.381
UnderRf (T.E15.I45)	17220.00	AFlr Construction	0.184
SURFACE	SURFACE-TYPE	ADJACENT SPACE	
Ceiling (T.E13.I38)	DELAYED STANDARD	East Perim Spc (T.E13)	
UnderRf (T.E15.I45)	DELAYED STANDARD	Under Roof (T.15)	

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
South Wall (T.E15.E21)	1.0	472.32	EWall Construction	0.439	DELAYED
East Wall (T.E15.E22)	1.0	472.50	EWall Construction	0.439	DELAYED
North Wall (T.E15.E23)	1.0	472.32	EWall Construction	0.439	DELAYED
West Wall (T.E15.E24)	1.0	472.50	EWall Construction	0.439	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
South Wall (T.E15.E21)	-180.0	90.0	-153.20	-148.40	58.90	0.00	0.00	0.00
East Wall (T.E15.E22)	-270.0	90.0	-22.00	-148.40	58.90	131.20	0.00	0.00
North Wall (T.E15.E23)	0.0	90.0	-22.00	-17.15	58.90	131.20	131.25	0.00
West Wall (T.E15.E24)	-90.0	90.0	-153.20	-17.15	58.90	0.00	131.25	0.00

REPORT- LV-C Details of Space

Core Plnm (T.C16)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Plnm (T.C16) IN FLOOR Top Abv-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
72.00	56.00	8.90	0.00	1.0	3.60	1600.00	5760.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	0	6	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
ZG0-S1 (VAVS) C-Inf Sch	AIR-CHANGE	0.001	0.02

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
Ceiling (T.C14.I44)	1600.00	Ceilg Construction	0.381
North Wall (T.C16.I46)	115.20	IWall Construction	0.315
West Wall (T.C16.I47)	180.00	IWall Construction	0.315
South Wall (T.C16.I48)	115.20	IWall Construction	0.315
East Wall (T.C16.I49)	180.00	IWall Construction	0.315
UnderRf (T.C16.I50)	1600.00	AFlr Construction	0.184

REPORT- LV-C Details of Space

Core Plnm (T.C16)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

SURFACE	SURFACE-TYPE	ADJACENT SPACE
Ceiling (T.C14.I44)	DELAYED STANDARD	Core Spc (T.C14)
North Wall (T.C16.I46)	DELAYED ADIABATIC	
West Wall (T.C16.I47)	DELAYED ADIABATIC	
South Wall (T.C16.I48)	DELAYED ADIABATIC	
East Wall (T.C16.I49)	DELAYED ADIABATIC	
UnderRf (T.C16.I50)	DELAYED STANDARD	Under Roof (T.15)

REPORT- LV-C Details of Space

Under Roof (T.15)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Under Roof (T.15) IN FLOOR Top Abv-Grade Flr

LOCATION OF ORIGIN IN
BUILDING COORDINATES

XB (FT)	YB (FT)	ZB (FT)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (FT)	AREA (SQFT)	VOLUME (CUFT)
0.00	0.00	12.50	0.00	1.0	5.87	17220.00	101021.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
6	4	2	0	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
0	0	0	0

FLOOR WEIGHT (LB/SQFT)	CALCULATION TEMPERATURE (F)
0.0	70.0

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (CFM/SQFT)	AIR CHANGES PER HOUR
	AIR-CHANGE	0.489	5.00

INTERIOR SURFACES (U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)
UnderRf (T.E15.I45)	17220.00	AFlr Construction	0.184
UnderRf (T.C16.I50)	1600.00	AFlr Construction	0.184
SURFACE	SURFACE-TYPE	ADJACENT SPACE	
UnderRf (T.E15.I45)	DELAYED STANDARD	East Perim Plnm (T.E15)	
UnderRf (T.C16.I50)	DELAYED STANDARD	Core Plnm (T.C16)	

REPORT- LV-C Details of Space

Under Roof (T.15)

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (SQFT)	CONSTRUCTION	U-VALUE (BTU/HR-SQFT-F)	SURFACE TYPE
Roof (T.15.E25)	1.0	4454.90	Roof Construction	0.512	DELAYED
Roof (T.15.E26)	1.0	4456.59	Roof Construction	0.512	DELAYED
Roof (T.15.E27)	1.0	4458.18	Roof Construction	0.512	DELAYED
Roof (T.15.E28)	1.0	4456.59	Roof Construction	0.512	DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (FT)	YB (FT)	ZB (FT)	X (FT)	Y (FT)	Z (FT)
Roof (T.15.E25)	0.0	15.0	-22.00	-148.40	62.50	153.20	148.40	0.00
Roof (T.15.E26)	-90.0	15.0	-22.00	-17.15	62.50	22.00	148.40	0.00
Roof (T.15.E27)	180.0	15.0	-153.20	-17.15	62.50	22.00	17.15	0.00
Roof (T.15.E28)	90.0	15.0	-153.20	-148.40	62.50	153.20	17.15	0.00

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- Los Angeles CA TMY2

NUMBER OF EXTERIOR SURFACES 30

(U-VALUE INCLUDES OUTSIDE FILM; WINDOW INCLUDES FRAME AND CURB, IF DEFINED)

SURFACE	- - - W I N D O W S - - -		- - - - W A L L - - - -		- W A L L + W I N D O W S -		AZIMUTH
	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	
North Wall (G.E5.E3)	1.093	729.33	0.373	438.35	0.823	1167.68	NORTH
in space: East Perim Spc (G.E5)							
North Wall (G.E7.E7)	0.000	0.00	0.373	472.32	0.373	472.32	NORTH
in space: East Perim Plnm (G.E7)							
North Wall (M.E9.E11)	1.095	2139.54	0.373	1363.50	0.814	3503.04	NORTH
in space: East Perim Spc (M.E9)							
North Wall (M.E11.E15)	0.000	0.00	0.373	1416.96	0.373	1416.96	NORTH
in space: East Perim Plnm (M.E11)							
North Wall (T.E13.E19)	1.095	713.18	0.373	454.50	0.814	1167.68	NORTH
in space: East Perim Spc (T.E13)							
North Wall (T.E15.E23)	0.000	0.00	0.373	472.32	0.373	472.32	NORTH
in space: East Perim Plnm (T.E15)							
East Wall (M.E11.E14)	0.000	0.00	0.373	1417.50	0.373	1417.50	EAST
in space: East Perim Plnm (M.E11)							
East Wall (G.E5.E2)	1.093	729.36	0.373	438.76	0.823	1168.13	EAST
in space: East Perim Spc (G.E5)							
East Wall (T.E13.E18)	1.095	713.18	0.373	454.95	0.814	1168.13	EAST
in space: East Perim Spc (T.E13)							
East Wall (M.E9.E10)	1.095	2139.54	0.373	1364.84	0.814	3504.38	EAST
in space: East Perim Spc (M.E9)							
East Wall (T.E15.E22)	0.000	0.00	0.373	472.50	0.373	472.50	EAST
in space: East Perim Plnm (T.E15)							
East Wall (G.E7.E6)	0.000	0.00	0.373	472.50	0.373	472.50	EAST
in space: East Perim Plnm (G.E7)							
South Wall (T.E13.E17)	1.095	713.18	0.373	454.50	0.814	1167.68	SOUTH
in space: East Perim Spc (T.E13)							
South Wall (G.E7.E5)	0.000	0.00	0.373	472.32	0.373	472.32	SOUTH
in space: East Perim Plnm (G.E7)							
South Wall (M.E11.E13)	0.000	0.00	0.373	1416.96	0.373	1416.96	SOUTH
in space: East Perim Plnm (M.E11)							
South Wall (T.E15.E21)	0.000	0.00	0.373	472.32	0.373	472.32	SOUTH
in space: East Perim Plnm (T.E15)							
South Wall (M.E9.E9)	1.095	2139.54	0.373	1363.50	0.814	3503.04	SOUTH
in space: East Perim Spc (M.E9)							
South Wall (G.E5.E1)	1.093	729.33	0.373	438.35	0.823	1167.68	SOUTH
in space: East Perim Spc (G.E5)							
West Wall (M.E9.E12)	1.095	2139.54	0.373	1364.84	0.814	3504.38	WEST
in space: East Perim Spc (M.E9)							
West Wall (T.E13.E20)	1.095	713.18	0.373	454.95	0.814	1168.13	WEST
in space: East Perim Spc (T.E13)							
West Wall (M.E11.E16)	0.000	0.00	0.373	1417.50	0.373	1417.50	WEST
in space: East Perim Plnm (M.E11)							
West Wall (G.E7.E8)	0.000	0.00	0.373	472.50	0.373	472.50	WEST
in space: East Perim Plnm (G.E7)							
West Wall (G.E5.E4)	1.093	729.36	0.373	438.76	0.823	1168.13	WEST
in space: East Perim Spc (G.E5)							
West Wall (T.E15.E24)	0.000	0.00	0.373	472.50	0.373	472.50	WEST
in space: East Perim Plnm (T.E15)							

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

Flr (B.E1.I1)	0.000	0.00	0.547	17220.00	0.547	17220.00	FLOOR
in space: East Perim Spc (B.E1)							
Flr (B.C2.I3)	0.000	0.00	0.547	1600.00	0.547	1600.00	FLOOR
in space: Core Spc (B.C2)							
Roof (T.15.E25)	0.000	0.00	0.425	4454.90	0.425	4454.90	ROOF
in space: Under Roof (T.15)							
Roof (T.15.E26)	0.000	0.00	0.425	4456.59	0.425	4456.59	ROOF
in space: Under Roof (T.15)							
Roof (T.15.E27)	0.000	0.00	0.425	4458.18	0.425	4458.18	ROOF
in space: Under Roof (T.15)							
Roof (T.15.E28)	0.000	0.00	0.425	4456.59	0.425	4456.59	ROOF
in space: Under Roof (T.15)							
South Wall (B.E1.U1)	0.000	0.00	0.218	1167.68	0.218	1167.68	UNDERGRND
in space: East Perim Spc (B.E1)							
East Wall (B.E1.U2)	0.000	0.00	0.218	1168.13	0.218	1168.13	UNDERGRND
in space: East Perim Spc (B.E1)							
North Wall (B.E1.U3)	0.000	0.00	0.218	1167.68	0.218	1167.68	UNDERGRND
in space: East Perim Spc (B.E1)							
West Wall (B.E1.U4)	0.000	0.00	0.218	1168.13	0.218	1168.13	UNDERGRND
in space: East Perim Spc (B.E1)							
South Wall (B.E3.U5)	0.000	0.00	0.290	472.32	0.290	472.32	UNDERGRND
in space: East Perim Plnm (B.E3)							
East Wall (B.E3.U6)	0.000	0.00	0.290	472.50	0.290	472.50	UNDERGRND
in space: East Perim Plnm (B.E3)							
North Wall (B.E3.U7)	0.000	0.00	0.290	472.32	0.290	472.32	UNDERGRND
in space: East Perim Plnm (B.E3)							
West Wall (B.E3.U8)	0.000	0.00	0.290	472.50	0.290	472.50	UNDERGRND
in space: East Perim Plnm (B.E3)							

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

	AVERAGE U-VALUE/WINDOWS (BTU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AVERAGE U-VALUE WALLS+WINDOWS (BTU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WINDOW+WALL AREA (SQFT)
NORTH	1.094	0.373	0.688	3582.04	4617.96	8200.00
EAST	1.094	0.373	0.688	3582.07	4621.05	8203.13
SOUTH	1.094	0.373	0.688	3582.04	4617.96	8200.00
WEST	1.094	0.373	0.688	3582.07	4621.05	8203.13
FLOOR	0.000	0.547	0.547	0.00	18820.00	18820.00
ROOF	0.000	0.425	0.425	0.00	17826.26	17826.26
ALL WALLS	1.094	0.373	0.688	14328.23	18478.02	32806.25
WALLS+ROOFS	1.094	0.399	0.595	14328.23	36304.28	50632.51
UNDERGRND	0.000	0.239	0.239	0.00	6561.25	6561.25
BUILDING	1.094	0.427	0.553	14328.23	61685.53	76013.76

NUMBER OF UNDERGROUND SURFACES 8

SURFACE NAME	MULTIPLIER	AREA (SQFT)	CONSTRUCTION NAME	U-VALUE (BTU/HR-SQFT-F)
South Wall (B.E1.U1)	1.0	1167.68	UWCons (B.E1.U1)	0.218
East Wall (B.E1.U2)	1.0	1168.13	UWCons (B.E1.U1)	0.218
North Wall (B.E1.U3)	1.0	1167.68	UWCons (B.E1.U1)	0.218
West Wall (B.E1.U4)	1.0	1168.13	UWCons (B.E1.U1)	0.218
South Wall (B.E3.U5)	1.0	472.32	UWCons (B.E3.U5)	0.290
East Wall (B.E3.U6)	1.0	472.50	UWCons (B.E3.U5)	0.290
North Wall (B.E3.U7)	1.0	472.32	UWCons (B.E3.U5)	0.290
West Wall (B.E3.U8)	1.0	472.50	UWCons (B.E3.U5)	0.290

REPORT- LV-F Details of Interior Surfaces

WEATHER FILE- Los Angeles CA TMY2

Number of Interior Surfaces 48
(U-VALUE includes both air films)

SURFACE NAME	AREA (SQFT)	CONSTRUCTION NAME	SURFACE TYPE	U-VALUE (BTU/HR-SQFT-F)
Ceiling (B.E1.I2)	17220.00	Ceilg Construction	DELAYED STANDARD	0.514
North Wall (B.C2.I4)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (B.C2.I5)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (B.C2.I6)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (B.C2.I7)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
Ceiling (B.C2.I8)	1600.00	Ceilg Construction	DELAYED STANDARD	0.514
North Wall (B.C4.I9)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (B.C4.I10)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (B.C4.I11)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (B.C4.I12)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
Flr (G.E5.I13)	17220.00	IFlr Construction	DELAYED STANDARD	0.355
Ceiling (G.E5.I14)	17220.00	Ceilg Construction	DELAYED STANDARD	0.514
Flr (G.C6.I15)	1600.00	IFlr Construction	DELAYED STANDARD	0.355
North Wall (G.C6.I16)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (G.C6.I17)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (G.C6.I18)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (G.C6.I19)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
Ceiling (G.C6.I20)	1600.00	Ceilg Construction	DELAYED STANDARD	0.514
North Wall (G.C8.I21)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (G.C8.I22)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (G.C8.I23)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (G.C8.I24)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
Flr (M.E9.I25)	17220.00	IFlr Construction	DELAYED STANDARD	0.355
Ceiling (M.E9.I26)	17220.00	Ceilg Construction	DELAYED STANDARD	0.514
Flr (M.C10.I27)	1600.00	IFlr Construction	DELAYED STANDARD	0.355
North Wall (M.C10.I28)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (M.C10.I29)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (M.C10.I30)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (M.C10.I31)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
Ceiling (M.C10.I32)	1600.00	Ceilg Construction	DELAYED STANDARD	0.514
North Wall (M.C12.I33)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (M.C12.I34)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (M.C12.I35)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (M.C12.I36)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
Flr (T.E13.I37)	17220.00	IFlr Construction	DELAYED STANDARD	0.355
Ceiling (T.E13.I38)	17220.00	Ceilg Construction	DELAYED STANDARD	0.514
Flr (T.C14.I39)	1600.00	IFlr Construction	DELAYED STANDARD	0.355
North Wall (T.C14.I40)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (T.C14.I41)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (T.C14.I42)	284.80	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (T.C14.I43)	445.00	IWall Construction	DELAYED ADIABATIC	0.402
Ceiling (T.C14.I44)	1600.00	Ceilg Construction	DELAYED STANDARD	0.514
UnderRf (T.E15.I45)	17220.00	AFlr Construction	DELAYED STANDARD	0.211
North Wall (T.C16.I46)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
West Wall (T.C16.I47)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
South Wall (T.C16.I48)	115.20	IWall Construction	DELAYED ADIABATIC	0.402
East Wall (T.C16.I49)	180.00	IWall Construction	DELAYED ADIABATIC	0.402
UnderRf (T.C16.I50)	1600.00	AFlr Construction	DELAYED STANDARD	0.211

ADJACENT SPACES

SURFACE NAME	SPACE-1	SPACE-2
Ceiling (B.E1.I2)	East Perim Spc (B.E1)	East Perim Plnm (B.E3)
North Wall (B.C2.I4)	Core Spc (B.C2)	Core Spc (B.C2)
West Wall (B.C2.I5)	Core Spc (B.C2)	Core Spc (B.C2)
South Wall (B.C2.I6)	Core Spc (B.C2)	Core Spc (B.C2)
East Wall (B.C2.I7)	Core Spc (B.C2)	Core Spc (B.C2)
Ceiling (B.C2.I8)	Core Spc (B.C2)	Core Plnm (B.C4)
North Wall (B.C4.I9)	Core Plnm (B.C4)	Core Plnm (B.C4)
West Wall (B.C4.I10)	Core Plnm (B.C4)	Core Plnm (B.C4)
South Wall (B.C4.I11)	Core Plnm (B.C4)	Core Plnm (B.C4)
East Wall (B.C4.I12)	Core Plnm (B.C4)	Core Plnm (B.C4)
Flr (G.E5.I13)	East Perim Spc (G.E5)	East Perim Plnm (B.E3)
Ceiling (G.E5.I14)	East Perim Spc (G.E5)	East Perim Plnm (G.E7)
Flr (G.C6.I15)	Core Spc (G.C6)	Core Plnm (B.C4)
North Wall (G.C6.I16)	Core Spc (G.C6)	Core Spc (G.C6)
West Wall (G.C6.I17)	Core Spc (G.C6)	Core Spc (G.C6)
South Wall (G.C6.I18)	Core Spc (G.C6)	Core Spc (G.C6)
East Wall (G.C6.I19)	Core Spc (G.C6)	Core Spc (G.C6)
Ceiling (G.C6.I20)	Core Spc (G.C6)	Core Plnm (G.C8)
North Wall (G.C8.I21)	Core Plnm (G.C8)	Core Plnm (G.C8)
West Wall (G.C8.I22)	Core Plnm (G.C8)	Core Plnm (G.C8)
South Wall (G.C8.I23)	Core Plnm (G.C8)	Core Plnm (G.C8)
East Wall (G.C8.I24)	Core Plnm (G.C8)	Core Plnm (G.C8)
Flr (M.E9.I25)	East Perim Spc (M.E9)	East Perim Plnm (G.E7)
Ceiling (M.E9.I26)	East Perim Spc (M.E9)	East Perim Plnm (M.E11)
Flr (M.C10.I27)	Core Spc (M.C10)	Core Plnm (G.C8)
North Wall (M.C10.I28)	Core Spc (M.C10)	Core Spc (M.C10)
West Wall (M.C10.I29)	Core Spc (M.C10)	Core Spc (M.C10)
South Wall (M.C10.I30)	Core Spc (M.C10)	Core Spc (M.C10)
East Wall (M.C10.I31)	Core Spc (M.C10)	Core Spc (M.C10)
Ceiling (M.C10.I32)	Core Spc (M.C10)	Core Plnm (M.C12)
North Wall (M.C12.I33)	Core Plnm (M.C12)	Core Plnm (M.C12)
West Wall (M.C12.I34)	Core Plnm (M.C12)	Core Plnm (M.C12)
South Wall (M.C12.I35)	Core Plnm (M.C12)	Core Plnm (M.C12)
East Wall (M.C12.I36)	Core Plnm (M.C12)	Core Plnm (M.C12)
Flr (T.E13.I37)	East Perim Spc (T.E13)	East Perim Plnm (M.E11)
Ceiling (T.E13.I38)	East Perim Spc (T.E13)	East Perim Plnm (T.E15)
Flr (T.C14.I39)	Core Spc (T.C14)	Core Plnm (M.C12)
North Wall (T.C14.I40)	Core Spc (T.C14)	Core Spc (T.C14)
West Wall (T.C14.I41)	Core Spc (T.C14)	Core Spc (T.C14)
South Wall (T.C14.I42)	Core Spc (T.C14)	Core Spc (T.C14)
East Wall (T.C14.I43)	Core Spc (T.C14)	Core Spc (T.C14)
Ceiling (T.C14.I44)	Core Spc (T.C14)	Core Plnm (T.C16)
UnderRf (T.E15.I45)	East Perim Plnm (T.E15)	Under Roof (T.15)
North Wall (T.C16.I46)	Core Plnm (T.C16)	Core Plnm (T.C16)
West Wall (T.C16.I47)	Core Plnm (T.C16)	Core Plnm (T.C16)
South Wall (T.C16.I48)	Core Plnm (T.C16)	Core Plnm (T.C16)
East Wall (T.C16.I49)	Core Plnm (T.C16)	Core Plnm (T.C16)
UnderRf (T.C16.I50)	Core Plnm (T.C16)	Under Roof (T.15)

Type of Schedule: FRACTION

Type of Schedule: FRACTION

[illegible]

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS MON TUE WED THU FRI CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.05	0.05	0.05	0.05	0.05	0.08	0.32	0.74	0.89	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.87	0.77	0.50	0.32	0.24	0.12	0.08	0.05

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05

FOR DAYS HDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

THROUGH 31 12

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

FOR DAYS MON TUE WED THU FRI CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.05	0.05	0.05	0.05	0.05	0.08	0.32	0.74	0.89	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.87	0.77	0.50	0.32	0.24	0.12	0.08	0.05

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05

FOR DAYS HDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Schedule: Bldg OffEq Sch

Type of Schedule: FRACTION

THROUGH 31 8

WEATHER FILE- Los Angeles CA TMY2

-- (CONTINUED) -----

[illegible]

	FOR	DAYS	MON	TUE	WED	THU	FRI	CDD																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.12	0.12	0.12	0.12	0.12	0.13	0.28	0.70	0.88	0.90	0.88	0.76	0.75	0.85	0.90	0.90	0.88	0.77	0.44	0.25	0.20	0.16	0.14	0.12

[illegible][illegible]

THROUGH 31 12

[illegible]

FOR DAYS		MON	TUE	WED	THU	FRI	CDD																	
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.12	0.12	0.12	0.12	0.12	0.13	0.28	0.70	0.88	0.90	0.88	0.76	0.75	0.85	0.90	0.90	0.88	0.77	0.44	0.25	0.20	0.16	0.14	0.12

[illegible]

WEATHER FILE- Los Angeles CA TMY2

-- (CONTINUED) -----

[illegible]

Type of Schedule: FRACTION

[illegible]

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.20	0.20	0.20	0.20	0.20	0.21	0.35	0.74	0.89	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.84	0.52	0.32	0.27	0.21	0.20	0.20

[illegible][illegible][illegible]

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS		MON	TUE	WED	THU	FRI	CDD																	
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.20	0.20	0.20	0.20	0.20	0.21	0.35	0.74	0.89	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.84	0.52	0.32	0.27	0.21	0.20	0.20

FOR DAYS		SAT																							
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	

FOR DAYS		HDD																							
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Schedule: Ext Lighting Sch

Type of Schedule: FRACTION

THROUGH 31 1

FOR DAYS		SUN	MON	TUE	WED	THU	FRI	SAT	HOL															
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.60	0.60	0.60	0.60	0.60	0.60	0.30	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.15	0.60	0.90	0.90	0.90	0.90	0.80	0.70

THROUGH 28 2

FOR DAYS		SUN	MON	TUE	WED	THU	FRI	SAT	HOL															
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.60	0.60	0.60	0.60	0.60	0.45	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25	0.70	0.90	0.90	0.90	0.80	0.70

THROUGH 31 3

FOR DAYS		SUN	MON	TUE	WED	THU	FRI	SAT	HOL															
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.60	0.60	0.60	0.60	0.60	0.45	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25	0.70	0.90	0.90	0.90	0.80	0.70

THROUGH 30 4

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

	FOR	DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
	0.60	0.60	0.60	0.60	0.60	0.45	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25	0.70	0.90	0.90	0.90	0.80	0.70		

THROUGH 31 5

	FOR	DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
	0.60	0.60	0.60	0.60	0.60	0.40	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.40	0.75	0.90	0.80	0.70		

THROUGH 30 6

	FOR	DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
	0.60	0.60	0.60	0.60	0.60	0.40	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.40	0.75	0.90	0.80	0.70		

THROUGH 31 7

	FOR	DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
	0.60	0.60	0.60	0.60	0.60	0.40	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.40	0.75	0.90	0.80	0.70		

THROUGH 31 8

	FOR	DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
	0.60	0.60	0.60	0.60	0.60	0.60	0.30	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.15	0.60	0.90	0.90	0.90	0.90	0.80	0.70		

THROUGH 30 9

WEATHER FILE- Los Angeles CA TMY2

-- (CONTINUED) -----

THROUGH 31 10

THROUGH 30 11

THROUGH 31 12

Schedule: ZG0-S1 (VAVS) P-Inf Sch Type of Schedule: MULTIPLIER

[illegible]

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS MON TUE WED THU FRI CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.12	1.25	1.25	1.12	0.52	1.25	1.23	1.06	1.25	0.67	0.50	1.04	1.25	1.25	1.17	1.00	1.00	1.03	1.01

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

FOR DAYS HDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00	1.00

THROUGH 31 12

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

FOR DAYS MON TUE WED THU FRI CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.12	1.25	1.25	1.12	0.52	1.25	1.23	1.06	1.25	0.67	0.50	1.04	1.25	1.25	1.17	1.00	1.00	1.03	1.01

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

FOR DAYS HDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00	1.00

Schedule: ZG0-S1 (VAVS) C-Inf Sch

Type of Schedule: FRACTION

THROUGH 31 8

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

FOR DAYS MON TUE WED THU FRI HDD CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

THROUGH 31 12

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

FOR DAYS MON TUE WED THU FRI HDD CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

Schedule: Sys1 (VAVS) Fan Sch

Type of Schedule: ON/OFF/FLAG

THROUGH 31 8

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS		SUN	HOL																					
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.

FOR DAYS		MON	TUE	WED	THU	FRI	HDD	CDD																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.	0.	0.	0.	0.	0.	0.	1.	1.	1.	1.	1.	1.	1.	1.	1.	1.	1.	1.	0.	0.	0.	0.	0.

FOR DAYS		SAT																						
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.	0.	0.	0.	0.	0.	0.	1.	1.	1.	1.	1.	1.	1.	1.	0.	0.	0.	0.	0.	0.	0.	0.	0.

THROUGH 31 12

FOR DAYS		SUN	HOL																					
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.

FOR DAYS		MON	TUE	WED	THU	FRI	HDD	CDD																
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.	0.	0.	0.	0.	0.	0.	1.	1.	1.	1.	1.	1.	1.	1.	1.	1.	1.	1.	0.	0.	0.	0.	0.

FOR DAYS		SAT																						
HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.	0.	0.	0.	0.	0.	0.	1.	1.	1.	1.	1.	1.	1.	1.	0.	0.	0.	0.	0.	0.	0.	0.	0.

Schedule: Sys1 (VAVS) Cool Sch

Type of Schedule: TEMPERATURE

THROUGH 31 8

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0

FOR DAYS MON TUE WED THU FRI HDD CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	82.0	82.0	82.0	82.0	82.0	82.0	82.0	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	82.0	82.0	82.0	82.0	82.0

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	82.0	82.0	82.0	82.0	82.0	82.0	82.0	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0

THROUGH 31 12

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0

FOR DAYS MON TUE WED THU FRI HDD CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	82.0	82.0	82.0	82.0	82.0	82.0	82.0	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	82.0	82.0	82.0	82.0	82.0

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	82.0	82.0	82.0	82.0	82.0	82.0	82.0	75.2	75.2	75.2	75.2	75.2	75.2	75.2	75.2	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0	82.0

Schedule: Sys1 (VAVS) Heat Sch

Type of Schedule: TEMPERATURE

THROUGH 31 8

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0

FOR DAYS MON TUE WED THU FRI HDD CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	64.0	64.0	64.0	64.0	64.0	64.0	64.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	64.0	64.0	64.0	64.0	64.0

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	64.0	64.0	64.0	64.0	64.0	64.0	64.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0

THROUGH 31 12

FOR DAYS SUN HOL

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0

FOR DAYS MON TUE WED THU FRI HDD CDD

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	64.0	64.0	64.0	64.0	64.0	64.0	64.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	64.0	64.0	64.0	64.0	64.0

FOR DAYS SAT

HOUR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	64.0	64.0	64.0	64.0	64.0	64.0	64.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0

Schedule: Sys1 (VAVS) (B) CRS

Type of Schedule: RESET-TEMP

THROUGH 31 12

REPORT- LV-G Details of Schedules

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

FOR DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
80.0	60.0	65.0	55.0	1.	24.	0.0	0.0	0.0	0.0																

Schedule: Sys1 (VAVS) (G) CRS Type of Schedule: RESET-TEMP

THROUGH 31 12

FOR DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
80.0	60.0	65.0	55.0	1.	24.	0.0	0.0	0.0	0.0																

Schedule: Sys1 (VAVS) (M) CRS Type of Schedule: RESET-TEMP

THROUGH 31 12

FOR DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
80.0	60.0	65.0	55.0	1.	24.	0.0	0.0	0.0	0.0																

Schedule: Sys1 (VAVS) (T) CRS Type of Schedule: RESET-TEMP

THROUGH 31 12

FOR DAYS	SUN	MON	TUE	WED	THU	FRI	SAT	HOL																	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
80.0	60.0	65.0	55.0	1.	24.	0.0	0.0	0.0	0.0																

Schedule: Cust 1 Elec Season Sched Type of Schedule: FLAG

THROUGH 31 12

WEATHER FILE- Los Angeles CA TMY2

-- (CONTINUED) -----

[illegible]

Schedule: Hourly Report Schedule Type of Schedule: ON/OFF

THROUGH 31 12

[illegible]

Schedule: Dirt Depre Windows Type of Schedule: FRACTION

THROUGH 31 12

[illegible]

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

NUMBER OF WINDOWS 276

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME CURB U-VALUE	
					X (FT)	Y (FT)			(BTU/HR-SQFT-F)	
South Win (G.E5.E1.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W2)	1.0	25.44	7.38	3.45	6.83	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W4)	1.0	25.44	7.38	3.45	18.24	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W5)	1.0	25.44	7.38	3.45	23.95	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W6)	1.0	25.44	7.38	3.45	29.65	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W7)	1.0	25.44	7.38	3.45	35.35	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W8)	1.0	25.44	7.38	3.45	41.06	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W9)	1.0	25.44	7.38	3.45	46.76	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W10)	1.0	25.44	7.38	3.45	52.47	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W11)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W12)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W13)	1.0	25.44	7.38	3.45	69.59	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W14)	1.0	25.44	7.38	3.45	75.30	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W15)	1.0	25.44	7.38	3.45	81.01	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W16)	1.0	25.44	7.38	3.45	86.72	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W17)	1.0	25.44	7.38	3.45	92.43	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W18)	1.0	25.44	7.38	3.45	98.14	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W19)	1.0	25.44	7.38	3.45	103.85	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W20)	1.0	25.44	7.38	3.45	109.56	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W21)	1.0	25.44	7.38	3.45	115.27	1.23	5.56	0.00	1.604	0.000
South Win (G.E5.E1.W22)	1.0	25.44	7.38	3.45	120.98	1.23	5.56	0.00	1.604	0.000
South Door (G.E5.E1.D1)	1.0	41.25	7.50	5.50	62.85	0.25	6.75	0.00	1.604	0.000
East Win (G.E5.E2.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W2)	1.0	25.44	7.38	3.45	6.84	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W4)	1.0	25.44	7.38	3.45	18.25	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W5)	1.0	25.44	7.38	3.45	23.96	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W6)	1.0	25.44	7.38	3.45	29.67	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W7)	1.0	25.44	7.38	3.45	35.37	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W8)	1.0	25.44	7.38	3.45	41.07	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W9)	1.0	25.44	7.38	3.45	46.78	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W10)	1.0	25.44	7.38	3.45	52.49	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W11)	1.0	25.44	7.38	3.45	58.19	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W12)	1.0	25.44	7.38	3.45	63.90	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W13)	1.0	25.44	7.38	3.45	69.61	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W14)	1.0	25.44	7.38	3.45	75.32	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W15)	1.0	25.44	7.38	3.45	81.03	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W16)	1.0	25.44	7.38	3.45	86.74	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W17)	1.0	25.44	7.38	3.45	92.45	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W18)	1.0	25.44	7.38	3.45	98.16	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W19)	1.0	25.44	7.38	3.45	103.87	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W20)	1.0	25.44	7.38	3.45	109.58	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W21)	1.0	25.44	7.38	3.45	115.29	1.23	5.56	0.00	1.604	0.000
East Win (G.E5.E2.W22)	1.0	25.44	7.38	3.45	120.99	1.23	5.56	0.00	1.604	0.000
East Door (G.E5.E2.D1)	1.0	41.25	7.50	5.50	62.88	0.25	6.75	0.00	1.604	0.000
North Win (G.E5.E3.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W2)	1.0	25.44	7.38	3.45	6.83	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME U-VALUE (BTU/HR-SQFT-F)	CURB
					X (FT)	Y (FT)				
North Win (G.E5.E3.W4)	1.0	25.44	7.38	3.45	18.24	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W5)	1.0	25.44	7.38	3.45	23.95	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W6)	1.0	25.44	7.38	3.45	29.65	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W7)	1.0	25.44	7.38	3.45	35.35	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W8)	1.0	25.44	7.38	3.45	41.06	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W9)	1.0	25.44	7.38	3.45	46.76	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W10)	1.0	25.44	7.38	3.45	52.47	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W11)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W12)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W13)	1.0	25.44	7.38	3.45	69.58	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W14)	1.0	25.44	7.38	3.45	75.29	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W15)	1.0	25.44	7.38	3.45	80.99	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W16)	1.0	25.44	7.38	3.45	86.69	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W17)	1.0	25.44	7.38	3.45	92.40	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W18)	1.0	25.44	7.38	3.45	98.10	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W19)	1.0	25.44	7.38	3.45	103.81	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W20)	1.0	25.44	7.38	3.45	109.51	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W21)	1.0	25.44	7.38	3.45	115.21	1.23	5.56	0.00	1.604	0.000
North Win (G.E5.E3.W22)	1.0	25.44	7.38	3.45	120.92	1.23	5.56	0.00	1.604	0.000
North Door (G.E5.E3.D1)	1.0	41.25	7.50	5.50	126.62	0.25	6.75	0.00	1.604	0.000
West Win (G.E5.E4.W1)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W2)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W3)	1.0	25.44	7.38	3.45	69.58	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W4)	1.0	25.44	7.38	3.45	75.29	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W5)	1.0	25.44	7.38	3.45	80.99	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W6)	1.0	25.44	7.38	3.45	86.69	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W7)	1.0	25.44	7.38	3.45	92.40	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W8)	1.0	25.44	7.38	3.45	98.10	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W9)	1.0	25.44	7.38	3.45	103.81	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W10)	1.0	25.44	7.38	3.45	109.51	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W11)	1.0	25.44	7.38	3.45	115.21	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W12)	1.0	25.44	7.38	3.45	120.92	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W13)	1.0	25.44	7.38	3.45	126.62	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W14)	1.0	25.44	7.38	3.45	132.33	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W15)	1.0	25.44	7.38	3.45	138.03	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W16)	1.0	25.44	7.38	3.45	143.74	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W17)	1.0	25.44	7.38	3.45	149.44	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W18)	1.0	25.44	7.38	3.45	155.15	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W19)	1.0	25.44	7.38	3.45	160.85	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W20)	1.0	25.44	7.38	3.45	166.56	1.23	5.56	0.00	1.604	0.000
West Win (G.E5.E4.W21)	1.0	25.06	7.38	3.40	172.26	1.23	5.54	0.00	1.604	0.000
West Win (G.E5.E4.W22)	1.0	25.06	7.38	3.40	177.97	1.23	5.54	0.00	1.604	0.000
West Door (G.E5.E4.D1)	1.0	41.25	7.50	5.50	183.67	0.25	6.75	0.00	1.604	0.000
South Win (M.E9.E9.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W2)	1.0	25.44	7.38	3.45	6.83	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W4)	1.0	25.44	7.38	3.45	18.24	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W5)	1.0	25.44	7.38	3.45	23.95	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W6)	1.0	25.44	7.38	3.45	29.65	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W7)	1.0	25.44	7.38	3.45	35.35	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W8)	1.0	25.44	7.38	3.45	41.06	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W9)	1.0	25.44	7.38	3.45	46.76	1.23	5.56	0.00	1.604	0.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME CURB U-VALUE	
					X (FT)	Y (FT)			(BTU/HR-SQFT-F)	
South Win (M.E9.E9.W10)	1.0	25.44	7.38	3.45	52.47	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W11)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W12)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W13)	1.0	25.44	7.38	3.45	69.58	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W14)	1.0	25.44	7.38	3.45	75.28	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W15)	1.0	25.44	7.38	3.45	80.99	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W16)	1.0	25.44	7.38	3.45	86.69	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W17)	1.0	25.44	7.38	3.45	92.40	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W18)	1.0	25.44	7.38	3.45	98.10	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W19)	1.0	25.44	7.38	3.45	103.81	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W20)	1.0	25.44	7.38	3.45	109.51	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W21)	1.0	25.44	7.38	3.45	115.21	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W22)	1.0	25.44	7.38	3.45	120.92	1.23	5.56	0.00	1.604	0.000
South Win (M.E9.E9.W23)	1.0	25.44	7.38	3.45	126.62	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W2)	1.0	25.44	7.38	3.45	6.84	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W4)	1.0	25.44	7.38	3.45	18.25	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W5)	1.0	25.44	7.38	3.45	23.96	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W6)	1.0	25.44	7.38	3.45	29.66	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W7)	1.0	25.44	7.38	3.45	35.37	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W8)	1.0	25.44	7.38	3.45	41.07	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W9)	1.0	25.44	7.38	3.45	46.78	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W10)	1.0	25.44	7.38	3.45	52.49	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W11)	1.0	25.44	7.38	3.45	58.19	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W12)	1.0	25.44	7.38	3.45	63.90	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W13)	1.0	25.44	7.38	3.45	69.61	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W14)	1.0	25.44	7.38	3.45	75.31	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W15)	1.0	25.44	7.38	3.45	81.02	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W16)	1.0	25.44	7.38	3.45	86.73	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W17)	1.0	25.44	7.38	3.45	92.43	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W18)	1.0	25.44	7.38	3.45	98.14	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W19)	1.0	25.44	7.38	3.45	103.85	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W20)	1.0	25.44	7.38	3.45	109.55	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W21)	1.0	25.44	7.38	3.45	115.26	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W22)	1.0	25.44	7.38	3.45	120.97	1.23	5.56	0.00	1.604	0.000
East Win (M.E9.E10.W23)	1.0	25.44	7.38	3.45	126.67	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W2)	1.0	25.44	7.38	3.45	6.83	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W4)	1.0	25.44	7.38	3.45	18.24	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W5)	1.0	25.44	7.38	3.45	23.95	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W6)	1.0	25.44	7.38	3.45	29.65	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W7)	1.0	25.44	7.38	3.45	35.35	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W8)	1.0	25.44	7.38	3.45	41.06	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W9)	1.0	25.44	7.38	3.45	46.76	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W10)	1.0	25.44	7.38	3.45	52.47	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W11)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W12)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W13)	1.0	25.44	7.38	3.45	69.58	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W14)	1.0	25.44	7.38	3.45	75.28	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W15)	1.0	25.44	7.38	3.45	80.99	1.23	5.56	0.00	1.604	0.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME U-VALUE	CURB
					X (FT)	Y (FT)				
North Win (M.E9.E11.W16)	1.0	25.44	7.38	3.45	86.69	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W17)	1.0	25.44	7.38	3.45	92.40	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W18)	1.0	25.44	7.38	3.45	98.10	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W19)	1.0	25.44	7.38	3.45	103.81	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W20)	1.0	25.44	7.38	3.45	109.51	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W21)	1.0	25.44	7.38	3.45	115.21	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W22)	1.0	25.44	7.38	3.45	120.92	1.23	5.56	0.00	1.604	0.000
North Win (M.E9.E11.W23)	1.0	25.44	7.38	3.45	126.62	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W2)	1.0	25.44	7.38	3.45	6.84	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W4)	1.0	25.44	7.38	3.45	18.25	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W5)	1.0	25.44	7.38	3.45	23.96	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W6)	1.0	25.44	7.38	3.45	29.66	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W7)	1.0	25.44	7.38	3.45	35.37	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W8)	1.0	25.44	7.38	3.45	41.07	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W9)	1.0	25.44	7.38	3.45	46.78	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W10)	1.0	25.44	7.38	3.45	52.49	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W11)	1.0	25.44	7.38	3.45	58.19	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W12)	1.0	25.44	7.38	3.45	63.90	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W13)	1.0	25.44	7.38	3.45	69.61	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W14)	1.0	25.44	7.38	3.45	75.31	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W15)	1.0	25.44	7.38	3.45	81.02	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W16)	1.0	25.44	7.38	3.45	86.73	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W17)	1.0	25.44	7.38	3.45	92.43	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W18)	1.0	25.44	7.38	3.45	98.14	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W19)	1.0	25.44	7.38	3.45	103.85	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W20)	1.0	25.44	7.38	3.45	109.55	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W21)	1.0	25.44	7.38	3.45	115.26	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W22)	1.0	25.44	7.38	3.45	120.97	1.23	5.56	0.00	1.604	0.000
West Win (M.E9.E12.W23)	1.0	25.44	7.38	3.45	126.67	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W2)	1.0	25.44	7.38	3.45	6.83	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W4)	1.0	25.44	7.38	3.45	18.24	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W5)	1.0	25.44	7.38	3.45	23.95	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W6)	1.0	25.44	7.38	3.45	29.65	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W7)	1.0	25.44	7.38	3.45	35.35	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W8)	1.0	25.44	7.38	3.45	41.06	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W9)	1.0	25.44	7.38	3.45	46.76	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W10)	1.0	25.44	7.38	3.45	52.47	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W11)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W12)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W13)	1.0	25.44	7.38	3.45	69.58	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W14)	1.0	25.44	7.38	3.45	75.28	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W15)	1.0	25.44	7.38	3.45	80.99	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W16)	1.0	25.44	7.38	3.45	86.69	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W17)	1.0	25.44	7.38	3.45	92.40	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W18)	1.0	25.44	7.38	3.45	98.10	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W19)	1.0	25.44	7.38	3.45	103.81	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W20)	1.0	25.44	7.38	3.45	109.51	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W21)	1.0	25.44	7.38	3.45	115.21	1.23	5.56	0.00	1.604	0.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME CURB U-VALUE	
					X (FT)	Y (FT)			(BTU/HR-SQFT-F)	
South Win (T.E13.E17.W22)	1.0	25.44	7.38	3.45	120.92	1.23	5.56	0.00	1.604	0.000
South Win (T.E13.E17.W23)	1.0	25.44	7.38	3.45	126.62	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W2)	1.0	25.44	7.38	3.45	6.84	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W4)	1.0	25.44	7.38	3.45	18.25	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W5)	1.0	25.44	7.38	3.45	23.96	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W6)	1.0	25.44	7.38	3.45	29.66	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W7)	1.0	25.44	7.38	3.45	35.37	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W8)	1.0	25.44	7.38	3.45	41.07	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W9)	1.0	25.44	7.38	3.45	46.78	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W10)	1.0	25.44	7.38	3.45	52.49	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W11)	1.0	25.44	7.38	3.45	58.19	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W12)	1.0	25.44	7.38	3.45	63.90	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W13)	1.0	25.44	7.38	3.45	69.61	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W14)	1.0	25.44	7.38	3.45	75.31	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W15)	1.0	25.44	7.38	3.45	81.02	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W16)	1.0	25.44	7.38	3.45	86.73	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W17)	1.0	25.44	7.38	3.45	92.43	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W18)	1.0	25.44	7.38	3.45	98.14	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W19)	1.0	25.44	7.38	3.45	103.85	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W20)	1.0	25.44	7.38	3.45	109.55	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W21)	1.0	25.44	7.38	3.45	115.26	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W22)	1.0	25.44	7.38	3.45	120.97	1.23	5.56	0.00	1.604	0.000
East Win (T.E13.E18.W23)	1.0	25.44	7.38	3.45	126.67	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W2)	1.0	25.44	7.38	3.45	6.83	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W4)	1.0	25.44	7.38	3.45	18.24	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W5)	1.0	25.44	7.38	3.45	23.95	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W6)	1.0	25.44	7.38	3.45	29.65	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W7)	1.0	25.44	7.38	3.45	35.35	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W8)	1.0	25.44	7.38	3.45	41.06	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W9)	1.0	25.44	7.38	3.45	46.76	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W10)	1.0	25.44	7.38	3.45	52.47	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W11)	1.0	25.44	7.38	3.45	58.17	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W12)	1.0	25.44	7.38	3.45	63.88	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W13)	1.0	25.44	7.38	3.45	69.58	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W14)	1.0	25.44	7.38	3.45	75.28	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W15)	1.0	25.44	7.38	3.45	80.99	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W16)	1.0	25.44	7.38	3.45	86.69	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W17)	1.0	25.44	7.38	3.45	92.40	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W18)	1.0	25.44	7.38	3.45	98.10	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W19)	1.0	25.44	7.38	3.45	103.81	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W20)	1.0	25.44	7.38	3.45	109.51	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W21)	1.0	25.44	7.38	3.45	115.21	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W22)	1.0	25.44	7.38	3.45	120.92	1.23	5.56	0.00	1.604	0.000
North Win (T.E13.E19.W23)	1.0	25.44	7.38	3.45	126.62	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W1)	1.0	25.44	7.38	3.45	1.13	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W2)	1.0	25.44	7.38	3.45	6.84	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W3)	1.0	25.44	7.38	3.45	12.54	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W4)	1.0	25.44	7.38	3.45	18.25	1.23	5.56	0.00	1.604	0.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME U-VALUE (BTU/HR-SQFT-F)	CURB
					X (FT)	Y (FT)				
West Win (T.E13.E20.W5)	1.0	25.44	7.38	3.45	23.96	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W6)	1.0	25.44	7.38	3.45	29.66	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W7)	1.0	25.44	7.38	3.45	35.37	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W8)	1.0	25.44	7.38	3.45	41.07	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W9)	1.0	25.44	7.38	3.45	46.78	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W10)	1.0	25.44	7.38	3.45	52.49	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W11)	1.0	25.44	7.38	3.45	58.19	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W12)	1.0	25.44	7.38	3.45	63.90	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W13)	1.0	25.44	7.38	3.45	69.61	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W14)	1.0	25.44	7.38	3.45	75.31	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W15)	1.0	25.44	7.38	3.45	81.02	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W16)	1.0	25.44	7.38	3.45	86.73	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W17)	1.0	25.44	7.38	3.45	92.43	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W18)	1.0	25.44	7.38	3.45	98.14	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W19)	1.0	25.44	7.38	3.45	103.85	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W20)	1.0	25.44	7.38	3.45	109.55	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W21)	1.0	25.44	7.38	3.45	115.26	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W22)	1.0	25.44	7.38	3.45	120.97	1.23	5.56	0.00	1.604	0.000
West Win (T.E13.E20.W23)	1.0	25.44	7.38	3.45	126.67	1.23	5.56	0.00	1.604	0.000

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF-GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
South Win (G.E5.E1.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (G.E5.E1.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Door (G.E5.E1.D1)	0.00	0.95	1	0.983	0.881	0.775	1.000
East Win (G.E5.E2.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
East Win (G.E5.E2.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (G.E5.E2.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Door (G.E5.E2.D1)	0.00	0.95	1	0.983	0.881	0.775	1.000
North Win (G.E5.E3.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (G.E5.E3.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Door (G.E5.E3.D1)	0.00	0.95	1	0.983	0.881	0.775	1.000
West Win (G.E5.E4.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
West Win (G.E5.E4.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (G.E5.E4.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Door (G.E5.E4.D1)	0.00	0.95	1	0.983	0.881	0.775	1.000
South Win (M.E9.E9.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (M.E9.E9.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
East Win (M.E9.E10.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (M.E9.E10.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (M.E9.E11.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (M.E9.E12.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
South Win (T.E13.E17.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
South Win (T.E13.E17.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
East Win (T.E13.E18.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000

REPORT- LV-H Details of Windows

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
North Win (T.E13.E19.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
North Win (T.E13.E19.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W1)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W2)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W3)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W4)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W5)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W6)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W7)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W8)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W9)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W10)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W11)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W12)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W13)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W14)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W15)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W16)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W17)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W18)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W19)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W20)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W21)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W22)	0.00	0.84	1	0.983	0.810	0.680	1.000
West Win (T.E13.E20.W23)	0.00	0.84	1	0.983	0.810	0.680	1.000

NUMBER OF CONSTRUCTIONS 9 DELAYED 9 QUICK 0

CONSTRUCTION NAME	U-VALUE (BTU/HR-SQFT-F)	SURFACE ABSORPTANCE	SURFACE ROUGHNESS INDEX	SURFACE TYPE	NUMBER OF RESPONSE FACTORS
EWall Construction	0.439	0.40	1	DELAYED	7
Roof Construction	0.512	0.40	1	DELAYED	10
Ceilg Construction	0.514	0.70	3	DELAYED	3
IWall Construction	0.402	0.70	3	DELAYED	4
IFlr Construction	0.355	0.70	3	DELAYED	15
GFlr Construction	0.701	0.70	3	DELAYED	8
AFlr Construction	0.211	0.70	3	DELAYED	4
UWCons (B.E1.U1)	0.218	0.70	3	DELAYED	37
UWCons (B.E3.U5)	0.290	0.70	3	DELAYED	34

NUMBER OF BUILDING SHADES 28 RECTANGULAR 0 OTHER 28

RECTANGULAR SHADES

SHADE NAME	TRANSMITTANCE	HEIGHT (FT)	WIDTH (FT)	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN BUILDING COORDINATES		
						XB (FT)	YB (FT)	ZB (FT)

REPORT- LS-A Space Peak Loads Summary

WEATHER FILE- Los Angeles CA TMY2

SPACE NAME	MULTIPLIER SPACE FLOOR	COOLING LOAD (KBTU/HR)	TIME OF PEAK	DRY- BULB	WET- BULB	HEATING LOAD (KBTU/HR)	TIME OF PEAK	DRY- BULB	WET- BULB
East Perim Spc (B.E1)	1. 1.	212.747	SEP 24 5 PM	83.F	60.F	-153.049	DEC 13 9 AM	51.F	40.F
Core Spc (B.C2)	1. 1.	22.180	SEP 24 5 PM	83.F	60.F	-14.864	DEC 13 9 AM	51.F	40.F
East Perim Plnm (B.E3)	1. 1.	0.000		0.F	0.F	-8.536	FEB 3 7 AM	44.F	44.F
Core Plnm (B.C4)	1. 1.	0.025	APR 11 5 PM	85.F	53.F	-0.051	DEC 12 6 AM	40.F	33.F
East Perim Spc (G.E5)	1. 1.	353.315	SEP 24 4 PM	86.F	59.F	-56.307	DEC 13 6 AM	42.F	35.F
Core Spc (G.C6)	1. 1.	11.085	SEP 24 4 PM	86.F	59.F	0.000		0.F	0.F
East Perim Plnm (G.E7)	1. 1.	13.400	SEP 24 6 PM	80.F	59.F	-19.457	DEC 12 7 AM	41.F	33.F
Core Plnm (G.C8)	1. 1.	0.025	APR 11 5 PM	85.F	53.F	-0.051	DEC 12 6 AM	40.F	33.F
East Perim Spc (M.E9)	1. 3.	371.853	SEP 24 4 PM	86.F	59.F	-53.732	DEC 13 6 AM	42.F	35.F
Core Spc (M.C10)	1. 3.	11.493	SEP 24 4 PM	86.F	59.F	0.000		0.F	0.F
East Perim Plnm (M.E11)	1. 3.	13.400	SEP 24 6 PM	80.F	59.F	-19.457	DEC 12 7 AM	41.F	33.F
Core Plnm (M.C12)	1. 3.	0.025	APR 11 5 PM	85.F	53.F	-0.051	DEC 12 6 AM	40.F	33.F
East Perim Spc (T.E13)	1. 1.	371.853	SEP 24 4 PM	86.F	59.F	-53.732	DEC 13 6 AM	42.F	35.F
Core Spc (T.C14)	1. 1.	11.493	SEP 24 4 PM	86.F	59.F	0.000		0.F	0.F
East Perim Plnm (T.E15)	1. 1.	17.573	SEP 24 5 PM	83.F	60.F	-21.877	DEC 12 7 AM	41.F	33.F
Core Plnm (T.C16)	1. 1.	0.025	APR 11 5 PM	85.F	53.F	-0.051	DEC 12 6 AM	40.F	33.F
Under Roof (T.15)	1. 1.	229.100	SEP 24 4 PM	86.F	59.F	-495.566	MAR 21 9 PM	50.F	42.F
SUM		2433.135				-1043.260			
BUILDING PEAK		2121.203	SEP 24 4 PM	86.F	59.F	-423.946	DEC 13 6 AM	42.F	35.F

REPORT- LS-B Space Peak Load Components

East Perim Spc (B.E1)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (B.E1)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	17220 SQFT	1600 M2	
VOLUME	153258 CUFT	4340 M3	

TIME	COOLING LOAD		HEATING LOAD	
	SEP 24 5PM		DEC 13 9AM	
DRY-BULB TEMP	83 F	28 C	51 F	11 C
WET-BULB TEMP	60 F	16 C	40 F	4 C
TOT HORIZONTAL SOLAR RAD	125 BTU/H.SQFT	394 W/M2	78 BTU/H.SQFT	245 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S	2.0 KTS	1.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	118.608	34.752	0.000	0.000	-149.243	-43.728	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	-3.626	-1.062	0.000	0.000	-6.753	-1.979	
OCCUPANTS TO SPACE	23.975	7.025	32.980	9.663	0.030	0.009	
LIGHT TO SPACE	28.757	8.426	0.000	0.000	0.650	0.190	
EQUIPMENT TO SPACE	45.033	13.195	0.000	0.000	2.268	0.665	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	0.000	0.000	0.000	0.000	0.000	0.000	
TOTAL	212.747	62.335	32.980	9.663	-153.049	-44.843	
TOTAL / AREA	0.012	0.039	0.002	0.006	-0.009	-0.028	
TOTAL LOAD	245.728 KBTU/H		71.998 KW		-153.049 KBTU/H		-44.843 KW
TOTAL LOAD / AREA	14.27 BTU/H.SQFT		45.005 W/M2		8.888 BTU/H.SQFT		28.031 W/M2

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components Core Spc (B.C2)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (B.C2)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	1600 SQFT	149 M2	
VOLUME	14240 CUFT	403 M3	

TIME	COOLING LOAD		HEATING LOAD	
	SEP 24 5PM		DEC 13 9AM	
DRY-BULB TEMP	83 F	28 C	51 F	11 C
WET-BULB TEMP	60 F	16 C	40 F	4 C
TOT HORIZONTAL SOLAR RAD	125 BTU/H.SQFT	394 W/M2	78 BTU/H.SQFT	245 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S	2.0 KTS	1.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	12.302	3.604	0.000	0.000	-15.128	-4.433	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	2.531	0.741	3.064	0.898	0.000	0.000	
LIGHT TO SPACE	2.986	0.875	0.000	0.000	0.056	0.016	
EQUIPMENT TO SPACE	4.361	1.278	0.000	0.000	0.208	0.061	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	0.000	0.000	0.000	0.000	0.000	0.000	
TOTAL	22.180	6.499	3.064	0.898	-14.864	-4.355	
TOTAL / AREA	0.014	0.044	0.002	0.006	-0.009	-0.029	
TOTAL LOAD	25.245 KBTU/H		7.397 KW		-14.864 KBTU/H	-4.355 KW	
TOTAL LOAD / AREA	15.78 BTU/H.SQFT		49.761 W/M2		9.290 BTU/H.SQFT	29.300 W/M2	

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components East Perim Plnm (B.E3)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (B.E3)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	17220 SQFT	1600 M2	
VOLUME	61992 CUFT	1756 M3	

COOLING LOAD

HEATING LOAD

TIME

FEB 3 7AM

DRY-BULB TEMP
 WET-BULB TEMP
 TOT HORIZONTAL SOLAR RAD
 WINDSPEED AT SPACE
 CLOUD AMOUNT 0 (CLEAR) -10

44 F 7 C
 44 F 7 C
 1 BTU/H.SQFT 3 W/M2
 2.1 KTS 1.1 M/S
 1

	SENSIBLE (KBTU/H) (KW)		LATENT (KBTU/H) (KW)		SENSIBLE (KBTU/H) (KW)	
	-----	-----	-----	-----	-----	-----
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	-6.066	-1.777
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.000	0.000	0.000	0.000	-2.470	-0.724
TOTAL	0.000	0.000	0.000	0.000	-8.536	-2.501
TOTAL / AREA	0.000	0.000	0.000	0.000	0.000	-0.002
TOTAL LOAD	0.000 KBTU/H		0.000 KW		-8.536 KBTU/H	-2.501 KW
TOTAL LOAD / AREA	0.00 BTU/H.SQFT		0.000 W/M2		0.496 BTU/H.SQFT	1.563 W/M2

 *
 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
 * ---- LOADS
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
 * IN CONSIDERATION
 * 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A
 * CONSTANT INDOOR SPACE TEMPERATURE
 *

REPORT- LS-B Space Peak Load Components Core Plnm (B.C4)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (B.C4)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	1600 SQFT	149 M2	
VOLUME	5760 CUFT	163 M3	

TIME	COOLING LOAD		HEATING LOAD	
	APR 11 5PM		DEC 12 6AM	
DRY-BULB TEMP	85 F	29 C	40 F	4 C
WET-BULB TEMP	53 F	12 C	33 F	1 C
TOT HORIZONTAL SOLAR RAD	176 BTU/H.SQFT	554 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	8.4 KTS	4.3 M/S	3.5 KTS	1.8 M/S
CLOUD AMOUNT 0 (CLEAR)-10	4		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	0.025	0.007	0.000	0.000	-0.051	-0.015	
TOTAL	0.025	0.007	0.000	0.000	-0.051	-0.015	
TOTAL / AREA	0.000	0.000	0.000	0.000	0.000	0.000	
TOTAL LOAD	0.025 KBTU/H	0.007 KW			-0.051 KBTU/H	-0.015 KW	
TOTAL LOAD / AREA	0.02 BTU/H.SQFT	0.050 W/M2			0.032 BTU/H.SQFT	0.100 W/M2	

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (G.E5)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0

FLOOR AREA	17220 SQFT	1600 M2
VOLUME	153258 CUFT	4340 M3

COOLING LOAD

=====

TIME SEP 24 4PM

DRY-BULB TEMP	86 F	30 C
WET-BULB TEMP	59 F	15 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0	

HEATING LOAD

=====

DEC 13 6AM

42 F	6 C
35 F	2 C
0 BTU/H.SQFT	0 W/M2
3.9 KTS	2.0 M/S
0	

SENSIBLE		LATENT	
(KBTU/H)	(KW)	(KBTU/H)	(KW)

WALL CONDUCTION	13.651	4.000	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	47.829	14.014	0.000	0.000
WINDOW GLASS SOLAR	113.892	33.370	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	32.132	9.415	34.524	10.115
LIGHT TO SPACE	48.181	14.117	0.000	0.000
EQUIPMENT TO SPACE	96.129	28.166	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000
INFILTRATION	1.501	0.440	0.000	0.000

TOTAL	353.315	103.521	34.524	10.115
TOTAL / AREA	0.021	0.065	0.002	0.006

SENSIBLE	
(KBTU/H)	(KW)

-17.614	-5.161
0.000	0.000
-51.659	-15.136
11.463	3.359
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.107	0.031
1.383	0.405
5.309	1.555
0.000	0.000
-5.296	-1.552

TOTAL	-56.307	-16.498
TOTAL / AREA	-0.003	-0.010

TOTAL LOAD	387.838 KBTU/H	113.637 KW	-56.307 KBTU/H	-16.498 KW
TOTAL LOAD / AREA	22.52 BTU/H.SQFT	71.032 W/M2	3.270 BTU/H.SQFT	10.313 W/M2

```

*****
*
*   NOTE  1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
*   ----  LOADS
*          2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
*          IN CONSIDERATION
*          3)THE ABOVE LOADS ARE CALCULATED ASSUMING A
*          CONSTANT INDOOR SPACE TEMPERATURE
*
*****

```


REPORT- LS-B Space Peak Load Components Core Spc (G.C6)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (G.C6)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	1600 SQFT	149 M2	
VOLUME	14240 CUFT	403 M3	

COOLING LOAD

HEATING LOAD

TIME

SEP 24 4PM

DRY-BULB TEMP	86 F	30 C
WET-BULB TEMP	59 F	15 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0	

	SENSIBLE (KBTU/H) (KW)		LATENT (KBTU/H) (KW)		SENSIBLE (KBTU/H) (KW)	
	-----	-----	-----	-----	-----	-----
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	0.945	0.277	1.073	0.314	0.000	0.000
LIGHT TO SPACE	6.813	1.996	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	3.314	0.971	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.013	0.004	0.000	0.000	0.000	0.000
TOTAL	11.085	3.248	1.073	0.314	0.000	0.000
TOTAL / AREA	0.007	0.022	0.001	0.002	0.000	0.000
TOTAL LOAD	12.159 KBTU/H	3.563 KW	0.000 KBTU/H	0.000 KW		
TOTAL LOAD / AREA	7.60 BTU/H.SQFT	23.967 W/M2	0.000 BTU/H.SQFT	0.000 W/M2		

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components East Perim Plnm (G.E7)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (G.E7)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	17220 SQFT	1600 M2	
VOLUME	61992 CUFT	1756 M3	

TIME	COOLING LOAD		HEATING LOAD	
	SEP 24 6PM		DEC 12 7AM	
DRY-BULB TEMP	80 F	27 C	41 F	5 C
WET-BULB TEMP	59 F	15 C	33 F	1 C
TOT HORIZONTAL SOLAR RAD	57 BTU/H.SQFT	179 W/M2	1 BTU/H.SQFT	3 W/M2
WINDSPEED AT SPACE	7.7 KTS	4.0 M/S	2.1 KTS	1.1 M/S
CLOUD AMOUNT 0 (CLEAR) -10	0		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	12.456	3.650	0.000	0.000	-17.246	-5.053	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	0.944	0.276	0.000	0.000	-2.211	-0.648	
TOTAL	13.400	3.926	0.000	0.000	-19.457	-5.701	
TOTAL / AREA	0.001	0.002	0.000	0.000	-0.001	-0.004	
TOTAL LOAD	13.400 KBTU/H	3.926 KW			-19.457 KBTU/H	-5.701 KW	
TOTAL LOAD / AREA	0.78 BTU/H.SQFT	2.454 W/M2			1.130 BTU/H.SQFT	3.564 W/M2	

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components Core Plnm (G.C8)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (G.C8)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0

FLOOR AREA	1600 SQFT	149 M2
VOLUME	5760 CUFT	163 M3

COOLING LOAD

HEATING LOAD

TIME

APR 11 5PM

DEC 12 6AM

DRY-BULB TEMP	85 F	29 C	40 F	4 C
WET-BULB TEMP	53 F	12 C	33 F	1 C
TOT HORIZONTAL SOLAR RAD	176 BTU/H.SQFT	554 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	8.4 KTS	4.3 M/S	3.5 KTS	1.8 M/S
CLOUD AMOUNT 0 (CLEAR)-10	4		0	

SENSIBLE		LATENT	
(KBTU/H)	(KW)	(KBTU/H)	(KW)

SENSIBLE	
(KBTU/H)	(KW)

WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.025	0.007	0.000	0.000	-0.051	-0.015
TOTAL	0.025	0.007	0.000	0.000	-0.051	-0.015
TOTAL / AREA	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL LOAD	0.025 KBTU/H	0.007 KW	-0.051 KBTU/H	-0.015 KW		
TOTAL LOAD / AREA	0.02 BTU/H.SQFT	0.050 W/M2	0.032 BTU/H.SQFT	0.100 W/M2		

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (M.E9)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	3.0
FLOOR AREA	17220 SQFT	1600 M2	
VOLUME	153258 CUFT	4340 M3	

TIME	COOLING LOAD		HEATING LOAD	
	SEP 24 4PM		DEC 13 6AM	
DRY-BULB TEMP	86 F	30 C	42 F	6 C
WET-BULB TEMP	59 F	15 C	35 F	2 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S	3.9 KTS	2.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	14.078	4.125	0.000	0.000	-18.169	-5.324	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	46.290	13.563	0.000	0.000	-49.456	-14.491	
WINDOW GLASS SOLAR	110.241	32.301	0.000	0.000	11.107	3.254	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	33.041	9.681	32.624	9.559	0.110	0.032	
LIGHT TO SPACE	44.338	12.991	0.000	0.000	1.274	0.373	
EQUIPMENT TO SPACE	122.364	35.853	0.000	0.000	6.698	1.963	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	1.501	0.440	0.000	0.000	-5.296	-1.552	
TOTAL	371.853	108.953	32.624	9.559	-53.732	-15.743	
TOTAL / AREA	0.022	0.068	0.002	0.006	-0.003	-0.010	
TOTAL LOAD	404.478 KBTU/H	118.512 KW			-53.732 KBTU/H	-15.743 KW	
TOTAL LOAD / AREA	23.49 BTU/H.SQFT	74.080 W/M2			3.120 BTU/H.SQFT	9.841 W/M2	

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components Core Spc (M.C10)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (M.C10)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	3.0
FLOOR AREA	1600 SQFT	149 M2	
VOLUME	14240 CUFT	403 M3	

COOLING LOAD

HEATING LOAD

TIME

SEP 24 4PM

DRY-BULB TEMP	86 F	30 C
WET-BULB TEMP	59 F	15 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0	

	SENSIBLE (KBTU/H) (KW)		LATENT (KBTU/H) (KW)		SENSIBLE (KBTU/H) (KW)	
	-----	-----	-----	-----	-----	-----
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	3.092	0.906	3.249	0.952	0.000	0.000
LIGHT TO SPACE	3.634	1.065	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	4.753	1.393	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.013	0.004	0.000	0.000	0.000	0.000
TOTAL	11.493	3.367	3.249	0.952	0.000	0.000
TOTAL / AREA	0.007	0.023	0.002	0.006	0.000	0.000
TOTAL LOAD	14.742 KBTU/H		4.319 KW		0.000 KBTU/H	0.000 KW
TOTAL LOAD / AREA	9.21 BTU/H.SQFT		29.058 W/M2		0.000 BTU/H.SQFT	0.000 W/M2

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components East Perim Plnm (M.E11)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (M.E11)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER 1.0 FLOOR MULTIPLIER 3.0

FLOOR AREA	17220 SQFT	1600 M2
VOLUME	61992 CUFT	1756 M3

COOLING LOAD

=====

TIME SEP 24 6PM

DRY-BULB TEMP	80 F	27 C
WET-BULB TEMP	59 F	15 C
TOT HORIZONTAL SOLAR RAD	57 BTU/H.SQFT	179 W/M2
WINDSPEED AT SPACE	7.7 KTS	4.0 M/S
CLOUD AMOUNT 0 (CLEAR) -10	0	

HEATING LOAD

=====

DEC 12 7AM

41 F	5 C
33 F	1 C
1 BTU/H.SQFT	3 W/M2
2.1 KTS	1.1 M/S
0	

SENSIBLE		LATENT	
(KBTU/H)	(KW)	(KBTU/H)	(KW)

WALL CONDUCTION	12.456	3.650	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000
INFILTRATION	0.944	0.276	0.000	0.000

TOTAL	13.400	3.926	0.000	0.000
TOTAL / AREA	0.001	0.002	0.000	0.000

SENSIBLE	
(KBTU/H)	(KW)

-17.246	-5.053
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
0.000	0.000
-2.211	-0.648

TOTAL	-19.457	-5.701
TOTAL / AREA	-0.001	-0.004

TOTAL LOAD	13.400 KBTU/H	3.926 KW	-19.457 KBTU/H	-5.701 KW
TOTAL LOAD / AREA	0.78 BTU/H.SQFT	2.454 W/M2	1.130 BTU/H.SQFT	3.564 W/M2

```

*****
*
*   NOTE  1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
*   ----  LOADS
*
*   2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
*   IN CONSIDERATION
*
*   3)THE ABOVE LOADS ARE CALCULATED ASSUMING A
*   CONSTANT INDOOR SPACE TEMPERATURE
*
*****

```

REPORT- LS-B Space Peak Load Components Core Plnm (M.C12)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (M.C12)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	3.0
FLOOR AREA	1600 SQFT	149 M2	
VOLUME	5760 CUFT	163 M3	

TIME	COOLING LOAD		HEATING LOAD	
	APR 11 5PM		DEC 12 6AM	
DRY-BULB TEMP	85 F	29 C	40 F	4 C
WET-BULB TEMP	53 F	12 C	33 F	1 C
TOT HORIZONTAL SOLAR RAD	176 BTU/H.SQFT	554 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	8.4 KTS	4.3 M/S	3.5 KTS	1.8 M/S
CLOUD AMOUNT 0 (CLEAR)-10	4		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	0.025	0.007	0.000	0.000	-0.051	-0.015	
TOTAL	0.025	0.007	0.000	0.000	-0.051	-0.015	
TOTAL / AREA	0.000	0.000	0.000	0.000	0.000	0.000	
TOTAL LOAD	0.025 KBTU/H	0.007 KW			-0.051 KBTU/H	-0.015 KW	
TOTAL LOAD / AREA	0.02 BTU/H.SQFT	0.050 W/M2			0.032 BTU/H.SQFT	0.100 W/M2	

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

REPORT- LS-B Space Peak Load Components

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (T.E13)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	17220 SQFT	1600 M2	
VOLUME	153258 CUFT	4340 M3	

TIME	COOLING LOAD		HEATING LOAD	
	SEP 24 4PM		DEC 13 6AM	
DRY-BULB TEMP	86 F	30 C	42 F	6 C
WET-BULB TEMP	59 F	15 C	35 F	2 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S	3.9 KTS	2.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	14.078	4.125	0.000	0.000	-18.169	-5.324	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	46.290	13.563	0.000	0.000	-49.456	-14.491	
WINDOW GLASS SOLAR	110.241	32.301	0.000	0.000	11.107	3.254	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	33.041	9.681	32.624	9.559	0.110	0.032	
LIGHT TO SPACE	44.338	12.991	0.000	0.000	1.274	0.373	
EQUIPMENT TO SPACE	122.364	35.853	0.000	0.000	6.698	1.963	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	1.501	0.440	0.000	0.000	-5.296	-1.552	
TOTAL	371.853	108.953	32.624	9.559	-53.732	-15.743	
TOTAL / AREA	0.022	0.068	0.002	0.006	-0.003	-0.010	
TOTAL LOAD	404.478 KBTU/H	118.512 KW			-53.732 KBTU/H	-15.743 KW	
TOTAL LOAD / AREA	23.49 BTU/H.SQFT	74.080 W/M2			3.120 BTU/H.SQFT	9.841 W/M2	

```

*****
*
*  NOTE  1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
*  ----  LOADS
*
*        2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
*        IN CONSIDERATION
*
*        3)THE ABOVE LOADS ARE CALCULATED ASSUMING A
*        CONSTANT INDOOR SPACE TEMPERATURE
*
*****

```


REPORT- LS-B Space Peak Load Components Core Spc (T.C14)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (T.C14)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0

FLOOR AREA	1600 SQFT	149 M2
VOLUME	14240 CUFT	403 M3

COOLING LOAD

HEATING LOAD

TIME

SEP 24 4PM

DRY-BULB TEMP	86 F	30 C
WET-BULB TEMP	59 F	15 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2
WINDSPEED AT SPACE	7.9 KTS	4.0 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0	

	SENSIBLE (KBTU/H) (KW)		LATENT (KBTU/H) (KW)		SENSIBLE (KBTU/H) (KW)	
	-----	-----	-----	-----	-----	-----
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	3.092	0.906	3.249	0.952	0.000	0.000
LIGHT TO SPACE	3.634	1.065	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	4.753	1.393	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.013	0.004	0.000	0.000	0.000	0.000
TOTAL	11.493	3.367	3.249	0.952	0.000	0.000
TOTAL / AREA	0.007	0.023	0.002	0.006	0.000	0.000
TOTAL LOAD	14.742 KBTU/H		4.319 KW		0.000 KBTU/H	0.000 KW
TOTAL LOAD / AREA	9.21 BTU/H.SQFT		29.058 W/M2		0.000 BTU/H.SQFT	0.000 W/M2

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (T.E15)
SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER		1.0	FLOOR MULTIPLIER		1.0
FLOOR AREA	17220	SQFT	1600	M2	
VOLUME	61992	CUFT	1756	M3	

	COOLING LOAD		HEATING LOAD	
TIME	SEP 24	5PM	DEC 12	7AM
DRY-BULB TEMP	83 F	28 C	41 F	5 C
WET-BULB TEMP	60 F	16 C	33 F	1 C
TOT HORIZONTAL SOLAR RAD	125 BTU/H.SQFT	394 W/M2	1 BTU/H.SQFT	3 W/M2
WINDSPEED AT SPACE	8.4 KTS	4.3 M/S	2.1 KTS	1.1 M/S
CLOUD AMOUNT 0 (CLEAR) -10	0		0	

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
	-----	-----	-----	-----	-----	-----
WALL CONDUCTION	16.554	4.850	0.000	0.000	-19.666	-5.762
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	1.019	0.299	0.000	0.000	-2.211	-0.648
	-----	-----	-----	-----	-----	-----
TOTAL	17.573	5.149	0.000	0.000	-21.877	-6.410
TOTAL / AREA	0.001	0.003	0.000	0.000	-0.001	-0.004
TOTAL LOAD	17.573 KBTU/H		5.149 KW		-21.877 KBTU/H	-6.410 KW
TOTAL LOAD / AREA	1.02 BTU/H.SQFT		3.219 W/M2		1.270 BTU/H.SQFT	4.007 W/M2

```

*****
*
*   NOTE  1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
*   ----   LOADS
*           2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
*           IN CONSIDERATION
*           3)THE ABOVE LOADS ARE CALCULATED ASSUMING A
*           CONSTANT INDOOR SPACE TEMPERATURE
*
*****

```

REPORT- LS-B Space Peak Load Components Core Plnm (T.C16)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (T.C16)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	1600 SQFT	149 M2	
VOLUME	5760 CUFT	163 M3	

TIME	COOLING LOAD		HEATING LOAD	
	APR 11 5PM		DEC 12 6AM	
DRY-BULB TEMP	85 F	29 C	40 F	4 C
WET-BULB TEMP	53 F	12 C	33 F	1 C
TOT HORIZONTAL SOLAR RAD	176 BTU/H.SQFT	554 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	8.4 KTS	4.3 M/S	3.5 KTS	1.8 M/S
CLOUD AMOUNT 0 (CLEAR)-10	4		0	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	0.025	0.007	0.000	0.000	-0.051	-0.015	
TOTAL	0.025	0.007	0.000	0.000	-0.051	-0.015	
TOTAL / AREA	0.000	0.000	0.000	0.000	0.000	0.000	
TOTAL LOAD	0.025 KBTU/H	0.007 KW			-0.051 KBTU/H	-0.015 KW	
TOTAL LOAD / AREA	0.02 BTU/H.SQFT	0.050 W/M2			0.032 BTU/H.SQFT	0.100 W/M2	

```

*****
*
*   NOTE  1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
*   ----  LOADS
*
*   2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
*   IN CONSIDERATION
*
*   3)THE ABOVE LOADS ARE CALCULATED ASSUMING A
*   CONSTANT INDOOR SPACE TEMPERATURE
*
*****

```

REPORT- LS-B Space Peak Load Components Under Roof (T.15)

WEATHER FILE- Los Angeles CA TMY2

SPACE Under Roof (T.15)

SPACE TEMPERATURE USED FOR THE LOADS CALCULATION IS 70 F / 21 C

MULTIPLIER	1.0	FLOOR MULTIPLIER	1.0
FLOOR AREA	17220 SQFT	1600 M2	
VOLUME	101021 CUFT	2861 M3	

TIME	COOLING LOAD		HEATING LOAD	
	SEP 24 4PM		MAR 21 9PM	
DRY-BULB TEMP	86 F	30 C	50 F	10 C
WET-BULB TEMP	59 F	15 C	42 F	6 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT	595 W/M2	0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	10.0 KTS	5.2 M/S	18.4 KTS	9.4 M/S
CLOUD AMOUNT 0 (CLEAR)-10	0		3	

	SENSIBLE		LATENT		SENSIBLE		
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)	
WALL CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
ROOF CONDUCTION	65.540	19.203	0.000	0.000	-121.999	-35.746	
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000	
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000	
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000	
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000	
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000	
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000	
INFILTRATION	163.560	47.923	0.000	0.000	-373.568	-109.455	
TOTAL	229.100	67.126	0.000	0.000	-495.566	-145.201	
TOTAL / AREA	0.013	0.042	0.000	0.000	-0.029	-0.091	
TOTAL LOAD	229.100 KBTU/H	67.126 KW			-495.566 KBTU/H	-145.201 KW	
TOTAL LOAD / AREA	13.30 BTU/H.SQFT	41.959 W/M2			28.779 BTU/H.SQFT	90.763 W/M2	

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

* *****

REPORT- LS-C Building Peak Load Components

WEATHER FILE- Los Angeles CA TMY2

*** BUILDING ***

FLOOR AREA	112920	SQFT	10490	M2
VOLUME	1004988	CUFT	28461	M3

TIME	COOLING LOAD				HEATING LOAD	
	SEP 24 4PM				DEC 13 6AM	
DRY-BULB TEMP	86 F		30 C		42 F	6 C
WET-BULB TEMP	59 F		15 C		35 F	2 C
TOT HORIZONTAL SOLAR RAD	189 BTU/H.SQFT		595 W/M2		0 BTU/H.SQFT	0 W/M2
WINDSPEED AT SPACE	10.0 KTS		5.2 M/S		5.0 KTS	2.6 M/S
CLOUD AMOUNT 0 (CLEAR) -10	0				0	

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	187.449	54.923	0.000	0.000	-239.638	-70.214
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	232.988	68.266	0.000	0.000	-249.482	-73.098
WINDOW GLASS SOLAR	554.855	162.572	0.000	0.000	55.892	16.376
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-3.626	-1.062	0.000	0.000	-6.753	-1.979
OCCUPANTS TO SPACE	204.904	60.037	217.311	63.672	0.592	0.173
LIGHT TO SPACE	279.087	81.773	0.000	0.000	7.255	2.126
EQUIPMENT TO SPACE	657.973	192.786	0.000	0.000	34.667	10.157
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	7.573	2.219	0.000	0.000	-26.480	-7.759
TOTAL	2121.203	621.513	217.311	63.672	-423.946	-124.216
TOTAL / AREA	0.019	0.059	0.002	0.006	-0.004	-0.012
TOTAL LOAD	2338.514 KBTU/H		685.185 KW		-423.946 KBTU/H	-124.216 KW
TOTAL LOAD / AREA	20.71 BTU/H.SQFT		65.314 W/M2		3.754 BTU/H.SQFT	11.841 W/M2

* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *

* ---- LOADS *

* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *

* IN CONSIDERATION *

* 3)THE ABOVE LOADS ARE CALCULATED ASSUMING A *

* CONSTANT INDOOR SPACE TEMPERATURE *

* *****

REPORT- LS-D Building Monthly Loads Summary

WEATHER FILE- Los Angeles CA TMY2

- - - - - C O O L I N G - - - - -							- - - - - H E A T I N G - - - - -						- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)		HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	340.14282	14 15	70.F	50.F	1681.071		-61.028	18 7	50.F	41.F	-403.349	87318.	313.022		
FEB	342.53973	12 16	77.F	59.F	1818.866		-52.192	22 7	47.F	45.F	-301.564	82093.	313.022		
MAR	411.72061	31 15	75.F	53.F	1837.243		-40.099	22 6	46.F	40.F	-421.263	94305.	313.022		
APR	450.55786	8 15	74.F	54.F	1846.279		-21.066	5 6	52.F	48.F	-231.372	94010.	313.022		
MAY	452.33661	29 16	73.F	65.F	1818.298		-12.368	3 6	57.F	55.F	-110.160	87318.	313.022		
JUN	482.76962	30 16	75.F	63.F	1836.170		-6.269	6 8	61.F	57.F	-67.161	94010.	313.022		
JUL	553.37408	10 16	80.F	64.F	1890.952		-1.504	5 8	64.F	61.F	-38.595	94279.	313.022		
AUG	549.71783	13 16	75.F	68.F	1880.624		-1.077	6 5	59.F	58.F	-33.142	91112.	313.022		
SEP	516.81177	24 15	86.F	59.F	2121.203		-2.032	20 6	61.F	57.F	-84.130	90217.	313.022		
OCT	471.08505	5 15	77.F	62.F	1931.450		-7.348	25 6	60.F	56.F	-101.610	91085.	313.022		
NOV	378.80988	20 15	77.F	58.F	1842.784		-25.973	29 7	47.F	39.F	-292.486	82630.	313.022		
DEC	382.86823	18 15	72.F	54.F	1814.306		-42.552	13 6	42.F	35.F	-423.946	94279.	313.022		
TOTAL	5332.734						-273.507					1082656.			
MAX					2121.203						-423.946		313.022		

REPORT- LS-E Space Monthly Load Components East Perim Spc (B.El)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-55.094	0.000	0.000	-4.948	0.000	0.000	0.000	3.497	5.396	8.986	0.000	-42.163
	SEN CL	-4.733	0.000	0.000	-0.990	0.000	0.000	0.000	2.213	2.860	4.415	0.000	3.765
	LAT CL					0.000			3.046		0.000	0.000	3.046
FEB	HEATNG	-49.011	0.000	0.000	-4.763	0.000	0.000	0.000	3.096	4.804	7.979	0.000	-37.896
	SEN CL	-4.631	0.000	0.000	-1.089	0.000	0.000	0.000	2.329	3.002	4.594	0.000	4.205
	LAT CL					0.000			3.153		0.000	0.000	3.153
MAR	HEATNG	-39.103	0.000	0.000	-4.691	0.000	0.000	0.000	2.423	3.934	6.701	0.000	-30.735
	SEN CL	-7.459	0.000	0.000	-1.833	0.000	0.000	0.000	3.842	5.050	7.706	0.000	7.307
	LAT CL					0.000			5.249		0.000	0.000	5.249
APR	HEATNG	-23.922	0.000	0.000	-3.487	0.000	0.000	0.000	1.700	2.835	4.883	0.000	-17.991
	SEN CL	-5.636	0.000	0.000	-2.577	0.000	0.000	0.000	4.581	6.155	9.478	0.000	12.001
	LAT CL					0.000			6.250		0.000	0.000	6.250
MAY	HEATNG	-12.552	0.000	0.000	-2.400	0.000	0.000	0.000	0.552	1.168	2.400	0.000	-10.832
	SEN CL	-3.326	0.000	0.000	-2.835	0.000	0.000	0.000	5.176	7.114	11.016	0.000	17.145
	LAT CL					0.000			6.904		0.000	0.000	6.904
JUN	HEATNG	-7.138	0.000	0.000	-1.425	0.000	0.000	0.000	0.336	0.806	1.735	0.000	-5.686
	SEN CL	0.252	0.000	0.000	-2.645	0.000	0.000	0.000	5.928	8.162	12.614	0.000	24.310
	LAT CL					0.000			7.882		0.000	0.000	7.882
JUL	HEATNG	-1.698	0.000	0.000	-0.387	0.000	0.000	0.000	0.064	0.187	0.453	0.000	-1.381
	SEN CL	13.841	0.000	0.000	-2.926	0.000	0.000	0.000	6.217	8.816	13.958	0.000	39.907
	LAT CL					0.000			8.003		0.000	0.000	8.003
AUG	HEATNG	-1.689	0.000	0.000	-0.343	0.000	0.000	0.000	0.125	0.298	0.629	0.000	-0.980
	SEN CL	15.928	0.000	0.000	-2.404	0.000	0.000	0.000	5.871	8.348	13.339	0.000	41.082
	LAT CL					0.000			7.614		0.000	0.000	7.614
SEP	HEATNG	-2.414	0.000	0.000	-0.479	0.000	0.000	0.000	0.097	0.297	0.754	0.000	-1.744
	SEN CL	11.328	0.000	0.000	-2.132	0.000	0.000	0.000	5.898	8.306	13.044	0.000	36.444
	LAT CL					0.000			7.636		0.000	0.000	7.636
OCT	HEATNG	-8.341	0.000	0.000	-1.311	0.000	0.000	0.000	0.353	0.871	1.965	0.000	-6.462
	SEN CL	-3.571	0.000	0.000	-1.846	0.000	0.000	0.000	5.659	7.794	12.006	0.000	20.043
	LAT CL					0.000			7.526		0.000	0.000	7.526
NOV	HEATNG	-23.978	0.000	0.000	-2.536	0.000	0.000	0.000	1.153	2.137	3.926	0.000	-19.299
	SEN CL	-8.458	0.000	0.000	-1.358	0.000	0.000	0.000	4.254	5.672	8.738	0.000	8.847
	LAT CL					0.000			5.899		0.000	0.000	5.899
DEC	HEATNG	-41.660	0.000	0.000	-3.672	0.000	0.000	0.000	2.840	4.455	7.413	0.000	-30.623
	SEN CL	-7.424	0.000	0.000	-1.350	0.000	0.000	0.000	3.440	4.547	6.998	0.000	6.211
	LAT CL					0.000			4.721		0.000	0.000	4.721
TOT	HEATNG	-266.600	0.000	0.000	-30.442	0.000	0.000	0.000	16.237	27.189	47.824	0.000	-205.792
	SEN CL	-3.889	0.000	0.000	-23.984	0.000	0.000	0.000	55.409	75.827	117.907	0.000	221.269
	LAT CL					0.000			73.882		0.000	0.000	73.882

REPORT- LS-E Space Monthly Load Components Core Spc (B.C2)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-5.258	0.000	0.000	0.000	0.000	0.000	0.000	0.283	0.452	0.741	0.000	-3.782
	SEN CL	-0.703	0.000	0.000	0.000	0.000	0.000	0.000	0.294	0.378	0.542	0.000	0.511
	LAT CL					0.000			0.357		0.000	0.000	0.357
FEB	HEATNG	-4.756	0.000	0.000	0.000	0.000	0.000	0.000	0.266	0.424	0.689	0.000	-3.376
	SEN CL	-0.590	0.000	0.000	0.000	0.000	0.000	0.000	0.282	0.360	0.515	0.000	0.566
	LAT CL					0.000			0.338		0.000	0.000	0.338
MAR	HEATNG	-3.587	0.000	0.000	0.000	0.000	0.000	0.000	0.151	0.269	0.476	0.000	-2.692
	SEN CL	-1.042	0.000	0.000	0.000	0.000	0.000	0.000	0.483	0.635	0.904	0.000	0.981
	LAT CL					0.000			0.586		0.000	0.000	0.586
APR	HEATNG	-2.278	0.000	0.000	0.000	0.000	0.000	0.000	0.124	0.221	0.392	0.000	-1.542
	SEN CL	-0.673	0.000	0.000	0.000	0.000	0.000	0.000	0.510	0.683	0.983	0.000	1.503
	LAT CL					0.000			0.616		0.000	0.000	0.616
MAY	HEATNG	-1.237	0.000	0.000	0.000	0.000	0.000	0.000	0.032	0.085	0.195	0.000	-0.925
	SEN CL	-0.338	0.000	0.000	0.000	0.000	0.000	0.000	0.545	0.746	1.089	0.000	2.043
	LAT CL					0.000			0.653		0.000	0.000	0.653
JUN	HEATNG	-0.720	0.000	0.000	0.000	0.000	0.000	0.000	0.018	0.059	0.144	0.000	-0.498
	SEN CL	0.036	0.000	0.000	0.000	0.000	0.000	0.000	0.616	0.844	1.230	0.000	2.726
	LAT CL					0.000			0.735		0.000	0.000	0.735
JUL	HEATNG	-0.180	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.014	0.039	0.000	-0.123
	SEN CL	1.389	0.000	0.000	0.000	0.000	0.000	0.000	0.631	0.890	1.341	0.000	4.251
	LAT CL					0.000			0.744		0.000	0.000	0.744
AUG	HEATNG	-0.184	0.000	0.000	0.000	0.000	0.000	0.000	0.007	0.023	0.056	0.000	-0.097
	SEN CL	1.602	0.000	0.000	0.000	0.000	0.000	0.000	0.598	0.846	1.281	0.000	4.327
	LAT CL					0.000			0.707		0.000	0.000	0.707
SEP	HEATNG	-0.253	0.000	0.000	0.000	0.000	0.000	0.000	0.005	0.023	0.066	0.000	-0.159
	SEN CL	1.138	0.000	0.000	0.000	0.000	0.000	0.000	0.600	0.842	1.255	0.000	3.835
	LAT CL					0.000			0.709		0.000	0.000	0.709
OCT	HEATNG	-0.841	0.000	0.000	0.000	0.000	0.000	0.000	0.020	0.067	0.172	0.000	-0.582
	SEN CL	-0.345	0.000	0.000	0.000	0.000	0.000	0.000	0.586	0.803	1.166	0.000	2.209
	LAT CL					0.000			0.700		0.000	0.000	0.700
NOV	HEATNG	-2.318	0.000	0.000	0.000	0.000	0.000	0.000	0.077	0.161	0.318	0.000	-1.763
	SEN CL	-0.919	0.000	0.000	0.000	0.000	0.000	0.000	0.470	0.625	0.895	0.000	1.072
	LAT CL					0.000			0.573		0.000	0.000	0.573
DEC	HEATNG	-4.007	0.000	0.000	0.000	0.000	0.000	0.000	0.233	0.376	0.623	0.000	-2.775
	SEN CL	-0.882	0.000	0.000	0.000	0.000	0.000	0.000	0.401	0.529	0.757	0.000	0.804
	LAT CL					0.000			0.486		0.000	0.000	0.486
TOT	HEATNG	-25.620	0.000	0.000	0.000	0.000	0.000	0.000	1.220	2.175	3.912	0.000	-18.312
	SEN CL	-1.328	0.000	0.000	0.000	0.000	0.000	0.000	6.016	8.181	11.958	0.000	24.827
	LAT CL					0.000			7.204		0.000	0.000	7.204

REPORT- LS-E Space Monthly Load Components East Perim Plnm (B.E3)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	-4.143	-0.799	0.000	0.000	0.000	0.000	0.000	0.000	-4.942
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	0.000	0.000	0.000	-4.080	-0.729	0.000	0.000	0.000	0.000	0.000	0.000	-4.809
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	0.000	0.000	0.000	-4.552	-0.674	0.000	0.000	0.000	0.000	0.000	0.000	-5.226
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	0.000	0.000	0.000	-4.233	-0.558	0.000	0.000	0.000	0.000	0.000	0.000	-4.791
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAY	HEATNG	0.000	0.000	0.000	-3.659	-0.429	0.000	0.000	0.000	0.000	0.000	0.000	-4.087
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
JUN	HEATNG	0.000	0.000	0.000	-2.846	-0.349	0.000	0.000	0.000	0.000	0.000	0.000	-3.195
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
JUL	HEATNG	0.000	0.000	0.000	-2.317	-0.141	0.000	0.000	0.000	0.000	0.000	0.000	-2.458
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
AUG	HEATNG	0.000	0.000	0.000	-1.920	-0.114	0.000	0.000	0.000	0.000	0.000	0.000	-2.034
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
SEP	HEATNG	0.000	0.000	0.000	-1.822	-0.118	0.000	0.000	0.000	0.000	0.000	0.000	-1.940
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
OCT	HEATNG	0.000	0.000	0.000	-2.200	-0.311	0.000	0.000	0.000	0.000	0.000	0.000	-2.511
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
NOV	HEATNG	0.000	0.000	0.000	-2.713	-0.517	0.000	0.000	0.000	0.000	0.000	0.000	-3.230
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
DEC	HEATNG	0.000	0.000	0.000	-3.499	-0.694	0.000	0.000	0.000	0.000	0.000	0.000	-4.193
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	0.000	0.000	0.000	-37.985	-5.434	0.000	0.000	0.000	0.000	0.000	0.000	-43.419
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000

REPORT- LS-E Space Monthly Load Components Core Plnm (B.C4)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.000	0.000	0.000	0.000	-0.015
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.000	0.000	0.000	0.000	-0.014
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAY	HEATNG	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.000	0.000	0.000	0.000	-0.008
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.001			0.000		0.000	0.000	0.001
JUN	HEATNG	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.000	0.000	0.000	0.000	-0.007
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
JUL	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
AUG	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.004			0.000		0.000	0.000	0.004
SEP	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
OCT	HEATNG	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	-0.006
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
NOV	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
DEC	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	0.000	0.000	0.000	0.000	-0.109	0.000	0.000	0.000	0.000	0.000	0.000	-0.109
	SEN CL	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004
	LAT CL					0.009			0.000		0.000	0.000	0.009

REPORT- LS-E Space Monthly Load Components East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-2.504	0.000	0.000	0.000	-0.792	-7.357	2.668	0.359	1.064	2.924	0.000	-3.638
	SEN CL	-3.836	0.000	0.000	0.000	-1.184	-7.281	25.749	7.383	12.935	25.655	0.000	59.421
	LAT CL					0.019			7.159		0.000	0.000	7.178
FEB	HEATNG	-1.981	0.000	0.000	0.000	-0.633	-5.706	2.500	0.252	0.771	2.156	0.000	-2.641
	SEN CL	-3.612	0.000	0.000	0.000	-1.169	-6.991	27.775	7.105	12.468	24.664	0.000	60.239
	LAT CL					0.013			6.808		0.000	0.000	6.821
MAR	HEATNG	-1.128	0.000	0.000	0.000	-0.349	-3.299	1.497	0.106	0.389	1.205	0.000	-1.579
	SEN CL	-3.950	0.000	0.000	0.000	-1.319	-7.579	32.201	8.380	14.833	29.519	0.000	72.086
	LAT CL					0.127			7.910		0.000	0.000	8.037
APR	HEATNG	-0.570	0.000	0.000	0.000	-0.175	-1.581	0.898	0.071	0.237	0.691	0.000	-0.429
	SEN CL	-3.100	0.000	0.000	0.000	-1.204	-5.701	35.452	8.447	15.011	29.947	0.000	78.851
	LAT CL					0.205			7.919		0.000	0.000	8.123
MAY	HEATNG	-0.238	0.000	0.000	0.000	-0.078	-0.676	0.500	0.011	0.070	0.250	0.000	-0.161
	SEN CL	-2.168	0.000	0.000	0.000	-0.982	-3.423	35.114	7.766	13.993	28.386	0.000	78.686
	LAT CL					0.632			7.201		0.000	0.000	7.833
JUN	HEATNG	-0.065	0.000	0.000	0.000	-0.021	-0.177	0.161	0.001	0.015	0.059	0.000	-0.027
	SEN CL	-1.560	0.000	0.000	0.000	-0.841	-2.078	32.823	8.483	15.176	30.536	0.000	82.539
	LAT CL					1.026			7.923		0.000	0.000	8.949
JUL	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.232	0.000	0.000	0.000	-0.349	2.261	36.703	8.518	15.268	30.744	0.000	93.378
	LAT CL					1.581			7.923		0.000	0.000	9.504
AUG	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.509	0.000	0.000	0.000	-0.281	2.953	36.956	8.132	14.665	29.795	0.000	92.730
	LAT CL					1.864			7.563		0.000	0.000	9.427
SEP	HEATNG	-0.031	0.000	0.000	0.000	-0.010	-0.091	0.056	0.001	0.009	0.033	0.000	-0.033
	SEN CL	0.282	0.000	0.000	0.000	-0.282	2.285	32.769	8.129	14.580	29.401	0.000	87.164
	LAT CL					1.333			7.563		0.000	0.000	8.896
OCT	HEATNG	-0.121	0.000	0.000	0.000	-0.043	-0.376	0.254	0.007	0.043	0.150	0.000	-0.087
	SEN CL	-1.399	0.000	0.000	0.000	-0.727	-1.745	32.819	8.156	14.667	29.667	0.000	81.438
	LAT CL					1.059			7.562		0.000	0.000	8.621
NOV	HEATNG	-0.913	0.000	0.000	0.000	-0.313	-2.791	1.367	0.070	0.311	1.074	0.000	-1.196
	SEN CL	-2.628	0.000	0.000	0.000	-0.966	-4.676	28.471	7.251	12.917	25.925	0.000	66.294
	LAT CL					0.384			6.837		0.000	0.000	7.221
DEC	HEATNG	-1.666	0.000	0.000	0.000	-0.562	-5.040	1.959	0.253	0.750	2.048	0.000	-2.259
	SEN CL	-3.588	0.000	0.000	0.000	-1.155	-6.825	26.707	8.264	14.515	28.695	0.000	66.613
	LAT CL					0.130			7.894		0.000	0.000	8.024
TOT	HEATNG	-9.218	0.000	0.000	0.000	-2.976	-27.095	11.860	1.131	3.659	10.588	0.000	-12.050
	SEN CL	-24.819	0.000	0.000	0.000	-10.458	-38.799	383.540	96.014	171.027	342.931	0.000	919.436
	LAT CL					8.374			90.259		0.000	0.000	98.633

REPORT- LS-E Space Monthly Load Components Core Spc (G.C6)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.224	1.954	0.999	0.000	3.162
	LAT CL					0.000			0.224		0.000	0.000	0.224
FEB	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.213	1.848	0.937	0.000	2.984
	LAT CL					0.000			0.213		0.000	0.000	0.213
MAR	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.246	2.125	1.073	0.000	3.432
	LAT CL					0.001			0.246		0.000	0.000	0.247
APR	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.246	2.128	1.070	0.000	3.434
	LAT CL					0.002			0.246		0.000	0.000	0.248
MAY	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.225	1.961	1.001	0.000	3.179
	LAT CL					0.005			0.224		0.000	0.000	0.229
JUN	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.245	2.121	1.069	0.000	3.429
	LAT CL					0.007			0.246		0.000	0.000	0.254
JUL	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.246	2.131	1.074	0.000	3.448
	LAT CL					0.011			0.246		0.000	0.000	0.258
AUG	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.235	2.047	1.041	0.000	3.321
	LAT CL					0.013			0.235		0.000	0.000	0.248
SEP	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.235	2.036	1.028	0.000	3.297
	LAT CL					0.010			0.235		0.000	0.000	0.245
OCT	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.236	2.052	1.042	0.000	3.324
	LAT CL					0.008			0.235		0.000	0.000	0.243
NOV	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.212	1.847	0.944	0.000	2.993
	LAT CL					0.003			0.213		0.000	0.000	0.216
DEC	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.246	2.131	1.074	0.000	3.438
	LAT CL					0.001			0.246		0.000	0.000	0.247
TOT	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.104	0.000	0.000	2.809	24.381	12.353	0.000	39.439
	LAT CL					0.061			2.810		0.000	0.000	2.871

REPORT- LS-E Space Monthly Load Components East Perim Plnm (G.E7)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-6.426	0.000	0.000	0.000	-0.801	0.000	0.000	0.000	0.000	0.000	0.000	-7.227
	SEN CL	0.052	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.053
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	-5.692	0.000	0.000	0.000	-0.725	0.000	0.000	0.000	0.000	0.000	0.000	-6.418
	SEN CL	0.064	0.000	0.000	0.000	-0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.061
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	-5.229	0.000	0.000	0.000	-0.670	0.000	0.000	0.000	0.000	0.000	0.000	-5.899
	SEN CL	0.060	0.000	0.000	0.000	-0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.055
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	-3.862	0.000	0.000	0.000	-0.553	0.000	0.000	0.000	0.000	0.000	0.000	-4.415
	SEN CL	0.162	0.000	0.000	0.000	-0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.157
	LAT CL					0.005			0.000		0.000	0.000	0.005
MAY	HEATNG	-2.731	0.000	0.000	0.000	-0.418	0.000	0.000	0.000	0.000	0.000	0.000	-3.149
	SEN CL	0.223	0.000	0.000	0.000	-0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.212
	LAT CL					0.070			0.000		0.000	0.000	0.070
JUN	HEATNG	-1.961	0.000	0.000	0.000	-0.326	0.000	0.000	0.000	0.000	0.000	0.000	-2.288
	SEN CL	0.272	0.000	0.000	0.000	-0.023	0.000	0.000	0.000	0.000	0.000	0.000	0.249
	LAT CL					0.105			0.000		0.000	0.000	0.105
JUL	HEATNG	-0.796	0.000	0.000	0.000	-0.136	0.000	0.000	0.000	0.000	0.000	0.000	-0.932
	SEN CL	0.965	0.000	0.000	0.000	-0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.961
	LAT CL					0.314			0.000		0.000	0.000	0.314
AUG	HEATNG	-0.777	0.000	0.000	0.000	-0.126	0.000	0.000	0.000	0.000	0.000	0.000	-0.903
	SEN CL	1.229	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000	0.000	1.241
	LAT CL					0.416			0.000		0.000	0.000	0.416
SEP	HEATNG	-0.850	0.000	0.000	0.000	-0.138	0.000	0.000	0.000	0.000	0.000	0.000	-0.988
	SEN CL	1.054	0.000	0.000	0.000	0.020	0.000	0.000	0.000	0.000	0.000	0.000	1.074
	LAT CL					0.244			0.000		0.000	0.000	0.244
OCT	HEATNG	-1.893	0.000	0.000	0.000	-0.283	0.000	0.000	0.000	0.000	0.000	0.000	-2.176
	SEN CL	0.316	0.000	0.000	0.000	-0.028	0.000	0.000	0.000	0.000	0.000	0.000	0.288
	LAT CL					0.108			0.000		0.000	0.000	0.108
NOV	HEATNG	-3.669	0.000	0.000	0.000	-0.514	0.000	0.000	0.000	0.000	0.000	0.000	-4.183
	SEN CL	0.116	0.000	0.000	0.000	-0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.112
	LAT CL					0.008			0.000		0.000	0.000	0.008
DEC	HEATNG	-5.393	0.000	0.000	0.000	-0.688	0.000	0.000	0.000	0.000	0.000	0.000	-6.081
	SEN CL	0.097	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.091
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	-39.279	0.000	0.000	0.000	-5.379	0.000	0.000	0.000	0.000	0.000	0.000	-44.657
	SEN CL	4.610	0.000	0.000	0.000	-0.056	0.000	0.000	0.000	0.000	0.000	0.000	4.554
	LAT CL					1.270			0.000		0.000	0.000	1.270

REPORT- LS-E Space Monthly Load Components Core Plnm (G.C8)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.000	0.000	0.000	0.000	-0.015
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.000	0.000	0.000	0.000	-0.014
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAY	HEATNG	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.000	0.000	0.000	0.000	-0.008
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.001			0.000		0.000	0.000	0.001
JUN	HEATNG	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.000	0.000	0.000	0.000	-0.007
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
JUL	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
AUG	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.004			0.000		0.000	0.000	0.004
SEP	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
OCT	HEATNG	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	-0.006
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
NOV	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
DEC	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	0.000	0.000	0.000	0.000	-0.109	0.000	0.000	0.000	0.000	0.000	0.000	-0.109
	SEN CL	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004
	LAT CL					0.009			0.000		0.000	0.000	0.009

REPORT- LS-E Space Monthly Load Components East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-2.292	0.000	0.000	0.000	-0.698	-6.209	2.239	0.272	0.773	3.055	0.000	-2.861
	SEN CL	-4.249	0.000	0.000	0.000	-1.278	-7.631	25.267	7.691	12.111	33.238	0.000	65.150
	LAT CL					0.019			6.774		0.000	0.000	6.793
FEB	HEATNG	-1.828	0.000	0.000	0.000	-0.560	-4.829	2.131	0.192	0.560	2.264	0.000	-2.070
	SEN CL	-3.942	0.000	0.000	0.000	-1.242	-7.144	27.175	7.375	11.625	31.798	0.000	65.644
	LAT CL					0.013			6.458		0.000	0.000	6.471
MAR	HEATNG	-0.933	0.000	0.000	0.000	-0.276	-2.530	1.168	0.053	0.218	1.026	0.000	-1.273
	SEN CL	-4.306	0.000	0.000	0.000	-1.392	-7.683	31.455	8.675	13.791	37.997	0.000	78.537
	LAT CL					0.132			7.483		0.000	0.000	7.615
APR	HEATNG	-0.432	0.000	0.000	0.000	-0.128	-1.095	0.643	0.044	0.138	0.554	0.000	-0.276
	SEN CL	-3.354	0.000	0.000	0.000	-1.251	-5.665	34.546	8.717	13.895	38.360	0.000	85.248
	LAT CL					0.207			7.483		0.000	0.000	7.690
MAY	HEATNG	-0.154	0.000	0.000	0.000	-0.048	-0.391	0.314	0.002	0.026	0.139	0.000	-0.113
	SEN CL	-2.328	0.000	0.000	0.000	-1.012	-3.328	34.161	7.997	12.917	36.227	0.000	84.633
	LAT CL					0.639			6.806		0.000	0.000	7.445
JUN	HEATNG	-0.044	0.000	0.000	0.000	-0.014	-0.111	0.098	0.001	0.009	0.047	0.000	-0.014
	SEN CL	-1.632	0.000	0.000	0.000	-0.849	-1.859	31.832	8.725	13.973	38.813	0.000	89.002
	LAT CL					1.033			7.487		0.000	0.000	8.520
JUL	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.239	0.000	0.000	0.000	-0.349	2.357	35.530	8.761	14.052	39.049	0.000	99.640
	LAT CL					1.581			7.487		0.000	0.000	9.068
AUG	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.525	0.000	0.000	0.000	-0.281	3.013	35.776	8.364	13.497	37.840	0.000	98.734
	LAT CL					1.864			7.146		0.000	0.000	9.011
SEP	HEATNG	-0.028	0.000	0.000	0.000	-0.008	-0.072	0.043	0.001	0.007	0.034	0.000	-0.024
	SEN CL	0.286	0.000	0.000	0.000	-0.284	2.342	31.735	8.361	13.421	37.350	0.000	93.212
	LAT CL					1.334			7.146		0.000	0.000	8.481
OCT	HEATNG	-0.078	0.000	0.000	0.000	-0.026	-0.219	0.153	0.001	0.018	0.097	0.000	-0.054
	SEN CL	-1.490	0.000	0.000	0.000	-0.743	-1.630	31.863	8.395	13.521	37.770	0.000	87.685
	LAT CL					1.066			7.146		0.000	0.000	8.212
NOV	HEATNG	-0.760	0.000	0.000	0.000	-0.250	-2.127	1.046	0.036	0.183	0.943	0.000	-0.929
	SEN CL	-2.893	0.000	0.000	0.000	-1.029	-4.843	27.836	7.494	11.991	33.344	0.000	71.899
	LAT CL					0.395			6.463		0.000	0.000	6.858
DEC	HEATNG	-1.472	0.000	0.000	0.000	-0.480	-4.130	1.633	0.183	0.515	2.027	0.000	-1.724
	SEN CL	-3.949	0.000	0.000	0.000	-1.236	-7.055	26.112	8.576	13.535	37.019	0.000	73.003
	LAT CL					0.133			7.479		0.000	0.000	7.612
TOT	HEATNG	-8.021	0.000	0.000	0.000	-2.488	-21.714	9.468	0.784	2.446	10.187	0.000	-9.338
	SEN CL	-27.094	0.000	0.000	0.000	-10.946	-39.127	373.289	99.131	158.326	438.806	0.000	992.385
	LAT CL					8.416			85.359		0.000	0.000	93.775

REPORT- LS-E Space Monthly Load Components Core Spc (M.C10)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.733	1.042	1.412	0.000	3.171
	LAT CL					0.000			0.678		0.000	0.000	0.678
FEB	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.696	0.986	1.325	0.000	2.992
	LAT CL					0.000			0.644		0.000	0.000	0.644
MAR	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.803	1.134	1.518	0.000	3.442
	LAT CL					0.001			0.746		0.000	0.000	0.747
APR	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.806	1.135	1.513	0.000	3.444
	LAT CL					0.002			0.746		0.000	0.000	0.747
MAY	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.735	1.046	1.414	0.000	3.188
	LAT CL					0.005			0.678		0.000	0.000	0.683
JUN	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.803	1.131	1.511	0.000	3.439
	LAT CL					0.007			0.746		0.000	0.000	0.753
JUL	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.806	1.137	1.519	0.000	3.458
	LAT CL					0.011			0.746		0.000	0.000	0.757
AUG	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.769	1.092	1.472	0.000	3.330
	LAT CL					0.013			0.712		0.000	0.000	0.725
SEP	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.769	1.086	1.454	0.000	3.306
	LAT CL					0.010			0.712		0.000	0.000	0.722
OCT	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.772	1.094	1.473	0.000	3.333
	LAT CL					0.008			0.712		0.000	0.000	0.720
NOV	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.693	0.985	1.334	0.000	3.002
	LAT CL					0.003			0.644		0.000	0.000	0.647
DEC	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.806	1.136	1.518	0.000	3.448
	LAT CL					0.001			0.746		0.000	0.000	0.747
TOT	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.104	0.000	0.000	9.192	13.004	17.462	0.000	39.554
	LAT CL					0.061			8.507		0.000	0.000	8.569

REPORT- LS-E Space Monthly Load Components East Perim Plnm (M.E11)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-6.426	0.000	0.000	0.000	-0.801	0.000	0.000	0.000	0.000	0.000	0.000	-7.227
	SEN CL	0.052	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.053
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	-5.692	0.000	0.000	0.000	-0.725	0.000	0.000	0.000	0.000	0.000	0.000	-6.418
	SEN CL	0.064	0.000	0.000	0.000	-0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.061
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	-5.229	0.000	0.000	0.000	-0.670	0.000	0.000	0.000	0.000	0.000	0.000	-5.899
	SEN CL	0.060	0.000	0.000	0.000	-0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.055
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	-3.862	0.000	0.000	0.000	-0.553	0.000	0.000	0.000	0.000	0.000	0.000	-4.415
	SEN CL	0.162	0.000	0.000	0.000	-0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.157
	LAT CL					0.005			0.000		0.000	0.000	0.005
MAY	HEATNG	-2.731	0.000	0.000	0.000	-0.418	0.000	0.000	0.000	0.000	0.000	0.000	-3.149
	SEN CL	0.223	0.000	0.000	0.000	-0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.212
	LAT CL					0.070			0.000		0.000	0.000	0.070
JUN	HEATNG	-1.961	0.000	0.000	0.000	-0.326	0.000	0.000	0.000	0.000	0.000	0.000	-2.288
	SEN CL	0.272	0.000	0.000	0.000	-0.023	0.000	0.000	0.000	0.000	0.000	0.000	0.249
	LAT CL					0.105			0.000		0.000	0.000	0.105
JUL	HEATNG	-0.796	0.000	0.000	0.000	-0.136	0.000	0.000	0.000	0.000	0.000	0.000	-0.932
	SEN CL	0.965	0.000	0.000	0.000	-0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.961
	LAT CL					0.314			0.000		0.000	0.000	0.314
AUG	HEATNG	-0.777	0.000	0.000	0.000	-0.126	0.000	0.000	0.000	0.000	0.000	0.000	-0.903
	SEN CL	1.229	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000	0.000	1.241
	LAT CL					0.416			0.000		0.000	0.000	0.416
SEP	HEATNG	-0.850	0.000	0.000	0.000	-0.138	0.000	0.000	0.000	0.000	0.000	0.000	-0.988
	SEN CL	1.054	0.000	0.000	0.000	0.020	0.000	0.000	0.000	0.000	0.000	0.000	1.074
	LAT CL					0.244			0.000		0.000	0.000	0.244
OCT	HEATNG	-1.893	0.000	0.000	0.000	-0.283	0.000	0.000	0.000	0.000	0.000	0.000	-2.176
	SEN CL	0.316	0.000	0.000	0.000	-0.028	0.000	0.000	0.000	0.000	0.000	0.000	0.288
	LAT CL					0.108			0.000		0.000	0.000	0.108
NOV	HEATNG	-3.669	0.000	0.000	0.000	-0.514	0.000	0.000	0.000	0.000	0.000	0.000	-4.183
	SEN CL	0.116	0.000	0.000	0.000	-0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.112
	LAT CL					0.008			0.000		0.000	0.000	0.008
DEC	HEATNG	-5.393	0.000	0.000	0.000	-0.688	0.000	0.000	0.000	0.000	0.000	0.000	-6.081
	SEN CL	0.097	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.091
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	-39.279	0.000	0.000	0.000	-5.379	0.000	0.000	0.000	0.000	0.000	0.000	-44.657
	SEN CL	4.610	0.000	0.000	0.000	-0.056	0.000	0.000	0.000	0.000	0.000	0.000	4.554
	LAT CL					1.270			0.000		0.000	0.000	1.270

REPORT- LS-E Space Monthly Load Components Core Plnm (M.C12)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.000	0.000	0.000	0.000	-0.015
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.000	0.000	0.000	0.000	-0.014
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAY	HEATNG	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.000	0.000	0.000	0.000	-0.008
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.001			0.000		0.000	0.000	0.001
JUN	HEATNG	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.000	0.000	0.000	0.000	-0.007
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
JUL	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
AUG	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.004			0.000		0.000	0.000	0.004
SEP	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
OCT	HEATNG	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	-0.006
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
NOV	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
DEC	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	0.000	0.000	0.000	0.000	-0.109	0.000	0.000	0.000	0.000	0.000	0.000	-0.109
	SEN CL	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004
	LAT CL					0.009			0.000		0.000	0.000	0.009

REPORT- LS-E Space Monthly Load Components East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-2.292	0.000	0.000	0.000	-0.698	-6.209	2.239	0.272	0.773	3.055	0.000	-2.861
	SEN CL	-4.249	0.000	0.000	0.000	-1.278	-7.631	25.267	7.691	12.111	33.238	0.000	65.150
	LAT CL					0.019			6.774		0.000	0.000	6.793
FEB	HEATNG	-1.828	0.000	0.000	0.000	-0.560	-4.829	2.131	0.192	0.560	2.264	0.000	-2.070
	SEN CL	-3.942	0.000	0.000	0.000	-1.242	-7.144	27.175	7.375	11.625	31.798	0.000	65.644
	LAT CL					0.013			6.458		0.000	0.000	6.471
MAR	HEATNG	-0.933	0.000	0.000	0.000	-0.276	-2.530	1.168	0.053	0.218	1.026	0.000	-1.273
	SEN CL	-4.306	0.000	0.000	0.000	-1.392	-7.683	31.455	8.675	13.791	37.997	0.000	78.537
	LAT CL					0.132			7.483		0.000	0.000	7.615
APR	HEATNG	-0.432	0.000	0.000	0.000	-0.128	-1.095	0.643	0.044	0.138	0.554	0.000	-0.276
	SEN CL	-3.354	0.000	0.000	0.000	-1.251	-5.665	34.546	8.717	13.895	38.360	0.000	85.248
	LAT CL					0.207			7.483		0.000	0.000	7.690
MAY	HEATNG	-0.154	0.000	0.000	0.000	-0.048	-0.391	0.314	0.002	0.026	0.139	0.000	-0.113
	SEN CL	-2.328	0.000	0.000	0.000	-1.012	-3.328	34.161	7.997	12.917	36.227	0.000	84.633
	LAT CL					0.639			6.806		0.000	0.000	7.445
JUN	HEATNG	-0.044	0.000	0.000	0.000	-0.014	-0.111	0.098	0.001	0.009	0.047	0.000	-0.014
	SEN CL	-1.632	0.000	0.000	0.000	-0.849	-1.859	31.832	8.725	13.973	38.813	0.000	89.002
	LAT CL					1.033			7.487		0.000	0.000	8.520
JUL	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.239	0.000	0.000	0.000	-0.349	2.357	35.530	8.761	14.052	39.049	0.000	99.640
	LAT CL					1.581			7.487		0.000	0.000	9.068
AUG	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.525	0.000	0.000	0.000	-0.281	3.013	35.776	8.364	13.497	37.840	0.000	98.734
	LAT CL					1.864			7.146		0.000	0.000	9.011
SEP	HEATNG	-0.028	0.000	0.000	0.000	-0.008	-0.072	0.043	0.001	0.007	0.034	0.000	-0.024
	SEN CL	0.286	0.000	0.000	0.000	-0.284	2.342	31.735	8.361	13.421	37.350	0.000	93.212
	LAT CL					1.334			7.146		0.000	0.000	8.481
OCT	HEATNG	-0.078	0.000	0.000	0.000	-0.026	-0.219	0.153	0.001	0.018	0.097	0.000	-0.054
	SEN CL	-1.490	0.000	0.000	0.000	-0.743	-1.630	31.863	8.395	13.521	37.770	0.000	87.685
	LAT CL					1.066			7.146		0.000	0.000	8.212
NOV	HEATNG	-0.760	0.000	0.000	0.000	-0.250	-2.127	1.046	0.036	0.183	0.943	0.000	-0.929
	SEN CL	-2.893	0.000	0.000	0.000	-1.029	-4.843	27.836	7.494	11.991	33.344	0.000	71.899
	LAT CL					0.395			6.463		0.000	0.000	6.858
DEC	HEATNG	-1.472	0.000	0.000	0.000	-0.480	-4.130	1.633	0.183	0.515	2.027	0.000	-1.724
	SEN CL	-3.949	0.000	0.000	0.000	-1.236	-7.055	26.112	8.576	13.535	37.019	0.000	73.003
	LAT CL					0.133			7.479		0.000	0.000	7.612
TOT	HEATNG	-8.021	0.000	0.000	0.000	-2.488	-21.714	9.468	0.784	2.446	10.187	0.000	-9.338
	SEN CL	-27.094	0.000	0.000	0.000	-10.946	-39.127	373.289	99.131	158.326	438.806	0.000	992.385
	LAT CL					8.416			85.359		0.000	0.000	93.775

REPORT- LS-E Space Monthly Load Components Core Spc (T.C14)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.733	1.042	1.412	0.000	3.171
	LAT CL					0.000			0.678		0.000	0.000	0.678
FEB	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.696	0.986	1.325	0.000	2.992
	LAT CL					0.000			0.644		0.000	0.000	0.644
MAR	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.803	1.134	1.518	0.000	3.442
	LAT CL					0.001			0.746		0.000	0.000	0.747
APR	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.806	1.135	1.513	0.000	3.444
	LAT CL					0.002			0.746		0.000	0.000	0.747
MAY	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.735	1.046	1.414	0.000	3.188
	LAT CL					0.005			0.678		0.000	0.000	0.683
JUN	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.803	1.131	1.511	0.000	3.439
	LAT CL					0.007			0.746		0.000	0.000	0.753
JUL	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.806	1.137	1.519	0.000	3.458
	LAT CL					0.011			0.746		0.000	0.000	0.757
AUG	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.769	1.092	1.472	0.000	3.330
	LAT CL					0.013			0.712		0.000	0.000	0.725
SEP	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.003	0.000	0.000	0.769	1.086	1.454	0.000	3.306
	LAT CL					0.010			0.712		0.000	0.000	0.722
OCT	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.772	1.094	1.473	0.000	3.333
	LAT CL					0.008			0.712		0.000	0.000	0.720
NOV	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.693	0.985	1.334	0.000	3.002
	LAT CL					0.003			0.644		0.000	0.000	0.647
DEC	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.806	1.136	1.518	0.000	3.448
	LAT CL					0.001			0.746		0.000	0.000	0.747
TOT	HEATNG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	SEN CL	0.000	0.000	0.000	0.000	-0.104	0.000	0.000	9.192	13.004	17.462	0.000	39.554
	LAT CL					0.061			8.507		0.000	0.000	8.569

REPORT- LS-E Space Monthly Load Components East Perim Plnm (T.E15)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-6.535	0.000	0.000	0.000	-0.791	0.000	0.000	0.000	0.000	0.000	0.000	-7.326
	SEN CL	0.161	0.000	0.000	0.000	-0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.152
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	-5.792	0.000	0.000	0.000	-0.723	0.000	0.000	0.000	0.000	0.000	0.000	-6.515
	SEN CL	0.153	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.148
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	-5.297	0.000	0.000	0.000	-0.659	0.000	0.000	0.000	0.000	0.000	0.000	-5.956
	SEN CL	0.194	0.000	0.000	0.000	-0.015	0.000	0.000	0.000	0.000	0.000	0.000	0.179
	LAT CL					0.002			0.000		0.000	0.000	0.002
APR	HEATNG	-4.093	0.000	0.000	0.000	-0.539	0.000	0.000	0.000	0.000	0.000	0.000	-4.632
	SEN CL	0.353	0.000	0.000	0.000	-0.019	0.000	0.000	0.000	0.000	0.000	0.000	0.334
	LAT CL					0.010			0.000		0.000	0.000	0.010
MAY	HEATNG	-2.946	0.000	0.000	0.000	-0.387	0.000	0.000	0.000	0.000	0.000	0.000	-3.333
	SEN CL	0.493	0.000	0.000	0.000	-0.042	0.000	0.000	0.000	0.000	0.000	0.000	0.451
	LAT CL					0.093			0.000		0.000	0.000	0.093
JUN	HEATNG	-2.250	0.000	0.000	0.000	-0.300	0.000	0.000	0.000	0.000	0.000	0.000	-2.549
	SEN CL	0.568	0.000	0.000	0.000	-0.050	0.000	0.000	0.000	0.000	0.000	0.000	0.519
	LAT CL					0.142			0.000		0.000	0.000	0.142
JUL	HEATNG	-1.188	0.000	0.000	0.000	-0.134	0.000	0.000	0.000	0.000	0.000	0.000	-1.323
	SEN CL	1.355	0.000	0.000	0.000	-0.007	0.000	0.000	0.000	0.000	0.000	0.000	1.348
	LAT CL					0.314			0.000		0.000	0.000	0.314
AUG	HEATNG	-1.212	0.000	0.000	0.000	-0.125	0.000	0.000	0.000	0.000	0.000	0.000	-1.337
	SEN CL	1.656	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.000	1.667
	LAT CL					0.395			0.000		0.000	0.000	0.395
SEP	HEATNG	-1.237	0.000	0.000	0.000	-0.137	0.000	0.000	0.000	0.000	0.000	0.000	-1.374
	SEN CL	1.424	0.000	0.000	0.000	0.019	0.000	0.000	0.000	0.000	0.000	0.000	1.443
	LAT CL					0.239			0.000		0.000	0.000	0.239
OCT	HEATNG	-2.254	0.000	0.000	0.000	-0.264	0.000	0.000	0.000	0.000	0.000	0.000	-2.518
	SEN CL	0.682	0.000	0.000	0.000	-0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.635
	LAT CL					0.141			0.000		0.000	0.000	0.141
NOV	HEATNG	-3.921	0.000	0.000	0.000	-0.494	0.000	0.000	0.000	0.000	0.000	0.000	-4.416
	SEN CL	0.325	0.000	0.000	0.000	-0.023	0.000	0.000	0.000	0.000	0.000	0.000	0.302
	LAT CL					0.022			0.000		0.000	0.000	0.022
DEC	HEATNG	-5.554	0.000	0.000	0.000	-0.677	0.000	0.000	0.000	0.000	0.000	0.000	-6.231
	SEN CL	0.268	0.000	0.000	0.000	-0.017	0.000	0.000	0.000	0.000	0.000	0.000	0.251
	LAT CL					0.005			0.000		0.000	0.000	0.005
TOT	HEATNG	-42.280	0.000	0.000	0.000	-5.230	0.000	0.000	0.000	0.000	0.000	0.000	-47.510
	SEN CL	7.633	0.000	0.000	0.000	-0.204	0.000	0.000	0.000	0.000	0.000	0.000	7.429
	LAT CL					1.362			0.000		0.000	0.000	1.362

REPORT- LS-E Space Monthly Load Components Core Plnm (T.C16)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	0.000	0.000	0.000	-0.015	0.000	0.000	0.000	0.000	0.000	0.000	-0.015
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	0.000	0.000	0.000	0.000	-0.014	0.000	0.000	0.000	0.000	0.000	0.000	-0.014
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAY	HEATNG	0.000	0.000	0.000	0.000	-0.008	0.000	0.000	0.000	0.000	0.000	0.000	-0.008
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.001			0.000		0.000	0.000	0.001
JUN	HEATNG	0.000	0.000	0.000	0.000	-0.007	0.000	0.000	0.000	0.000	0.000	0.000	-0.007
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
JUL	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
AUG	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.004			0.000		0.000	0.000	0.004
SEP	HEATNG	0.000	0.000	0.000	0.000	-0.004	0.000	0.000	0.000	0.000	0.000	0.000	-0.004
	SEN CL	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	LAT CL					0.002			0.000		0.000	0.000	0.002
OCT	HEATNG	0.000	0.000	0.000	0.000	-0.006	0.000	0.000	0.000	0.000	0.000	0.000	-0.006
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
NOV	HEATNG	0.000	0.000	0.000	0.000	-0.010	0.000	0.000	0.000	0.000	0.000	0.000	-0.010
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
DEC	HEATNG	0.000	0.000	0.000	0.000	-0.013	0.000	0.000	0.000	0.000	0.000	0.000	-0.013
	SEN CL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	0.000	0.000	0.000	0.000	-0.109	0.000	0.000	0.000	0.000	0.000	0.000	-0.109
	SEN CL	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.004
	LAT CL					0.009			0.000		0.000	0.000	0.009

REPORT- LS-E Space Monthly Load Components Under Roof (T.15)

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	0.000	-70.583	0.000	0.000	-54.698	0.000	0.000	0.000	0.000	0.000	0.000	-125.281
	SEN CL	0.000	-0.215	0.000	0.000	0.399	0.000	0.000	0.000	0.000	0.000	0.000	0.184
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATNG	0.000	-58.247	0.000	0.000	-58.250	0.000	0.000	0.000	0.000	0.000	0.000	-116.497
	SEN CL	0.000	-0.104	0.000	0.000	0.268	0.000	0.000	0.000	0.000	0.000	0.000	0.164
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATNG	0.000	-51.356	0.000	0.000	-56.371	0.000	0.000	0.000	0.000	0.000	0.000	-107.727
	SEN CL	0.000	-0.073	0.000	0.000	0.340	0.000	0.000	0.000	0.000	0.000	0.000	0.267
	LAT CL					0.000			0.000		0.000	0.000	0.000
APR	HEATNG	0.000	-33.272	0.000	0.000	-43.276	0.000	0.000	0.000	0.000	0.000	0.000	-76.548
	SEN CL	0.000	0.734	0.000	0.000	1.185	0.000	0.000	0.000	0.000	0.000	0.000	1.919
	LAT CL					0.043			0.000		0.000	0.000	0.043
MAY	HEATNG	0.000	-18.512	0.000	0.000	-29.938	0.000	0.000	0.000	0.000	0.000	0.000	-48.449
	SEN CL	0.000	2.546	0.000	0.000	0.466	0.000	0.000	0.000	0.000	0.000	0.000	3.012
	LAT CL					5.916			0.000		0.000	0.000	5.916
JUN	HEATNG	0.000	-9.504	0.000	0.000	-19.027	0.000	0.000	0.000	0.000	0.000	0.000	-28.531
	SEN CL	0.000	4.748	0.000	0.000	-0.947	0.000	0.000	0.000	0.000	0.000	0.000	3.801
	LAT CL					9.826			0.000		0.000	0.000	9.826
JUL	HEATNG	0.000	-2.895	0.000	0.000	-8.720	0.000	0.000	0.000	0.000	0.000	0.000	-11.615
	SEN CL	0.000	11.867	0.000	0.000	1.639	0.000	0.000	0.000	0.000	0.000	0.000	13.506
	LAT CL					31.503			0.000		0.000	0.000	31.503
AUG	HEATNG	0.000	-3.018	0.000	0.000	-7.251	0.000	0.000	0.000	0.000	0.000	0.000	-10.269
	SEN CL	0.000	12.330	0.000	0.000	4.340	0.000	0.000	0.000	0.000	0.000	0.000	16.671
	LAT CL					44.585			0.000		0.000	0.000	44.585
SEP	HEATNG	0.000	-5.747	0.000	0.000	-8.319	0.000	0.000	0.000	0.000	0.000	0.000	-14.066
	SEN CL	0.000	7.943	0.000	0.000	4.857	0.000	0.000	0.000	0.000	0.000	0.000	12.800
	LAT CL					18.217			0.000		0.000	0.000	18.217
OCT	HEATNG	0.000	-19.392	0.000	0.000	-20.016	0.000	0.000	0.000	0.000	0.000	0.000	-39.408
	SEN CL	0.000	0.250	0.000	0.000	0.580	0.000	0.000	0.000	0.000	0.000	0.000	0.830
	LAT CL					2.684			0.000		0.000	0.000	2.684
NOV	HEATNG	0.000	-42.298	0.000	0.000	-33.005	0.000	0.000	0.000	0.000	0.000	0.000	-75.303
	SEN CL	0.000	-0.398	0.000	0.000	0.561	0.000	0.000	0.000	0.000	0.000	0.000	0.163
	LAT CL					0.000			0.000		0.000	0.000	0.000
DEC	HEATNG	0.000	-63.588	0.000	0.000	-40.420	0.000	0.000	0.000	0.000	0.000	0.000	-104.007
	SEN CL	0.000	-0.079	0.000	0.000	0.089	0.000	0.000	0.000	0.000	0.000	0.000	0.010
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATNG	0.000	-378.410	0.000	0.000	-379.292	0.000	0.000	0.000	0.000	0.000	0.000	-757.702
	SEN CL	0.000	39.548	0.000	0.000	13.778	0.000	0.000	0.000	0.000	0.000	0.000	53.326
	LAT CL					112.775			0.000		0.000	0.000	112.775

REPORT- LS-F Building Monthly Load Component

WEATHER FILE- Los Angeles CA TMY2

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATNG	-72.026	0.000	0.000	-4.948	-3.585	-32.195	11.624	5.228	10.002	24.872	0.000	-61.028
	SEN CL	-26.269	0.000	0.000	-0.990	-6.370	-37.804	126.817	43.806	70.742	170.211	0.000	340.143
	LAT CL					0.096			40.594		0.000	0.000	40.690
FEB	HEATNG	-63.060	0.000	0.000	-4.763	-2.871	-25.024	11.024	4.380	8.240	19.880	0.000	-52.192
	SEN CL	-24.604	0.000	0.000	-1.089	-6.207	-35.569	136.476	42.211	68.118	163.203	0.000	342.539
	LAT CL					0.063			38.921		0.000	0.000	38.984
MAR	HEATNG	-47.548	0.000	0.000	-4.691	-1.451	-13.418	6.169	2.890	5.466	12.484	0.000	-40.099
	SEN CL	-29.676	0.000	0.000	-1.833	-6.949	-38.311	158.021	50.864	82.343	197.261	0.000	411.720
	LAT CL					0.658			46.906		0.000	0.000	47.564
APR	HEATNG	-28.498	0.000	0.000	-3.487	-0.687	-5.961	3.471	2.070	3.844	8.182	0.000	-21.066
	SEN CL	-22.825	0.000	0.000	-2.577	-6.258	-28.362	173.638	51.877	84.095	200.970	0.000	450.557
	LAT CL					1.040			47.948		0.000	0.000	48.987
MAY	HEATNG	-14.644	0.000	0.000	-2.400	-0.271	-2.240	1.757	0.604	1.426	3.399	0.000	-12.368
	SEN CL	-15.146	0.000	0.000	-2.835	-5.071	-16.736	171.759	48.643	79.665	192.057	0.000	452.336
	LAT CL					3.210			44.918		0.000	0.000	48.128
JUN	HEATNG	-8.098	0.000	0.000	-1.425	-0.077	-0.623	0.551	0.359	0.916	2.127	0.000	-6.269
	SEN CL	-7.802	0.000	0.000	-2.645	-4.272	-9.513	160.150	53.387	86.720	206.744	0.000	482.769
	LAT CL					5.197			49.715		0.000	0.000	54.912
JUL	HEATNG	-1.878	0.000	0.000	-0.387	0.000	0.000	0.000	0.067	0.202	0.492	0.000	-1.504
	SEN CL	16.419	0.000	0.000	-2.926	-1.759	11.687	178.823	53.880	87.860	209.389	0.000	553.373
	LAT CL					7.961			49.845		0.000	0.000	57.806
AUG	HEATNG	-1.873	0.000	0.000	-0.343	0.000	0.000	0.000	0.133	0.322	0.685	0.000	-1.077
	SEN CL	20.140	0.000	0.000	-2.404	-1.419	15.004	180.062	51.371	84.258	202.704	0.000	549.718
	LAT CL					9.389			47.553		0.000	0.000	56.941
SEP	HEATNG	-2.811	0.000	0.000	-0.479	-0.044	-0.381	0.228	0.105	0.357	0.991	0.000	-2.032
	SEN CL	13.893	0.000	0.000	-2.132	-1.431	11.654	159.709	51.382	83.791	199.945	0.000	516.811
	LAT CL					6.720			47.576		0.000	0.000	54.295
OCT	HEATNG	-9.615	0.000	0.000	-1.311	-0.148	-1.252	0.865	0.387	1.052	2.675	0.000	-7.348
	SEN CL	-11.276	0.000	0.000	-1.846	-3.730	-8.266	160.272	51.304	83.775	200.851	0.000	471.085
	LAT CL					5.363			47.454		0.000	0.000	52.817
NOV	HEATNG	-30.248	0.000	0.000	-2.536	-1.313	-11.299	5.551	1.442	3.340	9.091	0.000	-25.973
	SEN CL	-23.578	0.000	0.000	-1.358	-5.132	-24.048	139.814	44.935	72.965	175.212	0.000	378.810
	LAT CL					1.979			41.949		0.000	0.000	43.928
DEC	HEATNG	-53.223	0.000	0.000	-3.672	-2.484	-21.558	8.492	4.058	7.641	18.193	0.000	-42.552
	SEN CL	-27.690	0.000	0.000	-1.350	-6.164	-35.044	131.156	49.880	80.406	191.674	0.000	382.868
	LAT CL					0.667			46.245		0.000	0.000	46.912
TOT	HEATNG	-333.522	0.000	0.000	-30.442	-12.930	-113.950	49.733	21.724	42.806	103.073	0.000	-273.507
	SEN CL	-138.413	0.000	0.000	-23.984	-54.766	-195.308	1876.696	593.516	964.709	2310.247	0.000	5332.698
	LAT CL					42.343			549.627		0.000	0.000	591.969

REPORT- LS-K Space Input Fuels Summary

East Perim Spc (B.E1)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (B.E1)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - - - -	P R O C E S S	- - - - - - - -
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	3288.03	4503.33	0.00	0.0000	0.0000
FEB	0.00	3107.76	4223.62	0.00	0.0000	0.0000
MAR	0.00	3584.57	4842.83	0.00	0.0000	0.0000
APR	0.00	3579.13	4824.12	0.00	0.0000	0.0000
MAY	0.00	3288.02	4503.33	0.00	0.0000	0.0000
JUN	0.00	3579.13	4824.12	0.00	0.0000	0.0000
JUL	0.00	3584.09	4841.17	0.00	0.0000	0.0000
AUG	0.00	3441.84	4692.14	0.00	0.0000	0.0000
SEP	0.00	3425.31	4635.32	0.00	0.0000	0.0000
OCT	0.00	3441.36	4690.48	0.00	0.0000	0.0000
NOV	0.00	3117.67	4257.71	0.00	0.0000	0.0000
DEC	0.00	3584.09	4841.17	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	41021.64	55678.74	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Spc (B.C2)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (B.C2)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - P R O C E S S - - - - -		
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	305.51	418.43	0.00	0.0000	0.0000
FEB	0.00	288.76	392.44	0.00	0.0000	0.0000
MAR	0.00	333.06	449.97	0.00	0.0000	0.0000
APR	0.00	332.56	448.24	0.00	0.0000	0.0000
MAY	0.00	305.51	418.43	0.00	0.0000	0.0000
JUN	0.00	332.56	448.24	0.00	0.0000	0.0000
JUL	0.00	333.02	449.82	0.00	0.0000	0.0000
AUG	0.00	319.80	435.97	0.00	0.0000	0.0000
SEP	0.00	318.26	430.69	0.00	0.0000	0.0000
OCT	0.00	319.76	435.82	0.00	0.0000	0.0000
NOV	0.00	289.68	395.61	0.00	0.0000	0.0000
DEC	0.00	333.02	449.82	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	3811.53	5173.39	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Plnm (B.E3)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (B.E3)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Plnm (B.C4)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (B.C4)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - P R O C E S S - - - - -		
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Spc (G.E5)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (G.E5)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - - - - -	P R O C E S S	- - - - - - - - -
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	4498.63	8847.39	0.00	0.0000	0.0000
FEB	0.00	4251.99	8298.41	0.00	0.0000	0.0000
MAR	0.00	4904.37	9515.48	0.00	0.0000	0.0000
APR	0.00	4896.92	9478.92	0.00	0.0000	0.0000
MAY	0.00	4498.63	8847.39	0.00	0.0000	0.0000
JUN	0.00	4896.92	9478.92	0.00	0.0000	0.0000
JUL	0.00	4903.71	9512.24	0.00	0.0000	0.0000
AUG	0.00	4709.09	9218.69	0.00	0.0000	0.0000
SEP	0.00	4686.47	9107.63	0.00	0.0000	0.0000
OCT	0.00	4708.43	9215.45	0.00	0.0000	0.0000
NOV	0.00	4265.56	8365.04	0.00	0.0000	0.0000
DEC	0.00	4903.71	9512.24	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	56123.91	109398.60	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Spc (G.C6)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (G.C6)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	572.80	292.95	0.00	0.0000	0.0000
FEB	0.00	541.39	274.62	0.00	0.0000	0.0000
MAR	0.00	624.46	314.75	0.00	0.0000	0.0000
APR	0.00	623.51	313.49	0.00	0.0000	0.0000
MAY	0.00	572.80	292.95	0.00	0.0000	0.0000
JUN	0.00	623.51	313.49	0.00	0.0000	0.0000
JUL	0.00	624.37	314.64	0.00	0.0000	0.0000
AUG	0.00	599.59	305.14	0.00	0.0000	0.0000
SEP	0.00	596.71	301.30	0.00	0.0000	0.0000
OCT	0.00	599.51	305.03	0.00	0.0000	0.0000
NOV	0.00	543.12	276.92	0.00	0.0000	0.0000
DEC	0.00	624.37	314.64	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	7146.28	3619.89	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Plnm (G.E7)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (G.E7)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Plnm (G.C8)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (G.C8)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - P R O C E S S - - - - -		
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (M.E9)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - P R O C E S S - - - - -		
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	12410.60	33861.13	0.00	0.0000	0.0000
FEB	0.00	11730.17	31762.14	0.00	0.0000	0.0000
MAR	0.00	13529.95	36422.33	0.00	0.0000	0.0000
APR	0.00	13509.40	36283.15	0.00	0.0000	0.0000
MAY	0.00	12410.63	33861.13	0.00	0.0000	0.0000
JUN	0.00	13509.41	36283.15	0.00	0.0000	0.0000
JUL	0.00	13528.13	36409.99	0.00	0.0000	0.0000
AUG	0.00	12991.21	35283.55	0.00	0.0000	0.0000
SEP	0.00	12928.81	34860.72	0.00	0.0000	0.0000
OCT	0.00	12989.38	35271.23	0.00	0.0000	0.0000
NOV	0.00	11767.63	32015.85	0.00	0.0000	0.0000
DEC	0.00	13528.14	36410.01	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	154824.23	418736.78	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Spc (M.C10)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (M.C10)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	916.52	1255.28	0.00	0.0000	0.0000
FEB	0.00	866.27	1177.32	0.00	0.0000	0.0000
MAR	0.00	999.18	1349.91	0.00	0.0000	0.0000
APR	0.00	997.67	1344.70	0.00	0.0000	0.0000
MAY	0.00	916.52	1255.28	0.00	0.0000	0.0000
JUN	0.00	997.67	1344.70	0.00	0.0000	0.0000
JUL	0.00	999.05	1349.45	0.00	0.0000	0.0000
AUG	0.00	959.40	1307.91	0.00	0.0000	0.0000
SEP	0.00	954.79	1292.08	0.00	0.0000	0.0000
OCT	0.00	959.26	1307.45	0.00	0.0000	0.0000
NOV	0.00	869.04	1186.82	0.00	0.0000	0.0000
DEC	0.00	999.05	1349.45	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	11434.60	15520.36	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Plnm (M.E11)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (M.E11)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Plnm (M.C12)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (M.C12)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Spc (T.E13)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Spc (T.E13)

	- - - - L I G H T I N G - - - -	E Q U I P M E N T	- - - - - P R O C E S S - - - - -			
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	4136.87	11287.09	0.00	0.0000	0.0000
FEB	0.00	3910.06	10587.43	0.00	0.0000	0.0000
MAR	0.00	4509.98	12140.82	0.00	0.0000	0.0000
APR	0.00	4503.13	12094.42	0.00	0.0000	0.0000
MAY	0.00	4136.87	11287.08	0.00	0.0000	0.0000
JUN	0.00	4503.13	12094.43	0.00	0.0000	0.0000
JUL	0.00	4509.37	12136.71	0.00	0.0000	0.0000
AUG	0.00	4330.40	11761.22	0.00	0.0000	0.0000
SEP	0.00	4309.60	11620.27	0.00	0.0000	0.0000
OCT	0.00	4329.80	11757.12	0.00	0.0000	0.0000
NOV	0.00	3922.53	10671.99	0.00	0.0000	0.0000
DEC	0.00	4509.37	12136.70	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	51611.65	139571.34	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Spc (T.C14)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Spc (T.C14)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	305.51	418.43	0.00	0.0000	0.0000
FEB	0.00	288.76	392.44	0.00	0.0000	0.0000
MAR	0.00	333.06	449.97	0.00	0.0000	0.0000
APR	0.00	332.56	448.24	0.00	0.0000	0.0000
MAY	0.00	305.51	418.43	0.00	0.0000	0.0000
JUN	0.00	332.56	448.24	0.00	0.0000	0.0000
JUL	0.00	333.02	449.82	0.00	0.0000	0.0000
AUG	0.00	319.80	435.97	0.00	0.0000	0.0000
SEP	0.00	318.26	430.69	0.00	0.0000	0.0000
OCT	0.00	319.76	435.82	0.00	0.0000	0.0000
NOV	0.00	289.68	395.61	0.00	0.0000	0.0000
DEC	0.00	333.02	449.82	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	3811.53	5173.39	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

East Perim Plnm (T.E15)

WEATHER FILE- Los Angeles CA TMY2

SPACE East Perim Plnm (T.E15)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Core Plnm (T.C16)

WEATHER FILE- Los Angeles CA TMY2

SPACE Core Plnm (T.C16)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T		- - - - - P R O C E S S - - - - -	
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Space Input Fuels Summary

Under Roof (T.15)

WEATHER FILE- Los Angeles CA TMY2

SPACE Under Roof (T.15)

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - P R O C E S S - - - - -		
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	0.00	0.00	0.00	0.0000	0.0000
FEB	0.00	0.00	0.00	0.00	0.0000	0.0000
MAR	0.00	0.00	0.00	0.00	0.0000	0.0000
APR	0.00	0.00	0.00	0.00	0.0000	0.0000
MAY	0.00	0.00	0.00	0.00	0.0000	0.0000
JUN	0.00	0.00	0.00	0.00	0.0000	0.0000
JUL	0.00	0.00	0.00	0.00	0.0000	0.0000
AUG	0.00	0.00	0.00	0.00	0.0000	0.0000
SEP	0.00	0.00	0.00	0.00	0.0000	0.0000
OCT	0.00	0.00	0.00	0.00	0.0000	0.0000
NOV	0.00	0.00	0.00	0.00	0.0000	0.0000
DEC	0.00	0.00	0.00	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	0.00	0.00	0.00	0.0000	0.0000

REPORT- LS-K Building Input Fuels Summary

WEATHER FILE- Los Angeles CA TMY2

BUILDING

	- - - - L I G H T I N G - - - -		E Q U I P M E N T	- - - - - - - -	P R O C E S S	- - - - - - - -
MONTH	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	26434.27	60883.84	0.00	0.0000	0.0000
FEB	0.00	24984.96	57108.19	0.00	0.0000	0.0000
MAR	0.00	28818.46	65485.82	0.00	0.0000	0.0000
APR	0.00	28774.70	65235.11	0.00	0.0000	0.0000
MAY	0.00	26434.32	60883.55	0.00	0.0000	0.0000
JUN	0.00	28774.68	65235.03	0.00	0.0000	0.0000
JUL	0.00	28814.58	65463.72	0.00	0.0000	0.0000
AUG	0.00	27670.95	63440.32	0.00	0.0000	0.0000
SEP	0.00	27538.03	62678.45	0.00	0.0000	0.0000
OCT	0.00	27667.06	63418.16	0.00	0.0000	0.0000
NOV	0.00	25064.75	57564.99	0.00	0.0000	0.0000
DEC	0.00	28814.57	65463.42	0.00	0.0000	0.0000
	-----	-----	-----	-----	-----	-----
ANNUAL	0.00	329753.91	752900.94	0.00	0.0000	0.0000

REPORT- LS-L Management and Solar Summary East Perim Spc (B.E1)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Spc (B.E1)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

REPORT- LS-L Management and Solar Summary Core Spc (B.C2)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (B.C2)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE East Perim Plnm (B.E3)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE Core Plnm (B.C4)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE East Perim Spc (G.E5)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	1048607.875	184005.484
FEB	0.	1238805.750	188645.047
MAR	0.	1244151.875	180986.016
APR	0.	1379026.125	177773.813
MAY	0.	1320027.250	154735.203
JUN	0.	1258088.875	147598.422
JUL	0.	1352391.500	149168.359
AUG	0.	1364782.125	158654.703
SEP	0.	1246429.750	173410.750
OCT	0.	1224390.375	182621.109
NOV	0.	1132814.250	179050.469
DEC	0.	1056736.875	179975.906
	-----	-----	-----
ANNUAL	0.	1238687.875	188645.047

DATA FOR SPACE Core Spc (G.C6)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE East Perim Plnm (G.E7)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE Core Plnm (G.C8)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

REPORT- LS-L Management and Solar Summary East Perim Spc (M.E9)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE East Perim Spc (M.E9)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	1013471.063	177857.156
FEB	0.	1197397.250	182372.484
MAR	0.	1202638.375	174976.984
APR	0.	1332977.750	171860.703
MAY	0.	1275916.250	149589.781
JUN	0.	1216055.750	142641.844
JUL	0.	1307191.500	144204.578
AUG	0.	1319238.625	153384.625
SEP	0.	1204861.250	167664.688
OCT	0.	1183505.500	176547.625
NOV	0.	1094879.250	173081.594
DEC	0.	1021294.375	173959.047
	-----	-----	-----
ANNUAL	0.	1197291.625	182372.484

REPORT- LS-L Management and Solar Summary Core Spc (M.C10)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (M.C10)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE East Perim Plnm (M.E11)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE Core Plnm (M.C12)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE East Perim Spc (T.E13)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	1013471.063	177857.156
FEB	0.	1197397.250	182372.484
MAR	0.	1202638.375	174976.984
APR	0.	1332977.750	171860.703
MAY	0.	1275916.250	149589.781
JUN	0.	1216055.750	142641.844
JUL	0.	1307191.500	144204.578
AUG	0.	1319238.625	153384.625
SEP	0.	1204861.250	167664.688
OCT	0.	1183505.500	176547.625
NOV	0.	1094879.250	173081.594
DEC	0.	1021294.375	173959.047
	-----	-----	-----
ANNUAL	0.	1197291.625	182372.484

REPORT- LS-L Management and Solar Summary Core Spc (T.C14)

WEATHER FILE- Los Angeles CA TMY2

DATA FOR SPACE Core Spc (T.C14)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE East Perim Plnm (T.E15)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE Core Plnm (T.C16)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

DATA FOR SPACE Under Roof (T.15)

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	0.000	0.000
FEB	0.	0.000	0.000
MAR	0.	0.000	0.000
APR	0.	0.000	0.000
MAY	0.	0.000	0.000
JUN	0.	0.000	0.000
JUL	0.	0.000	0.000
AUG	0.	0.000	0.000
SEP	0.	0.000	0.000
OCT	0.	0.000	0.000
NOV	0.	0.000	0.000
DEC	0.	0.000	0.000
	-----	-----	-----
ANNUAL	0.	0.000	0.000

WARNING***

ZONE East Perim Zn (B.E1)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (B)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

WARNING***

ZONE Core Zn (B.C2)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (B)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

CAUTION***

In curve: Variable Speed Drive FPLR the dependent value
is exceeding the limits.
Value/Min/Max/First time: 1.257 0.100 1.000 12/31/24

WARNING***

ZONE East Perim Zn (G.E5)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (G)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

WARNING***

ZONE Core Zn (G.C6)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (G)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

WARNING***

ZONE East Perim Zn (M.E9)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (M)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

WARNING***

ZONE Core Zn (M.C10)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (M)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

WARNING***

ZONE East Perim Zn (T.E13)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (T)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

WARNING***

ZONE Core Zn (T.C14)
might have insufficient heating capability.
Check that the SYSTEM or ZONE HEATING-CAPACITY plus this
ZONES BASEBOARD-RATING is adequate to maintain the ZONE
specified DESIGN-HEAT-T for the calculated peak ZONE load
(see LS-A or LS-B for the ZONE peak load.)

SYSTEM Sys1 (VAVS) (T)
which supplies the above listed ZONE, has a design heating
coil exit temperature, HEAT-SET-T, (plus any zone reheat)
below its MAX-SUPPLY-T or the ZONE DESIGN-HEAT-T, which
might account for the insufficient heating capability.

REPORT- SV-A System Design Parameters for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

SYSTEM TYPE	ALTITUDE FACTOR	FLOOR AREA (SQFT)	MAX PEOPLE	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
VAVS	1.000	37640.0	185.	0.066	1482.763	0.672	0.000	0.000	0.000	0.000

FAN TYPE	CAPACITY (CFM)	DIVERSITY FACTOR (FRAC)	POWER DEMAND (KW)	FAN DELTA-T (F)	STATIC PRESSURE (IN-WATER)	TOTAL EFF (FRAC)	MECH EFF (FRAC)	FAN PLACEMENT	FAN CONTROL	MAX FAN RATIO (FRAC)	MIN FAN RATIO (FRAC)
SUPPLY	43286.	1.00	28.225	2.02	3.5	0.63	0.72	DRAW-THRU	BY USER	1.10	0.30
RETURN	43286.	1.00	9.408	0.67	1.2	0.63	0.70	RETURN	BY USER	1.10	0.30

ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW (FRAC)	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (FRAC)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	ZONE MULT
East Perim Zn (B.E1)	39606.	0.	0.000	0.200	2622.	0.00	0.00	855.49	0.00	145.43	1.
Core Zn (B.C2)	3680.	0.	0.000	0.200	244.	0.00	0.00	79.49	0.00	13.51	1.
East Perim Pl Zn (B.E3)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.
Core Pl Zn (B.C4)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.

REPORT- SV-A System Design Parameters for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

SYSTEM TYPE	ALTITUDE FACTOR	FLOOR AREA (SQFT)	MAX PEOPLE	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
VAVS	1.000	37640.0	188.	0.067	1482.777	0.672	0.000	0.000	0.000	0.000

FAN TYPE	CAPACITY (CFM)	DIVERSITY FACTOR (FRAC)	POWER DEMAND (KW)	FAN DELTA-T (F)	STATIC PRESSURE (IN-WATER)	TOTAL EFF (FRAC)	MECH EFF (FRAC)	FAN PLACEMENT	FAN CONTROL	MAX FAN RATIO (FRAC)	MIN FAN RATIO (FRAC)
SUPPLY	43286.	1.00	28.225	2.02	3.5	0.63	0.72	DRAW-THRU	BY USER	1.10	0.30
RETURN	43286.	1.00	9.408	0.67	1.2	0.63	0.70	RETURN	BY USER	1.10	0.30

ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW (FRAC)	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (FRAC)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	ZONE MULT
East Perim Zn (G.E5)	39606.	0.	0.000	0.200	2640.	0.00	0.00	855.49	0.00	145.43	1.
Core Zn (G.C6)	3680.	0.	0.000	0.200	240.	0.00	0.00	79.49	0.00	13.51	1.
East Perim Pl Zn (G.E7)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.
Core Pl Zn (G.C8)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.

REPORT- SV-A System Design Parameters for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

SYSTEM TYPE	ALTITUDE FACTOR	FLOOR AREA (SQFT)	MAX PEOPLE	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
VAVS	1.000	112920.0	612.	0.067	4448.685	0.671	0.000	0.000	0.000	0.000

FAN TYPE	CAPACITY (CFM)	DIVERSITY FACTOR (FRAC)	POWER DEMAND (KW)	FAN DELTA-T (F)	STATIC PRESSURE (IN-WATER)	TOTAL EFF (FRAC)	MECH EFF (FRAC)	FAN PLACEMENT	FAN CONTROL	MAX FAN RATIO (FRAC)	MIN FAN RATIO (FRAC)
SUPPLY	129858.	1.00	84.675	2.02	3.5	0.63	0.72	DRAW-THRU	BY USER	1.10	0.30
RETURN	129858.	1.00	28.225	0.67	1.2	0.63	0.70	RETURN	BY USER	1.10	0.30

ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW (FRAC)	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (FRAC)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	ZONE MULT
East Perim Zn (M.E9)	39606.	0.	0.000	0.200	2667.	0.00	0.00	855.49	0.00	145.43	3.
Core Zn (M.C10)	3680.	0.	0.000	0.200	244.	0.00	0.00	79.49	0.00	13.51	3.
East Perim Pl Zn (M.E11)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	3.
Core Pl Zn (M.C12)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	3.

REPORT- SV-A System Design Parameters for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

SYSTEM TYPE	ALTITUDE FACTOR	FLOOR AREA (SQFT)	MAX PEOPLE	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
VAVS	1.000	54860.0	204.	0.067	1482.894	0.671	0.000	0.000	0.000	0.000

FAN TYPE	CAPACITY (CFM)	DIVERSITY FACTOR (FRAC)	POWER DEMAND (KW)	FAN DELTA-T (F)	STATIC PRESSURE (IN-WATER)	TOTAL EFF (FRAC)	MECH EFF (FRAC)	FAN PLACEMENT	FAN CONTROL	MAX FAN RATIO (FRAC)	MIN FAN RATIO (FRAC)
SUPPLY	43286.	1.00	28.225	2.02	3.5	0.63	0.72	DRAW-THRU	BY USER	1.10	0.30
RETURN	43286.	1.00	9.408	0.67	1.2	0.63	0.70	RETURN	BY USER	1.10	0.30

ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW (FRAC)	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (FRAC)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	ZONE MULT
East Perim Zn (T.E13)	39606.	0.	0.000	0.200	2667.	0.00	0.00	855.49	0.00	145.43	1.
Core Zn (T.C14)	3680.	0.	0.000	0.200	244.	0.00	0.00	79.49	0.00	13.51	1.
Roof Zone 1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.
East Perim Pl Zn (T.E15)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.
Core Pl Zn (T.C16)	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.

REPORT- SS-D Building HVAC Load Summary

WEATHER FILE- Los Angeles CA TMY2

	C O O L I N G						H E A T I N G						E L E C	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	49.55088	26 14	82.F	55.F	1787.487	-0.047	3 8	53.F	42.F	-9.447	94346.	348.911		
FEB	56.09909	12 14	85.F	60.F	1933.199	-0.042	21 12	61.F	51.F	-8.237	88837.	348.118		
MAR	75.47161	31 16	75.F	53.F	1900.508	-0.010	28 8	53.F	52.F	-3.868	102063.	347.241		
APR	105.91557	13 14	77.F	61.F	2101.329	-0.006	25 8	56.F	53.F	-2.896	102421.	353.516		
MAY	233.59656	29 16	74.F	65.F	2969.483	0.000	31 1	61.F	57.F	0.000	94830.	345.754		
JUN	316.91837	30 15	75.F	64.F	2776.791	0.000	30 1	64.F	61.F	0.000	102173.	348.395		
JUL	549.98285	20 16	74.F	67.F	3504.209	0.000	31 1	65.F	60.F	0.000	102613.	349.755		
AUG	612.42670	17 15	75.F	68.F	4119.633	0.000	31 1	62.F	59.F	0.000	99422.	349.232		
SEP	481.32880	8 9	72.F	66.F	3500.041	0.000	30 1	64.F	60.F	0.000	98103.	349.885		
OCT	328.37399	22 15	73.F	68.F	3066.977	0.000	31 1	59.F	55.F	0.000	99010.	350.194		
NOV	131.68567	10 13	73.F	62.F	2012.969	-0.005	28 8	53.F	44.F	-5.089	89454.	348.945		
DEC	92.99192	18 14	76.F	56.F	1756.078	-0.060	12 8	46.F	36.F	-28.268	101730.	345.885		
TOTAL	3034.342					-0.170					1175006.			
MAX					4119.633					-28.268		353.516		
MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY)						0.000 (KBTU)								
MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE)						37170.744 (KBTU)								

REPORT- SS-E Building HVAC Load Hours

WEATHER FILE- Los Angeles CA TMY2

```

- - - - - N U M B E R   O F   H O U R S - - - - - --COINCIDENT LOADS--
MONTH  HOURS COOLING  HOURS HEATING  HOURS COINCIDENT  HOURS HEATING  HOURS COOLING  HOURS HEATING  HOURS COOLING  HOURS HEATING  HOURS COOLING  HOURS HEATING  HOURS COOLING  HOURS HEATING
      LOAD      LOAD      COOL-HEAT      AVAIL.      AVAIL.      FANS ON      FANS ON      FANS ON      FANS ON      FANS ON      FANS ON      FANS ON      FANS ON
      LOAD      LOAD      LOAD      FLOATING      FLOATING      FLOATING      FLOATING      FLOATING      FLOATING      FLOATING      FLOATING      FLOATING      FLOATING
      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)      (KBTU/HR)
      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)      (KW)

JAN      78      12      0      654      744      744      280      0      0      190      0.000      328.189
FEB      77      7      0      588      672      672      260      0      0      176      0.000      328.654
MAR     133      3      0      608      744      744      296      0      0      160      0.000      341.433
APR     143      2      0      575      720      720      296      0      0      151      0.000      331.955
MAY     234      0      0      510      744      744      280      0      0      46      0.000      342.600
JUN     274      0      0      446      720      720      296      0      0      22      0.000      341.200
JUL     294      0      0      450      744      744      296      0      0      2      0.000      343.310
AUG     290      0      0      454      744      744      292      0      0      2      0.000      345.663
SEP     281      0      0      439      720      720      284      0      0      3      0.000      344.460
OCT     271      0      0      473      744      744      292      0      0      21      0.000      337.731
NOV     179      1      0      540      720      720      260      0      0      80      0.000      311.261
DEC     134      8      0      602      744      744      296      0      0      154      0.000      330.259
-----
ANNUAL  2388      33      0      6339      8760      8760      3428      0      0      1007

```

REPORT- SS-M Building HVAC Fan Elec Energy

WEATHER FILE- Los Angeles CA TMY2

MONTH	FAN ELECTRIC ENERGY DURING HEATING (KWH)	FAN ELECTRIC ENERGY DURING COOLING (KWH)	FAN ELECTRIC ENERGY DURING HEATING-COOLING (KWH)	FAN ELECTRIC ENERGY DURING FLOATING (KWH)
JAN	55.880	1959.266	0.000	5012.427
FEB	39.914	2015.985	0.000	4687.729
MAR	11.974	3486.173	0.000	4259.992
APR	7.983	4124.959	0.000	4277.552
MAY	0.000	6291.171	0.000	1220.450
JUN	0.000	7326.634	0.000	836.432
JUL	0.000	8242.713	0.000	92.138
AUG	0.000	8178.165	0.000	132.363
SEP	0.000	7750.158	0.000	135.543
OCT	0.000	7253.408	0.000	671.332
NOV	3.991	4762.853	0.000	2056.741
DEC	51.889	3394.661	0.000	4004.311
ANNUAL	171.632	64787.934	0.000	27387.646

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
		DY	HR					DY	HR					
JAN	5.87761	27	12	75.F	54.F	184.721	-0.040	31	8	51.F	50.F	-4.325	9633.	34.735
FEB	5.89824	12	14	85.F	60.F	185.265	-0.035	21	12	61.F	51.F	-8.237	9050.	34.735
MAR	8.07525	4	16	75.F	53.F	181.228	-0.010	28	8	53.F	52.F	-3.868	10392.	34.735
APR	10.56677	11	15	73.F	64.F	247.390	-0.006	25	8	56.F	53.F	-2.896	10366.	34.735
MAY	25.45620	30	13	74.F	67.F	321.434	0.000	31	1	61.F	57.F	0.000	9633.	34.735
JUN	33.04829	23	12	75.F	66.F	309.564	0.000	30	1	64.F	61.F	0.000	10366.	34.735
JUL	56.43051	20	16	74.F	67.F	317.410	0.000	31	1	65.F	60.F	0.000	10390.	34.735
AUG	62.85980	13	10	75.F	69.F	376.520	0.000	31	1	62.F	59.F	0.000	10055.	34.735
SEP	49.43209	9	10	75.F	66.F	309.026	0.000	30	1	64.F	60.F	0.000	9943.	34.735
OCT	34.86008	22	15	73.F	68.F	328.121	0.000	31	1	59.F	55.F	0.000	10053.	34.735
NOV	14.52886	10	13	73.F	62.F	206.284	-0.005	28	8	53.F	44.F	-5.089	9098.	34.735
DEC	10.83862	17	11	75.F	51.F	185.075	-0.039	12	13	60.F	43.F	-8.181	10390.	34.735
TOTAL	317.872						-0.135						119370.	
MAX						376.520						-8.237		34.735

REPORT- SS-B System Loads Summary for

Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

	- - Z O N E C O O L I N G - -		- - Z O N E H E A T I N G - -		- - B A S E B O A R D S - -		--PREHEAT OR FURN FAN ELEC--	
MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)	BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)	PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (MBTU)	MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (KBTU/HR)
JAN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
FEB	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
MAR	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
APR	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
MAY	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUL	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
AUG	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
SEP	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
OCT	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
NOV	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
DEC	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
	-----	-----	-----	-----	-----	-----	-----	-----
TOTAL	0.000		0.000		0.000		0.000	
MAX		0.000		0.000		0.000		0.000

REPORT- SS-C System Load Hours for Sys1 (VAVS) (B) WEATHER FILE- Los Angeles CA TMY2

- - - - - N U M B E R O F H O U R S - - - - -											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	76	12	0	656	744	744	280	0	0	192	0.000	32.571
FEB	77	7	0	588	672	672	260	0	0	176	0.000	34.013
MAR	133	3	0	608	744	744	296	0	0	160	0.000	34.657
APR	143	2	0	575	720	720	296	0	0	151	0.000	7.332
MAY	234	0	0	510	744	744	280	0	0	46	0.000	7.332
JUN	274	0	0	446	720	720	296	0	0	22	0.000	32.571
JUL	294	0	0	450	744	744	296	0	0	2	0.000	34.657
AUG	290	0	0	454	744	744	292	0	0	2	0.000	34.735
SEP	281	0	0	439	720	720	284	0	0	3	0.000	34.735
OCT	271	0	0	473	744	744	292	0	0	21	0.000	34.662
NOV	179	1	0	540	720	720	260	0	0	80	0.000	32.498
DEC	134	8	0	602	744	744	296	0	0	154	0.000	34.374
ANNUAL	2386	33	0	6341	8760	8760	3428	0	0	1009		

REPORT- SS-H System Utility Energy Use for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

	- F A N	E L E C - -	- F U E L	H E A T - -	- F U E L	C O O L - -	- E L E C	H E A T - -	- E L E C	C O O L - -
	FAN	MAXIMUM		MAXIMUM		MAXIMUM		MAXIMUM		MAXIMUM
	ENERGY	FAN	GAS OIL	GAS OIL	GAS OIL	GAS OIL	ELECTRIC	ELECTRIC	ELECTRIC	ELECTRIC
	(KWH)	LOAD	ENERGY	LOAD	ENERGY	LOAD	ENERGY	LOAD	ENERGY	LOAD
MONTH		(KW)	(MBTU)	(KBTU/HR)	(MBTU)	(KBTU/HR)	(KWH)	(KW)	(KWH)	(KW)
JAN	1118.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
FEB	1038.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAR	1181.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
APR	1181.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAY	1118.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUN	1181.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUL	1181.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
AUG	1166.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
SEP	1134.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
OCT	1166.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
NOV	1038.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
DEC	1181.	3.991	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
TOTAL	13682.		0.000		0.000		0.		0.	
MAX		3.991		0.000		0.000		0.000		0.000

REPORT- SS-I Sensible/Latent Summary for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	5.87531	0.00230	184.721	1.000	27 12	-0.04043	0.00000	-4.325
FEB	5.83267	0.06556	185.265	1.000	12 14	-0.03457	0.00000	-8.237
MAR	7.80822	0.26702	181.228	1.000	4 16	-0.01001	0.00000	-3.868
APR	8.91952	1.64725	247.390	0.638	11 15	-0.00562	0.00000	-2.896
MAY	17.63590	7.82031	321.434	0.534	30 13	0.00000	0.00000	0.000
JUN	20.82109	12.22721	309.564	0.596	23 12	0.00000	0.00000	0.000
JUL	34.34142	22.08910	317.410	0.534	20 16	0.00000	0.00000	0.000
AUG	36.29285	26.56696	376.520	0.488	13 10	0.00000	0.00000	0.000
SEP	32.71445	16.71764	309.026	0.591	9 10	0.00000	0.00000	0.000
OCT	23.44070	11.41937	328.121	0.481	22 15	0.00000	0.00000	0.000
NOV	11.95675	2.57212	206.284	0.752	10 13	-0.00509	0.00000	-5.089
DEC	10.36244	0.47618	185.075	1.000	17 11	-0.03879	0.00000	-8.181
TOTAL	216.002	101.871				-0.135	0.000	
MAX			376.520	0.488				-8.237

REPORT- SS-J Peak Heating and Cooling for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

- - - - C O O L I N G - - - - -					- - - H E A T I N G - - -			D A Y C O O L I N G P E A K			
AUG 13					FEB 21			AUG 12			
HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	
1	0.000	0.000	69.F	63.F	0.000	47.F	43.F	0.000	0.000	67.F	63.F
2	0.000	0.000	68.F	62.F	0.000	48.F	44.F	0.000	0.000	67.F	63.F
3	0.000	0.000	68.F	64.F	0.000	46.F	42.F	0.000	0.000	66.F	62.F
4	0.000	0.000	68.F	65.F	0.000	45.F	41.F	0.000	0.000	65.F	62.F
5	0.000	0.000	68.F	65.F	0.000	44.F	40.F	0.000	0.000	65.F	62.F
6	0.000	0.000	68.F	65.F	0.000	43.F	40.F	0.000	0.000	68.F	63.F
7	200.959	0.487	70.F	66.F	0.000	45.F	41.F	224.757	0.516	70.F	65.F
8	347.354	0.498	74.F	68.F	-5.004	48.F	43.F	357.262	0.521	75.F	68.F
9	376.520	0.488	75.F	69.F	0.000	52.F	46.F	276.318	0.634	78.F	70.F
10	374.586	0.488	75.F	69.F	0.000	56.F	49.F	279.383	0.648	79.F	70.F
11	251.858	0.652	76.F	69.F	0.000	59.F	51.F	252.083	0.662	77.F	69.F
12	257.856	0.670	77.F	69.F	-8.237	61.F	51.F	354.002	0.521	75.F	68.F
13	267.827	0.658	77.F	69.F	0.000	60.F	53.F	352.034	0.520	75.F	68.F
14	268.795	0.641	76.F	69.F	0.000	59.F	53.F	349.903	0.520	75.F	68.F
15	354.834	0.517	75.F	68.F	0.000	59.F	52.F	350.007	0.520	75.F	68.F
16	352.716	0.517	75.F	68.F	0.000	58.F	52.F	350.002	0.520	75.F	68.F
17	320.649	0.480	73.F	68.F	0.000	56.F	52.F	299.407	0.514	73.F	67.F
18	216.217	0.517	70.F	65.F	0.000	54.F	50.F	252.697	0.502	71.F	66.F
19	0.000	0.000	68.F	63.F	0.000	53.F	50.F	0.000	0.000	70.F	64.F
20	0.000	0.000	68.F	63.F	0.000	52.F	49.F	0.000	0.000	70.F	64.F
21	0.000	0.000	67.F	63.F	0.000	53.F	50.F	0.000	0.000	69.F	63.F
22	0.000	0.000	67.F	63.F	0.000	53.F	50.F	0.000	0.000	69.F	63.F
23	0.000	0.000	67.F	63.F	0.000	52.F	50.F	0.000	0.000	69.F	63.F
24	0.000	0.000	67.F	63.F	0.000	52.F	49.F	0.000	0.000	69.F	63.F
-----					-----			-----			
SUM								3697.855			
MAX	376.520				-8.237						

SYSTEM-TYPE	VAVS	SQFT/TON	1199.6
COOLING PEAK	10.00 (BTU/HR- SQFT)	HEATING PEAK	-0.22 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.15 (CFM/SQFT)	MIN-OA/PERSON	15.49 (CFM)
OA FRAC AT CLG PEAK	1.000	OA FRAC AT HTG PEAK	0.331

* ASTERISKS INDICATE HOURS LOADS NOT MET

REPORT- SS-K Space Temperature Summary for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

MONTH	A V E R A G E		S P A C E			T E M P		AVERAGE	TEMPERATURE	DIFFERENCE	SUMMED TEMP	DIFFERENCE	HUMIDITY RATIO
	ALL	COOLING	HEATING	FAN ON	FAN OFF		BETWEEN	BETWEEN	BETWEEN	BETWEEN	BETWEEN		
	HOURS	HOURS	HOURS	HOURS	HOURS		OUTDOOR&	OUTDOOR&	OUTDOOR&	OUTDOOR&	OUTDOOR&	DIFFERENCE	
	(F)	(F)	(F)	(F)	(F)		ROOM AIR	ROOM AIR	ROOM AIR	ROOM AIR	ROOM AIR	BETWEEN	
							ALL	FAN ON	FAN OFF	HEATING	ALL	OUTDOOR AND	
							HOURS	HOURS	HOURS	HOURS	HOURS	ROOM AIR	
							(F)	(F)	(F)	(F)	(F)	(FRAC.OR MULT.)	
JAN	63.55	65.74	62.80	64.76	62.82		-7.52	-5.59	-8.69	4.32	267.48	-0.00152	
FEB	64.02	66.62	61.63	65.09	63.34		-8.15	-5.15	-10.04	2.77	246.50	-0.00115	
MAR	65.48	67.09	61.87	66.43	64.86		-7.29	-4.74	-8.98	1.19	251.40	-0.00099	
APR	67.83	68.39	62.94	67.66	67.95		-7.84	-5.49	-9.48	0.66	253.84	-0.00074	
MAY	69.05	68.35	0.00	68.28	69.52		-6.46	-2.26	-8.99	0.00	223.65	0.00017	
JUN	70.30	69.45	0.00	69.37	70.95		-6.55	-2.68	-9.24	0.00	213.94	0.00039	
JUL	72.30	70.54	0.00	70.53	73.48		-4.70	-0.08	-7.76	0.00	184.14	0.00140	
AUG	72.58	70.42	0.00	70.41	73.98		-4.38	0.81	-7.73	0.00	195.89	0.00190	
SEP	72.08	70.39	0.00	70.39	73.19		-4.18	0.60	-7.29	0.00	183.57	0.00093	
OCT	69.74	68.90	0.00	68.86	70.32		-5.09	-1.28	-7.55	0.00	197.80	0.00017	
NOV	67.29	67.30	62.74	67.37	67.25		-6.55	-3.22	-8.43	0.41	232.64	-0.00046	
DEC	65.35	66.44	62.08	65.90	64.99		-7.38	-4.07	-9.57	3.27	272.86	-0.00103	
ANNUAL	68.32	68.91	62.30	67.96	68.56		-6.33	-2.74	-8.63	12.62	2723.72	-0.00007	

WEATHER FILE- Los Angeles CA TMY2

REPORT- SS-L Fan Electric Energy Use for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

MONTH	FAN ELEC DURING HEATING (KWH)	FAN ELEC DURING COOLING (KWH)	FAN ELEC DURING HEAT & COOL (KWH)	FAN ELEC DURING FLOATING (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	47.897	303.349	0.000	766.356	0	0	280	0	0	0	0	0	0	0	0	280
FEB	27.940	307.341	0.000	702.493	0	0	260	0	0	0	0	0	0	0	0	260
MAR	11.974	530.861	0.000	638.630	0	0	296	0	0	0	0	0	0	0	0	296
APR	7.983	570.775	0.000	602.707	0	0	296	0	0	0	0	0	0	0	0	296
MAY	0.000	933.997	0.000	183.606	0	0	280	0	0	0	0	0	0	0	0	280
JUN	0.000	1093.656	0.000	87.812	0	0	296	0	0	0	0	0	0	0	0	296
JUL	0.000	1173.485	0.000	7.983	0	0	296	0	0	0	0	0	0	0	0	296
AUG	0.000	1157.519	0.000	7.983	0	0	292	0	0	0	0	0	0	0	0	292
SEP	0.000	1121.596	0.000	11.974	0	0	284	0	0	0	0	0	0	0	0	284
OCT	0.000	1081.681	0.000	83.820	0	0	292	0	0	0	0	0	0	0	0	292
NOV	3.991	714.467	0.000	319.315	0	0	260	0	0	0	0	0	0	0	0	260
DEC	31.931	534.852	0.000	614.681	0	0	296	0	0	0	0	0	0	0	0	296
ANNUAL	131.717	9523.277	0.000	4027.375	0	0	3428	0	0	0	0	0	0	0	0	3428

BREAKDOWN OF ANNUAL FAN POWER USAGE

FAN TYPE	ANNUAL FAN ELEC (KWH)
SUPPLY	10262.
RETURN	3421.
TOTAL	13682.

REPORT- SS-N Relative Humidity Summary for Sys1 (VAVS) (B)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY																										
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
90-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-89	0	0	0	0	0	0	1	2	5	3	1	0	0	1	0	2	0	1	0	0	0	0	0	0	16	
70-79	0	0	0	0	0	0	51	63	48	26	19	12	6	17	13	11	18	17	11	0	0	0	0	0	312	
60-69	0	0	0	0	0	0	110	127	132	152	144	135	150	132	109	84	79	93	28	0	0	0	0	0	1475	
50-59	0	0	0	0	0	0	22	52	56	62	77	103	97	107	98	111	107	92	17	0	0	0	0	0	1001	
40-49	0	0	0	0	0	0	5	21	25	24	24	19	20	23	27	26	30	25	10	0	0	0	0	0	279	
30-39	0	0	0	0	0	0	6	24	22	23	24	16	19	17	17	11	11	13	7	0	0	0	0	0	210	
20-29	0	0	0	0	0	0	3	12	12	10	14	16	8	5	4	5	5	9	9	0	0	0	0	0	112	
10-19	0	0	0	0	0	0	2	2	3	3	0	2	3	1	1	1	1	1	3	0	0	0	0	0	23	
0-09	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====	

```
*****
*
* NOTE 1)THE RELATIVE HUMIDITY COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
		DY	HR					DY	HR					
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	7791.	28.129
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	7331.	28.129
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	8427.	28.129
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	8403.	28.129
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	7791.	28.129
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	8403.	28.129
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	8425.	28.129
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	8134.	28.129
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	8061.	28.129
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	8132.	28.129
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	7375.	28.129
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	8425.	28.129
TOTAL	0.000						0.000						96696.	
MAX							0.000							28.129

REPORT- SS-F Zone Demand Summary for East Perim Zn (B.El)

WEATHER FILE- Los Angeles CA TMY2

```

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S   N O T   M E T- -

```

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	8.62049	-0.060	0.00000	0.000	71.1	59.3	0	0
FEB	8.59341	-0.051	0.00000	0.000	71.5	57.9	0	0
MAR	12.56961	0.000	0.00000	0.000	71.2	59.3	0	0
APR	15.51444	-0.002	0.00000	0.000	72.4	62.2	0	0
MAY	19.05974	0.000	0.00000	0.000	72.8	64.2	0	0
JUN	23.60539	0.000	0.00000	0.000	72.8	63.8	0	0
JUL	30.79339	0.000	0.00000	0.000	73.3	66.4	0	0
AUG	30.72408	0.000	0.00000	0.000	73.6	65.9	0	0
SEP	29.20843	0.000	0.00000	0.000	74.2	65.7	0	0
OCT	23.24434	0.000	0.00000	0.000	72.6	64.0	0	0
NOV	14.37524	0.000	0.00000	0.000	71.5	61.7	0	0
DEC	12.57182	-0.037	0.00000	0.000	70.5	56.0	0	0

REPORT- SS-O Space Temperature Summary for East Perim Zn (B.E1)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-75	0	0	0	0	0	0	45	69	43	41	30	39	57	84	106	124	135	97	4	0	0	0	0	0	874
65-70	0	0	0	0	0	0	137	164	190	190	199	194	194	186	143	125	115	149	67	0	0	0	0	0	2053
60-65	0	0	0	0	0	0	18	64	66	67	68	66	48	31	18	2	1	5	14	0	0	0	0	0	468
BELOW 60	0	0	0	0	0	0	0	6	4	5	6	4	4	2	2	0	0	0	0	0	0	0	0	0	33
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY	HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY	HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	724.	2.614
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	681.	2.614
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	783.	2.614
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	781.	2.614
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	724.	2.614
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	781.	2.614
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	783.	2.614
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	756.	2.614
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	749.	2.614
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	756.	2.614
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	685.	2.614
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	783.	2.614
TOTAL	0.000						0.000						8985.	
MAX						0.000						0.000		2.614

REPORT- SS-F Zone Demand Summary for Core Zn (B.C2)

WEATHER FILE- Los Angeles CA TMY2

```

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S   N O T   M E T- -

```

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.85183	-0.008	0.00000	0.000	71.7	59.0	0	0
FEB	0.88784	-0.006	0.00000	0.000	72.4	57.7	0	0
MAR	1.28995	0.000	0.00000	0.000	72.0	59.2	0	0
APR	1.55926	0.000	0.00000	0.000	73.2	62.2	0	0
MAY	1.87823	0.000	0.00000	0.000	73.8	64.2	0	0
JUN	2.29208	0.000	0.00000	0.000	73.6	63.8	0	0
JUL	2.94512	0.000	0.00000	0.000	74.1	66.2	0	0
AUG	2.91787	0.000	0.00000	0.000	74.2	65.8	0	0
SEP	2.78297	0.000	0.00000	0.000	74.3	65.5	0	0
OCT	2.21690	0.000	0.00000	0.000	73.3	63.7	0	0
NOV	1.38861	0.000	0.00000	0.000	72.1	61.3	0	0
DEC	1.23836	-0.005	0.00000	0.000	71.1	56.0	0	0

REPORT- SS-O Space Temperature Summary for Core Zn (B.C2)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-75	0	0	0	0	0	0	57	75	62	55	40	46	75	105	125	145	158	134	8	0	0	0	0	0	1085
65-70	0	0	0	0	0	0	127	159	180	182	201	197	183	166	127	105	92	116	67	0	0	0	0	0	1902
60-65	0	0	0	0	0	0	16	62	57	61	55	55	41	28	15	1	1	1	10	0	0	0	0	0	403
BELOW 60	0	0	0	0	0	0	0	7	4	5	7	5	4	4	2	0	0	0	0	0	0	0	0	0	38
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
		DY	HR					DY	HR					
JAN	7.82597	26	14	82.F	55.F	285.778	-0.003	3	8	53.F	42.F	-3.255	15345.	56.284
FEB	8.91334	12	14	85.F	60.F	315.422	0.000	28	24	50.F	47.F	0.000	14437.	56.354
MAR	11.96382	31	16	75.F	53.F	312.538	0.000	31	1	55.F	52.F	0.000	16586.	56.178
APR	17.41693	13	14	77.F	61.F	348.311	0.000	30	1	60.F	56.F	0.000	16623.	57.322
MAY	38.10888	29	16	74.F	65.F	491.229	0.000	31	1	61.F	57.F	0.000	15389.	56.072
JUN	51.99514	30	15	75.F	64.F	461.418	0.000	30	1	64.F	61.F	0.000	16587.	56.449
JUL	91.07127	20	16	74.F	67.F	584.806	0.000	31	1	65.F	60.F	0.000	16661.	56.655
AUG	102.00149	17	15	75.F	68.F	696.754	0.000	31	1	62.F	59.F	0.000	16139.	56.648
SEP	79.81499	8	16	75.F	65.F	594.190	0.000	30	1	64.F	60.F	0.000	15936.	56.888
OCT	53.93514	7	16	71.F	66.F	507.661	0.000	31	1	59.F	55.F	0.000	16081.	56.748
NOV	21.39071	10	13	73.F	62.F	330.297	0.000	30	24	54.F	46.F	0.000	14531.	56.536
DEC	14.65351	18	14	76.F	56.F	290.883	-0.003	12	8	46.F	36.F	-2.860	16556.	55.962
TOTAL	499.091						-0.006						190870.	
MAX						696.754						-3.255		57.322

REPORT- SS-B System Loads Summary for

Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

	- - Z O N E C O O L I N G - -		- - Z O N E H E A T I N G - -		- - B A S E B O A R D S - -		--PREHEAT OR FURN FAN ELEC--	
MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)	BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)	PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (MBTU)	MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (KBTU/HR)
JAN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
FEB	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
MAR	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
APR	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
MAY	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUL	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
AUG	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
SEP	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
OCT	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
NOV	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
DEC	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
TOTAL	0.000		0.000		0.000		0.000	
MAX		0.000		0.000		0.000		0.000

REPORT- SS-C System Load Hours for Sys1 (VAVS) (G) WEATHER FILE- Los Angeles CA TMY2

- - - - - N U M B E R O F H O U R S - - - - -											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	78	1	0	665	744	744	280	0	0	201	0.000	53.733
FEB	76	0	0	596	672	672	260	0	0	184	0.000	53.733
MAR	131	0	0	613	744	744	296	0	0	165	0.000	55.434
APR	142	0	0	578	720	720	296	0	0	154	0.000	54.061
MAY	231	0	0	513	744	744	280	0	0	49	0.000	55.604
JUN	263	0	0	457	720	720	296	0	0	33	0.000	55.469
JUL	292	0	0	452	744	744	296	0	0	4	0.000	55.740
AUG	287	0	0	457	744	744	292	0	0	5	0.000	56.156
SEP	278	0	0	442	720	720	284	0	0	6	0.000	56.706
OCT	265	0	0	479	744	744	292	0	0	27	0.000	56.428
NOV	179	0	0	541	720	720	260	0	0	81	0.000	51.064
DEC	133	1	0	610	744	744	296	0	0	162	0.000	53.857
ANNUAL	2355	2	0	6403	8760	8760	3428	0	0	1071		

REPORT- SS-H System Utility Energy Use for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

	- F A N	E L E C - -	- F U E L	H E A T - -	- F U E L	C O O L - -	- E L E C	H E A T - -	- E L E C	C O O L - -
	FAN	MAXIMUM		MAXIMUM		MAXIMUM		MAXIMUM		MAXIMUM
	ENERGY	FAN	GAS OIL	GAS OIL	GAS OIL	GAS OIL	ELECTRIC	ELECTRIC	ELECTRIC	ELECTRIC
	(KWH)	LOAD	ENERGY	LOAD	ENERGY	LOAD	ENERGY	LOAD	ENERGY	LOAD
MONTH		(KW)	(MBTU)	(KBTU/HR)	(MBTU)	(KBTU/HR)	(KWH)	(KW)	(KWH)	(KW)
JAN	1133.	5.312	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
FEB	1070.	5.382	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAR	1227.	5.242	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
APR	1310.	6.350	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAY	1178.	5.240	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUN	1275.	5.570	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUL	1306.	5.683	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
AUG	1306.	5.954	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
SEP	1244.	5.916	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
OCT	1253.	5.793	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
NOV	1081.	5.564	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
DEC	1201.	4.990	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
TOTAL	14584.		0.000		0.000		0.		0.	
MAX		6.350		0.000		0.000		0.000		0.000

REPORT- SS-I Sensible/Latent Summary for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	7.81943	0.00655	285.778	1.000	26 14	-0.00325	0.00000	-3.255
FEB	8.83859	0.07475	315.422	1.000	12 14	0.00000	0.00000	0.000
MAR	11.57562	0.38821	312.538	1.000	31 16	0.00000	0.00000	0.000
APR	14.91525	2.50167	348.311	0.928	13 14	0.00000	0.00000	0.000
MAY	26.66266	11.44623	491.229	0.614	29 16	0.00000	0.00000	0.000
JUN	33.10693	18.88821	461.418	0.695	30 15	0.00000	0.00000	0.000
JUL	56.70189	34.36938	584.806	0.534	20 16	0.00000	0.00000	0.000
AUG	60.04956	41.95192	696.754	0.521	17 15	0.00000	0.00000	0.000
SEP	54.15846	25.65652	594.190	0.641	8 16	0.00000	0.00000	0.000
OCT	36.68823	17.24691	507.661	0.502	7 16	0.00000	0.00000	0.000
NOV	17.69397	3.69674	330.297	0.752	10 13	0.00000	0.00000	0.000
DEC	14.06936	0.58416	290.883	1.000	18 14	-0.00286	0.00000	-2.860
TOTAL	342.280	156.811				-0.006	0.000	
MAX			696.754	0.521				-3.255

REPORT- SS-J Peak Heating and Cooling for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

- - - - C O O L I N G - - - - -					- - - H E A T I N G - - -			D A Y C O O L I N G P E A K			
AUG 17					JAN 3			AUG 13			
HOURLY	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-	
COOLING	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB	
LOAD	RATIO	TEMP	TEMP	LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP	
(KBTU)				(KBTU)			(KBTU)				
1	0.000	0.000	69.F	65.F	0.000	51.F	43.F	0.000	0.000	69.F	63.F
2	0.000	0.000	69.F	64.F	0.000	51.F	41.F	0.000	0.000	68.F	62.F
3	0.000	0.000	69.F	64.F	0.000	51.F	41.F	0.000	0.000	68.F	64.F
4	0.000	0.000	69.F	64.F	0.000	54.F	42.F	0.000	0.000	68.F	65.F
5	0.000	0.000	69.F	64.F	0.000	51.F	41.F	0.000	0.000	68.F	65.F
6	0.000	0.000	69.F	64.F	0.000	52.F	42.F	0.000	0.000	68.F	65.F
7	275.996	0.591	70.F	65.F	0.000	53.F	42.F	276.400	0.533	70.F	66.F
8	585.684	0.549	73.F	66.F	-3.255	53.F	42.F	624.842	0.498	74.F	68.F
9	682.078	0.519	75.F	68.F	0.000	55.F	43.F	668.150	0.488	75.F	69.F
10	450.408	0.786	76.F	68.F	0.000	57.F	44.F	678.418	0.488	75.F	69.F
11	440.850	0.783	77.F	69.F	0.000	60.F	46.F	407.236	0.761	76.F	69.F
12	417.872	0.792	76.F	68.F	0.000	61.F	46.F	403.932	0.770	77.F	69.F
13	437.997	0.783	76.F	68.F	0.000	62.F	47.F	428.737	0.763	77.F	69.F
14	696.754	0.521	75.F	68.F	0.000	64.F	46.F	443.744	0.760	76.F	69.F
15	615.014	0.596	75.F	66.F	0.000	64.F	47.F	683.183	0.517	75.F	68.F
16	615.497	0.596	75.F	66.F	0.000	60.F	50.F	682.369	0.517	75.F	68.F
17	591.060	0.514	73.F	67.F	0.000	59.F	50.F	606.299	0.481	73.F	68.F
18	383.957	0.538	71.F	65.F	0.000	59.F	49.F	345.551	0.517	70.F	65.F
19	0.000	0.000	68.F	64.F	0.000	56.F	49.F	0.000	0.000	68.F	63.F
20	0.000	0.000	68.F	62.F	0.000	56.F	48.F	0.000	0.000	68.F	63.F
21	0.000	0.000	67.F	63.F	0.000	57.F	46.F	0.000	0.000	67.F	63.F
22	0.000	0.000	67.F	62.F	0.000	56.F	46.F	0.000	0.000	67.F	63.F
23	0.000	0.000	67.F	61.F	0.000	57.F	46.F	0.000	0.000	67.F	63.F
24	0.000	0.000	67.F	62.F	0.000	57.F	47.F	0.000	0.000	67.F	63.F
-----					-----			-----			
SUM								6248.860			
MAX	696.754				-3.255						

SYSTEM-TYPE	VAVS	SQFT/TON	648.3
COOLING PEAK	18.51 (BTU/HR- SQFT)	HEATING PEAK	-0.09 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.15 (CFM/SQFT)	MIN-OA/PERSON	15.32 (CFM)
OA FRAC AT CLG PEAK	1.000	OA FRAC AT HTG PEAK	0.333

* ASTERISKS INDICATE HOURS LOADS NOT MET

REPORT- SS-K Space Temperature Summary for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

MONTH	A V E R A G E		S P A C E		T E M P		AVERAGE TEMPERATURE	DIFFERENCE	SUMMED TEMP	DIFFERENCE	HUMIDITY RATIO
	ALL HOURS (F)	COOLING HOURS (F)	HEATING HOURS (F)	FAN ON HOURS (F)	FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN ON HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR HEATING HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	DIFFERENCE BETWEEN OUTDOOR AND ROOM AIR (FRAC.OR MULT.)
JAN	71.18	73.08	65.67	72.64	70.30	-15.15	-13.47	-16.17	0.53	473.88	-0.00120
FEB	72.25	74.08	0.00	73.43	71.50	-16.38	-13.49	-18.20	0.00	463.44	-0.00081
MAR	73.17	74.08	0.00	73.62	72.87	-14.98	-11.94	-16.98	0.00	467.96	-0.00076
APR	74.72	74.19	0.00	74.11	75.15	-14.73	-11.94	-16.68	0.00	444.95	-0.00047
MAY	75.05	74.06	0.00	74.03	75.67	-12.46	-8.01	-15.15	0.00	391.01	0.00031
JUN	75.53	74.20	0.00	74.18	76.48	-11.78	-7.50	-14.76	0.00	354.43	0.00052
JUL	76.70	74.37	0.00	74.37	78.24	-9.10	-3.92	-12.52	0.00	291.12	0.00149
AUG	76.83	74.30	0.00	74.30	78.46	-8.62	-3.08	-12.21	0.00	280.85	0.00198
SEP	76.48	74.30	0.00	74.29	77.91	-8.58	-3.31	-12.01	0.00	286.57	0.00103
OCT	75.41	74.11	0.00	74.08	76.27	-10.76	-6.50	-13.50	0.00	341.10	0.00028
NOV	73.97	73.96	0.00	73.89	74.01	-13.22	-9.74	-15.19	0.00	400.11	-0.00031
DEC	72.91	73.82	67.28	73.47	72.54	-14.94	-11.65	-17.11	0.89	470.69	-0.00078
ANNUAL	74.53	74.13	66.48	73.88	74.95	-12.53	-8.66	-15.02	1.41	4666.12	0.00011

WEATHER FILE- Los Angeles CA TMY2

REPORT- SS-L Fan Electric Energy Use for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

MONTH	FAN ELEC DURING HEATING (KWH)	FAN ELEC DURING COOLING (KWH)	FAN ELEC DURING HEAT & COOL (KWH)	FAN ELEC DURING FLOATING (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	3.991	318.961	0.000	810.437	0	0	226	53	1	0	0	0	0	0	0	280
FEB	0.000	315.639	0.000	754.636	0	0	180	78	2	0	0	0	0	0	0	260
MAR	0.000	548.485	0.000	678.737	0	0	196	96	4	0	0	0	0	0	0	296
APR	0.000	645.431	0.000	664.994	0	0	120	127	49	0	0	0	0	0	0	296
MAY	0.000	979.939	0.000	197.719	0	0	116	159	5	0	0	0	0	0	0	280
JUN	0.000	1140.437	0.000	134.076	0	0	83	199	14	0	0	0	0	0	0	296
JUL	0.000	1290.084	0.000	16.102	0	0	51	219	26	0	0	0	0	0	0	296
AUG	0.000	1286.023	0.000	20.272	0	0	64	185	43	0	0	0	0	0	0	292
SEP	0.000	1219.889	0.000	23.949	0	0	70	186	28	0	0	0	0	0	0	284
OCT	0.000	1144.077	0.000	108.579	0	0	130	134	28	0	0	0	0	0	0	292
NOV	0.000	752.078	0.000	328.718	0	0	144	110	6	0	0	0	0	0	0	260
DEC	3.991	543.050	0.000	653.784	0	0	233	63	0	0	0	0	0	0	0	296
ANNUAL	7.983	10183.994	0.000	4391.998	0	0	1613	1609	206	0	0	0	0	0	0	3428

BREAKDOWN OF ANNUAL FAN POWER USAGE

FAN TYPE	ANNUAL FAN ELEC (KWH)
SUPPLY	10938.
RETURN	3646.
TOTAL	14584.

REPORT- SS-N Relative Humidity Summary for Sys1 (VAVS) (G)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY																										
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
90-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-89	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
70-79	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
60-69	0	0	0	0	0	0	42	15	5	1	1	1	0	0	0	1	2	4	1	0	0	0	0	0	73	
50-59	0	0	0	0	0	0	108	149	139	115	93	87	105	109	90	97	112	109	23	0	0	0	0	0	1336	
40-49	0	0	0	0	0	0	26	64	79	108	134	143	135	135	121	102	85	89	27	0	0	0	0	0	1248	
30-39	0	0	0	0	0	0	12	35	37	35	30	36	30	33	32	33	33	32	18	0	0	0	0	0	396	
20-29	0	0	0	0	0	0	8	28	30	30	31	19	22	19	21	13	14	12	10	0	0	0	0	0	257	
10-19	0	0	0	0	0	0	4	12	13	14	14	17	11	7	4	4	4	4	5	0	0	0	0	0	113	
0-09	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	5	
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====	

```
*****
*
* NOTE 1)THE RELATIVE HUMIDITY COUNTS ARE MADE ONLY FOR
*         THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
		DY	HR					DY	HR					
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	13346.	47.929
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	12550.	47.929
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	14420.	47.929
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	14376.	47.929
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	13346.	47.929
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	14376.	47.929
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	14416.	47.929
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	13928.	47.929
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	13794.	47.929
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	13924.	47.929
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	12631.	47.929
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	14416.	47.929
TOTAL	0.000						0.000						165520.	
MAX						0.000						0.000		47.929

REPORT- SS-F Zone Demand Summary for East Perim Zn (G.E5)

WEATHER FILE- Los Angeles CA TMY2

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S N O T M E T- -

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	33.64823	0.000	0.00000	0.000	74.8	65.7	0	0
FEB	36.13432	0.000	0.00000	0.000	74.8	68.3	0	0
MAR	44.24158	0.000	0.00000	0.000	74.8	68.3	0	0
APR	53.25169	0.000	0.00000	0.000	75.0	69.7	0	0
MAY	52.06294	0.000	0.00000	0.000	74.8	70.7	0	0
JUN	59.88342	0.000	0.00000	0.000	74.8	70.9	0	0
JUL	69.44157	0.000	0.00000	0.000	74.9	73.2	0	0
AUG	69.03703	0.000	0.00000	0.000	74.9	72.1	0	0
SEP	65.42286	0.000	0.00000	0.000	74.9	71.4	0	0
OCT	57.82146	0.000	0.00000	0.000	74.9	70.3	0	0
NOV	43.26987	0.000	0.00000	0.000	74.9	70.0	0	0
DEC	40.77313	0.000	0.00000	0.000	74.8	67.1	0	0

REPORT- SS-O Space Temperature Summary for East Perim Zn (G.E5)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-75	0	0	0	0	0	0	195	278	288	294	298	298	300	300	267	251	251	251	84	0	0	0	0	0	3355
65-70	0	0	0	0	0	0	5	25	15	9	5	5	3	3	2	0	0	0	1	0	0	0	0	0	73
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

REPORT- SS-G Zone Loads Summary for

Core Zn (G.C6)

WEATHER FILE- Los Angeles CA TMY2

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	866.	3.168
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	816.	3.168
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	939.	3.168
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	937.	3.168
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	866.	3.168
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	937.	3.168
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	939.	3.168
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	905.	3.168
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	898.	3.168
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	905.	3.168
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	820.	3.168
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	939.	3.168
TOTAL	0.000						0.000						10766.	
MAX						0.000						0.000		3.168

REPORT- SS-F Zone Demand Summary for Core Zn (G.C6)

WEATHER FILE- Los Angeles CA TMY2

```

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S   N O T   M E T- -

```

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	1.91253	0.000	0.00000	0.000	73.7	64.3	0	0
FEB	2.00153	0.000	0.00000	0.000	73.4	68.2	0	0
MAR	2.42902	0.000	0.00000	0.000	73.8	67.6	0	0
APR	2.63107	0.000	0.00000	0.000	74.2	67.8	0	0
MAY	2.66532	0.000	0.00000	0.000	74.1	67.5	0	0
JUN	2.94945	0.000	0.00000	0.000	74.2	68.6	0	0
JUL	3.23852	0.000	0.00000	0.000	74.2	67.4	0	0
AUG	3.21647	0.000	0.00000	0.000	74.2	66.8	0	0
SEP	3.08941	0.000	0.00000	0.000	74.1	68.3	0	0
OCT	2.90233	0.000	0.00000	0.000	74.2	67.5	0	0
NOV	2.28058	0.000	0.00000	0.000	73.8	67.4	0	0
DEC	2.42026	0.000	0.00000	0.000	73.4	65.9	0	0

REPORT- SS-O Space Temperature Summary for Core Zn (G.C6)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-75	0	0	0	0	0	0	199	278	273	253	246	244	244	246	248	248	249	249	81	0	0	0	0	0	3058
65-70	0	0	0	0	0	0	1	24	30	50	57	58	58	56	20	3	2	2	4	0	0	0	0	0	365
60-65	0	0	0	0	0	0	0	1	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	5
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

REPORT- SS-A System Loads Summary for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	27.41446	26 14	82.F	55.F	1007.376	0.000	31 24	54.F	52.F	0.000	52069.	193.847	
FEB	31.55919	12 14	85.F	60.F	1086.045	0.000	28 24	50.F	47.F	0.000	49074.	193.337	
MAR	42.45033	31 16	75.F	53.F	1065.840	0.000	31 1	55.F	52.F	0.000	56385.	193.059	
APR	59.47476	13 14	77.F	61.F	1192.291	0.000	30 1	60.F	56.F	0.000	56689.	197.043	
MAY	129.45424	29 16	74.F	65.F	1658.946	0.000	31 1	61.F	57.F	0.000	52429.	191.716	
JUN	176.29857	30 15	75.F	64.F	1550.681	0.000	30 1	64.F	61.F	0.000	56495.	193.720	
JUL	305.43622	20 16	74.F	67.F	1968.438	0.000	31 1	65.F	60.F	0.000	56740.	194.329	
AUG	339.42996	17 15	75.F	68.F	2318.146	0.000	31 1	62.F	59.F	0.000	54987.	193.893	
SEP	267.20264	8 9	72.F	66.F	2004.684	0.000	30 1	64.F	60.F	0.000	54226.	194.197	
OCT	182.67555	22 15	73.F	68.F	1710.804	0.000	31 1	59.F	55.F	0.000	54729.	194.816	
NOV	73.43582	10 13	73.F	62.F	1125.865	0.000	30 24	54.F	46.F	0.000	49433.	194.034	
DEC	52.06366	18 14	76.F	56.F	1006.803	-0.015	12 8	46.F	36.F	-15.409	56137.	192.323	
TOTAL	1686.898					-0.015					649373.		
MAX					2318.146					-15.409		197.043	

REPORT- SS-B System Loads Summary for

Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

	- - Z O N E C O O L I N G - -	- - Z O N E H E A T I N G - -	- - B A S E B O A R D S - -	--PREHEAT OR FURN FAN ELEC--
MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)
			BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)
				PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (MBTU)
				MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (KBTU/HR)
JAN	0.00000	0.000	0.00000	0.000
FEB	0.00000	0.000	0.00000	0.000
MAR	0.00000	0.000	0.00000	0.000
APR	0.00000	0.000	0.00000	0.000
MAY	0.00000	0.000	0.00000	0.000
JUN	0.00000	0.000	0.00000	0.000
JUL	0.00000	0.000	0.00000	0.000
AUG	0.00000	0.000	0.00000	0.000
SEP	0.00000	0.000	0.00000	0.000
OCT	0.00000	0.000	0.00000	0.000
NOV	0.00000	0.000	0.00000	0.000
DEC	0.00000	0.000	0.00000	0.000
	-----	-----	-----	-----
TOTAL	0.000		0.000	
MAX		0.000		0.000

REPORT- SS-C System Load Hours for Sys1 (VAVS) (M) WEATHER FILE- Los Angeles CA TMY2

- - - - - N U M B E R O F H O U R S - - - - -											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	76	0	0	668	744	744	280	0	0	204	0.000	180.408
FEB	76	0	0	596	672	672	260	0	0	184	0.000	180.776
MAR	129	0	0	615	744	744	296	0	0	167	0.000	188.721
APR	139	0	0	581	720	720	296	0	0	157	0.000	183.151
MAY	231	0	0	513	744	744	280	0	0	49	0.000	189.333
JUN	260	0	0	460	720	720	296	0	0	36	0.000	188.463
JUL	292	0	0	452	744	744	296	0	0	4	0.000	189.921
AUG	286	0	0	458	744	744	292	0	0	6	0.000	191.368
SEP	278	0	0	442	720	720	284	0	0	6	0.000	191.419
OCT	263	0	0	481	744	744	292	0	0	29	0.000	186.263
NOV	178	0	0	542	720	720	260	0	0	82	0.000	171.024
DEC	133	1	0	610	744	744	296	0	0	162	0.000	181.984
ANNUAL	2341	1	0	6418	8760	8760	3428	0	0	1086		

REPORT- SS-H System Utility Energy Use for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

	- F A N	E L E C - -	- F U E L	H E A T - -	- F U E L	C O O L - -	- E L E C	H E A T - -	- E L E C	C O O L - -
	FAN	MAXIMUM		MAXIMUM		MAXIMUM		MAXIMUM		MAXIMUM
	ENERGY	FAN	GAS OIL	GAS OIL	GAS OIL	GAS OIL	ELECTRIC	ELECTRIC	ELECTRIC	ELECTRIC
	(KWH)	LOAD	ENERGY	LOAD	ENERGY	LOAD	ENERGY	LOAD	ENERGY	LOAD
MONTH		(KW)	(MBTU)	(KBTU/HR)	(MBTU)	(KBTU/HR)	(KWH)	(KW)	(KWH)	(KW)
JAN	3626.	20.872	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
FEB	3538.	20.362	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAR	4083.	20.404	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
APR	4554.	24.068	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAY	3985.	19.191	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUN	4360.	20.881	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUL	4453.	21.042	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
AUG	4444.	22.146	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
SEP	4189.	21.456	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
OCT	4202.	21.841	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
NOV	3594.	21.059	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
DEC	3851.	19.348	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
TOTAL	48879.		0.000		0.000		0.		0.	
MAX		24.068		0.000		0.000		0.000		0.000

REPORT- SS-I Sensible/Latent Summary for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	27.39482	0.01964	1007.376	1.000	26 14	0.00000	0.00000	0.000
FEB	31.31391	0.24527	1086.045	1.000	12 14	0.00000	0.00000	0.000
MAR	41.06095	1.38938	1065.840	1.000	31 16	0.00000	0.00000	0.000
APR	51.00538	8.46938	1192.291	0.934	13 14	0.00000	0.00000	0.000
MAY	90.74091	38.71334	1658.946	0.614	29 16	0.00000	0.00000	0.000
JUN	112.27961	64.01897	1550.681	0.694	30 15	0.00000	0.00000	0.000
JUL	190.37201	115.06421	1968.438	0.533	20 16	0.00000	0.00000	0.000
AUG	200.00127	139.42868	2318.146	0.520	17 15	0.00000	0.00000	0.000
SEP	181.24564	85.95700	2004.684	0.527	8 9	0.00000	0.00000	0.000
OCT	124.35840	58.31716	1710.804	0.481	22 15	0.00000	0.00000	0.000
NOV	60.64782	12.78800	1125.865	0.752	10 13	0.00000	0.00000	0.000
DEC	50.00134	2.06232	1006.803	1.000	18 14	-0.01541	0.00000	-15.409
TOTAL	1160.424	526.473				-0.015	0.000	
MAX			2318.146	0.520				-15.409

REPORT- SS-J Peak Heating and Cooling for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

- - - - C O O L I N G - - - - -					- - - H E A T I N G - - -			D A Y C O O L I N G P E A K			
AUG 17					DEC 12			AUG 13			
HOURLY	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-	
COOLING	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB	
LOAD	RATIO	TEMP	TEMP	LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP	
(KBTU)				(KBTU)			(KBTU)				
1	0.000	0.000	69.F	65.F	0.000	46.F	36.F	0.000	0.000	69.F	63.F
2	0.000	0.000	69.F	64.F	0.000	42.F	35.F	0.000	0.000	68.F	62.F
3	0.000	0.000	69.F	64.F	0.000	40.F	34.F	0.000	0.000	68.F	64.F
4	0.000	0.000	69.F	64.F	0.000	40.F	34.F	0.000	0.000	68.F	65.F
5	0.000	0.000	69.F	64.F	0.000	42.F	34.F	0.000	0.000	68.F	65.F
6	0.000	0.000	69.F	64.F	0.000	40.F	33.F	0.000	0.000	68.F	65.F
7	942.213	0.583	70.F	65.F	0.000	41.F	33.F	924.866	0.532	70.F	66.F
8	2009.734	0.548	73.F	66.F	-15.409	46.F	36.F	2115.031	0.498	74.F	68.F
9	2291.716	0.519	75.F	68.F	0.000	50.F	38.F	2232.660	0.488	75.F	69.F
10	1485.130	0.801	76.F	68.F	0.000	53.F	40.F	2256.042	0.488	75.F	69.F
11	1444.962	0.798	77.F	69.F	0.000	56.F	42.F	1327.754	0.776	76.F	69.F
12	1373.388	0.806	76.F	68.F	0.000	58.F	42.F	1316.302	0.784	77.F	69.F
13	1441.585	0.798	76.F	68.F	0.000	60.F	43.F	1399.297	0.778	77.F	69.F
14	2318.146	0.520	75.F	68.F	0.000	59.F	46.F	1447.305	0.775	76.F	69.F
15	2035.156	0.595	75.F	66.F	0.000	57.F	45.F	2251.760	0.517	75.F	68.F
16	2028.445	0.596	75.F	66.F	0.000	55.F	44.F	2239.304	0.517	75.F	68.F
17	1942.300	0.514	73.F	67.F	0.000	52.F	43.F	1983.204	0.480	73.F	68.F
18	1252.102	0.538	71.F	65.F	0.000	51.F	42.F	1118.888	0.517	70.F	65.F
19	0.000	0.000	68.F	64.F	0.000	52.F	42.F	0.000	0.000	68.F	63.F
20	0.000	0.000	68.F	62.F	0.000	52.F	42.F	0.000	0.000	68.F	63.F
21	0.000	0.000	67.F	63.F	0.000	50.F	40.F	0.000	0.000	67.F	63.F
22	0.000	0.000	67.F	62.F	0.000	48.F	40.F	0.000	0.000	67.F	63.F
23	0.000	0.000	67.F	61.F	0.000	48.F	40.F	0.000	0.000	67.F	63.F
24	0.000	0.000	67.F	62.F	0.000	46.F	38.F	0.000	0.000	67.F	63.F

SUM								20612.412			
MAX	2318.146				-15.409						

SYSTEM-TYPE	VAVS	SQFT/TON	584.5
COOLING PEAK	20.53 (BTU/HR- SQFT)	HEATING PEAK	-0.14 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.15 (CFM/SQFT)	MIN-OA/PERSON	14.26 (CFM)
OA FRAC AT CLG PEAK	1.000	OA FRAC AT HTG PEAK	0.336

* ASTERISKS INDICATE HOURS LOADS NOT MET

REPORT- SS-K Space Temperature Summary for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

MONTH	A V E R A G E		S P A C E		T E M P		AVERAGE TEMPERATURE	DIFFERENCE	SUMMED TEMP	DIFFERENCE	HUMIDITY RATIO
	ALL HOURS (F)	COOLING HOURS (F)	HEATING HOURS (F)	FAN ON HOURS (F)	FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN ON HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR HEATING HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	DIFFERENCE BETWEEN OUTDOOR AND ROOM AIR (FRAC.OR MULT.)
JAN	72.49	73.58	0.00	73.38	71.96	-16.46	-14.21	-17.83	0.00	513.57	-0.00115
FEB	73.54	74.40	0.00	74.06	73.22	-17.67	-14.12	-19.92	0.00	499.59	-0.00075
MAR	74.38	74.41	0.00	74.12	74.55	-16.19	-12.43	-18.66	0.00	505.08	-0.00070
APR	75.78	74.50	0.00	74.47	76.69	-15.78	-12.30	-18.21	0.00	476.13	-0.00042
MAY	76.08	74.38	0.00	74.37	77.11	-13.49	-8.35	-16.58	0.00	422.26	0.00034
JUN	76.41	74.47	0.00	74.45	77.77	-12.65	-7.77	-16.06	0.00	380.49	0.00054
JUL	77.47	74.55	0.00	74.55	79.40	-9.87	-4.11	-13.68	0.00	314.23	0.00150
AUG	77.59	74.51	0.00	74.51	79.58	-9.39	-3.29	-13.33	0.00	302.77	0.00199
SEP	77.25	74.48	0.00	74.48	79.06	-9.35	-3.49	-13.16	0.00	309.21	0.00104
OCT	76.33	74.39	0.00	74.37	77.60	-11.68	-6.80	-14.83	0.00	369.16	0.00031
NOV	75.03	74.31	0.00	74.29	75.45	-14.29	-10.13	-16.64	0.00	431.57	-0.00026
DEC	74.11	74.20	68.95	74.05	74.14	-16.14	-12.22	-18.72	0.96	506.69	-0.00073
ANNUAL	75.55	74.41	68.95	74.26	76.38	-13.55	-9.05	-16.45	0.96	5030.76	0.00015

WEATHER FILE- Los Angeles CA TMY2

REPORT- SS-L Fan Electric Energy Use for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

MONTH	FAN ELEC DURING HEATING (KWH)	FAN ELEC DURING COOLING (KWH)	FAN ELEC DURING HEAT & COOL (KWH)	FAN ELEC DURING FLOATING (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	0.000	1008.396	0.000	2617.259	0	0	139	108	33	0	0	0	0	0	0	280
FEB	0.000	1062.337	0.000	2475.917	0	0	111	90	59	0	0	0	0	0	0	260
MAR	0.000	1837.603	0.000	2245.838	0	0	95	131	70	0	0	0	0	0	0	296
APR	0.000	2227.875	0.000	2326.442	0	0	59	101	125	11	0	0	0	0	0	296
MAY	0.000	3346.440	0.000	638.906	0	0	52	141	87	0	0	0	0	0	0	280
JUN	0.000	3881.178	0.000	478.532	0	0	34	146	116	0	0	0	0	0	0	296
JUL	0.000	4401.249	0.000	51.667	0	0	33	128	135	0	0	0	0	0	0	296
AUG	0.000	4365.223	0.000	79.231	0	0	43	106	142	1	0	0	0	0	0	292
SEP	0.000	4113.804	0.000	75.497	0	0	41	140	103	0	0	0	0	0	0	284
OCT	0.000	3832.437	0.000	369.473	0	0	65	138	89	0	0	0	0	0	0	292
NOV	0.000	2518.906	0.000	1074.693	0	0	77	122	61	0	0	0	0	0	0	260
DEC	11.974	1761.501	0.000	2077.250	0	0	143	115	38	0	0	0	0	0	0	296
ANNUAL	11.974	34356.926	0.000	14510.745	0	0	892	1466	1058	12	0	0	0	0	0	3428

BREAKDOWN OF ANNUAL FAN POWER USAGE

FAN TYPE	ANNUAL FAN ELEC (KWH)
SUPPLY	36660.
RETURN	12220.
TOTAL	48879.

REPORT- SS-N Relative Humidity Summary for Sys1 (VAVS) (M)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
90-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-89	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-79	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
60-69	0	0	0	0	0	0	24	9	3	1	1	1	0	0	0	0	2	4	0	0	0	0	0	0	45
50-59	0	0	0	0	0	0	115	133	124	97	80	77	81	84	73	83	100	102	23	0	0	0	0	0	1172
40-49	0	0	0	0	0	0	30	79	91	121	140	147	152	155	135	115	94	95	27	0	0	0	0	0	1381
30-39	0	0	0	0	0	0	18	35	37	36	35	39	35	37	35	32	35	29	18	0	0	0	0	0	421
20-29	0	0	0	0	0	0	9	34	32	32	30	20	24	19	20	16	13	16	11	0	0	0	0	0	276
10-19	0	0	0	0	0	0	4	13	16	16	17	19	11	8	5	4	6	4	5	0	0	0	0	0	128
0-09	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	5
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE RELATIVE HUMIDITY COUNTS ARE MADE ONLY FOR
*         THE HOURS WHEN THE FANS ARE ON
*
*****
```

REPORT- SS-G Zone Loads Summary for

East Perim Zn (M.E9)

WEATHER FILE- Los Angeles CA TMY2

- - - - - C O O L I N G - - - - -							- - - - - H E A T I N G - - - - -						- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)			
JAN	0.00000	31 24	54.F	52.F	0.000	0.000	31 24	54.F	52.F	0.000	15424.	55.182			
FEB	0.00000	28 24	50.F	47.F	0.000	0.000	28 24	50.F	47.F	0.000	14497.	55.182			
MAR	0.00000	31 1	55.F	52.F	0.000	0.000	31 1	55.F	52.F	0.000	16651.	55.182			
APR	0.00000	30 1	60.F	56.F	0.000	0.000	30 1	60.F	56.F	0.000	16597.	55.182			
MAY	0.00000	31 1	61.F	57.F	0.000	0.000	31 1	61.F	57.F	0.000	15424.	55.182			
JUN	0.00000	30 1	64.F	61.F	0.000	0.000	30 1	64.F	61.F	0.000	16597.	55.182			
JUL	0.00000	31 1	65.F	60.F	0.000	0.000	31 1	65.F	60.F	0.000	16646.	55.182			
AUG	0.00000	31 1	62.F	59.F	0.000	0.000	31 1	62.F	59.F	0.000	16092.	55.182			
SEP	0.00000	30 1	64.F	60.F	0.000	0.000	30 1	64.F	60.F	0.000	15930.	55.182			
OCT	0.00000	31 1	59.F	55.F	0.000	0.000	31 1	59.F	55.F	0.000	16087.	55.182			
NOV	0.00000	30 24	54.F	46.F	0.000	0.000	30 24	54.F	46.F	0.000	14594.	55.182			
DEC	0.00000	31 24	59.F	57.F	0.000	0.000	31 24	59.F	57.F	0.000	16646.	55.182			
TOTAL	0.000					0.000					191181.				
MAX					0.000					0.000		55.182			

REPORT- SS-F Zone Demand Summary for East Perim Zn (M.E9)

WEATHER FILE- Los Angeles CA TMY2

```

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S   N O T   M E T- -
MONTH      HEAT      HEAT      BASEBOARD      MAXIMUM      MAXIMUM      MINIMUM      HOURS      HOURS
            EXTRACTION  ADDITION  ENERGY        BASEBOARD    ZONE         ZONE         UNDER      UNDER
            ENERGY    ENERGY    (MBTU)         LOAD         TEMP         TEMP         HEATED      COOLED
            (MBTU)      (MBTU)
JAN         43.09705      0.000      0.00000         0.000        75.0         66.9         0           0
FEB         45.85900      0.000      0.00000         0.000        75.0         69.6         0           0
MAR         55.90466      0.000      0.00000         0.000        75.0         69.5         0           0
APR         64.59766      0.000      0.00000         0.000        75.1         70.9         0           0
MAY         62.28926      0.000      0.00000         0.000        75.0         71.9         0           0
JUN         70.41377      0.000      0.00000         0.000        75.0         71.9         0           0
JUL         79.59129      0.000      0.00000         0.000        75.0         74.0         0           0
AUG         78.53859      0.000      0.00000         0.000        75.1         73.0         0           0
SEP         74.98852      0.000      0.00000         0.000        75.0         72.3         0           0
OCT         67.99451      0.000      0.00000         0.000        75.1         71.2         0           0
NOV         52.72510      0.000      0.00000         0.000        75.0         71.0         0           0
DEC         51.56677      0.000      0.00000         0.000        75.0         68.7         0           0

```


REPORT- SS-O Space Temperature Summary for East Perim Zn (M.E9)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	3	2	0	0	0	1	3	17	23	2	0	0	0	0	0	0	0	51
70-75	0	0	0	0	0	0	199	286	298	300	300	300	300	297	250	228	249	251	85	0	0	0	0	0	3343
65-70	0	0	0	0	0	0	1	14	3	3	3	3	2	3	2	0	0	0	0	0	0	0	0	0	34
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

REPORT- SS-G Zone Loads Summary for

Core Zn (M.C10)

WEATHER FILE- Los Angeles CA TMY2

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	724.	2.614
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	681.	2.614
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	783.	2.614
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	781.	2.614
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	724.	2.614
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	781.	2.614
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	783.	2.614
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	756.	2.614
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	749.	2.614
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	756.	2.614
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	685.	2.614
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	783.	2.614
TOTAL	0.000						0.000						8985.	
MAX						0.000						0.000		2.614

REPORT- SS-F Zone Demand Summary for

Core Zn (M.C10)

WEATHER FILE- Los Angeles CA TMY2

- - - D E M A N D S - - - - - B A S E B O A R D S - - - - - T E M P E R A T U R E S - - - L O A D S N O T M E T - -								
MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	2.16574	0.000	0.00000	0.000	74.3	65.2	0	0
FEB	2.27664	0.000	0.00000	0.000	74.3	69.2	0	0
MAR	2.72175	0.000	0.00000	0.000	74.3	68.6	0	0
APR	2.88696	0.000	0.00000	0.000	74.3	68.4	0	0
MAY	2.83980	0.000	0.00000	0.000	74.3	67.7	0	0
JUN	3.09432	0.000	0.00000	0.000	74.3	69.2	0	0
JUL	3.27946	0.000	0.00000	0.000	74.3	67.5	0	0
AUG	3.25348	0.000	0.00000	0.000	74.3	67.0	0	0
SEP	3.13263	0.000	0.00000	0.000	74.3	68.6	0	0
OCT	3.03251	0.000	0.00000	0.000	74.3	68.1	0	0
NOV	2.45625	0.000	0.00000	0.000	74.3	68.1	0	0
DEC	2.68436	0.000	0.00000	0.000	74.3	66.5	0	0

REPORT- SS-O Space Temperature Summary for Core Zn (M.C10)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-75	0	0	0	0	0	0	200	297	293	281	272	262	257	251	248	250	250	249	82	0	0	0	0	0	3192
65-70	0	0	0	0	0	0	0	6	10	22	31	41	46	52	21	1	1	2	3	0	0	0	0	0	236
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
		DY	HR					DY	HR					
JAN	8.43284	26	15	80.F	54.F	319.469	-0.004	3	8	53.F	42.F	-3.575	17299.	64.123
FEB	9.72835	12	16	77.F	59.F	352.667	-0.008	28	8	49.F	39.F	-3.185	16276.	63.974
MAR	12.98222	31	16	75.F	53.F	341.862	0.000	31	1	55.F	52.F	0.000	18700.	63.484
APR	18.45714	13	14	77.F	61.F	377.974	0.000	30	1	60.F	56.F	0.000	18743.	64.917
MAY	40.57726	29	16	74.F	65.F	546.532	0.000	31	1	61.F	57.F	0.000	17379.	63.308
JUN	55.57641	30	15	75.F	64.F	501.939	0.000	30	1	64.F	61.F	0.000	18726.	63.643
JUL	97.04470	20	16	74.F	67.F	633.555	0.000	31	1	65.F	60.F	0.000	18823.	64.099
AUG	108.13519	17	15	75.F	68.F	750.563	0.000	31	1	62.F	59.F	0.000	18242.	64.034
SEP	84.87935	8	9	72.F	66.F	640.359	0.000	30	1	64.F	60.F	0.000	17998.	64.199
OCT	56.90323	7	16	71.F	66.F	540.223	0.000	31	1	59.F	55.F	0.000	18147.	63.973
NOV	22.33032	9	16	70.F	62.F	353.794	0.000	30	24	54.F	46.F	0.000	16391.	63.719
DEC	15.43610	18	14	76.F	56.F	316.429	-0.003	12	8	46.F	36.F	-3.091	18647.	62.943
TOTAL	530.483						-0.014						215367.	
MAX						750.563						-3.575		64.917

REPORT- SS-B System Loads Summary for

Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

	- - Z O N E C O O L I N G - -		- - Z O N E H E A T I N G - -		- - B A S E B O A R D S - -		--PREHEAT OR FURN FAN ELEC--	
MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)	BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)	PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (MBTU)	MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (KBTU/HR)
JAN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
FEB	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
MAR	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
APR	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
MAY	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUL	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
AUG	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
SEP	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
OCT	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
NOV	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
DEC	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
	-----	-----	-----	-----	-----	-----	-----	-----
TOTAL	0.000		0.000		0.000		0.000	
MAX		0.000		0.000		0.000		0.000

REPORT- SS-C System Load Hours for Sys1 (VAVS) (T) WEATHER FILE- Los Angeles CA TMY2

- - - - - N U M B E R O F H O U R S - - - - -											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	78	1	0	665	744	744	280	0	0	201	0.000	61.665
FEB	76	3	0	593	672	672	260	0	0	181	0.000	62.210
MAR	130	0	0	614	744	744	296	0	0	166	0.000	62.622
APR	141	0	0	579	720	720	296	0	0	155	0.000	60.731
MAY	231	0	0	513	744	744	280	0	0	49	0.000	63.006
JUN	263	0	0	457	720	720	296	0	0	33	0.000	62.606
JUL	292	0	0	452	744	744	296	0	0	4	0.000	62.993
AUG	286	0	0	458	744	744	292	0	0	6	0.000	63.476
SEP	278	0	0	442	720	720	284	0	0	6	0.000	63.254
OCT	265	0	0	479	744	744	292	0	0	27	0.000	63.742
NOV	179	0	0	541	720	720	260	0	0	81	0.000	63.285
DEC	133	1	0	610	744	744	296	0	0	162	0.000	60.404
ANNUAL	2352	5	0	6403	8760	8760	3428	0	0	1071		

REPORT- SS-H System Utility Energy Use for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

	- FAN	ELEC -	- FUEL	HEAT -	- FUEL	COOL -	ELEC	HEAT -	ELEC	COOL -
	FAN	MAXIMUM	GAS OIL	MAXIMUM	GAS OIL	MAXIMUM	ELECTRIC	MAXIMUM	ELECTRIC	MAXIMUM
MONTH	ENERGY	FAN	ENERGY	GAS OIL	ENERGY	GAS OIL	ENERGY	ELECTRIC	ENERGY	ELECTRIC
	(KWH)	LOAD	(MBTU)	LOAD	(MBTU)	LOAD	(KWH)	LOAD	(KWH)	LOAD
		(KW)		(KBTU/HR)		(KBTU/HR)		(KW)		(KW)
JAN	1151.	6.465	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
FEB	1097.	6.315	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAR	1266.	5.837	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
APR	1364.	7.259	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAY	1231.	5.832	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUN	1347.	6.107	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUL	1394.	6.360	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
AUG	1394.	6.736	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
SEP	1319.	6.687	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
OCT	1305.	6.562	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
NOV	1111.	6.060	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
DEC	1218.	5.296	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
TOTAL	15199.		0.000		0.000		0.		0.	
MAX		7.259		0.000		0.000		0.000		0.000

REPORT- SS-I Sensible/Latent Summary for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	8.42630	0.00655	319.469	1.000	26 15	-0.00358	0.00000	-3.575
FEB	9.65099	0.07735	352.667	0.962	12 16	-0.00760	0.00000	-3.185
MAR	12.56705	0.41518	341.862	1.000	31 16	0.00000	0.00000	0.000
APR	15.84906	2.60808	377.974	0.931	13 14	0.00000	0.00000	0.000
MAY	28.39283	12.18443	546.532	0.614	29 16	0.00000	0.00000	0.000
JUN	35.37994	20.19647	501.939	0.694	30 15	0.00000	0.00000	0.000
JUL	60.50109	36.54361	633.555	0.534	20 16	0.00000	0.00000	0.000
AUG	63.68565	44.44954	750.563	0.521	17 15	0.00000	0.00000	0.000
SEP	57.75976	27.11959	640.359	0.527	8 9	0.00000	0.00000	0.000
OCT	38.66622	18.23702	540.223	0.501	7 16	0.00000	0.00000	0.000
NOV	18.47785	3.85247	353.794	0.655	9 16	0.00000	0.00000	0.000
DEC	14.82357	0.61253	316.429	1.000	18 14	-0.00309	0.00000	-3.091
TOTAL	364.180	166.303				-0.014	0.000	
MAX			750.563	0.521				-3.575

REPORT- SS-J Peak Heating and Cooling for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

- - - - - C O O L I N G - - - - -					- - - H E A T I N G - - -			D A Y C O O L I N G P E A K				
AUG 17					JAN 3			AUG 13				
HOURLY COOLING LOAD KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP		
1	0.000	0.000	69.F	65.F	0.000	51.F	43.F	0.000	0.000	69.F	63.F	
2	0.000	0.000	69.F	64.F	0.000	51.F	41.F	0.000	0.000	68.F	62.F	
3	0.000	0.000	69.F	64.F	0.000	51.F	41.F	0.000	0.000	68.F	64.F	
4	0.000	0.000	69.F	64.F	0.000	54.F	42.F	0.000	0.000	68.F	65.F	
5	0.000	0.000	69.F	64.F	0.000	51.F	41.F	0.000	0.000	68.F	65.F	
6	0.000	0.000	69.F	64.F	0.000	52.F	42.F	0.000	0.000	68.F	65.F	
7	304.650	0.585	70.F	65.F	0.000	53.F	42.F	299.707	0.532	70.F	66.F	
8	648.479	0.548	73.F	66.F	-3.575	53.F	42.F	682.091	0.498	74.F	68.F	
9	741.526	0.519	75.F	68.F	0.000	55.F	43.F	722.789	0.488	75.F	69.F	
10	480.815	0.796	76.F	68.F	0.000	57.F	44.F	729.177	0.488	75.F	69.F	
11	467.178	0.793	77.F	69.F	0.000	60.F	46.F	431.167	0.771	76.F	69.F	
12	443.925	0.801	76.F	68.F	0.000	61.F	46.F	428.078	0.779	77.F	69.F	
13	467.715	0.793	76.F	68.F	0.000	62.F	47.F	456.931	0.774	77.F	69.F	
14	750.563	0.521	75.F	68.F	0.000	64.F	46.F	474.411	0.772	76.F	69.F	
15	660.976	0.596	75.F	66.F	0.000	64.F	47.F	738.319	0.517	75.F	68.F	
16	659.657	0.596	75.F	66.F	0.000	60.F	50.F	735.719	0.517	75.F	68.F	
17	632.277	0.514	73.F	67.F	0.000	59.F	50.F	652.455	0.480	73.F	68.F	
18	406.671	0.538	71.F	65.F	0.000	59.F	49.F	368.455	0.517	70.F	65.F	
19	0.000	0.000	68.F	64.F	0.000	56.F	49.F	0.000	0.000	68.F	63.F	
20	0.000	0.000	68.F	62.F	0.000	56.F	48.F	0.000	0.000	68.F	63.F	
21	0.000	0.000	67.F	63.F	0.000	57.F	46.F	0.000	0.000	67.F	63.F	
22	0.000	0.000	67.F	62.F	0.000	56.F	46.F	0.000	0.000	67.F	63.F	
23	0.000	0.000	67.F	61.F	0.000	57.F	46.F	0.000	0.000	67.F	63.F	
24	0.000	0.000	67.F	62.F	0.000	57.F	47.F	0.000	0.000	67.F	63.F	
-----					-----			-----				
SUM								6719.299				
MAX	750.563				-3.575							

SYSTEM-TYPE	VAVS	SQFT/TON	877.1
COOLING PEAK	13.68 (BTU/HR- SQFT)	HEATING PEAK	-0.07 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	0.79 (CFM/SQFT)	MIN-OA/PERSON	14.26 (CFM)
OA FRAC AT CLG PEAK	1.000	OA FRAC AT HTG PEAK	0.336

* ASTERISKS INDICATE HOURS LOADS NOT MET

REPORT- SS-K Space Temperature Summary for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

MONTH	A V E R A G E		S P A C E T E M P			AVERAGE	TEMPERATURE	DIFFERENCE	SUMMED TEMP	DIFFERENCE	HUMIDITY RATIO DIFFERENCE BETWEEN OUTDOOR AND ROOM AIR (FRAC.OR MULT.)
	ALL HOURS (F)	COOLING HOURS (F)	HEATING HOURS (F)	FAN ON HOURS (F)	FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN ON HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR HEATING HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	
JAN	70.99	73.06	65.48	72.60	70.02	-14.96	-13.42	-15.89	0.52	467.97	-0.00119
FEB	72.01	74.10	67.87	73.35	71.16	-16.14	-13.41	-17.86	2.44	456.64	-0.00080
MAR	73.06	74.10	0.00	73.61	72.71	-14.87	-11.92	-16.82	0.00	464.69	-0.00074
APR	74.74	74.17	0.00	74.07	75.22	-14.75	-11.89	-16.75	0.00	445.56	-0.00046
MAY	75.27	74.10	0.00	74.07	75.99	-12.68	-8.05	-15.47	0.00	397.36	0.00032
JUN	75.74	74.24	0.00	74.22	76.80	-11.98	-7.53	-15.09	0.00	360.54	0.00053
JUL	77.00	74.43	0.00	74.43	78.69	-9.40	-3.98	-12.97	0.00	299.77	0.00149
AUG	77.16	74.37	0.00	74.36	78.97	-8.96	-3.14	-12.72	0.00	290.44	0.00198
SEP	76.73	74.34	0.00	74.33	78.30	-8.83	-3.35	-12.40	0.00	293.78	0.00103
OCT	75.52	74.11	0.00	74.08	76.44	-10.86	-6.51	-13.68	0.00	344.43	0.00029
NOV	73.83	73.90	0.00	73.84	73.82	-13.08	-9.68	-15.01	0.00	396.09	-0.00030
DEC	72.66	73.82	65.72	73.39	72.18	-14.69	-11.56	-16.76	0.82	463.34	-0.00078
ANNUAL	74.57	74.16	66.97	73.87	75.03	-12.58	-8.65	-15.10	3.78	4680.61	0.00012

WEATHER FILE- Los Angeles CA TMY2

REPORT- SS-L Fan Electric Energy Use for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

MONTH	FAN ELEC DURING HEATING (KWH)	FAN ELEC DURING COOLING (KWH)	FAN ELEC DURING HEAT & COOL (KWH)	FAN ELEC DURING FLOATING (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	3.991	328.557	0.000	818.388	0	0	209	65	6	0	0	0	0	0	0	280
FEB	11.974	330.667	0.000	754.686	0	0	159	82	19	0	0	0	0	0	0	260
MAR	0.000	569.218	0.000	696.784	0	0	165	100	31	0	0	0	0	0	0	296
APR	0.000	680.876	0.000	683.410	0	0	107	112	77	0	0	0	0	0	0	296
MAY	0.000	1030.825	0.000	200.218	0	0	86	157	37	0	0	0	0	0	0	280
JUN	0.000	1211.399	0.000	136.012	0	0	55	181	60	0	0	0	0	0	0	296
JUL	0.000	1377.941	0.000	16.386	0	0	38	180	78	0	0	0	0	0	0	296
AUG	0.000	1369.445	0.000	24.878	0	0	51	146	95	0	0	0	0	0	0	292
SEP	0.000	1294.917	0.000	24.123	0	0	51	162	71	0	0	0	0	0	0	284
OCT	0.000	1195.266	0.000	109.460	0	0	92	148	52	0	0	0	0	0	0	292
NOV	0.000	777.410	0.000	334.012	0	0	122	115	23	0	0	0	0	0	0	260
DEC	3.991	555.250	0.000	658.588	0	0	215	73	8	0	0	0	0	0	0	296
ANNUAL	19.957	10721.705	0.000	4456.936	0	0	1350	1521	557	0	0	0	0	0	0	3428

BREAKDOWN OF ANNUAL FAN POWER USAGE

FAN TYPE	ANNUAL FAN ELEC (KWH)
SUPPLY	11399.
RETURN	3800.
TOTAL	15198.

REPORT- SS-N Relative Humidity Summary for Sys1 (VAVS) (T)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY																										
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
90-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-89	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
70-79	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
60-69	0	0	0	0	0	0	36	15	7	1	1	1	0	0	0	1	2	4	1	0	0	0	0	0	69	
50-59	0	0	0	0	0	0	114	150	135	118	96	89	102	101	85	91	111	108	22	0	0	0	0	0	1322	
40-49	0	0	0	0	0	0	27	64	81	106	131	143	139	143	126	108	85	89	28	0	0	0	0	0	1270	
30-39	0	0	0	0	0	0	11	35	35	35	31	32	28	33	32	33	34	33	18	0	0	0	0	0	390	
20-29	0	0	0	0	0	0	8	27	32	28	30	21	23	19	21	13	14	12	10	0	0	0	0	0	258	
10-19	0	0	0	0	0	0	4	12	13	15	14	17	11	7	4	4	4	4	5	0	0	0	0	0	114	
0-09	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	5	
	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====	

```
*****
*
* NOTE 1)THE RELATIVE HUMIDITY COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY	HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY	HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	15424.	55.182
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	14497.	55.182
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	16651.	55.182
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	16597.	55.182
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	15424.	55.182
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	16597.	55.182
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	16646.	55.182
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	16092.	55.182
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	15930.	55.182
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	16087.	55.182
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	14594.	55.182
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	16646.	55.182
TOTAL	0.000						0.000						191181.	
MAX						0.000						0.000		55.182

REPORT- SS-F Zone Demand Summary for East Perim Zn (T.E13)

WEATHER FILE- Los Angeles CA TMY2

```

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S   N O T   M E T- -
MONTH      HEAT      HEAT      BASEBOARD      MAXIMUM      MAXIMUM      MINIMUM      HOURS      HOURS
            EXTRACTION  ADDITION  ENERGY        BASEBOARD    ZONE         ZONE         UNDER      UNDER
            (MBTU)      (MBTU)      (MBTU)        (KBTU/HR)    TEMP         TEMP         HEATED      COOLED
            (F)
JAN         35.78370      0.000      0.00000      0.000      75.0         65.5         0          0
FEB         38.29678      0.000      0.00000      0.000      74.9         67.6         0          0
MAR         47.77815      0.000      0.00000      0.000      74.9         67.6         0          0
APR         56.25680      0.000      0.00000      0.000      75.0         69.4         0          0
MAY         56.05357      0.000      0.00000      0.000      74.9         70.8         0          0
JUN         64.61814      0.000      0.00000      0.000      74.9         70.6         0          0
JUL         74.75494      0.000      0.00000      0.000      74.9         73.5         0          0
AUG         73.88406      0.000      0.00000      0.000      75.0         72.1         0          0
SEP         70.35875      0.000      0.00000      0.000      75.0         71.5         0          0
OCT         61.66469      0.000      0.00000      0.000      75.0         70.0         0          0
NOV         45.55919      0.000      0.00000      0.000      74.9         69.3         0          0
DEC         42.67785      0.000      0.00000      0.000      74.8         65.5         0          0

```


REPORT- SS-O Space Temperature Summary for East Perim Zn (T.E13)

WEATHER FILE- Los Angeles CA TMY2

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	2	0	0	0	0	0	0	0	0	5
70-75	0	0	0	0	0	0	193	275	287	290	292	296	298	300	264	249	251	251	84	0	0	0	0	0	3330
65-70	0	0	0	0	0	0	7	28	16	13	11	7	5	3	2	0	0	0	1	0	0	0	0	0	93
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

```
*****
*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*
*****
```

WEATHER FILE- Los Angeles CA TMY2

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
		DY	HR					DY	HR					
JAN	0.00000	31	24	54.F	52.F	0.000	0.000	31	24	54.F	52.F	0.000	724.	2.614
FEB	0.00000	28	24	50.F	47.F	0.000	0.000	28	24	50.F	47.F	0.000	681.	2.614
MAR	0.00000	31	1	55.F	52.F	0.000	0.000	31	1	55.F	52.F	0.000	783.	2.614
APR	0.00000	30	1	60.F	56.F	0.000	0.000	30	1	60.F	56.F	0.000	781.	2.614
MAY	0.00000	31	1	61.F	57.F	0.000	0.000	31	1	61.F	57.F	0.000	724.	2.614
JUN	0.00000	30	1	64.F	61.F	0.000	0.000	30	1	64.F	61.F	0.000	781.	2.614
JUL	0.00000	31	1	65.F	60.F	0.000	0.000	31	1	65.F	60.F	0.000	783.	2.614
AUG	0.00000	31	1	62.F	59.F	0.000	0.000	31	1	62.F	59.F	0.000	756.	2.614
SEP	0.00000	30	1	64.F	60.F	0.000	0.000	30	1	64.F	60.F	0.000	749.	2.614
OCT	0.00000	31	1	59.F	55.F	0.000	0.000	31	1	59.F	55.F	0.000	756.	2.614
NOV	0.00000	30	24	54.F	46.F	0.000	0.000	30	24	54.F	46.F	0.000	685.	2.614
DEC	0.00000	31	24	59.F	57.F	0.000	0.000	31	24	59.F	57.F	0.000	783.	2.614
TOTAL	0.000						0.000						8985.	
MAX							0.000							2.614

REPORT- SS-F Zone Demand Summary for Core Zn (T.C14)

WEATHER FILE- Los Angeles CA TMY2

```

- - - -D E M A N D S- - - - -B A S E B O A R D S- - - - -T E M P E R A T U R E S- - - -L O A D S   N O T   M E T- -

```

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	1.75460	0.000	0.00000	0.000	73.0	63.6	0	0
FEB	1.82962	0.000	0.00000	0.000	72.7	67.0	0	0
MAR	2.26783	0.000	0.00000	0.000	73.3	66.8	0	0
APR	2.46023	0.000	0.00000	0.000	73.9	67.1	0	0
MAY	2.56186	0.000	0.00000	0.000	73.8	67.5	0	0
JUN	2.86998	0.000	0.00000	0.000	74.1	67.8	0	0
JUL	3.18079	0.000	0.00000	0.000	74.2	67.4	0	0
AUG	3.15528	0.000	0.00000	0.000	74.0	66.8	0	0
SEP	3.03334	0.000	0.00000	0.000	74.0	67.8	0	0
OCT	2.80002	0.000	0.00000	0.000	74.0	66.9	0	0
NOV	2.12986	0.000	0.00000	0.000	73.2	66.7	0	0
DEC	2.20016	0.000	0.00000	0.000	72.9	65.4	0	0

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY																									
HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-75	0	0	0	0	0	0	193	251	242	232	227	216	220	235	244	246	248	246	70	0	0	0	0	0	2870
65-70	0	0	0	0	0	0	7	50	60	70	75	86	82	67	24	5	3	5	15	0	0	0	0	0	549
60-65	0	0	0	0	0	0	0	2	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	9
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

*
* NOTE 1)THE TEMPERATURE COUNTS ARE MADE ONLY FOR
* THE HOURS WHEN THE FANS ARE ON
*

REPORT- PV-A Plant Design Parameters

WEATHER FILE- Los Angeles CA TMY2

*** CIRCULATION LOOPS ***

HEATING CAPACITY (MBTU/HR)	COOLING CAPACITY (MBTU/HR)	LOOP FLOW (GAL/MIN)	TOTAL HEAD (FT)	SUPPLY UA PRODUCT (BTU/HR-F)	SUPPLY LOSS DT (F)	RETURN UA PRODUCT (BTU/HR-F)	RETURN LOSS DT (F)	LOOP VOLUME (GAL)	FLUID HEAT CAPACITY (BTU/LB-F)
Chilled Water Loop 0.000	8.998	1778.0	56.6	0.0	0.00	0.0	0.00	2667.0	1.00
Condenser Water Loop 0.000	11.278	2226.3	61.6	0.0	0.00	0.0	0.00	3339.4	1.00

*** PUMPS ***

ATTACHED TO	FLOW (GAL/MIN)	HEAD (FT)	HEAD SETPOINT (FT)	CAPACITY CONTROL	POWER (KW)	MECHANICAL EFFICIENCY (FRAC)	MOTOR EFFICIENCY (FRAC)
CHW Loop Pump Chilled Water Loop PRIMARY LOOP	1 PUMP(s) 1778.0	67.9	0.0	ONE-SPEED	31.769	0.770	0.930
CW Loop Pump Condenser Water Loop PRIMARY LOOP	1 PUMP(s) 2226.3	73.9	0.0	ONE-SPEED	44.736	0.770	0.900

*** PRIMARY EQUIPMENT ***

EQUIPMENT TYPE	ATTACHED TO	RATED CAPACITY (MBTU/HR)	FLOW (GAL/MIN)	RATED EIR (FRAC)	RATED HIR (FRAC)	AUXILIARY (KW)
Chiller1 (ElCentHerm) ELEC-HERM-CENT	Chilled Water Loop Condenser Water Loop	9.011 11.140	1798.2 2226.3	0.238	0.000	0.000

*** COOLING TOWERS ***

EQUIPMENT TYPE	ATTACHED TO	CAPACITY (MBTU/HR)	FLOW (GAL/MIN)	NUMBER OF CELLS	FAN POWER PER CELL (KW)	SPRAY PWR PER CELL (KW)	AUXILIARY (KW)
Open Tower OPEN-TWR	Condenser Water Loop	11.278	2253.7	1	74.774	0.000	0.000

*	SOURCE
*	14
*	TOTAL
*	SOURCE
*	ENERGY
*	(MBTU)
*	-----
*	1468.9
*	1383.4
*	1602.4
*	1649.4
*	1701.3
*	1891.3
*	2081.9
*	2088.1
*	1970.5
*	1878.8
*	1513.7
*	1630.2
*	=====
*	20860.0

WEATHER FILE- Los Angeles CA TMY2

WEATHER FILE- Los Angeles CA TMY2

[illegible]

WEATHER FILE- Los Angeles CA TMY2

[illegible]

REPORT- PS-E Energy End-Use Summary for all Electric Meters

WEATHER FILE- Los Angeles CA TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
JAN													
KWH	26434.	0.	60884.	0.	24250.	291.	21421.	7028.	0.	0.	0.	3155.	143463.
MAX KW	99.683	0.000	213.339	0.000	233.366	12.754	76.504	36.640	0.000	0.000	0.000	9.299	658.123
DAY/HR	2/10	0/ 0	2/10	0/ 0	26/14	26/14	2/ 8	27/16	0/ 0	0/ 0	0/ 0	1/19	26/15
PEAK ENDUSE	99.683	0.000	212.419	0.000	232.768	12.308	76.504	24.440	0.000	0.000	0.000	0.000	
PEAK PCT	15.1	0.0	32.3	0.0	35.4	1.9	11.6	3.7	0.0	0.0	0.0	0.0	
FEB													
KWH	24985.	0.	57108.	0.	23446.	404.	19891.	6744.	0.	0.	0.	2531.	135110.
MAX KW	99.683	0.000	213.339	0.000	240.087	16.821	76.504	35.847	0.000	0.000	0.000	9.299	671.567
DAY/HR	2/10	0/ 0	2/10	0/ 0	12/14	12/14	2/ 8	13/16	0/ 0	0/ 0	0/ 0	1/20	12/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	239.944	16.165	76.504	26.683	0.000	0.000	0.000	0.000	
PEAK PCT	14.8	0.0	31.7	0.0	35.7	2.4	11.4	4.0	0.0	0.0	0.0	0.0	
MAR													
KWH	28819.	0.	65486.	0.	28512.	477.	22645.	7758.	0.	0.	0.	2803.	156500.
MAX KW	99.683	0.000	213.339	0.000	237.041	13.563	76.504	35.474	0.000	0.000	0.000	9.299	667.333
DAY/HR	2/10	0/ 0	2/10	0/ 0	31/16	3/14	2/ 8	27/17	0/ 0	0/ 0	0/ 0	1/20	31/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	237.041	12.355	76.504	29.163	0.000	0.000	0.000	0.000	
PEAK PCT	14.9	0.0	31.9	0.0	35.5	1.9	11.5	4.4	0.0	0.0	0.0	0.0	
APR													
KWH	28775.	0.	65235.	0.	32438.	873.	22645.	8410.	0.	0.	0.	2712.	161089.
MAX KW	99.683	0.000	213.339	0.000	247.380	18.877	76.504	41.245	0.000	0.000	0.000	9.299	674.717
DAY/HR	1/10	0/ 0	1/10	0/ 0	13/14	13/14	1/ 8	17/16	0/ 0	0/ 0	0/ 0	1/20	13/14
PEAK ENDUSE	99.683	0.000	204.176	0.000	247.380	18.877	76.504	28.096	0.000	0.000	0.000	0.000	
PEAK PCT	14.8	0.0	30.3	0.0	36.7	2.8	11.3	4.2	0.0	0.0	0.0	0.0	
MAY													
KWH	26434.	0.	60884.	0.	45351.	2300.	21421.	7512.	0.	0.	0.	2258.	166161.
MAX KW	99.683	0.000	213.339	0.000	283.418	28.944	76.504	34.254	0.000	0.000	0.000	9.299	731.467
DAY/HR	1/10	0/ 0	1/10	0/ 0	29/16	29/16	1/ 8	14/17	0/ 0	0/ 0	0/ 0	1/22	29/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	283.418	28.944	76.504	30.330	0.000	0.000	0.000	0.000	
PEAK PCT	13.6	0.0	29.1	0.0	38.7	4.0	10.5	4.1	0.0	0.0	0.0	0.0	
JUN													
KWH	28775.	0.	65235.	0.	54499.	3214.	22645.	8163.	0.	0.	0.	2185.	184717.
MAX KW	99.683	0.000	213.339	0.000	275.207	28.360	76.504	36.549	0.000	0.000	0.000	9.299	718.495
DAY/HR	1/10	0/ 0	1/10	0/ 0	23/12	23/12	1/ 8	1/17	0/ 0	0/ 0	0/ 0	1/22	30/15
PEAK ENDUSE	99.683	0.000	212.419	0.000	274.539	26.252	76.504	29.098	0.000	0.000	0.000	0.000	
PEAK PCT	13.9	0.0	29.6	0.0	38.2	3.7	10.6	4.0	0.0	0.0	0.0	0.0	
JUL													
KWH	28815.	0.	65464.	0.	70059.	5759.	22645.	8335.	0.	0.	0.	2258.	203335.
MAX KW	99.683	0.000	213.339	0.000	308.597	34.540	76.504	36.871	0.000	0.000	0.000	9.299	762.952
DAY/HR	1/10	0/ 0	1/10	0/ 0	20/16	20/16	1/ 8	27/16	0/ 0	0/ 0	0/ 0	1/22	20/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	308.597	34.540	76.504	31.040	0.000	0.000	0.000	0.000	
PEAK PCT	13.0	0.0	27.9	0.0	40.4	4.5	10.0	4.1	0.0	0.0	0.0	0.0	
AUG													
KWH	27671.	0.	63441.	0.	72449.	6571.	22339.	8311.	0.	0.	0.	3155.	203937.
MAX KW	99.683	0.000	213.339	0.000	335.201	41.107	76.504	38.827	0.000	0.000	0.000	9.299	795.884
DAY/HR	3/10	0/ 0	3/10	0/ 0	13/11	13/11	1/ 8	10/17	0/ 0	0/ 0	0/ 0	1/19	17/10
PEAK ENDUSE	99.683	0.000	213.339	0.000	333.752	39.105	76.504	33.500	0.000	0.000	0.000	0.000	
PEAK PCT	12.5	0.0	26.8	0.0	41.9	4.9	9.6	4.2	0.0	0.0	0.0	0.0	

REPORT- PS-E Energy End-Use Summary for all Electric Meters

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

SEP													
KWH	27538.	0.	62679.	0.	64696.	4877.	21727.	7886.	0.	0.	0.	3053.	192456.
MAX KW	99.683	0.000	213.339	0.000	304.674	32.352	76.504	37.702	0.000	0.000	0.000	9.299	762.307
DAY/HR	1/10	0/ 0	1/10	0/ 0	8/16	9/12	1/ 8	8/17	0/ 0	0/ 0	0/ 0	1/19	8/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	304.674	31.765	76.504	37.093	0.000	0.000	0.000	0.000	
PEAK PCT	13.0	0.0	27.9	0.0	40.0	4.2	10.0	4.9	0.0	0.0	0.0	0.0	
OCT													
KWH	27667.	0.	63418.	0.	55756.	3234.	22339.	7925.	0.	0.	0.	3155.	183495.
MAX KW	99.683	0.000	213.339	0.000	289.577	33.666	76.504	37.923	0.000	0.000	0.000	9.299	741.029
DAY/HR	1/10	0/ 0	1/10	0/ 0	22/15	22/15	1/ 8	28/16	0/ 0	0/ 0	0/ 0	1/19	7/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	286.750	30.144	76.504	35.360	0.000	0.000	0.000	0.000	
PEAK PCT	13.4	0.0	28.7	0.0	38.7	4.1	10.3	4.8	0.0	0.0	0.0	0.0	
NOV													
KWH	25065.	0.	57566.	0.	34309.	1135.	19891.	6824.	0.	0.	0.	3053.	147842.
MAX KW	99.683	0.000	213.339	0.000	244.063	19.011	76.504	36.675	0.000	0.000	0.000	9.299	681.948
DAY/HR	2/10	0/ 0	2/10	0/ 0	10/13	10/13	2/ 8	5/16	0/ 0	0/ 0	0/ 0	1/19	9/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	241.802	18.616	76.504	32.754	0.000	0.000	0.000	0.000	
PEAK PCT	14.6	0.0	31.2	0.0	35.5	2.7	11.2	4.8	0.0	0.0	0.0	0.0	
DEC													
KWH	28815.	0.	65464.	0.	31058.	629.	22645.	7451.	0.	0.	0.	3155.	159216.
MAX KW	99.683	0.000	213.339	0.000	232.495	13.017	76.504	33.614	0.000	0.000	0.000	9.299	653.293
DAY/HR	1/10	0/ 0	1/10	0/ 0	18/14	18/14	1/ 8	9/16	0/ 0	0/ 0	0/ 0	1/19	18/15
PEAK ENDUSE	99.683	0.000	212.419	0.000	223.796	10.621	76.504	30.269	0.000	0.000	0.000	0.000	
PEAK PCT	15.3	0.0	32.5	0.0	34.3	1.6	11.7	4.6	0.0	0.0	0.0	0.0	
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
KWH	329793.	0.	752864.	0.	536822.	29766.	262256.	92345.	0.	0.	0.	33473.	2037321.
MAX KW	99.683	0.000	213.339	0.000	335.201	41.107	76.504	41.245	0.000	0.000	0.000	9.299	795.884
MON/DY	1/ 2	0/ 0	1/ 2	0/ 0	8/13	8/13	1/ 2	4/17	0/ 0	0/ 0	0/ 0	1/ 1	8/17
PEAK ENDUSE	99.683	0.000	213.339	0.000	333.752	39.105	76.504	33.500	0.000	0.000	0.000	0.000	
PEAK PCT	12.5	0.0	26.8	0.0	41.9	4.9	9.6	4.2	0.0	0.0	0.0	0.0	

WEATHER FILE- Los Angeles CA TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
JAN													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
FEB													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
MAR													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
APR													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
MAY													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
JUN													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
JUL													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
AUG													
MBTU	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

WEATHER FILE- Los Angeles CA TMY2

-- (CONTINUED) -----

[illegible]

REPORT- PS-F Energy End-Use Summary for EM1

WEATHER FILE- Los Angeles CA TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
JAN													
KWH	26434.	0.	60884.	0.	24250.	291.	21421.	7028.	0.	0.	0.	3155.	143463.
MAX KW	99.683	0.000	213.339	0.000	233.366	12.754	76.504	36.640	0.000	0.000	0.000	9.299	658.123
DAY/HR	2/10	0/ 0	2/10	0/ 0	26/14	26/14	2/ 8	27/16	0/ 0	0/ 0	0/ 0	1/19	26/15
PEAK ENDUSE	99.683	0.000	212.419	0.000	232.768	12.308	76.504	24.440	0.000	0.000	0.000	0.000	
PEAK PCT	15.1	0.0	32.3	0.0	35.4	1.9	11.6	3.7	0.0	0.0	0.0	0.0	
FEB													
KWH	24985.	0.	57108.	0.	23446.	404.	19891.	6744.	0.	0.	0.	2531.	135110.
MAX KW	99.683	0.000	213.339	0.000	240.087	16.821	76.504	35.847	0.000	0.000	0.000	9.299	671.567
DAY/HR	2/10	0/ 0	2/10	0/ 0	12/14	12/14	2/ 8	13/16	0/ 0	0/ 0	0/ 0	1/20	12/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	239.944	16.165	76.504	26.683	0.000	0.000	0.000	0.000	
PEAK PCT	14.8	0.0	31.7	0.0	35.7	2.4	11.4	4.0	0.0	0.0	0.0	0.0	
MAR													
KWH	28819.	0.	65486.	0.	28512.	477.	22645.	7758.	0.	0.	0.	2803.	156500.
MAX KW	99.683	0.000	213.339	0.000	237.041	13.563	76.504	35.474	0.000	0.000	0.000	9.299	667.333
DAY/HR	2/10	0/ 0	2/10	0/ 0	31/16	3/14	2/ 8	27/17	0/ 0	0/ 0	0/ 0	1/20	31/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	237.041	12.355	76.504	29.163	0.000	0.000	0.000	0.000	
PEAK PCT	14.9	0.0	31.9	0.0	35.5	1.9	11.5	4.4	0.0	0.0	0.0	0.0	
APR													
KWH	28775.	0.	65235.	0.	32438.	873.	22645.	8410.	0.	0.	0.	2712.	161089.
MAX KW	99.683	0.000	213.339	0.000	247.380	18.877	76.504	41.245	0.000	0.000	0.000	9.299	674.717
DAY/HR	1/10	0/ 0	1/10	0/ 0	13/14	13/14	1/ 8	17/16	0/ 0	0/ 0	0/ 0	1/20	13/14
PEAK ENDUSE	99.683	0.000	204.176	0.000	247.380	18.877	76.504	28.096	0.000	0.000	0.000	0.000	
PEAK PCT	14.8	0.0	30.3	0.0	36.7	2.8	11.3	4.2	0.0	0.0	0.0	0.0	
MAY													
KWH	26434.	0.	60884.	0.	45351.	2300.	21421.	7512.	0.	0.	0.	2258.	166161.
MAX KW	99.683	0.000	213.339	0.000	283.418	28.944	76.504	34.254	0.000	0.000	0.000	9.299	731.467
DAY/HR	1/10	0/ 0	1/10	0/ 0	29/16	29/16	1/ 8	14/17	0/ 0	0/ 0	0/ 0	1/22	29/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	283.418	28.944	76.504	30.330	0.000	0.000	0.000	0.000	
PEAK PCT	13.6	0.0	29.1	0.0	38.7	4.0	10.5	4.1	0.0	0.0	0.0	0.0	
JUN													
KWH	28775.	0.	65235.	0.	54499.	3214.	22645.	8163.	0.	0.	0.	2185.	184717.
MAX KW	99.683	0.000	213.339	0.000	275.207	28.360	76.504	36.549	0.000	0.000	0.000	9.299	718.495
DAY/HR	1/10	0/ 0	1/10	0/ 0	23/12	23/12	1/ 8	1/17	0/ 0	0/ 0	0/ 0	1/22	30/15
PEAK ENDUSE	99.683	0.000	212.419	0.000	274.539	26.252	76.504	29.098	0.000	0.000	0.000	0.000	
PEAK PCT	13.9	0.0	29.6	0.0	38.2	3.7	10.6	4.0	0.0	0.0	0.0	0.0	
JUL													
KWH	28815.	0.	65464.	0.	70059.	5759.	22645.	8335.	0.	0.	0.	2258.	203335.
MAX KW	99.683	0.000	213.339	0.000	308.597	34.540	76.504	36.871	0.000	0.000	0.000	9.299	762.952
DAY/HR	1/10	0/ 0	1/10	0/ 0	20/16	20/16	1/ 8	27/16	0/ 0	0/ 0	0/ 0	1/22	20/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	308.597	34.540	76.504	31.040	0.000	0.000	0.000	0.000	
PEAK PCT	13.0	0.0	27.9	0.0	40.4	4.5	10.0	4.1	0.0	0.0	0.0	0.0	
AUG													
KWH	27671.	0.	63441.	0.	72449.	6571.	22339.	8311.	0.	0.	0.	3155.	203937.
MAX KW	99.683	0.000	213.339	0.000	335.201	41.107	76.504	38.827	0.000	0.000	0.000	9.299	795.884
DAY/HR	3/10	0/ 0	3/10	0/ 0	13/11	13/11	1/ 8	10/17	0/ 0	0/ 0	0/ 0	1/19	17/10
PEAK ENDUSE	99.683	0.000	213.339	0.000	333.752	39.105	76.504	33.500	0.000	0.000	0.000	0.000	
PEAK PCT	12.5	0.0	26.8	0.0	41.9	4.9	9.6	4.2	0.0	0.0	0.0	0.0	

REPORT- PS-F Energy End-Use Summary for EM1

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

SEP													
KWH	27538.	0.	62679.	0.	64696.	4877.	21727.	7886.	0.	0.	0.	3053.	192456.
MAX KW	99.683	0.000	213.339	0.000	304.674	32.352	76.504	37.702	0.000	0.000	0.000	9.299	762.307
DAY/HR	1/10	0/ 0	1/10	0/ 0	8/16	9/12	1/ 8	8/17	0/ 0	0/ 0	0/ 0	1/19	8/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	304.674	31.765	76.504	37.093	0.000	0.000	0.000	0.000	
PEAK PCT	13.0	0.0	27.9	0.0	40.0	4.2	10.0	4.9	0.0	0.0	0.0	0.0	
OCT													
KWH	27667.	0.	63418.	0.	55756.	3234.	22339.	7925.	0.	0.	0.	3155.	183495.
MAX KW	99.683	0.000	213.339	0.000	289.577	33.666	76.504	37.923	0.000	0.000	0.000	9.299	741.029
DAY/HR	1/10	0/ 0	1/10	0/ 0	22/15	22/15	1/ 8	28/16	0/ 0	0/ 0	0/ 0	1/19	7/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	286.750	30.144	76.504	35.360	0.000	0.000	0.000	0.000	
PEAK PCT	13.4	0.0	28.7	0.0	38.7	4.1	10.3	4.8	0.0	0.0	0.0	0.0	
NOV													
KWH	25065.	0.	57566.	0.	34309.	1135.	19891.	6824.	0.	0.	0.	3053.	147842.
MAX KW	99.683	0.000	213.339	0.000	244.063	19.011	76.504	36.675	0.000	0.000	0.000	9.299	681.948
DAY/HR	2/10	0/ 0	2/10	0/ 0	10/13	10/13	2/ 8	5/16	0/ 0	0/ 0	0/ 0	1/19	9/16
PEAK ENDUSE	99.362	0.000	212.908	0.000	241.802	18.616	76.504	32.754	0.000	0.000	0.000	0.000	
PEAK PCT	14.6	0.0	31.2	0.0	35.5	2.7	11.2	4.8	0.0	0.0	0.0	0.0	
DEC													
KWH	28815.	0.	65464.	0.	31058.	629.	22645.	7451.	0.	0.	0.	3155.	159216.
MAX KW	99.683	0.000	213.339	0.000	232.495	13.017	76.504	33.614	0.000	0.000	0.000	9.299	653.293
DAY/HR	1/10	0/ 0	1/10	0/ 0	18/14	18/14	1/ 8	9/16	0/ 0	0/ 0	0/ 0	1/19	18/15
PEAK ENDUSE	99.683	0.000	212.419	0.000	223.796	10.621	76.504	30.269	0.000	0.000	0.000	0.000	
PEAK PCT	15.3	0.0	32.5	0.0	34.3	1.6	11.7	4.6	0.0	0.0	0.0	0.0	
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
KWH	329793.	0.	752864.	0.	536822.	29766.	262256.	92345.	0.	0.	0.	33473.	2037321.
MAX KW	99.683	0.000	213.339	0.000	335.201	41.107	76.504	41.245	0.000	0.000	0.000	9.299	795.884
MON/DY	1/ 2	0/ 0	1/ 2	0/ 0	8/13	8/13	1/ 2	4/17	0/ 0	0/ 0	0/ 0	1/ 1	8/17
PEAK ENDUSE	99.683	0.000	213.339	0.000	333.752	39.105	76.504	33.500	0.000	0.000	0.000	0.000	
PEAK PCT	12.5	0.0	26.8	0.0	41.9	4.9	9.6	4.2	0.0	0.0	0.0	0.0	

YEARLY TRANSFORMER LOSSES = 0.0 KWH

REPORT- PS-F Energy End-Use Summary for FM1

WEATHER FILE- Los Angeles CA TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
JAN													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
FEB													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
MAR													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
APR													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
MAY													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
JUN													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
JUL													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
AUG													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
MAX THERM/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DAY/HR	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PEAK PCT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

WEATHER FILE- Los Angeles CA TMY2

[illegible]

REPORT- BEPS Building Energy Performance

WEATHER FILE- Los Angeles CA TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRICITY MBTU	1125.6	0.0	2569.5	0.0	1832.2	101.6	895.1	315.2	0.0	0.0	0.0	114.2	6953.3
FM1 NATURAL-GAS MBTU	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MBTU	1125.6	0.0	2569.5	0.0	1832.2	101.6	895.1	315.2	0.0	0.0	0.0	114.2	6953.3

TOTAL SITE ENERGY 6953.31 MBTU 61.6 KBTU/SQFT-YR GROSS-AREA 61.6 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY 20859.97 MBTU 184.7 KBTU/SQFT-YR GROSS-AREA 184.7 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.00
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 0
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

REPORT- BEPU Building Utility Performance

WEATHER FILE- Los Angeles CA TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRICITY													
KWH	329793.	0.	752864.	0.	536822.	29766.	262256.	92345.	0.	0.	0.	33473.	2037321.
FM1 NATURAL-GAS													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.

TOTAL ELECTRICITY 2037321. KWH 18.042 KWH /SQFT-YR GROSS-AREA 18.042 KWH /SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.00
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00
 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 0
 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

REPORT- PS-H Loads and Energy Usage for Chilled Water Loop

WEATHER FILE- Los Angeles CA TMY2

HEATING CAPACITY (MBTU/HR)		COOLING CAPACITY (MBTU/HR)	LOOP FLOW (GAL/MIN)	TOTAL HEAD (FT)	SUPPLY UA PRODUCT (BTU/HR-F)	SUPPLY LOSS DT (F)	RETURN UA PRODUCT (BTU/HR-F)	RETURN LOSS DT (F)	LOOP VOLUME (GAL)	FLUID HEAT CAPACITY (BTU/LB-F)							
-----		-----	-----	-----	-----	-----	-----	-----	-----	-----							
0.000		8.998	1778.0	56.6	0.0	0.00	0.0	0.00	2667.0	1.00							
		COIL LOAD (MBTU) (KBTU/HR)	PIPE GAIN (MBTU) (KBTU/HR)	NET LOAD (MBTU) (KBTU/HR)	OVERLOAD (MBTU) (KBTU/HR)	Number of hours within each PART LOAD range								TOTAL RUN HOURS			
MON	SUM PEAK					00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100	100 +	
---	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
JAN	SUM	49.551	0.000	78.385	0.000	COOL 253	24	3	0	0	0	0	0	0	0	0	280
	PEAK	1787.487	0.000	1887.011	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	280	280
	DAY/HR	26/14	0/ 0	26/14	0/ 0												
FEB	SUM	56.099	0.000	82.316	0.000	COOL 225	31	4	0	0	0	0	0	0	0	0	260
	PEAK	1933.199	0.000	2028.698	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	260	260
	DAY/HR	12/14	0/ 0	12/14	0/ 0												
MAR	SUM	75.472	0.000	105.317	0.000	COOL 258	34	4	0	0	0	0	0	0	0	0	296
	PEAK	1900.508	0.000	2000.251	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	31/16	0/ 0	31/16	0/ 0												
APR	SUM	105.916	0.000	135.765	0.000	COOL 236	52	8	0	0	0	0	0	0	0	0	296
	PEAK	2101.329	0.000	2199.625	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	13/14	0/ 0	13/14	0/ 0												
MAY	SUM	233.597	0.000	261.801	0.000	COOL 153	89	35	3	0	0	0	0	0	0	0	280
	PEAK	2969.483	0.000	3060.464	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	280	280
	DAY/HR	29/16	0/ 0	29/16	0/ 0												
JUN	SUM	316.918	0.000	346.763	0.000	COOL 119	108	61	8	0	0	0	0	0	0	0	296
	PEAK	2776.791	0.000	2866.755	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	30/15	0/ 0	30/15	0/ 0												
JUL	SUM	549.983	0.000	579.833	0.000	COOL 34	86	127	48	1	0	0	0	0	0	0	296
	PEAK	3504.209	0.000	3600.534	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	20/16	0/ 0	20/16	0/ 0												
AUG	SUM	612.427	0.000	641.877	0.000	COOL 26	75	107	57	27	0	0	0	0	0	0	292
	PEAK	4119.633	0.000	4194.029	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	292	292
	DAY/HR	17/15	0/ 0	17/15	0/ 0												
SEP	SUM	481.329	0.000	509.983	0.000	COOL 45	92	107	40	0	0	0	0	0	0	0	284
	PEAK	3500.041	0.000	3579.975	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	284	284
	DAY/HR	8/ 9	0/ 0	8/16	0/ 0												
OCT	SUM	328.374	0.000	357.810	0.000	COOL 113	112	60	7	0	0	0	0	0	0	0	292
	PEAK	3066.977	0.000	3157.198	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	292	292
	DAY/HR	22/15	0/ 0	22/15	0/ 0												
NOV	SUM	131.686	0.000	157.916	0.000	COOL 188	58	14	0	0	0	0	0	0	0	0	260
	PEAK	2012.969	0.000	2108.340	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	260	260
	DAY/HR	10/13	0/ 0	10/13	0/ 0												
DEC	SUM	92.992	0.000	122.839	0.000	COOL 245	49	2	0	0	0	0	0	0	0	0	296
	PEAK	1756.077	0.000	1855.263	0.000	FLOW 0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	18/14	0/ 0	18/14	0/ 0												

REPORT- PS-H Loads and Energy Usage for Chilled Water Loop

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

YR	SUM	3034.342	0.000	3380.606	0.000	COOL1895	810	532	163	28	0	0	0	0	0	0	3428
	PEAK	4119.633	0.000	4194.029	0.000	FLOW	0	0	0	0	0	0	0	0	0	3428	3428
	MON/DAY	8/17	0/ 0	8/17	0/ 0												

Cooling Supply T at Peak: 43.9F Drybulb/Wetbulb: 75.F 68.F

WEATHER FILE- Los Angeles CA TMY2

HEATING CAPACITY (MBTU/HR)		COOLING CAPACITY (MBTU/HR)	LOOP FLOW (GAL/MIN)	TOTAL HEAD (FT)	SUPPLY UA PRODUCT (BTU/HR-F)	SUPPLY LOSS DT (F)	RETURN UA PRODUCT (BTU/HR-F)	RETURN LOSS DT (F)	LOOP VOLUME (GAL)	FLUID HEAT CAPACITY (BTU/LB-F)							
0.000		11.278	2226.3	61.6	0.0	0.00	0.0	0.00	3339.4	1.00							
		COIL LOAD (MBTU) (KBTU/HR)	PIPE GAIN (MBTU) (KBTU/HR)	NET LOAD (MBTU) (KBTU/HR)	OVERLOAD (MBTU) (KBTU/HR)	Number of hours within each				PART LOAD	range			TOTAL			
MON	SUM PEAK DAY/HR					00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100	100 +	RUN HOURS
JAN	SUM PEAK DAY/HR	161.149 2683.481 26/14	0.000 0.000 0/ 0	199.464 2816.207 26/14	0.000 0.000 0/ 0	COOL 238 FLOW 0	238 0	30 0	12 0	0 0	0 0	0 0	0 0	0 0	0 0	0 280	280
FEB	SUM PEAK DAY/HR	162.337 2848.108 12/14	0.000 0.000 0/ 0	198.066 2980.986 12/14	0.000 0.000 0/ 0	COOL 218 FLOW 0	218 0	26 0	16 0	0 0	0 0	0 0	0 0	0 0	0 0	0 260	260
MAR	SUM PEAK DAY/HR	202.628 2809.264 31/16	0.000 0.000 0/ 0	243.268 2944.048 31/16	0.000 0.000 0/ 0	COOL 236 FLOW 0	236 0	42 0	18 0	0 0	0 0	0 0	0 0	0 0	0 0	0 296	296
APR	SUM PEAK DAY/HR	246.475 3043.927 13/14	0.000 0.000 0/ 0	287.180 3166.211 13/14	0.000 0.000 0/ 0	COOL 208 FLOW 0	208 0	60 0	28 0	0 0	0 0	0 0	0 0	0 0	0 0	0 296	296
MAY	SUM PEAK DAY/HR	416.584 4027.760 29/16	0.000 0.000 0/ 0	454.947 4165.976 29/16	0.000 0.000 0/ 0	COOL 104 FLOW 0	104 0	97 0	67 0	12 0	0 0	0 0	0 0	0 0	0 0	0 280	280
JUN	SUM PEAK DAY/HR	532.765 3803.749 30/15	0.000 0.000 0/ 0	573.442 3930.765 30/15	0.000 0.000 0/ 0	COOL 71 FLOW 0	71 0	115 0	92 0	18 0	0 0	0 0	0 0	0 0	0 0	0 296	296
JUL	SUM PEAK DAY/HR	818.942 4653.766 20/16	0.000 0.000 0/ 0	859.612 4768.903 20/16	0.000 0.000 0/ 0	COOL 15 FLOW 0	15 0	57 0	114 0	106 0	4 0	0 0	0 0	0 0	0 0	0 296	296
AUG	SUM PEAK DAY/HR	889.145 5330.329 17/15	0.000 0.000 0/ 0	929.289 5444.875 17/15	0.000 0.000 0/ 0	COOL 14 FLOW 0	14 0	43 0	95 0	109 0	31 0	0 0	0 0	0 0	0 0	0 292	292
SEP	SUM PEAK DAY/HR	730.789 4619.817 8/16	0.000 0.000 0/ 0	769.864 4744.532 8/16	0.000 0.000 0/ 0	COOL 18 FLOW 0	18 0	67 0	119 0	76 0	4 0	0 0	0 0	0 0	0 0	0 284	284
OCT	SUM PEAK DAY/HR	548.102 4145.516 22/15	0.000 0.000 0/ 0	588.225 4249.877 22/15	0.000 0.000 0/ 0	COOL 59 FLOW 0	59 0	118 0	95 0	20 0	0 0	0 0	0 0	0 0	0 0	0 292	292
NOV	SUM PEAK DAY/HR	275.011 2941.320 10/13	0.000 0.000 0/ 0	310.786 3072.219 10/13	0.000 0.000 0/ 0	COOL 139 FLOW 0	139 0	97 0	24 0	0 0	0 0	0 0	0 0	0 0	0 0	0 260	260
DEC	SUM PEAK DAY/HR	228.838 2648.761 18/14	0.000 0.000 0/ 0	269.509 2785.193 18/14	0.000 0.000 0/ 0	COOL 215 FLOW 0	215 0	63 0	18 0	0 0	0 0	0 0	0 0	0 0	0 0	0 296	296

REPORT- PS-H Loads and Energy Usage for Condenser Water Loop WEATHER FILE- Los Angeles CA TMY2
----- (CONTINUED) -----
=====

YR	SUM	5212.764	0.000	5683.652	0.000	COOL1535	815	698	341	39	0	0	0	0	0	0	3428
	PEAK	5330.329	0.000	5444.875	0.000	FLOW	0	0	0	0	0	0	0	0	0	0	3428
	MON/DAY	8/17	0/ 0	8/17	0/ 0												

Cooling Supply T at Peak: 79.4F Drybulb/Wetbulb: 75.F 68.F

WEATHER FILE- Los Angeles CA TMY2

ATTACHED TO				FLOW (GAL/MIN)	HEAD (FT)	SETPPOINT (FT)	CAPACITY CONTROL		POWER (KW)		MECHANICAL EFFICIENCY (FRAC)		MOTOR EFFICIENCY (FRAC)			
Chilled Water Loop PRIMARY LOOP				1778.0	67.9	0.0	ONE-SPEED		31.769		0.770		0.930			
MON	SUM PEAK	HEAT GAIN (MBTU)	ENERGY USE (KWH)			Number of hours		within each		PART LOAD		range		TOTAL		
		(KBTU/HR)	(KW)	00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100	100 +	RUN HOURS	
JAN	SUM	28.2	8895.2	FLOW	0	0	0	0	0	0	0	0	0	0	280	280
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	280	280
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	280	280
FEB	SUM	26.2	8259.8	FLOW	0	0	0	0	0	0	0	0	0	0	260	260
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	260	260
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	260	260
MAR	SUM	29.8	9403.5	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
APR	SUM	29.8	9403.5	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
MAY	SUM	28.2	8895.2	FLOW	0	0	0	0	0	0	0	0	0	0	280	280
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	280	280
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	280	280
JUN	SUM	29.8	9403.5	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
JUL	SUM	29.8	9403.5	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
AUG	SUM	29.4	9276.4	FLOW	0	0	0	0	0	0	0	0	0	0	292	292
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	292	292
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	292	292
SEP	SUM	28.6	9022.3	FLOW	0	0	0	0	0	0	0	0	0	0	284	284
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	284	284
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	284	284
OCT	SUM	29.4	9276.4	FLOW	0	0	0	0	0	0	0	0	0	0	292	292
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	292	292
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	292	292
NOV	SUM	26.2	8259.8	FLOW	0	0	0	0								

REPORT- PS-H Loads and Energy Usage for CHW Loop Pump

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

DEC	SUM	29.8	9403.5	FLOW	0	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	0	296	296
		=====	=====		=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
YR	SUM	345.7	108902.9	FLOW	0	0	0	0	0	0	0	0	0	0	0	3428	3428
	PEAK	100.836	31.769	RPM	0	0	0	0	0	0	0	0	0	0	0	3428	3428
	MON/DAY	1/ 2	1/ 2	ELEC	0	0	0	0	0	0	0	0	0	0	0	3428	3428

Hours pump could not meet flow requirements: 0

REPORT- PS-H Loads and Energy Usage for CW Loop Pump

WEATHER FILE- Los Angeles CA TMY2

NOTE: DATA BELOW IS FOR THE SUM OF 1 PUMP(s)

ATTACHED TO				FLOW (GAL/MIN)	HEAD (FT)	SETPOINT (FT)	CAPACITY CONTROL		POWER (KW)		MECHANICAL EFFICIENCY (FRAC)		MOTOR EFFICIENCY (FRAC)			
Condenser Water Loop PRIMARY LOOP				2226.3	73.9	0.0	ONE-SPEED		44.736		0.770		0.900			
MON	SUM PEAK	HEAT GAIN (MBTU) (KBTU/HR)	ENERGY USE (KWH) (KW)			Number of hours within each		PART LOAD		range				TOTAL		
				00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100	100 +	RUN HOURS	
JAN	SUM	38.5	12525.9	FLOW	0	0	0	0	0	0	0	0	0	0	280	280
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	280	280
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	280	280
FEB	SUM	35.7	11631.2	FLOW	0	0	0	0	0	0	0	0	0	0	260	260
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	260	260
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	260	260
MAR	SUM	40.7	13241.7	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
APR	SUM	40.7	13241.7	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
MAY	SUM	38.5	12525.9	FLOW	0	0	0	0	0	0	0	0	0	0	280	280
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	280	280
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	280	280
JUN	SUM	40.7	13241.7	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
JUL	SUM	40.7	13241.7	FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	296	296
AUG	SUM	40.1	13062.7	FLOW	0	0	0	0	0	0	0	0	0	0	292	292
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	292	292
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	292	292
SEP	SUM	39.0	12704.9	FLOW	0	0	0	0	0	0	0	0	0	0	284	284
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	284	284
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	284	284
OCT	SUM	40.1	13062.7	FLOW	0	0	0	0	0	0	0	0	0	0	292	292
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	292	292
	DAY/HR	1/ 8	1/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	292	292
NOV	SUM	35.7	11631.2	FLOW	0	0	0	0	0	0	0	0	0	0	260	260
	PEAK	137.413	44.736	RPM	0	0	0	0	0	0	0	0	0	0	260	260
	DAY/HR	2/ 8	2/ 8	ELEC	0	0	0	0	0	0	0	0	0	0	260	260

REPORT- PS-H Loads and Energy Usage for CW Loop Pump

WEATHER FILE- Los Angeles CA TMY2

----- (CONTINUED) -----

DEC	SUM	40.7	13241.7		FLOW	0	0	0	0	0	0	0	0	0	0	296	296
	PEAK	137.413	44.736		RPM	0	0	0	0	0	0	0	0	0	0	296	296
	DAY/HR	1/ 8	1/ 8		ELEC	0	0	0	0	0	0	0	0	0	0	296	296
		=====	=====	=====		=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
YR	SUM	471.0	153353.0		FLOW	0	0	0	0	0	0	0	0	0	0	3428	3428
	PEAK	137.413	44.736		RPM	0	0	0	0	0	0	0	0	0	0	3428	3428
	MON/DAY	1/ 2	1/ 2		ELEC	0	0	0	0	0	0	0	0	0	0	3428	3428

Hours pump could not meet flow requirements: 0

WEATHER FILE- Los Angeles CA TMY2

EQUIPMENT TYPE		ATTACHED TO				CAPACITY (MBTU/HR)	FLOW (GAL/MIN)			EIR (FRAC)	AUXILIARY (KW)								
ELEC-HERM-CENT		Chilled Water Loop Condenser Water Loop				9.011 11.140	1798.2 2226.3			0.238	0.000								
MON	SUM	COOL LOAD (MBTU) (KBTU/HR)	HEAT LOAD (MBTU) (KBTU/HR)	ELEC USE (KWH) (KW)	AUX ENERGY (KWH) (KW)	Number of hours within each PART LOAD range												TOTAL RUN HOURS	
---	---	---	---	---	---	00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100	100 +	---		
JAN	SUM	78.385	0.000	24249.736	0.000	LOAD 258	22	0	0	0	0	0	0	0	0	0	280		
	PEAK	1887.011	0.000	233.366	0.000	ELEC 180	58	17	25	0	0	0	0	0	0	0	280		
	DAY/HR	26/14	0/ 0	26/14	0/ 0														
FEB	SUM	82.316	0.000	23446.008	0.000	LOAD 230	30	0	0	0	0	0	0	0	0	0	260		
	PEAK	2028.698	0.000	240.087	0.000	ELEC 162	53	13	32	0	0	0	0	0	0	0	260		
	DAY/HR	12/14	0/ 0	12/14	0/ 0														
MAR	SUM	105.317	0.000	28511.980	0.000	LOAD 268	28	0	0	0	0	0	0	0	0	0	296		
	PEAK	2000.251	0.000	237.041	0.000	ELEC 142	92	26	36	0	0	0	0	0	0	0	296		
	DAY/HR	31/16	0/ 0	31/16	0/ 0														
APR	SUM	135.765	0.000	32438.080	0.000	LOAD 250	45	1	0	0	0	0	0	0	0	0	296		
	PEAK	2199.625	0.000	247.380	0.000	ELEC 130	76	37	53	0	0	0	0	0	0	0	296		
	DAY/HR	13/14	0/ 0	13/14	0/ 0														
MAY	SUM	261.801	0.000	45351.273	0.000	LOAD 173	85	22	0	0	0	0	0	0	0	0	280		
	PEAK	3060.464	0.000	283.418	0.000	ELEC 27	75	56	104	18	0	0	0	0	0	0	280		
	DAY/HR	29/16	0/ 0	29/16	0/ 0														
JUN	SUM	346.763	0.000	54498.531	0.000	LOAD 141	106	49	0	0	0	0	0	0	0	0	296		
	PEAK	2866.755	0.000	275.207	0.000	ELEC 12	57	55	143	29	0	0	0	0	0	0	296		
	DAY/HR	30/15	0/ 0	23/12	0/ 0														
JUL	SUM	579.833	0.000	70058.797	0.000	LOAD 43	95	145	13	0	0	0	0	0	0	0	296		
	PEAK	3600.534	0.000	308.597	0.000	ELEC 0	10	20	131	135	0	0	0	0	0	0	296		
	DAY/HR	20/16	0/ 0	20/16	0/ 0														
AUG	SUM	641.877	0.000	72449.320	0.000	LOAD 33	90	124	42	3	0	0	0	0	0	0	292		
	PEAK	4194.029	0.000	335.201	0.000	ELEC 1	10	12	114	134	21	0	0	0	0	0	292		
	DAY/HR	17/15	0/ 0	13/11	0/ 0														
SEP	SUM	509.983	0.000	64696.188	0.000	LOAD 61	109	107	7	0	0	0	0	0	0	0	284		
	PEAK	3579.975	0.000	304.674	0.000	ELEC 0	11	35	150	88	0	0	0	0	0	0	284		
	DAY/HR	8/16	0/ 0	8/16	0/ 0														
OCT	SUM	357.810	0.000	55755.543	0.000	LOAD 128	121	42	1	0	0	0	0	0	0	0	292		
	PEAK	3157.198	0.000	289.577	0.000	ELEC 8	49	57	144	34	0	0	0	0	0	0	292		
	DAY/HR	22/15	0/ 0	22/15	0/ 0														
NOV	SUM	157.916	0.000	34308.625	0.000	LOAD 212	47	1	0	0	0	0	0	0	0	0	260		
	PEAK	2108.340	0.000	244.063	0.000	ELEC 60	75	63	62	0	0	0	0	0	0	0	260		
	DAY/HR	10/13	0/ 0	10/13	0/ 0														
DEC	SUM	122.839	0.000	31057.518	0.000	LOAD 253	43	0	0	0	0	0	0	0	0	0	296		
	PEAK	1855.263	0.000	232.495	0.000	ELEC 137	75	35	49	0	0	0	0	0	0	0	296		
	DAY/HR	18/14	0/ 0	18/14	0/ 0														

REPORT- PS-H Loads and Energy Usage for Chiller1 (ElCentHerm)

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

YR	SUM	3380.606	0.000	536821.563	0.000	LOAD2050	821	491	63	3	0	0	0	0	0	0	3428
	PEAK	4194.029	0.000	335.201	0.000	ELEC 859	641	426	1043	438	21	0	0	0	0	0	3428
	MON/DAY	8/17	0/ 0	8/13	0/ 0												

Normalized (ARI) Capacity at Peak: 3.972 MBTU/HR at CHW T/Adjusted Condenser T: 43.9F 79.5F and Drybulb/Wetbulb: 75.F 68.F

WEATHER FILE- Los Angeles CA TMY2

EQUIPMENT TYPE		ATTACHED TO				CAPACITY (MBTU/HR)	FLOW (GAL/MIN)			NUMBER OF CELLS	FAN POWER PER CELL (KW)	SPRAY PWR PER CELL (KW)	AUXILIARY (KW)						
OPEN-TWR		Condenser Water Loop				11.278	2253.7			1	74.774	0.000	0.000						
MON	SUM	HTREJ LOAD (MBTU)	ELEC USE (KWH)	AUX ENERGY (KWH)	AUX ENERGY (MBTU)	Number of hours within each PART LOAD range												TOTAL RUN	
	PEAK	(KBTU/HR)	(KW)	(KW)	(KBTU/HR)	00	10	20	30	40	50	60	70	80	90	100	HOURS		
---	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----		
JAN	SUM	199.464	291.228	0.000	0.000	LOAD	0	0	0	0	280	0	0	0	0	0	280		
	PEAK	2816.207	12.754	0.000	0.000	ELEC	35	15	0	0	0	0	0	0	0	0	50		
	DAY/HR	26/14	26/14	0/ 0	0/ 0														
FEB	SUM	198.066	404.262	0.000	0.000	LOAD	0	0	0	0	260	0	0	0	0	0	260		
	PEAK	2980.986	16.821	0.000	0.000	ELEC	26	26	3	0	0	0	0	0	0	0	55		
	DAY/HR	12/14	12/14	0/ 0	0/ 0														
MAR	SUM	243.268	476.942	0.000	0.000	LOAD	0	0	0	0	296	0	0	0	0	0	296		
	PEAK	2944.048	13.563	0.000	0.000	ELEC	65	25	0	0	0	0	0	0	0	0	90		
	DAY/HR	31/16	3/14	0/ 0	0/ 0														
APR	SUM	287.180	872.928	0.000	0.000	LOAD	0	0	0	0	296	0	0	0	0	0	296		
	PEAK	3166.211	18.877	0.000	0.000	ELEC	63	52	4	0	0	0	0	0	0	0	119		
	DAY/HR	13/14	13/14	0/ 0	0/ 0														
MAY	SUM	454.947	2300.368	0.000	0.000	LOAD	0	0	0	0	280	0	0	0	0	0	280		
	PEAK	4165.976	28.944	0.000	0.000	ELEC	85	70	46	16	0	0	0	0	0	0	217		
	DAY/HR	29/16	29/16	0/ 0	0/ 0														
JUN	SUM	573.442	3214.367	0.000	0.000	LOAD	0	0	0	0	296	0	0	0	0	0	296		
	PEAK	3930.765	28.360	0.000	0.000	ELEC	71	89	76	22	0	0	0	0	0	0	258		
	DAY/HR	30/15	23/12	0/ 0	0/ 0														
JUL	SUM	859.612	5759.360	0.000	0.000	LOAD	0	0	0	0	296	0	0	0	0	0	296		
	PEAK	4768.903	34.540	0.000	0.000	ELEC	23	53	90	114	13	0	0	0	0	0	293		
	DAY/HR	20/16	20/16	0/ 0	0/ 0														
AUG	SUM	929.289	6570.824	0.000	0.000	LOAD	0	0	0	0	278	14	0	0	0	0	292		
	PEAK	5444.875	41.107	0.000	0.000	ELEC	17	41	68	110	39	16	0	0	0	0	291		
	DAY/HR	17/15	13/11	0/ 0	0/ 0														
SEP	SUM	769.864	4876.792	0.000	0.000	LOAD	0	0	0	0	284	0	0	0	0	0	284		
	PEAK	4744.532	32.352	0.000	0.000	ELEC	38	55	119	59	12	0	0	0	0	0	283		
	DAY/HR	8/16	9/12	0/ 0	0/ 0														
OCT	SUM	588.225	3234.381	0.000	0.000	LOAD	0	0	0	0	292	0	0	0	0	0	292		
	PEAK	4249.877	33.666	0.000	0.000	ELEC	75	105	55	30	2	0	0	0	0	0	267		
	DAY/HR	22/15	22/15	0/ 0	0/ 0														
NOV	SUM	310.786	1135.378	0.000	0.000	LOAD	0	0	0	0	260	0	0	0	0	0	260		
	PEAK	3072.219	19.011	0.000	0.000	ELEC	79	62	13	0	0	0	0	0	0	0	154		
	DAY/HR	10/13	10/13	0/ 0	0/ 0														
DEC	SUM	269.509	629.034	0.000	0.000	LOAD	0	0	0	0	296	0	0	0	0	0	296		
	PEAK	2785.193	13.017	0.000	0.000	ELEC	65	42	0	0	0	0	0	0	0	0	107		
	DAY/HR	18/14	18/14	0/ 0	0/ 0														

REPORT- PS-H Loads and Energy Usage for Open Tower

WEATHER FILE- Los Angeles CA TMY2

(CONTINUED)

	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
YR	SUM	5683.652	29765.865	0.000	0.000	LOAD	0	0	0	0	3414	14	0	0	0	0	0	3428
	PEAK	5444.875	41.107	0.000	0.000	ELEC	642	635	474	351	66	16	0	0	0	0	0	2184
	MON/DAY	8/17	8/13	0/ 0	0/ 0													

MAXIMUM TOWER SUPPLY TEMPERATURE WAS 116.9F ON 10/ 8 AT 8:00

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 2 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 2 8	81.785	0.000	168.037	0.000	210.688	1.372	76.504	23.949	0.000	0.000
1 2 9	98.066	0.000	208.826	0.000	58.783	0.000	76.504	23.949	0.000	0.000
1 210	99.683	0.000	213.339	0.000	57.671	0.000	76.504	23.949	0.000	0.000
1 211	99.683	0.000	208.758	0.000	63.597	0.000	76.504	23.949	0.000	0.000
1 212	99.683	0.000	185.850	0.000	76.015	0.000	76.504	23.949	0.000	0.000
1 213	99.683	0.000	184.930	0.000	88.322	0.000	76.504	23.949	0.000	0.000
1 214	99.683	0.000	204.176	0.000	58.726	0.000	76.504	23.949	0.000	0.000
1 215	99.683	0.000	212.419	0.000	57.726	0.000	76.504	23.949	0.000	0.000
1 216	99.362	0.000	212.908	0.000	57.684	0.000	76.504	23.949	0.000	0.000
1 217	96.460	0.000	208.973	0.000	57.666	0.000	76.504	23.949	0.000	0.000
1 218	84.742	0.000	185.644	0.000	57.666	0.000	76.504	23.949	0.000	0.000
1 219	55.756	0.000	106.856	0.000	57.666	0.000	76.504	23.949	0.000	0.000
1 220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	210.688	1.372	76.504	23.949	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	902.209	1.372	918.051	287.384	0.000	0.000
AV	53.189	0.000	116.048	0.000	37.592	0.057	38.252	11.974	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 3 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 3 8	5.538	0.000	31.745	0.000	113.346	0.000	76.504	23.949	0.000	0.000
1 3 9	5.538	0.000	31.745	0.000	57.937	0.000	76.504	23.949	0.000	0.000
1 310	5.538	0.000	31.745	0.000	57.675	0.000	76.504	23.949	0.000	0.000
1 311	5.538	0.000	31.745	0.000	57.700	0.000	76.504	23.949	0.000	0.000
1 312	5.538	0.000	31.745	0.000	57.701	0.000	76.504	23.949	0.000	0.000
1 313	5.538	0.000	31.745	0.000	62.671	0.000	76.504	23.949	0.000	0.000
1 314	5.538	0.000	31.745	0.000	88.500	0.000	76.504	23.949	0.000	0.000
1 315	5.538	0.000	31.745	0.000	88.214	0.000	76.504	23.949	0.000	0.000
1 316	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 317	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 318	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 319	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 320	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 321	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 322	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 323	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	113.346	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	583.744	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	24.323	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 5 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 5 8	81.785	0.000	168.037	0.000	112.454	0.000	76.504	23.949	0.000	0.000
1 5 9	98.066	0.000	208.826	0.000	58.074	0.000	76.504	23.949	0.000	0.000
1 510	99.683	0.000	213.339	0.000	57.754	0.000	76.504	23.949	0.000	0.000
1 511	99.683	0.000	208.758	0.000	57.763	0.000	76.504	23.949	0.000	0.000
1 512	99.683	0.000	185.850	0.000	57.787	0.000	76.504	23.949	0.000	0.000
1 513	99.683	0.000	184.930	0.000	57.765	0.000	76.504	23.949	0.000	0.000
1 514	99.683	0.000	204.176	0.000	57.787	0.000	76.504	23.949	0.000	0.000
1 515	99.683	0.000	212.419	0.000	57.788	0.000	76.504	23.949	0.000	0.000
1 516	99.362	0.000	212.908	0.000	57.813	0.000	76.504	23.949	0.000	0.000
1 517	96.460	0.000	208.973	0.000	57.814	0.000	76.504	23.949	0.000	0.000
1 518	84.742	0.000	185.644	0.000	57.840	0.000	76.504	23.949	0.000	0.000
1 519	55.756	0.000	106.856	0.000	57.815	0.000	76.504	23.949	0.000	0.000
1 520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.454	0.000	76.504	23.949	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.452	0.000	918.051	287.384	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.185	0.000	38.252	11.974	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 6 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 6 8	81.785	0.000	168.037	0.000	111.771	0.000	76.504	23.949	0.000	0.000
1 6 9	98.066	0.000	208.826	0.000	58.032	0.000	76.504	23.949	0.000	0.000
1 610	99.683	0.000	213.339	0.000	57.797	0.000	76.504	23.949	0.000	0.000
1 611	99.683	0.000	208.758	0.000	57.840	0.000	76.504	23.949	0.000	0.000
1 612	99.683	0.000	185.850	0.000	57.841	0.000	76.504	23.949	0.000	0.000
1 613	99.683	0.000	184.930	0.000	57.815	0.000	76.504	23.949	0.000	0.000
1 614	99.683	0.000	204.176	0.000	57.840	0.000	76.504	24.470	0.000	0.000
1 615	99.683	0.000	212.419	0.000	57.841	0.000	76.504	25.326	0.000	0.000
1 616	99.362	0.000	212.908	0.000	57.841	0.000	76.504	25.094	0.000	0.000
1 617	96.460	0.000	208.973	0.000	57.841	0.000	76.504	23.949	0.000	0.000
1 618	84.742	0.000	185.644	0.000	57.815	0.000	76.504	23.949	0.000	0.000
1 619	55.756	0.000	106.856	0.000	57.814	0.000	76.504	23.949	0.000	0.000
1 620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.771	0.000	76.504	25.326	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.088	0.000	918.051	290.428	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.170	0.000	38.252	12.101	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 7 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 7 8	81.785	0.000	168.037	0.000	111.804	0.000	76.504	23.949	0.000	0.000
1 7 9	98.066	0.000	208.826	0.000	58.033	0.000	76.504	23.949	0.000	0.000
1 710	99.683	0.000	213.339	0.000	57.798	0.000	76.504	23.949	0.000	0.000
1 711	99.683	0.000	208.758	0.000	57.868	0.000	76.504	24.384	0.000	0.000
1 712	99.683	0.000	185.850	0.000	57.902	0.000	76.504	24.103	0.000	0.000
1 713	99.683	0.000	184.930	0.000	57.873	0.000	76.504	24.345	0.000	0.000
1 714	99.683	0.000	204.176	0.000	57.872	0.000	76.504	25.572	0.000	0.000
1 715	99.683	0.000	212.419	0.000	57.871	0.000	76.504	27.263	0.000	0.000
1 716	99.362	0.000	212.908	0.000	57.902	0.000	76.504	27.141	0.000	0.000
1 717	96.460	0.000	208.973	0.000	57.873	0.000	76.504	25.260	0.000	0.000
1 718	84.742	0.000	185.644	0.000	57.816	0.000	76.504	23.949	0.000	0.000
1 719	55.756	0.000	106.856	0.000	57.840	0.000	76.504	23.949	0.000	0.000
1 720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.804	0.000	76.504	27.263	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.452	0.000	918.051	297.811	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.186	0.000	38.252	12.409	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 8 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 8 8	81.785	0.000	168.037	0.000	111.911	0.000	76.504	23.949	0.000	0.000
1 8 9	98.066	0.000	208.826	0.000	58.065	0.000	76.504	23.949	0.000	0.000
1 810	99.683	0.000	213.339	0.000	57.799	0.000	76.504	23.949	0.000	0.000
1 811	99.683	0.000	208.758	0.000	57.840	0.000	76.504	24.097	0.000	0.000
1 812	99.683	0.000	185.850	0.000	57.841	0.000	76.504	24.443	0.000	0.000
1 813	99.683	0.000	184.930	0.000	57.870	0.000	76.504	24.856	0.000	0.000
1 814	99.683	0.000	204.176	0.000	57.843	0.000	76.504	26.399	0.000	0.000
1 815	99.683	0.000	212.419	0.000	57.841	0.000	76.504	27.001	0.000	0.000
1 816	99.362	0.000	212.908	0.000	57.870	0.000	76.504	27.857	0.000	0.000
1 817	96.460	0.000	208.973	0.000	57.871	0.000	76.504	25.301	0.000	0.000
1 818	84.742	0.000	185.644	0.000	57.843	0.000	76.504	23.949	0.000	0.000
1 819	55.756	0.000	106.856	0.000	57.870	0.000	76.504	23.949	0.000	0.000
1 820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.911	0.000	76.504	27.857	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.464	0.000	918.051	299.696	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.186	0.000	38.252	12.487	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 9 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 9 8	81.785	0.000	168.037	0.000	111.856	0.000	76.504	23.949	0.000	0.000
1 9 9	98.066	0.000	208.826	0.000	58.064	0.000	76.504	23.949	0.000	0.000
1 910	99.683	0.000	213.339	0.000	57.851	0.000	76.504	24.170	0.000	0.000
1 911	99.683	0.000	208.758	0.000	57.871	0.000	76.504	25.151	0.000	0.000
1 912	99.683	0.000	185.850	0.000	83.795	0.000	76.504	24.439	0.000	0.000
1 913	99.683	0.000	184.930	0.000	58.857	0.000	76.504	25.724	0.000	0.000
1 914	99.683	0.000	204.176	0.000	57.969	0.000	76.504	28.438	0.000	0.000
1 915	99.683	0.000	212.419	0.000	57.940	0.000	76.504	31.463	0.000	0.000
1 916	99.362	0.000	212.908	0.000	57.905	0.000	76.504	31.149	0.000	0.000
1 917	96.460	0.000	208.973	0.000	57.904	0.000	76.504	26.445	0.000	0.000
1 918	84.742	0.000	185.644	0.000	57.904	0.000	76.504	24.097	0.000	0.000
1 919	55.756	0.000	106.856	0.000	57.873	0.000	76.504	23.949	0.000	0.000
1 920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1 924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.856	0.000	76.504	31.463	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	775.789	0.000	918.051	312.921	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.325	0.000	38.252	13.038	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 10 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
110 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
110 8	5.538	0.000	31.745	0.000	111.908	0.000	76.504	23.949	0.000	0.000
110 9	5.538	0.000	31.745	0.000	58.132	0.000	76.504	23.949	0.000	0.000
11010	5.538	0.000	31.745	0.000	101.583	0.718	76.504	23.949	0.000	0.000
11011	5.538	0.000	31.745	0.000	151.304	3.804	76.504	23.949	0.000	0.000
11012	5.538	0.000	31.745	0.000	154.186	5.299	76.504	23.949	0.000	0.000
11013	5.538	0.000	31.745	0.000	100.440	0.820	76.504	23.949	0.000	0.000
11014	5.538	0.000	31.745	0.000	101.474	1.019	76.504	23.949	0.000	0.000
11015	5.538	0.000	31.745	0.000	63.463	0.000	76.504	23.949	0.000	0.000
11016	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11017	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11018	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11019	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11020	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11021	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11022	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11023	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	154.186	5.299	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	842.490	11.660	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	35.104	0.486	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 12 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
112 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112 8	81.785	0.000	168.037	0.000	111.925	0.000	76.504	23.949	0.000	0.000
112 9	98.066	0.000	208.826	0.000	58.065	0.000	76.504	23.949	0.000	0.000
11210	99.683	0.000	213.339	0.000	57.880	0.000	76.504	23.949	0.000	0.000
11211	99.683	0.000	208.758	0.000	57.903	0.000	76.504	24.606	0.000	0.000
11212	99.683	0.000	185.850	0.000	82.836	0.000	76.504	24.165	0.000	0.000
11213	99.683	0.000	184.930	0.000	58.822	0.000	76.504	25.079	0.000	0.000
11214	99.683	0.000	204.176	0.000	57.844	0.000	76.504	26.817	0.000	0.000
11215	99.683	0.000	212.419	0.000	57.870	0.000	76.504	29.147	0.000	0.000
11216	99.362	0.000	212.908	0.000	57.843	0.000	76.504	28.644	0.000	0.000
11217	96.460	0.000	208.973	0.000	57.841	0.000	76.504	25.920	0.000	0.000
11218	84.742	0.000	185.644	0.000	57.745	0.000	76.504	23.949	0.000	0.000
11219	55.756	0.000	106.856	0.000	57.668	0.000	76.504	23.949	0.000	0.000
11220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.925	0.000	76.504	29.147	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	774.242	0.000	918.051	304.122	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.260	0.000	38.252	12.672	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 13 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
113 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113 8	81.785	0.000	168.037	0.000	111.557	0.000	76.504	23.949	0.000	0.000
113 9	98.066	0.000	208.826	0.000	57.903	0.000	76.504	23.949	0.000	0.000
11310	99.683	0.000	213.339	0.000	82.060	0.000	76.504	24.180	0.000	0.000
11311	99.683	0.000	208.758	0.000	138.246	1.693	76.504	24.629	0.000	0.000
11312	99.683	0.000	185.850	0.000	184.063	4.451	76.504	24.133	0.000	0.000
11313	99.683	0.000	184.930	0.000	202.156	5.356	76.504	24.409	0.000	0.000
11314	99.683	0.000	204.176	0.000	209.897	6.797	76.504	25.547	0.000	0.000
11315	99.683	0.000	212.419	0.000	174.520	4.270	76.504	29.818	0.000	0.000
11316	99.362	0.000	212.908	0.000	86.381	0.000	76.504	32.263	0.000	0.000
11317	96.460	0.000	208.973	0.000	58.767	0.000	76.504	28.843	0.000	0.000
11318	84.742	0.000	185.644	0.000	57.842	0.000	76.504	24.509	0.000	0.000
11319	55.756	0.000	106.856	0.000	57.790	0.000	76.504	23.949	0.000	0.000
11320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	209.897	6.797	76.504	32.263	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1421.182	22.568	918.051	310.177	0.000	0.000
AV	53.189	0.000	116.048	0.000	59.216	0.940	38.252	12.924	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 14 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
114 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
114 8	81.785	0.000	168.037	0.000	111.705	0.000	76.504	23.949	0.000	0.000
114 9	98.066	0.000	208.826	0.000	81.129	0.000	76.504	23.949	0.000	0.000
11410	99.683	0.000	213.339	0.000	186.360	4.425	76.504	24.212	0.000	0.000
11411	99.683	0.000	208.758	0.000	207.171	6.288	76.504	24.679	0.000	0.000
11412	99.683	0.000	185.850	0.000	220.709	9.569	76.504	24.061	0.000	0.000
11413	99.683	0.000	184.930	0.000	207.286	7.061	76.504	24.297	0.000	0.000
11414	99.683	0.000	204.176	0.000	202.866	6.389	76.504	26.139	0.000	0.000
11415	99.683	0.000	212.419	0.000	209.278	7.086	76.504	27.938	0.000	0.000
11416	99.362	0.000	212.908	0.000	149.790	2.796	76.504	29.770	0.000	0.000
11417	96.460	0.000	208.973	0.000	60.561	0.000	76.504	30.809	0.000	0.000
11418	84.742	0.000	185.644	0.000	57.861	0.000	76.504	24.925	0.000	0.000
11419	55.756	0.000	106.856	0.000	57.791	0.000	76.504	23.949	0.000	0.000
11420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	220.709	9.569	76.504	30.809	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1752.505	43.614	918.051	308.674	0.000	0.000
AV	53.189	0.000	116.048	0.000	73.021	1.817	38.252	12.861	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 15 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
115 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
115 8	81.785	0.000	168.037	0.000	111.755	0.000	76.504	23.949	0.000	0.000
115 9	98.066	0.000	208.826	0.000	58.003	0.000	76.504	23.949	0.000	0.000
11510	99.683	0.000	213.339	0.000	57.751	0.000	76.504	25.278	0.000	0.000
11511	99.683	0.000	208.758	0.000	57.786	0.000	76.504	24.331	0.000	0.000
11512	99.683	0.000	185.850	0.000	57.868	0.000	76.504	24.183	0.000	0.000
11513	99.683	0.000	184.930	0.000	57.871	0.000	76.504	24.368	0.000	0.000
11514	99.683	0.000	204.176	0.000	57.871	0.000	76.504	24.858	0.000	0.000
11515	99.683	0.000	212.419	0.000	57.902	0.000	76.504	25.067	0.000	0.000
11516	99.362	0.000	212.908	0.000	57.904	0.000	76.504	24.690	0.000	0.000
11517	96.460	0.000	208.973	0.000	57.873	0.000	76.504	24.201	0.000	0.000
11518	84.742	0.000	185.644	0.000	57.872	0.000	76.504	23.949	0.000	0.000
11519	55.756	0.000	106.856	0.000	57.843	0.000	76.504	23.949	0.000	0.000
11520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.755	0.000	76.504	25.278	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.299	0.000	918.051	292.772	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.179	0.000	38.252	12.199	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 16 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
116 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
116 8	81.785	0.000	168.037	0.000	111.967	0.000	76.504	23.949	0.000	0.000
116 9	98.066	0.000	208.826	0.000	58.134	0.000	76.504	23.949	0.000	0.000
11610	99.683	0.000	213.339	0.000	57.854	0.000	76.504	24.606	0.000	0.000
11611	99.683	0.000	208.758	0.000	57.842	0.000	76.504	25.061	0.000	0.000
11612	99.683	0.000	185.850	0.000	57.815	0.000	76.504	24.866	0.000	0.000
11613	99.683	0.000	184.930	0.000	57.840	0.000	76.504	25.154	0.000	0.000
11614	99.683	0.000	204.176	0.000	57.870	0.000	76.504	26.420	0.000	0.000
11615	99.683	0.000	212.419	0.000	57.816	0.000	76.504	26.209	0.000	0.000
11616	99.362	0.000	212.908	0.000	57.814	0.000	76.504	25.386	0.000	0.000
11617	96.460	0.000	208.973	0.000	57.814	0.000	76.504	24.341	0.000	0.000
11618	84.742	0.000	185.644	0.000	57.814	0.000	76.504	23.949	0.000	0.000
11619	55.756	0.000	106.856	0.000	57.814	0.000	76.504	23.949	0.000	0.000
11620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.967	0.000	76.504	26.420	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.392	0.000	918.051	297.837	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.183	0.000	38.252	12.410	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 17 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
117 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
117 8	5.538	0.000	31.745	0.000	112.332	0.000	76.504	23.949	0.000	0.000
117 9	5.538	0.000	31.745	0.000	58.264	0.000	76.504	23.949	0.000	0.000
11710	5.538	0.000	31.745	0.000	57.889	0.000	76.504	23.949	0.000	0.000
11711	5.538	0.000	31.745	0.000	57.792	0.000	76.504	23.949	0.000	0.000
11712	5.538	0.000	31.745	0.000	57.868	0.000	76.504	23.949	0.000	0.000
11713	5.538	0.000	31.745	0.000	57.816	0.000	76.504	23.949	0.000	0.000
11714	5.538	0.000	31.745	0.000	57.814	0.000	76.504	23.949	0.000	0.000
11715	5.538	0.000	31.745	0.000	57.814	0.000	76.504	23.949	0.000	0.000
11716	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11717	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11718	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11719	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11720	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11721	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11722	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11723	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.332	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	517.587	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	21.566	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 20 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
120 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
120 8	81.785	0.000	168.037	0.000	111.465	0.000	76.504	23.949	0.000	0.000
120 9	98.066	0.000	208.826	0.000	57.827	0.000	76.504	23.949	0.000	0.000
12010	99.683	0.000	213.339	0.000	57.641	0.000	76.504	23.949	0.000	0.000
12011	99.683	0.000	208.758	0.000	57.649	0.000	76.504	23.949	0.000	0.000
12012	99.683	0.000	185.850	0.000	57.650	0.000	76.504	23.949	0.000	0.000
12013	99.683	0.000	184.930	0.000	57.650	0.000	76.504	23.949	0.000	0.000
12014	99.683	0.000	204.176	0.000	57.650	0.000	76.504	25.158	0.000	0.000
12015	99.683	0.000	212.419	0.000	57.665	0.000	76.504	26.161	0.000	0.000
12016	99.362	0.000	212.908	0.000	57.738	0.000	76.504	26.000	0.000	0.000
12017	96.460	0.000	208.973	0.000	57.653	0.000	76.504	24.312	0.000	0.000
12018	84.742	0.000	185.644	0.000	57.718	0.000	76.504	23.949	0.000	0.000
12019	55.756	0.000	106.856	0.000	57.740	0.000	76.504	23.949	0.000	0.000
12020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.465	0.000	76.504	26.161	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	746.045	0.000	918.051	293.221	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.085	0.000	38.252	12.218	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 21 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
121 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121 8	81.785	0.000	168.037	0.000	111.487	0.000	76.504	23.949	0.000	0.000
121 9	98.066	0.000	208.826	0.000	57.902	0.000	76.504	23.949	0.000	0.000
12110	99.683	0.000	213.339	0.000	57.708	0.000	76.504	23.949	0.000	0.000
12111	99.683	0.000	208.758	0.000	57.762	0.000	76.504	24.239	0.000	0.000
12112	99.683	0.000	185.850	0.000	57.787	0.000	76.504	24.337	0.000	0.000
12113	99.683	0.000	184.930	0.000	57.812	0.000	76.504	24.823	0.000	0.000
12114	99.683	0.000	204.176	0.000	57.840	0.000	76.504	26.796	0.000	0.000
12115	99.683	0.000	212.419	0.000	57.841	0.000	76.504	27.621	0.000	0.000
12116	99.362	0.000	212.908	0.000	57.815	0.000	76.504	26.204	0.000	0.000
12117	96.460	0.000	208.973	0.000	57.814	0.000	76.504	24.548	0.000	0.000
12118	84.742	0.000	185.644	0.000	57.766	0.000	76.504	23.949	0.000	0.000
12119	55.756	0.000	106.856	0.000	57.787	0.000	76.504	23.949	0.000	0.000
12120	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12121	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12122	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12123	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12124	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.487	0.000	76.504	27.621	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	747.320	0.000	918.051	298.310	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.138	0.000	38.252	12.430	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 22 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
122 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122 8	81.785	0.000	168.037	0.000	111.662	0.000	76.504	23.949	0.000	0.000
122 9	98.066	0.000	208.826	0.000	57.950	0.000	76.504	23.949	0.000	0.000
12210	99.683	0.000	213.339	0.000	57.729	0.000	76.504	23.967	0.000	0.000
12211	99.683	0.000	208.758	0.000	57.702	0.000	76.504	24.724	0.000	0.000
12212	99.683	0.000	185.850	0.000	99.253	0.000	76.504	24.113	0.000	0.000
12213	99.683	0.000	184.930	0.000	83.170	0.000	76.504	24.895	0.000	0.000
12214	99.683	0.000	204.176	0.000	106.771	0.000	76.504	26.192	0.000	0.000
12215	99.683	0.000	212.419	0.000	88.223	0.000	76.504	29.101	0.000	0.000
12216	99.362	0.000	212.908	0.000	66.635	0.000	76.504	29.634	0.000	0.000
12217	96.460	0.000	208.973	0.000	58.030	0.000	76.504	27.523	0.000	0.000
12218	84.742	0.000	185.644	0.000	57.749	0.000	76.504	24.181	0.000	0.000
12219	55.756	0.000	106.856	0.000	57.786	0.000	76.504	23.949	0.000	0.000
12220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.662	0.000	76.504	29.634	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	902.658	0.000	918.051	306.175	0.000	0.000
AV	53.189	0.000	116.048	0.000	37.611	0.000	38.252	12.757	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 23 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
123 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123 8	81.785	0.000	168.037	0.000	111.587	0.000	76.504	23.949	0.000	0.000
123 9	98.066	0.000	208.826	0.000	57.904	0.000	76.504	23.949	0.000	0.000
12310	99.683	0.000	213.339	0.000	57.708	0.000	76.504	24.267	0.000	0.000
12311	99.683	0.000	208.758	0.000	101.546	0.000	76.504	24.559	0.000	0.000
12312	99.683	0.000	185.850	0.000	164.770	3.602	76.504	24.007	0.000	0.000
12313	99.683	0.000	184.930	0.000	119.357	1.170	76.504	25.202	0.000	0.000
12314	99.683	0.000	204.176	0.000	86.804	0.000	76.504	27.737	0.000	0.000
12315	99.683	0.000	212.419	0.000	89.423	0.023	76.504	28.792	0.000	0.000
12316	99.362	0.000	212.908	0.000	58.951	0.000	76.504	29.563	0.000	0.000
12317	96.460	0.000	208.973	0.000	57.905	0.000	76.504	26.406	0.000	0.000
12318	84.742	0.000	185.644	0.000	57.904	0.000	76.504	24.137	0.000	0.000
12319	55.756	0.000	106.856	0.000	57.904	0.000	76.504	23.949	0.000	0.000
12320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	164.770	3.602	76.504	29.563	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1021.762	4.794	918.051	306.516	0.000	0.000
AV	53.189	0.000	116.048	0.000	42.573	0.200	38.252	12.772	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 24 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
124 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
124 8	5.538	0.000	31.745	0.000	111.799	0.000	76.504	23.949	0.000	0.000
124 9	5.538	0.000	31.745	0.000	58.032	0.000	76.504	23.949	0.000	0.000
12410	5.538	0.000	31.745	0.000	113.961	1.142	76.504	23.949	0.000	0.000
12411	5.538	0.000	31.745	0.000	204.043	7.762	76.504	23.949	0.000	0.000
12412	5.538	0.000	31.745	0.000	76.731	0.000	76.504	23.949	0.000	0.000
12413	5.538	0.000	31.745	0.000	164.353	5.524	76.504	23.949	0.000	0.000
12414	5.538	0.000	31.745	0.000	205.304	8.457	76.504	23.949	0.000	0.000
12415	5.538	0.000	31.745	0.000	188.400	6.464	76.504	23.949	0.000	0.000
12416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	205.304	8.457	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	1122.625	29.349	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	46.776	1.223	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 26 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
126 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
126 8	81.785	0.000	168.037	0.000	115.354	0.000	76.504	23.949	0.000	0.000
126 9	98.066	0.000	208.826	0.000	96.221	0.000	76.504	23.949	0.000	0.000
12610	99.683	0.000	213.339	0.000	202.055	6.063	76.504	23.949	0.000	0.000
12611	99.683	0.000	208.758	0.000	221.071	9.578	76.504	24.103	0.000	0.000
12612	99.683	0.000	185.850	0.000	220.257	9.715	76.504	23.986	0.000	0.000
12613	99.683	0.000	184.930	0.000	230.055	12.261	76.504	24.006	0.000	0.000
12614	99.683	0.000	204.176	0.000	233.366	12.754	76.504	24.329	0.000	0.000
12615	99.683	0.000	212.419	0.000	232.768	12.308	76.504	24.440	0.000	0.000
12616	99.362	0.000	212.908	0.000	217.059	9.457	76.504	25.971	0.000	0.000
12617	96.460	0.000	208.973	0.000	144.936	3.680	76.504	27.387	0.000	0.000
12618	84.742	0.000	185.644	0.000	182.643	5.281	76.504	23.949	0.000	0.000
12619	55.756	0.000	106.856	0.000	167.266	4.143	76.504	23.949	0.000	0.000
12620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	233.366	12.754	76.504	27.387	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2263.051	85.239	918.051	293.965	0.000	0.000
AV	53.189	0.000	116.048	0.000	94.294	3.552	38.252	12.249	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 27 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
127 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
127 8	81.785	0.000	168.037	0.000	119.897	0.000	76.504	23.949	0.000	0.000
127 9	98.066	0.000	208.826	0.000	82.168	0.000	76.504	23.949	0.000	0.000
12710	99.683	0.000	213.339	0.000	168.091	4.122	76.504	24.049	0.000	0.000
12711	99.683	0.000	208.758	0.000	189.076	5.451	76.504	24.381	0.000	0.000
12712	99.683	0.000	185.850	0.000	221.082	10.282	76.504	24.005	0.000	0.000
12713	99.683	0.000	184.930	0.000	225.779	11.498	76.504	24.057	0.000	0.000
12714	99.683	0.000	204.176	0.000	227.346	12.148	76.504	26.267	0.000	0.000
12715	99.683	0.000	212.419	0.000	217.110	10.339	76.504	28.728	0.000	0.000
12716	99.362	0.000	212.908	0.000	110.414	1.743	76.504	36.640	0.000	0.000
12717	96.460	0.000	208.973	0.000	88.469	0.000	76.504	29.022	0.000	0.000
12718	84.742	0.000	185.644	0.000	58.822	0.000	76.504	26.555	0.000	0.000
12719	55.756	0.000	106.856	0.000	57.843	0.000	76.504	23.949	0.000	0.000
12720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	227.346	12.148	76.504	36.640	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1766.096	55.583	918.051	315.550	0.000	0.000
AV	53.189	0.000	116.048	0.000	73.587	2.316	38.252	13.148	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 28 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
128 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
128 8	81.785	0.000	168.037	0.000	112.154	0.000	76.504	23.949	0.000	0.000
128 9	98.066	0.000	208.826	0.000	58.071	0.000	76.504	24.989	0.000	0.000
12810	99.683	0.000	213.339	0.000	159.010	3.828	76.504	24.680	0.000	0.000
12811	99.683	0.000	208.758	0.000	209.519	7.908	76.504	25.113	0.000	0.000
12812	99.683	0.000	185.850	0.000	220.564	10.113	76.504	24.514	0.000	0.000
12813	99.683	0.000	184.930	0.000	164.569	5.726	76.504	26.422	0.000	0.000
12814	99.683	0.000	204.176	0.000	155.951	4.944	76.504	29.563	0.000	0.000
12815	99.683	0.000	212.419	0.000	139.438	3.256	76.504	33.455	0.000	0.000
12816	99.362	0.000	212.908	0.000	111.414	1.275	76.504	30.385	0.000	0.000
12817	96.460	0.000	208.973	0.000	65.268	0.000	76.504	28.379	0.000	0.000
12818	84.742	0.000	185.644	0.000	84.920	0.000	76.504	24.732	0.000	0.000
12819	55.756	0.000	106.856	0.000	91.580	0.000	76.504	23.949	0.000	0.000
12820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	220.564	10.113	76.504	33.455	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1572.456	37.050	918.051	320.128	0.000	0.000
AV	53.189	0.000	116.048	0.000	65.519	1.544	38.252	13.339	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 29 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
129 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
129 8	81.785	0.000	168.037	0.000	112.389	0.000	76.504	23.949	0.000	0.000
129 9	98.066	0.000	208.826	0.000	58.042	0.000	76.504	25.041	0.000	0.000
12910	99.683	0.000	213.339	0.000	57.879	0.000	76.504	27.162	0.000	0.000
12911	99.683	0.000	208.758	0.000	88.806	0.000	76.504	27.058	0.000	0.000
12912	99.683	0.000	185.850	0.000	59.157	0.000	76.504	29.523	0.000	0.000
12913	99.683	0.000	184.930	0.000	58.059	0.000	76.504	27.920	0.000	0.000
12914	99.683	0.000	204.176	0.000	57.981	0.000	76.504	30.125	0.000	0.000
12915	99.683	0.000	212.419	0.000	57.907	0.000	76.504	31.934	0.000	0.000
12916	99.362	0.000	212.908	0.000	57.904	0.000	76.504	31.593	0.000	0.000
12917	96.460	0.000	208.973	0.000	57.873	0.000	76.504	27.846	0.000	0.000
12918	84.742	0.000	185.644	0.000	57.843	0.000	76.504	24.578	0.000	0.000
12919	55.756	0.000	106.856	0.000	57.841	0.000	76.504	23.949	0.000	0.000
12920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.389	0.000	76.504	31.934	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	781.681	0.000	918.051	330.676	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.570	0.000	38.252	13.778	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 30 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
130 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
130 8	81.785	0.000	168.037	0.000	112.052	0.000	76.504	23.949	0.000	0.000
130 9	98.066	0.000	208.826	0.000	58.101	0.000	76.504	23.949	0.000	0.000
13010	99.683	0.000	213.339	0.000	57.852	0.000	76.504	25.795	0.000	0.000
13011	99.683	0.000	208.758	0.000	57.842	0.000	76.504	25.449	0.000	0.000
13012	99.683	0.000	185.850	0.000	57.870	0.000	76.504	26.356	0.000	0.000
13013	99.683	0.000	184.930	0.000	57.902	0.000	76.504	26.565	0.000	0.000
13014	99.683	0.000	204.176	0.000	57.904	0.000	76.504	30.316	0.000	0.000
13015	99.683	0.000	212.419	0.000	57.904	0.000	76.504	29.267	0.000	0.000
13016	99.362	0.000	212.908	0.000	57.904	0.000	76.504	29.583	0.000	0.000
13017	96.460	0.000	208.973	0.000	57.873	0.000	76.504	26.512	0.000	0.000
13018	84.742	0.000	185.644	0.000	57.816	0.000	76.504	24.198	0.000	0.000
13019	55.756	0.000	106.856	0.000	57.840	0.000	76.504	23.949	0.000	0.000
13020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.052	0.000	76.504	30.316	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.861	0.000	918.051	315.887	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.203	0.000	38.252	13.162	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 31 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
131 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
131 8	5.538	0.000	31.745	0.000	112.034	0.000	76.504	23.949	0.000	0.000
131 9	5.538	0.000	31.745	0.000	58.135	0.000	76.504	23.949	0.000	0.000
13110	5.538	0.000	31.745	0.000	57.883	0.000	76.504	23.949	0.000	0.000
13111	5.538	0.000	31.745	0.000	57.872	0.000	76.504	23.949	0.000	0.000
13112	5.538	0.000	31.745	0.000	57.843	0.000	76.504	23.949	0.000	0.000
13113	5.538	0.000	31.745	0.000	57.841	0.000	76.504	23.949	0.000	0.000
13114	5.538	0.000	31.745	0.000	57.841	0.000	76.504	23.949	0.000	0.000
13115	5.538	0.000	31.745	0.000	57.841	0.000	76.504	23.949	0.000	0.000
13116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JAN 31)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.034	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	517.291	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	21.554	0.000	25.501	7.983	0.000	0.000
MONTHLY SUMMARY (JAN)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	233.366	12.754	76.504	36.640	0.000	0.000
SM	26434.461	0.000	60883.973	0.000	24249.746	291.228	21421.191	7027.579	0.000	0.000
AV	35.530	0.000	81.833	0.000	32.594	0.391	28.792	9.446	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 33 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 2 8	81.785	0.000	168.037	0.000	112.104	0.000	76.504	23.949	0.000	0.000
2 2 9	98.066	0.000	208.826	0.000	58.102	0.000	76.504	23.949	0.000	0.000
2 210	99.683	0.000	213.339	0.000	57.800	0.000	76.504	23.949	0.000	0.000
2 211	99.683	0.000	208.758	0.000	57.788	0.000	76.504	23.949	0.000	0.000
2 212	99.683	0.000	185.850	0.000	57.813	0.000	76.504	23.949	0.000	0.000
2 213	99.683	0.000	184.930	0.000	57.814	0.000	76.504	23.949	0.000	0.000
2 214	99.683	0.000	204.176	0.000	57.840	0.000	76.504	23.949	0.000	0.000
2 215	99.683	0.000	212.419	0.000	57.870	0.000	76.504	23.949	0.000	0.000
2 216	99.362	0.000	212.908	0.000	57.871	0.000	76.504	23.949	0.000	0.000
2 217	96.460	0.000	208.973	0.000	57.816	0.000	76.504	23.949	0.000	0.000
2 218	84.742	0.000	185.644	0.000	57.814	0.000	76.504	23.949	0.000	0.000
2 219	55.756	0.000	106.856	0.000	57.814	0.000	76.504	23.949	0.000	0.000
2 220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.104	0.000	76.504	23.949	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.446	0.000	918.051	287.384	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.185	0.000	38.252	11.974	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 34 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 3 8	81.785	0.000	168.037	0.000	111.805	0.000	76.504	23.949	0.000	0.000
2 3 9	98.066	0.000	208.826	0.000	58.063	0.000	76.504	23.949	0.000	0.000
2 310	99.683	0.000	213.339	0.000	57.824	0.000	76.504	23.949	0.000	0.000
2 311	99.683	0.000	208.758	0.000	57.814	0.000	76.504	24.814	0.000	0.000
2 312	99.683	0.000	185.850	0.000	57.869	0.000	76.504	24.766	0.000	0.000
2 313	99.683	0.000	184.930	0.000	57.843	0.000	76.504	25.297	0.000	0.000
2 314	99.683	0.000	204.176	0.000	57.870	0.000	76.504	27.983	0.000	0.000
2 315	99.683	0.000	212.419	0.000	57.871	0.000	76.504	31.066	0.000	0.000
2 316	99.362	0.000	212.908	0.000	57.816	0.000	76.504	32.682	0.000	0.000
2 317	96.460	0.000	208.973	0.000	57.766	0.000	76.504	29.918	0.000	0.000
2 318	84.742	0.000	185.644	0.000	57.812	0.000	76.504	24.685	0.000	0.000
2 319	55.756	0.000	106.856	0.000	57.789	0.000	76.504	23.949	0.000	0.000
2 320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.805	0.000	76.504	32.682	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.141	0.000	918.051	317.006	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.173	0.000	38.252	13.209	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 35 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 4 8	81.785	0.000	168.037	0.000	111.755	0.000	76.504	23.949	0.000	0.000
2 4 9	98.066	0.000	208.826	0.000	58.003	0.000	76.504	23.949	0.000	0.000
2 410	99.683	0.000	213.339	0.000	57.773	0.000	76.504	24.112	0.000	0.000
2 411	99.683	0.000	208.758	0.000	57.812	0.000	76.504	25.396	0.000	0.000
2 412	99.683	0.000	185.850	0.000	84.332	0.000	76.504	24.659	0.000	0.000
2 413	99.683	0.000	184.930	0.000	84.957	0.000	76.504	25.194	0.000	0.000
2 414	99.683	0.000	204.176	0.000	58.889	0.000	76.504	29.393	0.000	0.000
2 415	99.683	0.000	212.419	0.000	57.936	0.000	76.504	31.041	0.000	0.000
2 416	99.362	0.000	212.908	0.000	57.905	0.000	76.504	30.545	0.000	0.000
2 417	96.460	0.000	208.973	0.000	57.904	0.000	76.504	27.615	0.000	0.000
2 418	84.742	0.000	185.644	0.000	57.873	0.000	76.504	24.256	0.000	0.000
2 419	55.756	0.000	106.856	0.000	57.843	0.000	76.504	23.949	0.000	0.000
2 420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.755	0.000	76.504	31.041	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	802.981	0.000	918.051	314.056	0.000	0.000
AV	53.189	0.000	116.048	0.000	33.458	0.000	38.252	13.086	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 36 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 5 8	81.785	0.000	168.037	0.000	111.855	0.000	76.504	23.949	0.000	0.000
2 5 9	98.066	0.000	208.826	0.000	58.064	0.000	76.504	23.949	0.000	0.000
2 510	99.683	0.000	213.339	0.000	57.824	0.000	76.504	24.839	0.000	0.000
2 511	99.683	0.000	208.758	0.000	57.869	0.000	76.504	26.060	0.000	0.000
2 512	99.683	0.000	185.850	0.000	57.902	0.000	76.504	25.230	0.000	0.000
2 513	99.683	0.000	184.930	0.000	57.904	0.000	76.504	26.142	0.000	0.000
2 514	99.683	0.000	204.176	0.000	57.904	0.000	76.504	29.029	0.000	0.000
2 515	99.683	0.000	212.419	0.000	57.873	0.000	76.504	31.281	0.000	0.000
2 516	99.362	0.000	212.908	0.000	57.872	0.000	76.504	32.983	0.000	0.000
2 517	96.460	0.000	208.973	0.000	57.871	0.000	76.504	29.419	0.000	0.000
2 518	84.742	0.000	185.644	0.000	57.843	0.000	76.504	24.763	0.000	0.000
2 519	55.756	0.000	106.856	0.000	57.841	0.000	76.504	23.949	0.000	0.000
2 520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.855	0.000	76.504	32.983	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.622	0.000	918.051	321.592	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.193	0.000	38.252	13.400	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 37 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 6 8	81.785	0.000	168.037	0.000	112.036	0.000	76.504	23.949	0.000	0.000
2 6 9	98.066	0.000	208.826	0.000	58.101	0.000	76.504	23.949	0.000	0.000
2 610	99.683	0.000	213.339	0.000	57.852	0.000	76.504	24.748	0.000	0.000
2 611	99.683	0.000	208.758	0.000	57.871	0.000	76.504	26.385	0.000	0.000
2 612	99.683	0.000	185.850	0.000	57.902	0.000	76.504	25.945	0.000	0.000
2 613	99.683	0.000	184.930	0.000	57.937	0.000	76.504	26.099	0.000	0.000
2 614	99.683	0.000	204.176	0.000	57.939	0.000	76.504	28.917	0.000	0.000
2 615	99.683	0.000	212.419	0.000	57.905	0.000	76.504	33.201	0.000	0.000
2 616	99.362	0.000	212.908	0.000	57.904	0.000	76.504	33.560	0.000	0.000
2 617	96.460	0.000	208.973	0.000	57.873	0.000	76.504	29.351	0.000	0.000
2 618	84.742	0.000	185.644	0.000	57.872	0.000	76.504	24.663	0.000	0.000
2 619	55.756	0.000	106.856	0.000	57.843	0.000	76.504	23.949	0.000	0.000
2 620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.036	0.000	76.504	33.560	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	749.034	0.000	918.051	324.715	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.210	0.000	38.252	13.530	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 38 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 7 8	5.538	0.000	31.745	0.000	111.858	0.000	76.504	23.949	0.000	0.000
2 7 9	5.538	0.000	31.745	0.000	58.064	0.000	76.504	23.949	0.000	0.000
2 710	5.538	0.000	31.745	0.000	57.851	0.000	76.504	23.949	0.000	0.000
2 711	5.538	0.000	31.745	0.000	57.871	0.000	76.504	23.949	0.000	0.000
2 712	5.538	0.000	31.745	0.000	57.902	0.000	76.504	23.949	0.000	0.000
2 713	5.538	0.000	31.745	0.000	64.989	0.000	76.504	23.949	0.000	0.000
2 714	5.538	0.000	31.745	0.000	58.245	0.000	76.504	23.949	0.000	0.000
2 715	5.538	0.000	31.745	0.000	57.950	0.000	76.504	23.949	0.000	0.000
2 716	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 717	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 718	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 719	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 720	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 721	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 722	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 723	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	111.858	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	524.729	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	21.864	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 40 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
2 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 9 8	81.785	0.000	168.037	0.000	111.805	0.000	76.504	23.949	0.000	0.000
2 9 9	98.066	0.000	208.826	0.000	58.167	0.000	76.504	23.949	0.000	0.000
2 910	99.683	0.000	213.339	0.000	57.884	0.000	76.504	23.949	0.000	0.000
2 911	99.683	0.000	208.758	0.000	66.736	0.000	76.504	23.949	0.000	0.000
2 912	99.683	0.000	185.850	0.000	87.873	0.274	76.504	23.949	0.000	0.000
2 913	99.683	0.000	184.930	0.000	66.807	0.000	76.504	24.426	0.000	0.000
2 914	99.683	0.000	204.176	0.000	187.307	6.820	76.504	24.196	0.000	0.000
2 915	99.683	0.000	212.419	0.000	205.516	7.391	76.504	25.253	0.000	0.000
2 916	99.362	0.000	212.908	0.000	126.794	2.942	76.504	28.519	0.000	0.000
2 917	96.460	0.000	208.973	0.000	85.650	0.028	76.504	26.605	0.000	0.000
2 918	84.742	0.000	185.644	0.000	58.898	0.000	76.504	24.344	0.000	0.000
2 919	55.756	0.000	106.856	0.000	57.937	0.000	76.504	23.949	0.000	0.000
2 920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2 924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	205.516	7.391	76.504	28.519	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1171.375	17.454	918.051	297.035	0.000	0.000
AV	53.189	0.000	116.048	0.000	48.807	0.727	38.252	12.376	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 41 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
210 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
210 8	81.785	0.000	168.037	0.000	111.707	0.000	76.504	23.949	0.000	0.000
210 9	98.066	0.000	208.826	0.000	114.163	0.559	76.504	23.949	0.000	0.000
21010	99.683	0.000	213.339	0.000	203.085	6.319	76.504	23.949	0.000	0.000
21011	99.683	0.000	208.758	0.000	219.678	9.656	76.504	24.054	0.000	0.000
21012	99.683	0.000	185.850	0.000	215.539	9.703	76.504	24.260	0.000	0.000
21013	99.683	0.000	184.930	0.000	213.391	9.709	76.504	24.595	0.000	0.000
21014	99.683	0.000	204.176	0.000	213.613	9.769	76.504	26.510	0.000	0.000
21015	99.683	0.000	212.419	0.000	207.739	8.626	76.504	29.656	0.000	0.000
21016	99.362	0.000	212.908	0.000	201.735	6.988	76.504	30.634	0.000	0.000
21017	96.460	0.000	208.973	0.000	172.895	5.295	76.504	28.517	0.000	0.000
21018	84.742	0.000	185.644	0.000	120.002	1.835	76.504	25.103	0.000	0.000
21019	55.756	0.000	106.856	0.000	63.545	0.000	76.504	23.949	0.000	0.000
21020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	219.678	9.769	76.504	30.634	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2057.093	68.458	918.051	309.124	0.000	0.000
AV	53.189	0.000	116.048	0.000	85.712	2.852	38.252	12.880	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 42 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
211 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
211 8	81.785	0.000	168.037	0.000	112.091	0.000	76.504	23.949	0.000	0.000
211 9	98.066	0.000	208.826	0.000	82.175	0.000	76.504	24.289	0.000	0.000
21110	99.683	0.000	213.339	0.000	200.998	7.807	76.504	24.223	0.000	0.000
21111	99.683	0.000	208.758	0.000	213.730	10.985	76.504	24.559	0.000	0.000
21112	99.683	0.000	185.850	0.000	206.935	9.302	76.504	25.016	0.000	0.000
21113	99.683	0.000	184.930	0.000	207.525	9.506	76.504	25.366	0.000	0.000
21114	99.683	0.000	204.176	0.000	218.053	11.225	76.504	26.460	0.000	0.000
21115	99.683	0.000	212.419	0.000	221.388	11.753	76.504	28.264	0.000	0.000
21116	99.362	0.000	212.908	0.000	221.645	11.801	76.504	28.424	0.000	0.000
21117	96.460	0.000	208.973	0.000	194.473	7.665	76.504	28.885	0.000	0.000
21118	84.742	0.000	185.644	0.000	156.898	5.008	76.504	24.861	0.000	0.000
21119	55.756	0.000	106.856	0.000	61.171	0.000	76.504	23.949	0.000	0.000
21120	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21121	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21122	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21123	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21124	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	221.645	11.801	76.504	28.885	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2097.083	85.052	918.051	308.245	0.000	0.000
AV	53.189	0.000	116.048	0.000	87.378	3.544	38.252	12.844	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 43 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
212 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
212 8	81.785	0.000	168.037	0.000	136.723	0.365	76.504	23.949	0.000	0.000
212 9	98.066	0.000	208.826	0.000	204.242	7.517	76.504	23.949	0.000	0.000
21210	99.683	0.000	213.339	0.000	221.438	11.713	76.504	23.949	0.000	0.000
21211	99.683	0.000	208.758	0.000	227.069	13.165	76.504	23.949	0.000	0.000
21212	99.683	0.000	185.850	0.000	228.406	14.136	76.504	23.949	0.000	0.000
21213	99.683	0.000	184.930	0.000	229.443	14.886	76.504	23.949	0.000	0.000
21214	99.683	0.000	204.176	0.000	240.087	16.821	76.504	24.795	0.000	0.000
21215	99.683	0.000	212.419	0.000	239.206	16.023	76.504	25.531	0.000	0.000
21216	99.362	0.000	212.908	0.000	239.944	16.165	76.504	26.683	0.000	0.000
21217	96.460	0.000	208.973	0.000	216.022	10.670	76.504	27.391	0.000	0.000
21218	84.742	0.000	185.644	0.000	121.808	2.503	76.504	26.836	0.000	0.000
21219	55.756	0.000	106.856	0.000	94.406	0.461	76.504	23.949	0.000	0.000
21220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	240.087	16.821	76.504	27.391	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2398.796	124.425	918.051	298.876	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.950	5.184	38.252	12.453	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 44 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
213 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
213 8	81.785	0.000	168.037	0.000	113.342	0.000	76.504	24.195	0.000	0.000
213 9	98.066	0.000	208.826	0.000	178.976	4.984	76.504	24.753	0.000	0.000
21310	99.683	0.000	213.339	0.000	214.334	9.031	76.504	25.218	0.000	0.000
21311	99.683	0.000	208.758	0.000	229.068	12.452	76.504	25.349	0.000	0.000
21312	99.683	0.000	185.850	0.000	232.952	13.737	76.504	24.320	0.000	0.000
21313	99.683	0.000	184.930	0.000	218.701	11.962	76.504	27.056	0.000	0.000
21314	99.683	0.000	204.176	0.000	218.031	11.587	76.504	29.113	0.000	0.000
21315	99.683	0.000	212.419	0.000	216.026	10.778	76.504	32.910	0.000	0.000
21316	99.362	0.000	212.908	0.000	206.651	8.721	76.504	35.847	0.000	0.000
21317	96.460	0.000	208.973	0.000	186.608	7.170	76.504	33.491	0.000	0.000
21318	84.742	0.000	185.644	0.000	62.347	0.000	76.504	30.747	0.000	0.000
21319	55.756	0.000	106.856	0.000	58.039	0.000	76.504	23.949	0.000	0.000
21320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	232.952	13.737	76.504	35.847	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2135.077	90.421	918.051	336.946	0.000	0.000
AV	53.189	0.000	116.048	0.000	88.962	3.768	38.252	14.039	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 45 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
214 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
214 8	5.538	0.000	31.745	0.000	112.059	0.000	76.504	23.949	0.000	0.000
214 9	5.538	0.000	31.745	0.000	58.213	0.000	76.504	23.949	0.000	0.000
21410	5.538	0.000	31.745	0.000	57.952	0.000	76.504	23.949	0.000	0.000
21411	5.538	0.000	31.745	0.000	58.015	0.000	76.504	23.949	0.000	0.000
21412	5.538	0.000	31.745	0.000	113.900	2.370	76.504	23.949	0.000	0.000
21413	5.538	0.000	31.745	0.000	126.380	3.187	76.504	23.949	0.000	0.000
21414	5.538	0.000	31.745	0.000	84.641	0.379	76.504	23.949	0.000	0.000
21415	5.538	0.000	31.745	0.000	59.032	0.000	76.504	23.949	0.000	0.000
21416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	126.380	3.187	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	670.193	5.936	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	27.925	0.247	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 48 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
217 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
217 8	81.785	0.000	168.037	0.000	112.036	0.000	76.504	23.949	0.000	0.000
217 9	98.066	0.000	208.826	0.000	58.135	0.000	76.504	23.949	0.000	0.000
21710	99.683	0.000	213.339	0.000	57.854	0.000	76.504	23.949	0.000	0.000
21711	99.683	0.000	208.758	0.000	57.815	0.000	76.504	23.949	0.000	0.000
21712	99.683	0.000	185.850	0.000	57.869	0.000	76.504	23.949	0.000	0.000
21713	99.683	0.000	184.930	0.000	57.902	0.000	76.504	24.232	0.000	0.000
21714	99.683	0.000	204.176	0.000	57.937	0.000	76.504	25.646	0.000	0.000
21715	99.683	0.000	212.419	0.000	57.905	0.000	76.504	26.337	0.000	0.000
21716	99.362	0.000	212.908	0.000	57.873	0.000	76.504	26.213	0.000	0.000
21717	96.460	0.000	208.973	0.000	57.872	0.000	76.504	24.742	0.000	0.000
21718	84.742	0.000	185.644	0.000	57.871	0.000	76.504	23.949	0.000	0.000
21719	55.756	0.000	106.856	0.000	57.843	0.000	76.504	23.949	0.000	0.000
21720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.036	0.000	76.504	26.337	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.913	0.000	918.051	294.810	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.205	0.000	38.252	12.284	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 49 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
218 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
218 8	81.785	0.000	168.037	0.000	112.032	0.000	76.504	23.949	0.000	0.000
218 9	98.066	0.000	208.826	0.000	58.135	0.000	76.504	23.949	0.000	0.000
21810	99.683	0.000	213.339	0.000	57.854	0.000	76.504	24.000	0.000	0.000
21811	99.683	0.000	208.758	0.000	57.871	0.000	76.504	24.965	0.000	0.000
21812	99.683	0.000	185.850	0.000	66.288	0.000	76.504	24.622	0.000	0.000
21813	99.683	0.000	184.930	0.000	58.252	0.000	76.504	25.454	0.000	0.000
21814	99.683	0.000	204.176	0.000	57.949	0.000	76.504	27.875	0.000	0.000
21815	99.683	0.000	212.419	0.000	57.906	0.000	76.504	32.088	0.000	0.000
21816	99.362	0.000	212.908	0.000	57.873	0.000	76.504	33.210	0.000	0.000
21817	96.460	0.000	208.973	0.000	57.816	0.000	76.504	30.810	0.000	0.000
21818	84.742	0.000	185.644	0.000	57.789	0.000	76.504	25.064	0.000	0.000
21819	55.756	0.000	106.856	0.000	57.788	0.000	76.504	23.949	0.000	0.000
21820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.032	0.000	76.504	33.210	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	757.553	0.000	918.051	319.935	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.565	0.000	38.252	13.331	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 50 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
219 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
219 8	81.785	0.000	168.037	0.000	111.970	0.000	76.504	23.949	0.000	0.000
219 9	98.066	0.000	208.826	0.000	58.134	0.000	76.504	23.949	0.000	0.000
21910	99.683	0.000	213.339	0.000	57.827	0.000	76.504	23.949	0.000	0.000
21911	99.683	0.000	208.758	0.000	57.814	0.000	76.504	23.949	0.000	0.000
21912	99.683	0.000	185.850	0.000	57.840	0.000	76.504	23.949	0.000	0.000
21913	99.683	0.000	184.930	0.000	57.841	0.000	76.504	23.949	0.000	0.000
21914	99.683	0.000	204.176	0.000	57.901	0.000	76.504	24.801	0.000	0.000
21915	99.683	0.000	212.419	0.000	57.817	0.000	76.504	25.048	0.000	0.000
21916	99.362	0.000	212.908	0.000	57.789	0.000	76.504	26.559	0.000	0.000
21917	96.460	0.000	208.973	0.000	57.765	0.000	76.504	25.694	0.000	0.000
21918	84.742	0.000	185.644	0.000	57.742	0.000	76.504	23.949	0.000	0.000
21919	55.756	0.000	106.856	0.000	57.653	0.000	76.504	23.949	0.000	0.000
21920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.970	0.000	76.504	26.559	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.093	0.000	918.051	293.691	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.171	0.000	38.252	12.237	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 51 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
220 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
220 8	81.785	0.000	168.037	0.000	111.490	0.000	76.504	23.949	0.000	0.000
220 9	98.066	0.000	208.826	0.000	57.827	0.000	76.504	23.949	0.000	0.000
22010	99.683	0.000	213.339	0.000	57.627	0.000	76.504	24.414	0.000	0.000
22011	99.683	0.000	208.758	0.000	57.634	0.000	76.504	25.599	0.000	0.000
22012	99.683	0.000	185.850	0.000	57.665	0.000	76.504	25.501	0.000	0.000
22013	99.683	0.000	184.930	0.000	57.718	0.000	76.504	25.533	0.000	0.000
22014	99.683	0.000	204.176	0.000	57.720	0.000	76.504	29.021	0.000	0.000
22015	99.683	0.000	212.419	0.000	57.741	0.000	76.504	32.148	0.000	0.000
22016	99.362	0.000	212.908	0.000	57.741	0.000	76.504	32.570	0.000	0.000
22017	96.460	0.000	208.973	0.000	57.721	0.000	76.504	29.705	0.000	0.000
22018	84.742	0.000	185.644	0.000	57.720	0.000	76.504	24.815	0.000	0.000
22019	55.756	0.000	106.856	0.000	57.741	0.000	76.504	23.949	0.000	0.000
22020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.490	0.000	76.504	32.570	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	746.346	0.000	918.051	321.152	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.098	0.000	38.252	13.381	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 52 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
221 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
221 8	5.538	0.000	31.745	0.000	111.663	0.000	76.504	23.949	0.000	0.000
221 9	5.538	0.000	31.745	0.000	57.975	0.000	76.504	23.949	0.000	0.000
22110	5.538	0.000	31.745	0.000	57.772	0.000	76.504	23.949	0.000	0.000
22111	5.538	0.000	31.745	0.000	57.812	0.000	76.504	23.949	0.000	0.000
22112	5.538	0.000	31.745	0.000	57.814	0.000	76.504	23.949	0.000	0.000
22113	5.538	0.000	31.745	0.000	57.869	0.000	76.504	23.949	0.000	0.000
22114	5.538	0.000	31.745	0.000	57.871	0.000	76.504	23.949	0.000	0.000
22115	5.538	0.000	31.745	0.000	57.843	0.000	76.504	23.949	0.000	0.000
22116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	111.663	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	516.618	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	21.526	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 54 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
223 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
223 8	81.785	0.000	168.037	0.000	111.803	0.000	76.504	23.949	0.000	0.000
223 9	98.066	0.000	208.826	0.000	58.033	0.000	76.504	23.949	0.000	0.000
22310	99.683	0.000	213.339	0.000	57.752	0.000	76.504	23.949	0.000	0.000
22311	99.683	0.000	208.758	0.000	57.786	0.000	76.504	24.646	0.000	0.000
22312	99.683	0.000	185.850	0.000	82.428	0.000	76.504	24.205	0.000	0.000
22313	99.683	0.000	184.930	0.000	100.004	0.397	76.504	24.402	0.000	0.000
22314	99.683	0.000	204.176	0.000	86.010	0.000	76.504	26.497	0.000	0.000
22315	99.683	0.000	212.419	0.000	66.878	0.000	76.504	29.122	0.000	0.000
22316	99.362	0.000	212.908	0.000	68.180	0.000	76.504	30.121	0.000	0.000
22317	96.460	0.000	208.973	0.000	67.781	0.000	76.504	29.240	0.000	0.000
22318	84.742	0.000	185.644	0.000	58.192	0.000	76.504	25.456	0.000	0.000
22319	55.756	0.000	106.856	0.000	57.800	0.000	76.504	23.949	0.000	0.000
22320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.803	0.397	76.504	30.121	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	872.647	0.397	918.051	309.483	0.000	0.000
AV	53.189	0.000	116.048	0.000	36.360	0.017	38.252	12.895	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 55 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
224 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
224 8	81.785	0.000	168.037	0.000	111.801	0.000	76.504	23.949	0.000	0.000
224 9	98.066	0.000	208.826	0.000	58.033	0.000	76.504	23.949	0.000	0.000
22410	99.683	0.000	213.339	0.000	57.823	0.000	76.504	26.248	0.000	0.000
22411	99.683	0.000	208.758	0.000	124.954	1.776	76.504	25.458	0.000	0.000
22412	99.683	0.000	185.850	0.000	64.107	0.000	76.504	26.441	0.000	0.000
22413	99.683	0.000	184.930	0.000	67.235	0.000	76.504	26.359	0.000	0.000
22414	99.683	0.000	204.176	0.000	68.010	0.000	76.504	29.640	0.000	0.000
22415	99.683	0.000	212.419	0.000	68.857	0.000	76.504	32.333	0.000	0.000
22416	99.362	0.000	212.908	0.000	58.304	0.000	76.504	34.163	0.000	0.000
22417	96.460	0.000	208.973	0.000	57.829	0.000	76.504	32.274	0.000	0.000
22418	84.742	0.000	185.644	0.000	57.789	0.000	76.504	25.746	0.000	0.000
22419	55.756	0.000	106.856	0.000	57.813	0.000	76.504	23.949	0.000	0.000
22420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	124.954	1.776	76.504	34.163	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	852.554	1.776	918.051	330.509	0.000	0.000
AV	53.189	0.000	116.048	0.000	35.523	0.074	38.252	13.771	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 56 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
225 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
225 8	81.785	0.000	168.037	0.000	112.030	0.000	76.504	23.949	0.000	0.000
225 9	98.066	0.000	208.826	0.000	58.213	0.000	76.504	24.171	0.000	0.000
22510	99.683	0.000	213.339	0.000	57.918	0.000	76.504	26.569	0.000	0.000
22511	99.683	0.000	208.758	0.000	57.938	0.000	76.504	28.048	0.000	0.000
22512	99.683	0.000	185.850	0.000	57.939	0.000	76.504	27.313	0.000	0.000
22513	99.683	0.000	184.930	0.000	57.939	0.000	76.504	28.030	0.000	0.000
22514	99.683	0.000	204.176	0.000	57.905	0.000	76.504	30.870	0.000	0.000
22515	99.683	0.000	212.419	0.000	134.600	1.845	76.504	28.817	0.000	0.000
22516	99.362	0.000	212.908	0.000	87.546	0.000	76.504	31.274	0.000	0.000
22517	96.460	0.000	208.973	0.000	58.557	0.000	76.504	29.016	0.000	0.000
22518	84.742	0.000	185.644	0.000	57.641	0.000	76.504	24.714	0.000	0.000
22519	55.756	0.000	106.856	0.000	57.608	0.000	76.504	23.949	0.000	0.000
22520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 25)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	134.600	1.845	76.504	31.274	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	855.834	1.845	918.051	326.719	0.000	0.000
AV	53.189	0.000	116.048	0.000	35.660	0.077	38.252	13.613	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 57 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
226 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
226 8	81.785	0.000	168.037	0.000	111.492	0.000	76.504	23.949	0.000	0.000
226 9	98.066	0.000	208.826	0.000	57.862	0.000	76.504	24.138	0.000	0.000
22610	99.683	0.000	213.339	0.000	57.657	0.000	76.504	26.411	0.000	0.000
22611	99.683	0.000	208.758	0.000	67.141	0.000	76.504	26.815	0.000	0.000
22612	99.683	0.000	185.850	0.000	105.131	0.000	76.504	25.423	0.000	0.000
22613	99.683	0.000	184.930	0.000	142.290	1.775	76.504	25.304	0.000	0.000
22614	99.683	0.000	204.176	0.000	151.362	2.285	76.504	28.193	0.000	0.000
22615	99.683	0.000	212.419	0.000	156.822	2.191	76.504	30.608	0.000	0.000
22616	99.362	0.000	212.908	0.000	158.108	2.246	76.504	31.240	0.000	0.000
22617	96.460	0.000	208.973	0.000	109.495	0.000	76.504	30.878	0.000	0.000
22618	84.742	0.000	185.644	0.000	59.178	0.000	76.504	27.130	0.000	0.000
22619	55.756	0.000	106.856	0.000	57.640	0.000	76.504	23.949	0.000	0.000
22620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	158.108	2.285	76.504	31.240	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1234.176	8.498	918.051	324.037	0.000	0.000
AV	53.189	0.000	116.048	0.000	51.424	0.354	38.252	13.502	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 58 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
227 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
227 8	81.785	0.000	168.037	0.000	111.431	0.000	76.504	23.949	0.000	0.000
227 9	98.066	0.000	208.826	0.000	57.826	0.000	76.504	24.439	0.000	0.000
22710	99.683	0.000	213.339	0.000	57.627	0.000	76.504	26.893	0.000	0.000
22711	99.683	0.000	208.758	0.000	57.649	0.000	76.504	29.236	0.000	0.000
22712	99.683	0.000	185.850	0.000	57.650	0.000	76.504	27.499	0.000	0.000
22713	99.683	0.000	184.930	0.000	57.665	0.000	76.504	27.740	0.000	0.000
22714	99.683	0.000	204.176	0.000	57.682	0.000	76.504	30.825	0.000	0.000
22715	99.683	0.000	212.419	0.000	57.700	0.000	76.504	34.178	0.000	0.000
22716	99.362	0.000	212.908	0.000	57.701	0.000	76.504	34.954	0.000	0.000
22717	96.460	0.000	208.973	0.000	57.720	0.000	76.504	32.636	0.000	0.000
22718	84.742	0.000	185.644	0.000	57.720	0.000	76.504	25.660	0.000	0.000
22719	55.756	0.000	106.856	0.000	57.741	0.000	76.504	23.949	0.000	0.000
22720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.431	0.000	76.504	34.954	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	746.111	0.000	918.051	341.957	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.088	0.000	38.252	14.248	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 59 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
228 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
228 8	5.538	0.000	31.745	0.000	111.517	0.000	76.504	23.949	0.000	0.000
228 9	5.538	0.000	31.745	0.000	57.863	0.000	76.504	23.949	0.000	0.000
22810	5.538	0.000	31.745	0.000	57.642	0.000	76.504	23.949	0.000	0.000
22811	5.538	0.000	31.745	0.000	57.665	0.000	76.504	23.949	0.000	0.000
22812	5.538	0.000	31.745	0.000	57.682	0.000	76.504	23.949	0.000	0.000
22813	5.538	0.000	31.745	0.000	57.719	0.000	76.504	23.949	0.000	0.000
22814	5.538	0.000	31.745	0.000	57.740	0.000	76.504	23.949	0.000	0.000
22815	5.538	0.000	31.745	0.000	57.763	0.000	76.504	23.949	0.000	0.000
22816	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22817	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22818	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22819	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22820	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22821	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22822	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22823	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (FEB 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	111.517	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	515.591	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	21.483	0.000	25.501	7.983	0.000	0.000
MONTHLY SUMMARY (FEB)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	240.087	16.821	76.504	35.847	0.000	0.000
SM	24985.145	0.000	57108.359	0.000	23446.006	404.262	19891.109	6743.629	0.000	0.000
AV	37.180	0.000	84.983	0.000	34.890	0.602	29.600	10.035	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 61 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 2 8	81.785	0.000	168.037	0.000	112.035	0.000	76.504	23.949	0.000	0.000
3 2 9	98.066	0.000	208.826	0.000	58.101	0.000	76.504	23.949	0.000	0.000
3 210	99.683	0.000	213.339	0.000	57.825	0.000	76.504	24.012	0.000	0.000
3 211	99.683	0.000	208.758	0.000	65.469	0.000	76.504	24.002	0.000	0.000
3 212	99.683	0.000	185.850	0.000	65.656	0.000	76.504	24.362	0.000	0.000
3 213	99.683	0.000	184.930	0.000	58.117	0.000	76.504	24.868	0.000	0.000
3 214	99.683	0.000	204.176	0.000	87.475	0.000	76.504	26.167	0.000	0.000
3 215	99.683	0.000	212.419	0.000	58.852	0.000	76.504	29.313	0.000	0.000
3 216	99.362	0.000	212.908	0.000	57.871	0.000	76.504	30.576	0.000	0.000
3 217	96.460	0.000	208.973	0.000	57.843	0.000	76.504	29.144	0.000	0.000
3 218	84.742	0.000	185.644	0.000	57.815	0.000	76.504	24.799	0.000	0.000
3 219	55.756	0.000	106.856	0.000	57.814	0.000	76.504	23.949	0.000	0.000
3 220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.035	0.000	76.504	30.576	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	794.871	0.000	918.051	309.088	0.000	0.000
AV	53.189	0.000	116.048	0.000	33.120	0.000	38.252	12.879	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 62 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 3 8	81.785	0.000	168.037	0.000	111.972	0.000	76.504	23.949	0.000	0.000
3 3 9	98.066	0.000	208.826	0.000	58.099	0.000	76.504	24.186	0.000	0.000
3 310	99.683	0.000	213.339	0.000	97.524	0.149	76.504	23.949	0.000	0.000
3 311	99.683	0.000	208.758	0.000	141.048	3.164	76.504	24.948	0.000	0.000
3 312	99.683	0.000	185.850	0.000	189.964	6.874	76.504	24.372	0.000	0.000
3 313	99.683	0.000	184.930	0.000	205.514	8.542	76.504	24.762	0.000	0.000
3 314	99.683	0.000	204.176	0.000	224.773	13.563	76.504	25.204	0.000	0.000
3 315	99.683	0.000	212.419	0.000	180.312	6.466	76.504	31.703	0.000	0.000
3 316	99.362	0.000	212.908	0.000	124.653	3.121	76.504	33.471	0.000	0.000
3 317	96.460	0.000	208.973	0.000	99.869	1.355	76.504	30.671	0.000	0.000
3 318	84.742	0.000	185.644	0.000	59.543	0.000	76.504	27.089	0.000	0.000
3 319	55.756	0.000	106.856	0.000	58.033	0.000	76.504	23.949	0.000	0.000
3 320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	224.773	13.563	76.504	33.471	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1551.304	43.235	918.051	318.252	0.000	0.000
AV	53.189	0.000	116.048	0.000	64.638	1.801	38.252	13.260	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 63 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 4 8	81.785	0.000	168.037	0.000	113.395	0.000	76.504	23.949	0.000	0.000
3 4 9	98.066	0.000	208.826	0.000	137.610	2.380	76.504	23.949	0.000	0.000
3 410	99.683	0.000	213.339	0.000	202.008	6.601	76.504	23.949	0.000	0.000
3 411	99.683	0.000	208.758	0.000	217.325	9.598	76.504	23.949	0.000	0.000
3 412	99.683	0.000	185.850	0.000	219.663	10.470	76.504	23.949	0.000	0.000
3 413	99.683	0.000	184.930	0.000	223.678	11.548	76.504	23.949	0.000	0.000
3 414	99.683	0.000	204.176	0.000	225.282	11.814	76.504	24.545	0.000	0.000
3 415	99.683	0.000	212.419	0.000	230.210	11.379	76.504	26.036	0.000	0.000
3 416	99.362	0.000	212.908	0.000	228.788	11.099	76.504	25.526	0.000	0.000
3 417	96.460	0.000	208.973	0.000	190.186	6.614	76.504	27.686	0.000	0.000
3 418	84.742	0.000	185.644	0.000	137.786	3.234	76.504	24.925	0.000	0.000
3 419	55.756	0.000	106.856	0.000	119.250	1.772	76.504	23.949	0.000	0.000
3 420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	230.210	11.814	76.504	27.686	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2245.181	86.510	918.051	296.359	0.000	0.000
AV	53.189	0.000	116.048	0.000	93.549	3.605	38.252	12.348	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 64 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 5 8	81.785	0.000	168.037	0.000	114.192	0.000	76.504	23.949	0.000	0.000
3 5 9	98.066	0.000	208.826	0.000	66.412	0.000	76.504	24.371	0.000	0.000
3 510	99.683	0.000	213.339	0.000	66.015	0.000	76.504	24.553	0.000	0.000
3 511	99.683	0.000	208.758	0.000	103.781	0.669	76.504	24.802	0.000	0.000
3 512	99.683	0.000	185.850	0.000	100.128	0.584	76.504	24.221	0.000	0.000
3 513	99.683	0.000	184.930	0.000	59.434	0.000	76.504	24.849	0.000	0.000
3 514	99.683	0.000	204.176	0.000	68.639	0.000	76.504	25.149	0.000	0.000
3 515	99.683	0.000	212.419	0.000	93.593	0.694	76.504	25.148	0.000	0.000
3 516	99.362	0.000	212.908	0.000	121.835	2.921	76.504	24.912	0.000	0.000
3 517	96.460	0.000	208.973	0.000	96.995	1.220	76.504	24.864	0.000	0.000
3 518	84.742	0.000	185.644	0.000	59.507	0.000	76.504	24.142	0.000	0.000
3 519	55.756	0.000	106.856	0.000	58.074	0.000	76.504	23.949	0.000	0.000
3 520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	121.835	2.921	76.504	25.149	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1008.605	6.089	918.051	294.907	0.000	0.000
AV	53.189	0.000	116.048	0.000	42.025	0.254	38.252	12.288	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 65 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 6 8	81.785	0.000	168.037	0.000	112.608	0.000	76.504	23.949	0.000	0.000
3 6 9	98.066	0.000	208.826	0.000	58.368	0.000	76.504	24.118	0.000	0.000
3 610	99.683	0.000	213.339	0.000	58.036	0.000	76.504	24.550	0.000	0.000
3 611	99.683	0.000	208.758	0.000	165.428	6.465	76.504	24.225	0.000	0.000
3 612	99.683	0.000	185.850	0.000	165.343	5.979	76.504	24.138	0.000	0.000
3 613	99.683	0.000	184.930	0.000	92.350	1.033	76.504	24.619	0.000	0.000
3 614	99.683	0.000	204.176	0.000	59.313	0.000	76.504	26.180	0.000	0.000
3 615	99.683	0.000	212.419	0.000	58.067	0.000	76.504	26.876	0.000	0.000
3 616	99.362	0.000	212.908	0.000	58.021	0.000	76.504	27.163	0.000	0.000
3 617	96.460	0.000	208.973	0.000	57.979	0.000	76.504	25.818	0.000	0.000
3 618	84.742	0.000	185.644	0.000	58.016	0.000	76.504	24.211	0.000	0.000
3 619	55.756	0.000	106.856	0.000	57.979	0.000	76.504	23.949	0.000	0.000
3 620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	165.428	6.465	76.504	27.163	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1001.509	13.477	918.051	299.794	0.000	0.000
AV	53.189	0.000	116.048	0.000	41.730	0.562	38.252	12.491	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 66 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 7 8	5.538	0.000	31.745	0.000	112.544	0.000	76.504	23.949	0.000	0.000
3 7 9	5.538	0.000	31.745	0.000	58.367	0.000	76.504	23.949	0.000	0.000
3 710	5.538	0.000	31.745	0.000	57.959	0.000	76.504	23.949	0.000	0.000
3 711	5.538	0.000	31.745	0.000	57.976	0.000	76.504	23.949	0.000	0.000
3 712	5.538	0.000	31.745	0.000	57.941	0.000	76.504	23.949	0.000	0.000
3 713	5.538	0.000	31.745	0.000	57.939	0.000	76.504	23.949	0.000	0.000
3 714	5.538	0.000	31.745	0.000	65.148	0.000	76.504	23.949	0.000	0.000
3 715	5.538	0.000	31.745	0.000	66.408	0.000	76.504	23.949	0.000	0.000
3 716	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 717	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 718	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 719	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 720	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 721	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 722	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 723	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.544	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	534.282	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	22.262	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 68 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
3 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 9 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 9 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 9 7	81.785	0.000	168.037	0.000	112.496	0.000	76.504	23.949	0.000	0.000
3 9 8	98.066	0.000	208.826	0.000	58.267	0.000	76.504	23.949	0.000	0.000
3 9 9	99.683	0.000	213.339	0.000	57.889	0.000	76.504	23.949	0.000	0.000
3 910	99.683	0.000	208.758	0.000	57.937	0.000	76.504	24.286	0.000	0.000
3 911	99.683	0.000	185.850	0.000	127.577	3.078	76.504	24.519	0.000	0.000
3 912	99.683	0.000	184.930	0.000	108.941	1.734	76.504	24.449	0.000	0.000
3 913	99.683	0.000	204.176	0.000	59.882	0.000	76.504	27.227	0.000	0.000
3 914	99.683	0.000	212.419	0.000	72.599	0.000	76.504	29.207	0.000	0.000
3 915	99.362	0.000	212.908	0.000	73.252	0.000	76.504	32.307	0.000	0.000
3 916	96.460	0.000	208.973	0.000	58.609	0.000	76.504	33.755	0.000	0.000
3 917	84.742	0.000	185.644	0.000	58.000	0.000	76.504	29.823	0.000	0.000
3 918	55.756	0.000	106.856	0.000	57.978	0.000	76.504	23.949	0.000	0.000
3 919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3 924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	127.577	3.078	76.504	33.755	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	903.425	4.812	918.051	321.366	0.000	0.000
AV	53.189	0.000	116.048	0.000	37.643	0.201	38.252	13.390	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 69 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
310 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
310 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
310 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
310 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
310 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
310 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
310 7	81.785	0.000	168.037	0.000	112.271	0.000	76.504	23.949	0.000	0.000
310 8	98.066	0.000	208.826	0.000	58.262	0.000	76.504	23.949	0.000	0.000
310 9	99.683	0.000	213.339	0.000	57.954	0.000	76.504	24.111	0.000	0.000
31010	99.683	0.000	208.758	0.000	57.940	0.000	76.504	24.848	0.000	0.000
31011	99.683	0.000	185.850	0.000	57.975	0.000	76.504	25.172	0.000	0.000
31012	99.683	0.000	184.930	0.000	94.764	0.778	76.504	25.224	0.000	0.000
31013	99.683	0.000	204.176	0.000	120.528	2.557	76.504	27.136	0.000	0.000
31014	99.683	0.000	212.419	0.000	68.402	0.000	76.504	29.065	0.000	0.000
31015	99.362	0.000	212.908	0.000	72.516	0.000	76.504	29.613	0.000	0.000
31016	96.460	0.000	208.973	0.000	58.531	0.000	76.504	32.169	0.000	0.000
31017	84.742	0.000	185.644	0.000	57.997	0.000	76.504	29.162	0.000	0.000
31018	55.756	0.000	106.856	0.000	57.942	0.000	76.504	23.949	0.000	0.000
31019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	120.528	2.557	76.504	32.169	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	875.081	3.335	918.051	318.346	0.000	0.000
AV	53.189	0.000	116.048	0.000	36.462	0.139	38.252	13.264	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 70 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
311 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
311 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
311 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
311 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
311 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
311 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
311 7	81.785	0.000	168.037	0.000	112.260	0.000	76.504	23.949	0.000	0.000
311 8	98.066	0.000	208.826	0.000	58.262	0.000	76.504	24.167	0.000	0.000
311 9	99.683	0.000	213.339	0.000	57.954	0.000	76.504	25.820	0.000	0.000
31110	99.683	0.000	208.758	0.000	91.500	0.352	76.504	26.686	0.000	0.000
31111	99.683	0.000	185.850	0.000	107.358	1.412	76.504	26.178	0.000	0.000
31112	99.683	0.000	184.930	0.000	90.129	0.329	76.504	27.517	0.000	0.000
31113	99.683	0.000	204.176	0.000	93.669	0.625	76.504	29.543	0.000	0.000
31114	99.683	0.000	212.419	0.000	69.739	0.000	76.504	33.426	0.000	0.000
31115	99.362	0.000	212.908	0.000	74.846	0.000	76.504	34.934	0.000	0.000
31116	96.460	0.000	208.973	0.000	76.384	0.000	76.504	33.550	0.000	0.000
31117	84.742	0.000	185.644	0.000	58.790	0.000	76.504	28.095	0.000	0.000
31118	55.756	0.000	106.856	0.000	58.048	0.000	76.504	23.949	0.000	0.000
31119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.260	1.412	76.504	34.934	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	948.938	2.719	918.051	337.813	0.000	0.000
AV	53.189	0.000	116.048	0.000	39.539	0.113	38.252	14.076	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 71 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
312 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
312 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
312 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
312 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
312 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
312 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
312 7	81.785	0.000	168.037	0.000	112.536	0.000	76.504	23.949	0.000	0.000
312 8	98.066	0.000	208.826	0.000	58.366	0.000	76.504	23.949	0.000	0.000
312 9	99.683	0.000	213.339	0.000	58.036	0.000	76.504	24.620	0.000	0.000
31210	99.683	0.000	208.758	0.000	57.943	0.000	76.504	24.921	0.000	0.000
31211	99.683	0.000	185.850	0.000	58.014	0.000	76.504	24.767	0.000	0.000
31212	99.683	0.000	184.930	0.000	58.107	0.000	76.504	24.886	0.000	0.000
31213	99.683	0.000	204.176	0.000	100.111	1.389	76.504	25.060	0.000	0.000
31214	99.683	0.000	212.419	0.000	59.588	0.000	76.504	29.001	0.000	0.000
31215	99.362	0.000	212.908	0.000	57.995	0.000	76.504	27.781	0.000	0.000
31216	96.460	0.000	208.973	0.000	57.978	0.000	76.504	27.253	0.000	0.000
31217	84.742	0.000	185.644	0.000	57.907	0.000	76.504	25.939	0.000	0.000
31218	55.756	0.000	106.856	0.000	57.904	0.000	76.504	23.949	0.000	0.000
31219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.536	1.389	76.504	29.001	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	794.486	1.389	918.051	306.073	0.000	0.000
AV	53.189	0.000	116.048	0.000	33.104	0.058	38.252	12.753	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 72 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
313 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
313 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
313 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
313 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
313 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
313 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
313 7	81.785	0.000	168.037	0.000	112.266	0.000	76.504	23.949	0.000	0.000
313 8	98.066	0.000	208.826	0.000	58.262	0.000	76.504	23.949	0.000	0.000
313 9	99.683	0.000	213.339	0.000	57.954	0.000	76.504	23.949	0.000	0.000
31310	99.683	0.000	208.758	0.000	66.134	0.000	76.504	24.455	0.000	0.000
31311	99.683	0.000	185.850	0.000	88.249	0.120	76.504	25.140	0.000	0.000
31312	99.683	0.000	184.930	0.000	105.965	1.344	76.504	25.224	0.000	0.000
31313	99.683	0.000	204.176	0.000	135.796	3.675	76.504	26.351	0.000	0.000
31314	99.683	0.000	212.419	0.000	154.501	5.363	76.504	28.524	0.000	0.000
31315	99.362	0.000	212.908	0.000	66.796	0.000	76.504	34.301	0.000	0.000
31316	96.460	0.000	208.973	0.000	71.855	0.000	76.504	33.544	0.000	0.000
31317	84.742	0.000	185.644	0.000	58.416	0.000	76.504	32.393	0.000	0.000
31318	55.756	0.000	106.856	0.000	57.921	0.000	76.504	24.084	0.000	0.000
31319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	154.501	5.363	76.504	34.301	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1034.113	10.502	918.051	325.863	0.000	0.000
AV	53.189	0.000	116.048	0.000	43.088	0.438	38.252	13.578	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 73 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
314 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
314 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
314 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
314 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
314 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
314 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
314 7	5.538	0.000	31.745	0.000	112.109	0.000	76.504	23.949	0.000	0.000
314 8	5.538	0.000	31.745	0.000	58.215	0.000	76.504	23.949	0.000	0.000
314 9	5.538	0.000	31.745	0.000	57.918	0.000	76.504	23.949	0.000	0.000
31410	5.538	0.000	31.745	0.000	57.974	0.000	76.504	23.949	0.000	0.000
31411	5.538	0.000	31.745	0.000	57.941	0.000	76.504	23.949	0.000	0.000
31412	5.538	0.000	31.745	0.000	57.939	0.000	76.504	23.949	0.000	0.000
31413	5.538	0.000	31.745	0.000	57.905	0.000	76.504	23.949	0.000	0.000
31414	5.538	0.000	31.745	0.000	57.937	0.000	76.504	23.949	0.000	0.000
31415	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31424	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 14)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.109	0.000	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	517.938	0.000	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	21.581	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 75 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
316 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
316 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
316 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
316 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
316 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
316 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
316 7	81.785	0.000	168.037	0.000	111.712	0.000	76.504	23.949	0.000	0.000
316 8	98.066	0.000	208.826	0.000	58.002	0.000	76.504	23.949	0.000	0.000
316 9	99.683	0.000	213.339	0.000	57.751	0.000	76.504	24.041	0.000	0.000
31610	99.683	0.000	208.758	0.000	57.786	0.000	76.504	24.869	0.000	0.000
31611	99.683	0.000	185.850	0.000	83.493	0.000	76.504	24.510	0.000	0.000
31612	99.683	0.000	184.930	0.000	65.311	0.000	76.504	25.023	0.000	0.000
31613	99.683	0.000	204.176	0.000	66.816	0.000	76.504	26.227	0.000	0.000
31614	99.683	0.000	212.419	0.000	67.569	0.000	76.504	28.533	0.000	0.000
31615	99.362	0.000	212.908	0.000	68.291	0.000	76.504	30.600	0.000	0.000
31616	96.460	0.000	208.973	0.000	58.283	0.000	76.504	31.536	0.000	0.000
31617	84.742	0.000	185.644	0.000	57.916	0.000	76.504	28.638	0.000	0.000
31618	55.756	0.000	106.856	0.000	57.904	0.000	76.504	23.949	0.000	0.000
31619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.712	0.000	76.504	31.536	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	810.836	0.000	918.051	315.822	0.000	0.000
AV	53.189	0.000	116.048	0.000	33.785	0.000	38.252	13.159	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 76 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
317 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
317 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
317 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
317 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
317 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
317 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
317 7	81.785	0.000	168.037	0.000	111.853	0.000	76.504	23.949	0.000	0.000
317 8	98.066	0.000	208.826	0.000	58.064	0.000	76.504	23.949	0.000	0.000
317 9	99.683	0.000	213.339	0.000	57.851	0.000	76.504	25.819	0.000	0.000
31710	99.683	0.000	208.758	0.000	57.901	0.000	76.504	27.754	0.000	0.000
31711	99.683	0.000	185.850	0.000	87.460	0.000	76.504	26.148	0.000	0.000
31712	99.683	0.000	184.930	0.000	147.020	4.374	76.504	25.144	0.000	0.000
31713	99.683	0.000	204.176	0.000	109.481	1.625	76.504	28.514	0.000	0.000
31714	99.683	0.000	212.419	0.000	100.237	1.344	76.504	31.537	0.000	0.000
31715	99.362	0.000	212.908	0.000	103.797	1.549	76.504	33.300	0.000	0.000
31716	96.460	0.000	208.973	0.000	70.537	0.000	76.504	35.165	0.000	0.000
31717	84.742	0.000	185.644	0.000	58.400	0.000	76.504	32.708	0.000	0.000
31718	55.756	0.000	106.856	0.000	57.955	0.000	76.504	24.052	0.000	0.000
31719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	147.020	4.374	76.504	35.165	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1020.556	8.892	918.051	338.038	0.000	0.000
AV	53.189	0.000	116.048	0.000	42.523	0.371	38.252	14.085	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 77 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
318 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
318 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
318 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
318 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
318 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
318 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
318 7	81.785	0.000	168.037	0.000	112.036	0.000	76.504	23.949	0.000	0.000
318 8	98.066	0.000	208.826	0.000	58.173	0.000	76.504	24.088	0.000	0.000
318 9	99.683	0.000	213.339	0.000	57.916	0.000	76.504	25.419	0.000	0.000
31810	99.683	0.000	208.758	0.000	57.904	0.000	76.504	25.274	0.000	0.000
31811	99.683	0.000	185.850	0.000	57.904	0.000	76.504	24.610	0.000	0.000
31812	99.683	0.000	184.930	0.000	57.904	0.000	76.504	25.251	0.000	0.000
31813	99.683	0.000	204.176	0.000	57.937	0.000	76.504	26.542	0.000	0.000
31814	99.683	0.000	212.419	0.000	68.319	0.000	76.504	29.127	0.000	0.000
31815	99.362	0.000	212.908	0.000	58.328	0.000	76.504	31.467	0.000	0.000
31816	96.460	0.000	208.973	0.000	57.952	0.000	76.504	34.063	0.000	0.000
31817	84.742	0.000	185.644	0.000	57.906	0.000	76.504	29.966	0.000	0.000
31818	55.756	0.000	106.856	0.000	57.844	0.000	76.504	23.949	0.000	0.000
31819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.036	0.000	76.504	34.063	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	760.123	0.000	918.051	323.704	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.672	0.000	38.252	13.488	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 78 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
319 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
319 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
319 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
319 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
319 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
319 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
319 7	81.785	0.000	168.037	0.000	111.670	0.000	76.504	23.949	0.000	0.000
319 8	98.066	0.000	208.826	0.000	57.950	0.000	76.504	24.424	0.000	0.000
319 9	99.683	0.000	213.339	0.000	57.729	0.000	76.504	27.141	0.000	0.000
31910	99.683	0.000	208.758	0.000	57.762	0.000	76.504	29.268	0.000	0.000
31911	99.683	0.000	185.850	0.000	57.787	0.000	76.504	27.287	0.000	0.000
31912	99.683	0.000	184.930	0.000	57.812	0.000	76.504	28.171	0.000	0.000
31913	99.683	0.000	204.176	0.000	57.814	0.000	76.504	30.216	0.000	0.000
31914	99.683	0.000	212.419	0.000	57.789	0.000	76.504	33.612	0.000	0.000
31915	99.362	0.000	212.908	0.000	57.813	0.000	76.504	34.347	0.000	0.000
31916	96.460	0.000	208.973	0.000	57.814	0.000	76.504	34.197	0.000	0.000
31917	84.742	0.000	185.644	0.000	57.789	0.000	76.504	27.933	0.000	0.000
31918	55.756	0.000	106.856	0.000	57.765	0.000	76.504	23.949	0.000	0.000
31919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.670	0.000	76.504	34.347	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	747.493	0.000	918.051	344.494	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.146	0.000	38.252	14.354	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 79 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
320 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
320 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
320 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
320 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
320 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
320 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
320 7	81.785	0.000	168.037	0.000	111.753	0.000	76.504	23.949	0.000	0.000
320 8	98.066	0.000	208.826	0.000	58.003	0.000	76.504	23.949	0.000	0.000
320 9	99.683	0.000	213.339	0.000	57.773	0.000	76.504	24.581	0.000	0.000
32010	99.683	0.000	208.758	0.000	57.787	0.000	76.504	26.238	0.000	0.000
32011	99.683	0.000	185.850	0.000	57.788	0.000	76.504	25.455	0.000	0.000
32012	99.683	0.000	184.930	0.000	66.899	0.000	76.504	25.646	0.000	0.000
32013	99.683	0.000	204.176	0.000	58.197	0.000	76.504	28.544	0.000	0.000
32014	99.683	0.000	212.419	0.000	57.852	0.000	76.504	31.765	0.000	0.000
32015	99.362	0.000	212.908	0.000	57.815	0.000	76.504	33.732	0.000	0.000
32016	96.460	0.000	208.973	0.000	57.814	0.000	76.504	31.708	0.000	0.000
32017	84.742	0.000	185.644	0.000	87.650	0.000	76.504	26.239	0.000	0.000
32018	55.756	0.000	106.856	0.000	58.902	0.000	76.504	23.949	0.000	0.000
32019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.753	0.000	76.504	33.732	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	788.234	0.000	918.051	325.754	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.843	0.000	38.252	13.573	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 80 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
321 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
321 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
321 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
321 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
321 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
321 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
321 7	5.538	0.000	31.745	0.000	111.855	0.000	76.504	23.949	0.000	0.000
321 8	5.538	0.000	31.745	0.000	58.034	0.000	76.504	23.949	0.000	0.000
321 9	5.538	0.000	31.745	0.000	57.774	0.000	76.504	23.949	0.000	0.000
32110	5.538	0.000	31.745	0.000	57.787	0.000	76.504	23.949	0.000	0.000
32111	5.538	0.000	31.745	0.000	57.765	0.000	76.504	23.949	0.000	0.000
32112	5.538	0.000	31.745	0.000	57.764	0.000	76.504	23.949	0.000	0.000
32113	5.538	0.000	31.745	0.000	57.669	0.000	76.504	23.949	0.000	0.000
32114	5.538	0.000	31.745	0.000	57.666	0.000	76.504	23.949	0.000	0.000
32115	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32124	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 21)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	111.855	0.000	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	516.313	0.000	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	21.513	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 82 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
323 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
323 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
323 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
323 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
323 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
323 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
323 7	81.785	0.000	168.037	0.000	111.711	0.000	76.504	23.949	0.000	0.000
323 8	98.066	0.000	208.826	0.000	58.002	0.000	76.504	23.949	0.000	0.000
323 9	99.683	0.000	213.339	0.000	57.773	0.000	76.504	23.949	0.000	0.000
32310	99.683	0.000	208.758	0.000	57.839	0.000	76.504	23.949	0.000	0.000
32311	99.683	0.000	185.850	0.000	57.870	0.000	76.504	24.074	0.000	0.000
32312	99.683	0.000	184.930	0.000	57.902	0.000	76.504	24.442	0.000	0.000
32313	99.683	0.000	204.176	0.000	57.873	0.000	76.504	25.367	0.000	0.000
32314	99.683	0.000	212.419	0.000	57.816	0.000	76.504	25.065	0.000	0.000
32315	99.362	0.000	212.908	0.000	57.840	0.000	76.504	25.176	0.000	0.000
32316	96.460	0.000	208.973	0.000	57.841	0.000	76.504	24.539	0.000	0.000
32317	84.742	0.000	185.644	0.000	57.841	0.000	76.504	23.949	0.000	0.000
32318	55.756	0.000	106.856	0.000	57.841	0.000	76.504	23.949	0.000	0.000
32319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.711	0.000	76.504	25.367	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.150	0.000	918.051	292.355	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.173	0.000	38.252	12.181	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 83 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
324 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
324 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
324 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
324 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
324 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
324 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
324 7	81.785	0.000	168.037	0.000	111.908	0.000	76.504	23.949	0.000	0.000
324 8	98.066	0.000	208.826	0.000	58.065	0.000	76.504	23.949	0.000	0.000
324 9	99.683	0.000	213.339	0.000	57.799	0.000	76.504	24.835	0.000	0.000
32410	99.683	0.000	208.758	0.000	66.616	0.000	76.504	25.393	0.000	0.000
32411	99.683	0.000	185.850	0.000	66.165	0.000	76.504	25.168	0.000	0.000
32412	99.683	0.000	184.930	0.000	58.169	0.000	76.504	25.390	0.000	0.000
32413	99.683	0.000	204.176	0.000	67.381	0.000	76.504	26.794	0.000	0.000
32414	99.683	0.000	212.419	0.000	58.215	0.000	76.504	29.737	0.000	0.000
32415	99.362	0.000	212.908	0.000	68.771	0.000	76.504	30.519	0.000	0.000
32416	96.460	0.000	208.973	0.000	58.230	0.000	76.504	27.674	0.000	0.000
32417	84.742	0.000	185.644	0.000	67.055	0.000	76.504	25.924	0.000	0.000
32418	55.756	0.000	106.856	0.000	77.840	0.000	76.504	23.949	0.000	0.000
32419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.908	0.000	76.504	30.519	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	816.214	0.000	918.051	313.282	0.000	0.000
AV	53.189	0.000	116.048	0.000	34.009	0.000	38.252	13.053	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 84 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
325 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
325 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
325 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
325 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
325 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
325 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
325 7	81.785	0.000	168.037	0.000	112.207	0.000	76.504	23.949	0.000	0.000
325 8	98.066	0.000	208.826	0.000	58.102	0.000	76.504	23.949	0.000	0.000
325 9	99.683	0.000	213.339	0.000	130.626	2.158	76.504	23.960	0.000	0.000
32510	99.683	0.000	208.758	0.000	202.292	6.886	76.504	24.309	0.000	0.000
32511	99.683	0.000	185.850	0.000	190.105	6.508	76.504	24.682	0.000	0.000
32512	99.683	0.000	184.930	0.000	175.161	5.182	76.504	24.978	0.000	0.000
32513	99.683	0.000	204.176	0.000	185.452	5.743	76.504	26.332	0.000	0.000
32514	99.683	0.000	212.419	0.000	204.576	7.099	76.504	27.558	0.000	0.000
32515	99.362	0.000	212.908	0.000	161.689	5.495	76.504	31.830	0.000	0.000
32516	96.460	0.000	208.973	0.000	156.481	4.342	76.504	29.962	0.000	0.000
32517	84.742	0.000	185.644	0.000	146.962	3.696	76.504	26.675	0.000	0.000
32518	55.756	0.000	106.856	0.000	61.714	0.000	76.504	23.949	0.000	0.000
32519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 25)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	204.576	7.099	76.504	31.830	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1785.368	47.108	918.051	312.132	0.000	0.000
AV	53.189	0.000	116.048	0.000	74.390	1.963	38.252	13.006	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 85 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
326 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
326 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
326 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
326 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
326 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
326 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
326 7	81.785	0.000	168.037	0.000	111.938	0.000	76.504	23.949	0.000	0.000
326 8	98.066	0.000	208.826	0.000	58.098	0.000	76.504	24.257	0.000	0.000
326 9	99.683	0.000	213.339	0.000	154.195	3.552	76.504	24.309	0.000	0.000
32610	99.683	0.000	208.758	0.000	211.650	8.301	76.504	24.555	0.000	0.000
32611	99.683	0.000	185.850	0.000	213.206	9.290	76.504	24.658	0.000	0.000
32612	99.683	0.000	184.930	0.000	184.091	6.980	76.504	26.118	0.000	0.000
32613	99.683	0.000	204.176	0.000	188.600	8.163	76.504	28.654	0.000	0.000
32614	99.683	0.000	212.419	0.000	180.799	6.477	76.504	29.593	0.000	0.000
32615	99.362	0.000	212.908	0.000	166.414	5.837	76.504	32.371	0.000	0.000
32616	96.460	0.000	208.973	0.000	113.884	1.688	76.504	33.520	0.000	0.000
32617	84.742	0.000	185.644	0.000	87.498	0.000	76.504	28.221	0.000	0.000
32618	55.756	0.000	106.856	0.000	58.971	0.000	76.504	23.949	0.000	0.000
32619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	213.206	9.290	76.504	33.520	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1729.344	50.289	918.051	324.154	0.000	0.000
AV	53.189	0.000	116.048	0.000	72.056	2.095	38.252	13.506	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 86 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
327 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
327 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
327 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
327 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
327 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
327 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
327 7	81.785	0.000	168.037	0.000	112.256	0.000	76.504	23.949	0.000	0.000
327 8	98.066	0.000	208.826	0.000	58.262	0.000	76.504	23.949	0.000	0.000
327 9	99.683	0.000	213.339	0.000	57.954	0.000	76.504	24.986	0.000	0.000
32710	99.683	0.000	208.758	0.000	68.124	0.000	76.504	25.086	0.000	0.000
32711	99.683	0.000	185.850	0.000	100.532	1.392	76.504	25.470	0.000	0.000
32712	99.683	0.000	184.930	0.000	115.762	2.262	76.504	25.442	0.000	0.000
32713	99.683	0.000	204.176	0.000	96.825	1.021	76.504	28.217	0.000	0.000
32714	99.683	0.000	212.419	0.000	108.073	2.089	76.504	30.781	0.000	0.000
32715	99.362	0.000	212.908	0.000	59.948	0.000	76.504	34.970	0.000	0.000
32716	96.460	0.000	208.973	0.000	58.047	0.000	76.504	35.474	0.000	0.000
32717	84.742	0.000	185.644	0.000	57.980	0.000	76.504	30.631	0.000	0.000
32718	55.756	0.000	106.856	0.000	57.941	0.000	76.504	23.949	0.000	0.000
32719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	115.762	2.262	76.504	35.474	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	951.704	6.764	918.051	332.904	0.000	0.000
AV	53.189	0.000	116.048	0.000	39.654	0.282	38.252	13.871	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 87 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
328 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
328 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
328 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
328 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
328 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
328 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
328 7	5.538	0.000	31.745	0.000	112.180	0.000	76.504	23.949	0.000	0.000
328 8	5.538	0.000	31.745	0.000	58.306	0.000	76.504	23.949	0.000	0.000
328 9	5.538	0.000	31.745	0.000	101.068	0.538	76.504	23.949	0.000	0.000
32810	5.538	0.000	31.745	0.000	125.745	1.800	76.504	23.949	0.000	0.000
32811	5.538	0.000	31.745	0.000	188.487	5.816	76.504	23.949	0.000	0.000
32812	5.538	0.000	31.745	0.000	201.135	7.601	76.504	23.949	0.000	0.000
32813	5.538	0.000	31.745	0.000	135.921	4.085	76.504	23.949	0.000	0.000
32814	5.538	0.000	31.745	0.000	136.556	4.161	76.504	23.949	0.000	0.000
32815	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32816	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32817	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32818	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32819	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32820	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32821	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32822	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32823	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
32824	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 28)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	201.135	7.601	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1059.397	24.000	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	44.142	1.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 89 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
330 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
330 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
330 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
330 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
330 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
330 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
330 7	81.785	0.000	168.037	0.000	113.069	0.000	76.504	23.949	0.000	0.000
330 8	98.066	0.000	208.826	0.000	100.482	0.000	76.504	24.464	0.000	0.000
330 9	99.683	0.000	213.339	0.000	192.815	4.466	76.504	24.651	0.000	0.000
33010	99.683	0.000	208.758	0.000	213.372	7.303	76.504	25.310	0.000	0.000
33011	99.683	0.000	185.850	0.000	221.092	8.897	76.504	24.869	0.000	0.000
33012	99.683	0.000	184.930	0.000	226.840	10.800	76.504	24.292	0.000	0.000
33013	99.683	0.000	204.176	0.000	230.620	11.401	76.504	25.462	0.000	0.000
33014	99.683	0.000	212.419	0.000	228.774	10.307	76.504	27.610	0.000	0.000
33015	99.362	0.000	212.908	0.000	210.259	7.567	76.504	33.740	0.000	0.000
33016	96.460	0.000	208.973	0.000	203.084	6.212	76.504	32.175	0.000	0.000
33017	84.742	0.000	185.644	0.000	152.385	3.359	76.504	29.743	0.000	0.000
33018	55.756	0.000	106.856	0.000	61.262	0.000	76.504	24.405	0.000	0.000
33019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	230.620	11.401	76.504	33.740	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2154.053	70.313	918.051	320.671	0.000	0.000
AV	53.189	0.000	116.048	0.000	89.752	2.930	38.252	13.361	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 90 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
331 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
331 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
331 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
331 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
331 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
331 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
331 7	81.785	0.000	168.037	0.000	133.481	0.000	76.504	23.949	0.000	0.000
331 8	98.066	0.000	208.826	0.000	176.437	3.898	76.504	24.653	0.000	0.000
331 9	99.683	0.000	213.339	0.000	213.095	7.658	76.504	25.138	0.000	0.000
33110	99.683	0.000	208.758	0.000	228.049	10.708	76.504	24.938	0.000	0.000
33111	99.683	0.000	185.850	0.000	228.521	11.040	76.504	24.523	0.000	0.000
33112	99.683	0.000	184.930	0.000	228.129	11.899	76.504	24.729	0.000	0.000
33113	99.683	0.000	204.176	0.000	225.218	11.780	76.504	27.640	0.000	0.000
33114	99.683	0.000	212.419	0.000	234.416	12.626	76.504	27.451	0.000	0.000
33115	99.362	0.000	212.908	0.000	237.041	12.355	76.504	29.163	0.000	0.000
33116	96.460	0.000	208.973	0.000	228.461	9.984	76.504	30.803	0.000	0.000
33117	84.742	0.000	185.644	0.000	202.187	5.560	76.504	32.323	0.000	0.000
33118	55.756	0.000	106.856	0.000	79.429	0.000	76.504	25.293	0.000	0.000
33119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
33124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAR 31)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	237.041	12.626	76.504	32.323	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2414.464	97.508	918.051	320.601	0.000	0.000
AV	53.189	0.000	116.048	0.000	100.603	4.063	38.252	13.358	0.000	0.000
MONTHLY SUMMARY (MAR)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	237.041	13.563	76.504	35.474	0.000	0.000
SM	28818.629	0.000	65486.039	0.000	28511.980	476.942	22645.262	7758.128	0.000	0.000
AV	38.735	0.000	88.019	0.000	38.323	0.641	30.437	10.428	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 91 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 1 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 1 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 1 7	81.785	0.000	168.037	0.000	112.743	0.000	76.504	23.949	0.000	0.000
4 1 8	98.066	0.000	208.826	0.000	57.995	0.000	76.504	27.672	0.000	0.000
4 1 9	99.683	0.000	213.339	0.000	57.711	0.000	76.504	28.892	0.000	0.000
4 110	99.683	0.000	208.758	0.000	57.740	0.000	76.504	32.318	0.000	0.000
4 111	99.683	0.000	185.850	0.000	57.786	0.000	76.504	30.540	0.000	0.000
4 112	99.683	0.000	184.930	0.000	57.868	0.000	76.504	30.590	0.000	0.000
4 113	99.683	0.000	204.176	0.000	57.843	0.000	76.504	32.097	0.000	0.000
4 114	99.683	0.000	212.419	0.000	70.034	0.000	76.504	34.153	0.000	0.000
4 115	99.362	0.000	212.908	0.000	58.275	0.000	76.504	38.460	0.000	0.000
4 116	96.460	0.000	208.973	0.000	57.883	0.000	76.504	39.198	0.000	0.000
4 117	84.742	0.000	185.644	0.000	57.816	0.000	76.504	33.655	0.000	0.000
4 118	55.756	0.000	106.856	0.000	57.814	0.000	76.504	24.683	0.000	0.000
4 119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.743	0.000	76.504	39.198	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	761.508	0.000	918.051	376.207	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.730	0.000	38.252	15.675	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 92 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 2 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 2 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 2 7	81.785	0.000	168.037	0.000	111.725	0.000	76.504	23.949	0.000	0.000
4 2 8	98.066	0.000	208.826	0.000	57.976	0.000	76.504	25.522	0.000	0.000
4 2 9	99.683	0.000	213.339	0.000	57.730	0.000	76.504	29.013	0.000	0.000
4 210	99.683	0.000	208.758	0.000	57.762	0.000	76.504	31.306	0.000	0.000
4 211	99.683	0.000	185.850	0.000	57.764	0.000	76.504	30.213	0.000	0.000
4 212	99.683	0.000	184.930	0.000	57.812	0.000	76.504	30.334	0.000	0.000
4 213	99.683	0.000	204.176	0.000	57.814	0.000	76.504	33.197	0.000	0.000
4 214	99.683	0.000	212.419	0.000	57.814	0.000	76.504	37.223	0.000	0.000
4 215	99.362	0.000	212.908	0.000	57.814	0.000	76.504	38.798	0.000	0.000
4 216	96.460	0.000	208.973	0.000	57.789	0.000	76.504	38.355	0.000	0.000
4 217	84.742	0.000	185.644	0.000	57.788	0.000	76.504	32.658	0.000	0.000
4 218	55.756	0.000	106.856	0.000	57.743	0.000	76.504	24.267	0.000	0.000
4 219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.725	0.000	76.504	38.798	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	747.529	0.000	918.051	374.835	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.147	0.000	38.252	15.618	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 93 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 3 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 3 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 3 7	81.785	0.000	168.037	0.000	111.910	0.000	76.504	23.949	0.000	0.000
4 3 8	98.066	0.000	208.826	0.000	58.098	0.000	76.504	25.541	0.000	0.000
4 3 9	99.683	0.000	213.339	0.000	57.825	0.000	76.504	29.396	0.000	0.000
4 310	99.683	0.000	208.758	0.000	57.841	0.000	76.504	30.764	0.000	0.000
4 311	99.683	0.000	185.850	0.000	57.870	0.000	76.504	28.667	0.000	0.000
4 312	99.683	0.000	184.930	0.000	57.871	0.000	76.504	28.697	0.000	0.000
4 313	99.683	0.000	204.176	0.000	57.871	0.000	76.504	31.476	0.000	0.000
4 314	99.683	0.000	212.419	0.000	57.902	0.000	76.504	34.814	0.000	0.000
4 315	99.362	0.000	212.908	0.000	57.904	0.000	76.504	36.826	0.000	0.000
4 316	96.460	0.000	208.973	0.000	57.904	0.000	76.504	37.678	0.000	0.000
4 317	84.742	0.000	185.644	0.000	57.844	0.000	76.504	31.776	0.000	0.000
4 318	55.756	0.000	106.856	0.000	57.842	0.000	76.504	24.198	0.000	0.000
4 319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.910	0.000	76.504	37.678	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.682	0.000	918.051	363.783	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.195	0.000	38.252	15.158	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 94 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 4 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 4 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 4 7	5.538	0.000	31.745	0.000	112.031	0.000	76.504	23.949	0.000	0.000
4 4 8	5.538	0.000	31.745	0.000	58.135	0.000	76.504	23.949	0.000	0.000
4 4 9	5.538	0.000	31.745	0.000	57.883	0.000	76.504	23.949	0.000	0.000
4 410	5.538	0.000	31.745	0.000	57.936	0.000	76.504	23.949	0.000	0.000
4 411	5.538	0.000	31.745	0.000	57.939	0.000	76.504	23.949	0.000	0.000
4 412	5.538	0.000	31.745	0.000	57.874	0.000	76.504	23.949	0.000	0.000
4 413	5.538	0.000	31.745	0.000	63.867	0.000	76.504	23.949	0.000	0.000
4 414	5.538	0.000	31.745	0.000	58.123	0.000	76.504	23.949	0.000	0.000
4 415	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 424	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 4)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.031	0.000	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	523.789	0.000	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	21.825	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 96 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 6 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 6 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 6 7	81.785	0.000	168.037	0.000	112.254	0.000	76.504	23.949	0.000	0.000
4 6 8	98.066	0.000	208.826	0.000	58.358	0.000	76.504	25.083	0.000	0.000
4 6 9	99.683	0.000	213.339	0.000	57.958	0.000	76.504	27.260	0.000	0.000
4 610	99.683	0.000	208.758	0.000	128.744	2.928	76.504	26.308	0.000	0.000
4 611	99.683	0.000	185.850	0.000	99.009	1.237	76.504	27.400	0.000	0.000
4 612	99.683	0.000	184.930	0.000	97.072	1.135	76.504	26.964	0.000	0.000
4 613	99.683	0.000	204.176	0.000	93.203	0.579	76.504	29.319	0.000	0.000
4 614	99.683	0.000	212.419	0.000	91.975	0.315	76.504	31.750	0.000	0.000
4 615	99.362	0.000	212.908	0.000	93.516	0.242	76.504	34.096	0.000	0.000
4 616	96.460	0.000	208.973	0.000	93.354	0.220	76.504	33.992	0.000	0.000
4 617	84.742	0.000	185.644	0.000	59.251	0.000	76.504	32.260	0.000	0.000
4 618	55.756	0.000	106.856	0.000	57.916	0.000	76.504	24.320	0.000	0.000
4 619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	128.744	2.928	76.504	34.096	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1042.611	6.656	918.051	342.701	0.000	0.000
AV	53.189	0.000	116.048	0.000	43.442	0.277	38.252	14.279	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 97 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 7	81.785	0.000	168.037	0.000	112.175	0.000	76.504	23.949	0.000	0.000
4 7 8	98.066	0.000	208.826	0.000	58.260	0.000	76.504	27.134	0.000	0.000
4 7 9	99.683	0.000	213.339	0.000	89.759	0.112	76.504	27.932	0.000	0.000
4 7 10	99.683	0.000	208.758	0.000	173.049	5.800	76.504	27.072	0.000	0.000
4 7 11	99.683	0.000	185.850	0.000	183.675	7.272	76.504	27.004	0.000	0.000
4 7 12	99.683	0.000	184.930	0.000	170.158	6.087	76.504	26.952	0.000	0.000
4 7 13	99.683	0.000	204.176	0.000	177.934	7.051	76.504	29.843	0.000	0.000
4 7 14	99.683	0.000	212.419	0.000	150.030	4.776	76.504	33.339	0.000	0.000
4 7 15	99.362	0.000	212.908	0.000	187.628	6.158	76.504	31.924	0.000	0.000
4 7 16	96.460	0.000	208.973	0.000	186.146	6.022	76.504	32.727	0.000	0.000
4 7 17	84.742	0.000	185.644	0.000	132.246	2.807	76.504	30.351	0.000	0.000
4 7 18	55.756	0.000	106.856	0.000	114.683	1.492	76.504	23.949	0.000	0.000
4 7 19	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 20	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 21	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 22	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 23	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 7 24	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	187.628	7.272	76.504	33.339	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1735.743	47.576	918.051	342.177	0.000	0.000
AV	53.189	0.000	116.048	0.000	72.323	1.982	38.252	14.257	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 98 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 8 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 8 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 8 7	81.785	0.000	168.037	0.000	118.778	0.000	76.504	24.214	0.000	0.000
4 8 8	98.066	0.000	208.826	0.000	181.245	5.058	76.504	24.958	0.000	0.000
4 8 9	99.683	0.000	213.339	0.000	218.871	9.826	76.504	25.242	0.000	0.000
4 810	99.683	0.000	208.758	0.000	229.097	12.064	76.504	25.412	0.000	0.000
4 811	99.683	0.000	185.850	0.000	232.703	13.693	76.504	24.283	0.000	0.000
4 812	99.683	0.000	184.930	0.000	228.768	13.441	76.504	24.978	0.000	0.000
4 813	99.683	0.000	204.176	0.000	228.197	11.973	76.504	26.794	0.000	0.000
4 814	99.683	0.000	212.419	0.000	231.762	12.521	76.504	28.498	0.000	0.000
4 815	99.362	0.000	212.908	0.000	233.494	12.430	76.504	29.826	0.000	0.000
4 816	96.460	0.000	208.973	0.000	226.027	11.879	76.504	31.709	0.000	0.000
4 817	84.742	0.000	185.644	0.000	213.339	9.348	76.504	30.492	0.000	0.000
4 818	55.756	0.000	106.856	0.000	155.066	4.287	76.504	24.964	0.000	0.000
4 819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	233.494	13.693	76.504	31.709	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2497.347	116.520	918.051	321.370	0.000	0.000
AV	53.189	0.000	116.048	0.000	104.056	4.855	38.252	13.390	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 99 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
4 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 9 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 9 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 9 7	81.785	0.000	168.037	0.000	114.011	0.000	76.504	25.116	0.000	0.000
4 9 8	98.066	0.000	208.826	0.000	133.058	2.951	76.504	27.445	0.000	0.000
4 9 9	99.683	0.000	213.339	0.000	205.541	8.591	76.504	27.371	0.000	0.000
4 910	99.683	0.000	208.758	0.000	227.096	14.491	76.504	27.390	0.000	0.000
4 911	99.683	0.000	185.850	0.000	215.744	12.127	76.504	29.289	0.000	0.000
4 912	99.683	0.000	184.930	0.000	194.702	8.255	76.504	29.082	0.000	0.000
4 913	99.683	0.000	204.176	0.000	183.260	7.458	76.504	31.932	0.000	0.000
4 914	99.683	0.000	212.419	0.000	173.125	6.298	76.504	34.349	0.000	0.000
4 915	99.362	0.000	212.908	0.000	169.572	5.751	76.504	35.910	0.000	0.000
4 916	96.460	0.000	208.973	0.000	168.455	5.661	76.504	35.617	0.000	0.000
4 917	84.742	0.000	185.644	0.000	114.224	1.876	76.504	34.354	0.000	0.000
4 918	55.756	0.000	106.856	0.000	65.882	0.000	76.504	25.835	0.000	0.000
4 919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4 924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	227.096	14.491	76.504	35.910	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1964.670	73.459	918.051	363.691	0.000	0.000
AV	53.189	0.000	116.048	0.000	81.861	3.061	38.252	15.154	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE100 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
410 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
410 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
410 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
410 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
410 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
410 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
410 7	81.785	0.000	168.037	0.000	112.699	0.000	76.504	24.370	0.000	0.000
410 8	98.066	0.000	208.826	0.000	58.425	0.000	76.504	29.064	0.000	0.000
410 9	99.683	0.000	213.339	0.000	134.607	3.911	76.504	28.732	0.000	0.000
41010	99.683	0.000	208.758	0.000	210.735	11.236	76.504	28.647	0.000	0.000
41011	99.683	0.000	185.850	0.000	229.318	15.724	76.504	26.207	0.000	0.000
41012	99.683	0.000	184.930	0.000	165.177	6.641	76.504	31.184	0.000	0.000
41013	99.683	0.000	204.176	0.000	178.154	7.538	76.504	31.510	0.000	0.000
41014	99.683	0.000	212.419	0.000	201.219	9.645	76.504	34.932	0.000	0.000
41015	99.362	0.000	212.908	0.000	211.082	11.332	76.504	35.426	0.000	0.000
41016	96.460	0.000	208.973	0.000	176.974	6.576	76.504	35.687	0.000	0.000
41017	84.742	0.000	185.644	0.000	138.053	3.755	76.504	32.932	0.000	0.000
41018	55.756	0.000	106.856	0.000	62.253	0.000	76.504	25.947	0.000	0.000
41019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	229.318	15.724	76.504	35.687	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1878.697	76.358	918.051	364.639	0.000	0.000
AV	53.189	0.000	116.048	0.000	78.279	3.182	38.252	15.193	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE101 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
411 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
411 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
411 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
411 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
411 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
411 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
411 7	5.538	0.000	31.745	0.000	112.569	0.000	76.504	23.949	0.000	0.000
411 8	5.538	0.000	31.745	0.000	58.422	0.000	76.504	23.949	0.000	0.000
411 9	5.538	0.000	31.745	0.000	58.130	0.000	76.504	23.949	0.000	0.000
41110	5.538	0.000	31.745	0.000	203.869	11.842	76.504	23.949	0.000	0.000
41111	5.538	0.000	31.745	0.000	153.247	6.379	76.504	23.949	0.000	0.000
41112	5.538	0.000	31.745	0.000	171.766	8.087	76.504	23.949	0.000	0.000
41113	5.538	0.000	31.745	0.000	206.313	11.428	76.504	23.949	0.000	0.000
41114	5.538	0.000	31.745	0.000	224.668	16.927	76.504	23.949	0.000	0.000
41115	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41124	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 11)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	224.668	16.927	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1188.984	54.664	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	49.541	2.278	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE103 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
413 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
413 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
413 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
413 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
413 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
413 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
413 7	81.785	0.000	168.037	0.000	115.848	0.000	76.504	28.706	0.000	0.000
413 8	98.066	0.000	208.826	0.000	188.426	5.235	76.504	31.093	0.000	0.000
413 9	99.683	0.000	213.339	0.000	225.728	10.640	76.504	28.499	0.000	0.000
41310	99.683	0.000	208.758	0.000	237.450	13.365	76.504	28.446	0.000	0.000
41311	99.683	0.000	185.850	0.000	239.347	14.763	76.504	26.162	0.000	0.000
41312	99.683	0.000	184.930	0.000	240.152	14.511	76.504	25.673	0.000	0.000
41313	99.683	0.000	204.176	0.000	247.380	18.877	76.504	28.096	0.000	0.000
41314	99.683	0.000	212.419	0.000	234.633	14.453	76.504	33.174	0.000	0.000
41315	99.362	0.000	212.908	0.000	217.311	11.332	76.504	40.820	0.000	0.000
41316	96.460	0.000	208.973	0.000	209.323	9.303	76.504	40.451	0.000	0.000
41317	84.742	0.000	185.644	0.000	206.193	9.193	76.504	36.278	0.000	0.000
41318	55.756	0.000	106.856	0.000	115.099	2.477	76.504	28.106	0.000	0.000
41319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	247.380	18.877	76.504	40.820	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2476.888	124.150	918.051	375.504	0.000	0.000
AV	53.189	0.000	116.048	0.000	103.204	5.173	38.252	15.646	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE104 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
414 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
414 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
414 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
414 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
414 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
414 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
414 7	81.785	0.000	168.037	0.000	113.483	0.000	76.504	26.539	0.000	0.000
414 8	98.066	0.000	208.826	0.000	116.324	1.685	76.504	30.656	0.000	0.000
414 9	99.683	0.000	213.339	0.000	201.660	7.597	76.504	28.998	0.000	0.000
41410	99.683	0.000	208.758	0.000	212.538	10.825	76.504	31.500	0.000	0.000
41411	99.683	0.000	185.850	0.000	219.365	12.988	76.504	28.971	0.000	0.000
41412	99.683	0.000	184.930	0.000	179.770	6.776	76.504	30.616	0.000	0.000
41413	99.683	0.000	204.176	0.000	186.676	7.678	76.504	33.458	0.000	0.000
41414	99.683	0.000	212.419	0.000	210.955	10.629	76.504	34.676	0.000	0.000
41415	99.362	0.000	212.908	0.000	148.450	4.437	76.504	41.046	0.000	0.000
41416	96.460	0.000	208.973	0.000	124.327	2.824	76.504	40.276	0.000	0.000
41417	84.742	0.000	185.644	0.000	96.370	0.862	76.504	35.839	0.000	0.000
41418	55.756	0.000	106.856	0.000	67.210	0.000	76.504	25.873	0.000	0.000
41419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	219.365	12.988	76.504	41.046	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1877.127	66.302	918.051	388.448	0.000	0.000
AV	53.189	0.000	116.048	0.000	78.214	2.763	38.252	16.185	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE105 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
415 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
415 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
415 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
415 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
415 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
415 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
415 7	81.785	0.000	168.037	0.000	112.710	0.000	76.504	24.800	0.000	0.000
415 8	98.066	0.000	208.826	0.000	75.524	0.000	76.504	29.326	0.000	0.000
415 9	99.683	0.000	213.339	0.000	193.170	8.388	76.504	28.046	0.000	0.000
41510	99.683	0.000	208.758	0.000	198.798	8.621	76.504	30.945	0.000	0.000
41511	99.683	0.000	185.850	0.000	194.369	8.533	76.504	29.563	0.000	0.000
41512	99.683	0.000	184.930	0.000	210.978	11.332	76.504	28.953	0.000	0.000
41513	99.683	0.000	204.176	0.000	222.006	13.547	76.504	29.850	0.000	0.000
41514	99.683	0.000	212.419	0.000	226.256	15.099	76.504	34.269	0.000	0.000
41515	99.362	0.000	212.908	0.000	217.354	12.535	76.504	36.836	0.000	0.000
41516	96.460	0.000	208.973	0.000	207.283	9.778	76.504	37.290	0.000	0.000
41517	84.742	0.000	185.644	0.000	163.457	6.164	76.504	32.870	0.000	0.000
41518	55.756	0.000	106.856	0.000	64.382	0.000	76.504	25.631	0.000	0.000
41519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	226.256	15.099	76.504	37.290	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2086.287	93.997	918.051	368.378	0.000	0.000
AV	53.189	0.000	116.048	0.000	86.929	3.917	38.252	15.349	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE106 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
416 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
416 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
416 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
416 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
416 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
416 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
416 7	81.785	0.000	168.037	0.000	113.364	0.000	76.504	24.840	0.000	0.000
416 8	98.066	0.000	208.826	0.000	184.923	7.819	76.504	26.227	0.000	0.000
416 9	99.683	0.000	213.339	0.000	216.416	12.337	76.504	26.861	0.000	0.000
41610	99.683	0.000	208.758	0.000	219.434	12.964	76.504	28.765	0.000	0.000
41611	99.683	0.000	185.850	0.000	218.126	11.977	76.504	26.788	0.000	0.000
41612	99.683	0.000	184.930	0.000	218.220	11.997	76.504	27.166	0.000	0.000
41613	99.683	0.000	204.176	0.000	224.262	13.955	76.504	29.830	0.000	0.000
41614	99.683	0.000	212.419	0.000	221.235	12.805	76.504	32.029	0.000	0.000
41615	99.362	0.000	212.908	0.000	217.101	11.363	76.504	33.527	0.000	0.000
41616	96.460	0.000	208.973	0.000	215.528	11.457	76.504	35.876	0.000	0.000
41617	84.742	0.000	185.644	0.000	213.076	11.682	76.504	31.880	0.000	0.000
41618	55.756	0.000	106.856	0.000	118.900	3.030	76.504	25.336	0.000	0.000
41619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	224.262	13.955	76.504	35.876	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2380.586	121.386	918.051	349.125	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.191	5.058	38.252	14.547	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE107 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
417 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
417 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
417 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
417 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
417 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
417 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
417 7	81.785	0.000	168.037	0.000	113.638	0.000	76.504	24.165	0.000	0.000
417 8	98.066	0.000	208.826	0.000	58.571	0.000	76.504	31.041	0.000	0.000
417 9	99.683	0.000	213.339	0.000	123.629	3.839	76.504	30.017	0.000	0.000
41710	99.683	0.000	208.758	0.000	124.761	3.774	76.504	32.264	0.000	0.000
41711	99.683	0.000	185.850	0.000	76.011	0.000	76.504	32.114	0.000	0.000
41712	99.683	0.000	184.930	0.000	78.659	0.197	76.504	32.055	0.000	0.000
41713	99.683	0.000	204.176	0.000	58.881	0.000	76.504	37.526	0.000	0.000
41714	99.683	0.000	212.419	0.000	125.807	3.626	76.504	36.465	0.000	0.000
41715	99.362	0.000	212.908	0.000	77.349	0.000	76.504	41.245	0.000	0.000
41716	96.460	0.000	208.973	0.000	80.480	0.130	76.504	39.235	0.000	0.000
41717	84.742	0.000	185.644	0.000	58.889	0.000	76.504	35.401	0.000	0.000
41718	55.756	0.000	106.856	0.000	58.010	0.000	76.504	25.524	0.000	0.000
41719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	125.807	3.839	76.504	41.245	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1034.685	11.566	918.051	397.052	0.000	0.000
AV	53.189	0.000	116.048	0.000	43.112	0.482	38.252	16.544	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE108 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
418 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
418 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
418 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
418 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
418 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
418 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
418 7	5.538	0.000	31.745	0.000	112.482	0.000	76.504	23.949	0.000	0.000
418 8	5.538	0.000	31.745	0.000	58.420	0.000	76.504	23.949	0.000	0.000
418 9	5.538	0.000	31.745	0.000	58.129	0.000	76.504	23.949	0.000	0.000
41810	5.538	0.000	31.745	0.000	107.365	2.200	76.504	23.949	0.000	0.000
41811	5.538	0.000	31.745	0.000	196.921	9.617	76.504	23.949	0.000	0.000
41812	5.538	0.000	31.745	0.000	121.819	3.393	76.504	23.949	0.000	0.000
41813	5.538	0.000	31.745	0.000	159.889	6.655	76.504	23.949	0.000	0.000
41814	5.538	0.000	31.745	0.000	145.893	5.564	76.504	23.949	0.000	0.000
41815	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41816	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41817	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41818	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41819	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41820	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41821	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41822	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41823	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
41824	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 18)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	196.921	9.617	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	960.918	27.430	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	40.038	1.143	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE110 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
420 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
420 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
420 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
420 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
420 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
420 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
420 7	81.785	0.000	168.037	0.000	113.902	0.000	76.504	24.106	0.000	0.000
420 8	98.066	0.000	208.826	0.000	58.342	0.000	76.504	26.666	0.000	0.000
420 9	99.683	0.000	213.339	0.000	57.995	0.000	76.504	27.392	0.000	0.000
42010	99.683	0.000	208.758	0.000	72.379	0.000	76.504	28.422	0.000	0.000
42011	99.683	0.000	185.850	0.000	207.408	11.224	76.504	25.627	0.000	0.000
42012	99.683	0.000	184.930	0.000	150.884	4.943	76.504	28.839	0.000	0.000
42013	99.683	0.000	204.176	0.000	174.572	7.230	76.504	30.299	0.000	0.000
42014	99.683	0.000	212.419	0.000	140.761	4.429	76.504	34.515	0.000	0.000
42015	99.362	0.000	212.908	0.000	145.389	4.749	76.504	36.045	0.000	0.000
42016	96.460	0.000	208.973	0.000	120.543	3.321	76.504	37.241	0.000	0.000
42017	84.742	0.000	185.644	0.000	60.395	0.000	76.504	35.254	0.000	0.000
42018	55.756	0.000	106.856	0.000	58.063	0.000	76.504	25.697	0.000	0.000
42019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	207.408	11.224	76.504	37.241	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1360.631	35.897	918.051	360.104	0.000	0.000
AV	53.189	0.000	116.048	0.000	56.693	1.496	38.252	15.004	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE111 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
421 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
421 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
421 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
421 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
421 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
421 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
421 7	81.785	0.000	168.037	0.000	112.235	0.000	76.504	23.949	0.000	0.000
421 8	98.066	0.000	208.826	0.000	58.218	0.000	76.504	25.577	0.000	0.000
421 9	99.683	0.000	213.339	0.000	57.887	0.000	76.504	26.959	0.000	0.000
42110	99.683	0.000	208.758	0.000	57.872	0.000	76.504	27.680	0.000	0.000
42111	99.683	0.000	185.850	0.000	57.871	0.000	76.504	27.221	0.000	0.000
42112	99.683	0.000	184.930	0.000	57.816	0.000	76.504	28.518	0.000	0.000
42113	99.683	0.000	204.176	0.000	57.814	0.000	76.504	31.668	0.000	0.000
42114	99.683	0.000	212.419	0.000	57.814	0.000	76.504	34.808	0.000	0.000
42115	99.362	0.000	212.908	0.000	57.840	0.000	76.504	38.178	0.000	0.000
42116	96.460	0.000	208.973	0.000	57.815	0.000	76.504	37.450	0.000	0.000
42117	84.742	0.000	185.644	0.000	57.814	0.000	76.504	32.497	0.000	0.000
42118	55.756	0.000	106.856	0.000	57.789	0.000	76.504	24.167	0.000	0.000
42119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.235	0.000	76.504	38.178	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.784	0.000	918.051	358.671	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.199	0.000	38.252	14.945	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE112 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
422 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
422 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
422 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
422 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
422 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
422 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
422 7	81.785	0.000	168.037	0.000	111.915	0.000	76.504	23.949	0.000	0.000
422 8	98.066	0.000	208.826	0.000	58.007	0.000	76.504	24.825	0.000	0.000
422 9	99.683	0.000	213.339	0.000	57.751	0.000	76.504	27.529	0.000	0.000
42210	99.683	0.000	208.758	0.000	57.763	0.000	76.504	27.495	0.000	0.000
42211	99.683	0.000	185.850	0.000	57.764	0.000	76.504	25.068	0.000	0.000
42212	99.683	0.000	184.930	0.000	57.812	0.000	76.504	26.961	0.000	0.000
42213	99.683	0.000	204.176	0.000	57.744	0.000	76.504	27.839	0.000	0.000
42214	99.683	0.000	212.419	0.000	57.811	0.000	76.504	33.394	0.000	0.000
42215	99.362	0.000	212.908	0.000	57.766	0.000	76.504	36.754	0.000	0.000
42216	96.460	0.000	208.973	0.000	57.787	0.000	76.504	36.350	0.000	0.000
42217	84.742	0.000	185.644	0.000	57.765	0.000	76.504	31.536	0.000	0.000
42218	55.756	0.000	106.856	0.000	57.742	0.000	76.504	24.056	0.000	0.000
42219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.915	0.000	76.504	36.754	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	747.625	0.000	918.051	345.757	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.151	0.000	38.252	14.407	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE113 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
423 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
423 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
423 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
423 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
423 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
423 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
423 7	81.785	0.000	168.037	0.000	111.855	0.000	76.504	23.949	0.000	0.000
423 8	98.066	0.000	208.826	0.000	58.064	0.000	76.504	24.035	0.000	0.000
423 9	99.683	0.000	213.339	0.000	57.799	0.000	76.504	23.958	0.000	0.000
42310	99.683	0.000	208.758	0.000	57.788	0.000	76.504	24.111	0.000	0.000
42311	99.683	0.000	185.850	0.000	57.788	0.000	76.504	23.949	0.000	0.000
42312	99.683	0.000	184.930	0.000	57.788	0.000	76.504	23.949	0.000	0.000
42313	99.683	0.000	204.176	0.000	57.813	0.000	76.504	24.478	0.000	0.000
42314	99.683	0.000	212.419	0.000	57.869	0.000	76.504	27.571	0.000	0.000
42315	99.362	0.000	212.908	0.000	57.816	0.000	76.504	25.577	0.000	0.000
42316	96.460	0.000	208.973	0.000	57.840	0.000	76.504	28.716	0.000	0.000
42317	84.742	0.000	185.644	0.000	57.790	0.000	76.504	25.780	0.000	0.000
42318	55.756	0.000	106.856	0.000	57.788	0.000	76.504	23.949	0.000	0.000
42319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.855	0.000	76.504	28.716	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	747.997	0.000	918.051	300.020	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.167	0.000	38.252	12.501	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE114 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
424 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
424 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
424 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
424 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
424 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
424 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
424 7	81.785	0.000	168.037	0.000	112.098	0.000	76.504	23.949	0.000	0.000
424 8	98.066	0.000	208.826	0.000	58.174	0.000	76.504	23.949	0.000	0.000
424 9	99.683	0.000	213.339	0.000	57.916	0.000	76.504	24.475	0.000	0.000
42410	99.683	0.000	208.758	0.000	57.873	0.000	76.504	26.235	0.000	0.000
42411	99.683	0.000	185.850	0.000	57.902	0.000	76.504	25.802	0.000	0.000
42412	99.683	0.000	184.930	0.000	66.816	0.000	76.504	25.445	0.000	0.000
42413	99.683	0.000	204.176	0.000	68.960	0.000	76.504	27.863	0.000	0.000
42414	99.683	0.000	212.419	0.000	58.308	0.000	76.504	31.510	0.000	0.000
42415	99.362	0.000	212.908	0.000	57.951	0.000	76.504	32.715	0.000	0.000
42416	96.460	0.000	208.973	0.000	57.906	0.000	76.504	34.614	0.000	0.000
42417	84.742	0.000	185.644	0.000	57.904	0.000	76.504	30.493	0.000	0.000
42418	55.756	0.000	106.856	0.000	57.904	0.000	76.504	24.244	0.000	0.000
42419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.098	0.000	76.504	34.614	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	769.714	0.000	918.051	331.291	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.071	0.000	38.252	13.804	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE115 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
425 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
425 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
425 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
425 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
425 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
425 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
425 7	5.538	0.000	31.745	0.000	112.257	0.000	76.504	23.949	0.000	0.000
425 8	5.538	0.000	31.745	0.000	58.308	0.000	76.504	23.949	0.000	0.000
425 9	5.538	0.000	31.745	0.000	78.003	0.000	76.504	23.949	0.000	0.000
42510	5.538	0.000	31.745	0.000	64.828	0.000	76.504	23.949	0.000	0.000
42511	5.538	0.000	31.745	0.000	65.117	0.000	76.504	23.949	0.000	0.000
42512	5.538	0.000	31.745	0.000	89.600	0.832	76.504	23.949	0.000	0.000
42513	5.538	0.000	31.745	0.000	81.863	0.000	76.504	23.949	0.000	0.000
42514	5.538	0.000	31.745	0.000	95.171	0.893	76.504	23.949	0.000	0.000
42515	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42516	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42517	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42518	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42519	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42520	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42521	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42522	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42523	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42524	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 25)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.257	0.893	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	645.149	1.726	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	26.881	0.072	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE117 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
427 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
427 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
427 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
427 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
427 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
427 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
427 7	81.785	0.000	168.037	0.000	113.179	0.000	76.504	23.949	0.000	0.000
427 8	98.066	0.000	208.826	0.000	58.435	0.000	76.504	23.949	0.000	0.000
427 9	99.683	0.000	213.339	0.000	91.517	0.805	76.504	23.949	0.000	0.000
42710	99.683	0.000	208.758	0.000	87.628	0.258	76.504	23.949	0.000	0.000
42711	99.683	0.000	185.850	0.000	88.867	0.443	76.504	23.949	0.000	0.000
42712	99.683	0.000	184.930	0.000	96.694	1.195	76.504	24.407	0.000	0.000
42713	99.683	0.000	204.176	0.000	123.905	3.132	76.504	25.357	0.000	0.000
42714	99.683	0.000	212.419	0.000	89.886	0.341	76.504	26.539	0.000	0.000
42715	99.362	0.000	212.908	0.000	66.581	0.000	76.504	27.419	0.000	0.000
42716	96.460	0.000	208.973	0.000	58.347	0.000	76.504	26.752	0.000	0.000
42717	84.742	0.000	185.644	0.000	57.991	0.000	76.504	25.131	0.000	0.000
42718	55.756	0.000	106.856	0.000	57.941	0.000	76.504	23.949	0.000	0.000
42719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	123.905	3.132	76.504	27.419	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	990.972	6.175	918.051	299.297	0.000	0.000
AV	53.189	0.000	116.048	0.000	41.290	0.257	38.252	12.471	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE118 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
428 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
428 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
428 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
428 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
428 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
428 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
428 7	81.785	0.000	168.037	0.000	112.464	0.000	76.504	23.949	0.000	0.000
428 8	98.066	0.000	208.826	0.000	58.364	0.000	76.504	23.949	0.000	0.000
428 9	99.683	0.000	213.339	0.000	85.183	0.000	76.504	24.019	0.000	0.000
42810	99.683	0.000	208.758	0.000	86.342	0.000	76.504	24.500	0.000	0.000
42811	99.683	0.000	185.850	0.000	163.480	5.990	76.504	24.009	0.000	0.000
42812	99.683	0.000	184.930	0.000	127.187	3.078	76.504	24.713	0.000	0.000
42813	99.683	0.000	204.176	0.000	60.551	0.000	76.504	25.455	0.000	0.000
42814	99.683	0.000	212.419	0.000	58.110	0.000	76.504	25.404	0.000	0.000
42815	99.362	0.000	212.908	0.000	57.983	0.000	76.504	25.673	0.000	0.000
42816	96.460	0.000	208.973	0.000	57.941	0.000	76.504	25.329	0.000	0.000
42817	84.742	0.000	185.644	0.000	57.939	0.000	76.504	24.064	0.000	0.000
42818	55.756	0.000	106.856	0.000	57.939	0.000	76.504	23.949	0.000	0.000
42819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	163.480	5.990	76.504	25.673	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	983.484	9.068	918.051	295.011	0.000	0.000
AV	53.189	0.000	116.048	0.000	40.978	0.378	38.252	12.292	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE119 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
429 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
429 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
429 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
429 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
429 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
429 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
429 7	81.785	0.000	168.037	0.000	112.436	0.000	76.504	23.949	0.000	0.000
429 8	98.066	0.000	208.826	0.000	58.418	0.000	76.504	25.652	0.000	0.000
429 9	99.683	0.000	213.339	0.000	57.998	0.000	76.504	25.656	0.000	0.000
42910	99.683	0.000	208.758	0.000	57.978	0.000	76.504	26.839	0.000	0.000
42911	99.683	0.000	185.850	0.000	57.941	0.000	76.504	25.098	0.000	0.000
42912	99.683	0.000	184.930	0.000	68.869	0.000	76.504	25.795	0.000	0.000
42913	99.683	0.000	204.176	0.000	71.348	0.000	76.504	27.822	0.000	0.000
42914	99.683	0.000	212.419	0.000	70.435	0.000	76.504	30.449	0.000	0.000
42915	99.362	0.000	212.908	0.000	58.404	0.000	76.504	34.184	0.000	0.000
42916	96.460	0.000	208.973	0.000	57.992	0.000	76.504	34.172	0.000	0.000
42917	84.742	0.000	185.644	0.000	57.941	0.000	76.504	30.392	0.000	0.000
42918	55.756	0.000	106.856	0.000	57.875	0.000	76.504	24.178	0.000	0.000
42919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
42924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.436	0.000	76.504	34.184	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	787.634	0.000	918.051	334.186	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.818	0.000	38.252	13.924	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE120 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
430 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
430 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
430 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
430 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
430 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
430 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
430 7	81.785	0.000	168.037	0.000	112.350	0.000	76.504	23.949	0.000	0.000
430 8	98.066	0.000	208.826	0.000	58.311	0.000	76.504	24.000	0.000	0.000
430 9	99.683	0.000	213.339	0.000	57.922	0.000	76.504	24.040	0.000	0.000
43010	99.683	0.000	208.758	0.000	57.938	0.000	76.504	24.220	0.000	0.000
43011	99.683	0.000	185.850	0.000	57.939	0.000	76.504	23.949	0.000	0.000
43012	99.683	0.000	184.930	0.000	57.939	0.000	76.504	24.227	0.000	0.000
43013	99.683	0.000	204.176	0.000	57.939	0.000	76.504	24.911	0.000	0.000
43014	99.683	0.000	212.419	0.000	57.939	0.000	76.504	24.879	0.000	0.000
43015	99.362	0.000	212.908	0.000	57.939	0.000	76.504	25.030	0.000	0.000
43016	96.460	0.000	208.973	0.000	57.939	0.000	76.504	24.773	0.000	0.000
43017	84.742	0.000	185.644	0.000	57.939	0.000	76.504	23.960	0.000	0.000
43018	55.756	0.000	106.856	0.000	57.939	0.000	76.504	23.949	0.000	0.000
43019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
43020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
43021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
43022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
43023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
43024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (APR 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.350	0.000	76.504	25.030	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	750.032	0.000	918.051	291.887	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.251	0.000	38.252	12.162	0.000	0.000
MONTHLY SUMMARY (APR)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	247.380	18.877	76.504	41.245	0.000	0.000
SM	28774.879	0.000	65235.250	0.000	32438.070	872.927	22645.258	8410.491	0.000	0.000
AV	39.965	0.000	90.605	0.000	45.053	1.212	31.452	11.681	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE121 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 1 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 1 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 1 7	81.785	0.000	168.037	0.000	112.761	0.000	76.504	23.949	0.000	0.000
5 1 8	98.066	0.000	208.826	0.000	73.060	0.000	76.504	24.516	0.000	0.000
5 1 9	99.683	0.000	213.339	0.000	165.604	6.959	76.504	24.806	0.000	0.000
5 110	99.683	0.000	208.758	0.000	210.470	11.553	76.504	25.382	0.000	0.000
5 111	99.683	0.000	185.850	0.000	221.190	14.640	76.504	24.563	0.000	0.000
5 112	99.683	0.000	184.930	0.000	222.129	14.810	76.504	24.651	0.000	0.000
5 113	99.683	0.000	204.176	0.000	225.848	15.609	76.504	25.737	0.000	0.000
5 114	99.683	0.000	212.419	0.000	229.739	16.363	76.504	27.504	0.000	0.000
5 115	99.362	0.000	212.908	0.000	229.512	15.753	76.504	28.337	0.000	0.000
5 116	96.460	0.000	208.973	0.000	222.396	14.025	76.504	30.700	0.000	0.000
5 117	84.742	0.000	185.644	0.000	206.082	10.136	76.504	29.391	0.000	0.000
5 118	55.756	0.000	106.856	0.000	97.411	1.799	76.504	24.513	0.000	0.000
5 119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	229.739	16.363	76.504	30.700	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2216.203	121.647	918.051	314.050	0.000	0.000
AV	53.189	0.000	116.048	0.000	92.342	5.069	38.252	13.085	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE122 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 2 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 2 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 2 7	5.538	0.000	31.745	0.000	113.245	0.000	76.504	23.949	0.000	0.000
5 2 8	5.538	0.000	31.745	0.000	58.497	0.000	76.504	23.949	0.000	0.000
5 2 9	5.538	0.000	31.745	0.000	113.515	3.068	76.504	23.949	0.000	0.000
5 210	5.538	0.000	31.745	0.000	123.928	3.362	76.504	23.949	0.000	0.000
5 211	5.538	0.000	31.745	0.000	147.477	5.641	76.504	23.949	0.000	0.000
5 212	5.538	0.000	31.745	0.000	159.014	6.521	76.504	23.949	0.000	0.000
5 213	5.538	0.000	31.745	0.000	158.447	6.510	76.504	23.949	0.000	0.000
5 214	5.538	0.000	31.745	0.000	185.208	8.988	76.504	23.949	0.000	0.000
5 215	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 216	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 217	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 218	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 219	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 220	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 221	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 222	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 223	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 224	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 2)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	185.208	8.988	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1059.332	34.089	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	44.139	1.420	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE124 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 4 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 4 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 4 7	81.785	0.000	168.037	0.000	114.511	0.000	76.504	23.949	0.000	0.000
5 4 8	98.066	0.000	208.826	0.000	58.305	0.000	76.504	24.371	0.000	0.000
5 4 9	99.683	0.000	213.339	0.000	57.956	0.000	76.504	25.392	0.000	0.000
5 410	99.683	0.000	208.758	0.000	70.525	0.000	76.504	25.123	0.000	0.000
5 411	99.683	0.000	185.850	0.000	111.257	1.941	76.504	24.446	0.000	0.000
5 412	99.683	0.000	184.930	0.000	114.036	2.134	76.504	25.242	0.000	0.000
5 413	99.683	0.000	204.176	0.000	119.272	2.606	76.504	27.367	0.000	0.000
5 414	99.683	0.000	212.419	0.000	173.696	6.706	76.504	27.809	0.000	0.000
5 415	99.362	0.000	212.908	0.000	158.926	5.717	76.504	30.752	0.000	0.000
5 416	96.460	0.000	208.973	0.000	94.410	0.787	76.504	33.230	0.000	0.000
5 417	84.742	0.000	185.644	0.000	67.949	0.000	76.504	27.529	0.000	0.000
5 418	55.756	0.000	106.856	0.000	58.307	0.000	76.504	23.949	0.000	0.000
5 419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	173.696	6.706	76.504	33.230	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1199.150	19.892	918.051	319.158	0.000	0.000
AV	53.189	0.000	116.048	0.000	49.965	0.829	38.252	13.298	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE125 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 5 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 5 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 5 7	81.785	0.000	168.037	0.000	112.425	0.000	76.504	23.949	0.000	0.000
5 5 8	98.066	0.000	208.826	0.000	85.094	0.000	76.504	25.142	0.000	0.000
5 5 9	99.683	0.000	213.339	0.000	105.589	1.345	76.504	25.334	0.000	0.000
5 510	99.683	0.000	208.758	0.000	115.028	2.242	76.504	25.690	0.000	0.000
5 511	99.683	0.000	185.850	0.000	160.890	5.822	76.504	25.013	0.000	0.000
5 512	99.683	0.000	184.930	0.000	133.593	3.596	76.504	25.736	0.000	0.000
5 513	99.683	0.000	204.176	0.000	96.887	1.128	76.504	29.355	0.000	0.000
5 514	99.683	0.000	212.419	0.000	120.605	2.764	76.504	27.280	0.000	0.000
5 515	99.362	0.000	212.908	0.000	120.725	2.662	76.504	28.178	0.000	0.000
5 516	96.460	0.000	208.973	0.000	90.891	0.467	76.504	28.412	0.000	0.000
5 517	84.742	0.000	185.644	0.000	59.146	0.000	76.504	26.153	0.000	0.000
5 518	55.756	0.000	106.856	0.000	57.945	0.000	76.504	23.949	0.000	0.000
5 519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	160.890	5.822	76.504	29.355	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1258.817	20.026	918.051	314.190	0.000	0.000
AV	53.189	0.000	116.048	0.000	52.451	0.834	38.252	13.091	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE126 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 6 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 6 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 6 7	81.785	0.000	168.037	0.000	112.350	0.000	76.504	23.949	0.000	0.000
5 6 8	98.066	0.000	208.826	0.000	58.264	0.000	76.504	24.582	0.000	0.000
5 6 9	99.683	0.000	213.339	0.000	86.908	0.077	76.504	24.636	0.000	0.000
5 610	99.683	0.000	208.758	0.000	103.917	1.187	76.504	24.817	0.000	0.000
5 611	99.683	0.000	185.850	0.000	127.844	3.122	76.504	24.451	0.000	0.000
5 612	99.683	0.000	184.930	0.000	182.999	7.281	76.504	24.253	0.000	0.000
5 613	99.683	0.000	204.176	0.000	150.920	4.796	76.504	26.719	0.000	0.000
5 614	99.683	0.000	212.419	0.000	189.923	7.837	76.504	27.417	0.000	0.000
5 615	99.362	0.000	212.908	0.000	95.401	1.054	76.504	32.862	0.000	0.000
5 616	96.460	0.000	208.973	0.000	69.961	0.000	76.504	31.455	0.000	0.000
5 617	84.742	0.000	185.644	0.000	69.683	0.000	76.504	28.493	0.000	0.000
5 618	55.756	0.000	106.856	0.000	58.377	0.000	76.504	24.128	0.000	0.000
5 619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	189.923	7.837	76.504	32.862	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1306.546	25.353	918.051	317.761	0.000	0.000
AV	53.189	0.000	116.048	0.000	54.439	1.056	38.252	13.240	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE127 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 7 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 7 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 7 7	81.785	0.000	168.037	0.000	112.263	0.000	76.504	23.949	0.000	0.000
5 7 8	98.066	0.000	208.826	0.000	58.262	0.000	76.504	25.774	0.000	0.000
5 7 9	99.683	0.000	213.339	0.000	67.262	0.000	76.504	26.240	0.000	0.000
5 710	99.683	0.000	208.758	0.000	67.491	0.000	76.504	28.222	0.000	0.000
5 711	99.683	0.000	185.850	0.000	90.927	0.331	76.504	26.772	0.000	0.000
5 712	99.683	0.000	184.930	0.000	179.063	6.990	76.504	25.033	0.000	0.000
5 713	99.683	0.000	204.176	0.000	197.589	8.196	76.504	26.241	0.000	0.000
5 714	99.683	0.000	212.419	0.000	192.779	8.023	76.504	28.813	0.000	0.000
5 715	99.362	0.000	212.908	0.000	180.682	7.255	76.504	31.057	0.000	0.000
5 716	96.460	0.000	208.973	0.000	125.919	3.169	76.504	33.151	0.000	0.000
5 717	84.742	0.000	185.644	0.000	92.128	0.614	76.504	29.671	0.000	0.000
5 718	55.756	0.000	106.856	0.000	59.253	0.000	76.504	25.068	0.000	0.000
5 719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	197.589	8.196	76.504	33.151	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1423.617	34.579	918.051	329.990	0.000	0.000
AV	53.189	0.000	116.048	0.000	59.317	1.441	38.252	13.750	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE128 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 8 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 8 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 8 7	81.785	0.000	168.037	0.000	112.436	0.000	76.504	23.962	0.000	0.000
5 8 8	98.066	0.000	208.826	0.000	67.303	0.000	76.504	25.501	0.000	0.000
5 8 9	99.683	0.000	213.339	0.000	108.382	1.546	76.504	26.105	0.000	0.000
5 810	99.683	0.000	208.758	0.000	137.406	3.724	76.504	27.158	0.000	0.000
5 811	99.683	0.000	185.850	0.000	148.497	4.570	76.504	25.499	0.000	0.000
5 812	99.683	0.000	184.930	0.000	179.529	7.118	76.504	25.472	0.000	0.000
5 813	99.683	0.000	204.176	0.000	203.404	8.682	76.504	26.844	0.000	0.000
5 814	99.683	0.000	212.419	0.000	196.278	8.250	76.504	29.770	0.000	0.000
5 815	99.362	0.000	212.908	0.000	163.241	6.099	76.504	33.190	0.000	0.000
5 816	96.460	0.000	208.973	0.000	166.017	6.281	76.504	32.406	0.000	0.000
5 817	84.742	0.000	185.644	0.000	123.810	3.001	76.504	30.927	0.000	0.000
5 818	55.756	0.000	106.856	0.000	86.161	0.196	76.504	24.727	0.000	0.000
5 819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	203.404	8.682	76.504	33.190	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1692.463	49.465	918.051	331.561	0.000	0.000
AV	53.189	0.000	116.048	0.000	70.519	2.061	38.252	13.815	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE129 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
5 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 9 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 9 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 9 7	5.538	0.000	31.745	0.000	113.089	0.000	76.504	23.949	0.000	0.000
5 9 8	5.538	0.000	31.745	0.000	86.151	0.391	76.504	23.949	0.000	0.000
5 9 9	5.538	0.000	31.745	0.000	115.052	2.489	76.504	23.949	0.000	0.000
5 910	5.538	0.000	31.745	0.000	136.842	4.011	76.504	23.949	0.000	0.000
5 911	5.538	0.000	31.745	0.000	147.065	5.191	76.504	23.949	0.000	0.000
5 912	5.538	0.000	31.745	0.000	147.407	5.275	76.504	23.949	0.000	0.000
5 913	5.538	0.000	31.745	0.000	136.699	4.140	76.504	23.949	0.000	0.000
5 914	5.538	0.000	31.745	0.000	158.428	6.051	76.504	23.949	0.000	0.000
5 915	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 916	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 917	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 918	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 919	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 920	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 921	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 922	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 923	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5 924	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 9)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	158.428	6.051	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1040.734	27.548	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	43.364	1.148	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE131 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
511 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
511 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
511 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
511 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
511 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
511 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
511 7	81.785	0.000	168.037	0.000	115.281	0.160	76.504	24.601	0.000	0.000
511 8	98.066	0.000	208.826	0.000	200.712	9.673	76.504	26.258	0.000	0.000
511 9	99.683	0.000	213.339	0.000	214.835	12.408	76.504	27.969	0.000	0.000
51110	99.683	0.000	208.758	0.000	230.376	16.520	76.504	27.519	0.000	0.000
51111	99.683	0.000	185.850	0.000	231.692	16.689	76.504	26.413	0.000	0.000
51112	99.683	0.000	184.930	0.000	240.826	19.444	76.504	25.865	0.000	0.000
51113	99.683	0.000	204.176	0.000	235.027	17.311	76.504	27.961	0.000	0.000
51114	99.683	0.000	212.419	0.000	237.767	17.879	76.504	30.131	0.000	0.000
51115	99.362	0.000	212.908	0.000	240.084	18.271	76.504	31.503	0.000	0.000
51116	96.460	0.000	208.973	0.000	231.389	16.605	76.504	33.892	0.000	0.000
51117	84.742	0.000	185.644	0.000	217.849	13.113	76.504	30.921	0.000	0.000
51118	55.756	0.000	106.856	0.000	174.079	8.316	76.504	25.090	0.000	0.000
51119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	240.826	19.444	76.504	33.892	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2569.916	166.389	918.051	338.122	0.000	0.000
AV	53.189	0.000	116.048	0.000	107.080	6.933	38.252	14.088	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE132 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
512 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
512 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
512 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
512 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
512 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
512 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
512 7	81.785	0.000	168.037	0.000	114.902	0.487	76.504	24.180	0.000	0.000
512 8	98.066	0.000	208.826	0.000	202.913	11.326	76.504	27.216	0.000	0.000
512 9	99.683	0.000	213.339	0.000	219.437	14.158	76.504	27.628	0.000	0.000
51210	99.683	0.000	208.758	0.000	221.096	14.589	76.504	29.232	0.000	0.000
51211	99.683	0.000	185.850	0.000	223.399	15.106	76.504	26.718	0.000	0.000
51212	99.683	0.000	184.930	0.000	223.254	15.056	76.504	26.796	0.000	0.000
51213	99.683	0.000	204.176	0.000	244.488	20.183	76.504	26.751	0.000	0.000
51214	99.683	0.000	212.419	0.000	250.120	21.037	76.504	29.299	0.000	0.000
51215	99.362	0.000	212.908	0.000	252.239	21.418	76.504	30.772	0.000	0.000
51216	96.460	0.000	208.973	0.000	241.965	18.558	76.504	32.026	0.000	0.000
51217	84.742	0.000	185.644	0.000	238.589	18.979	76.504	30.188	0.000	0.000
51218	55.756	0.000	106.856	0.000	213.600	12.865	76.504	24.956	0.000	0.000
51219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	252.239	21.418	76.504	32.026	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2646.002	183.762	918.051	335.763	0.000	0.000
AV	53.189	0.000	116.048	0.000	110.250	7.657	38.252	13.990	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE133 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
513 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
513 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
513 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
513 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
513 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
513 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
513 7	81.785	0.000	168.037	0.000	115.899	0.705	76.504	24.900	0.000	0.000
513 8	98.066	0.000	208.826	0.000	58.698	0.000	76.504	27.479	0.000	0.000
513 9	99.683	0.000	213.339	0.000	116.999	3.361	76.504	26.674	0.000	0.000
51310	99.683	0.000	208.758	0.000	211.777	12.788	76.504	27.236	0.000	0.000
51311	99.683	0.000	185.850	0.000	144.089	5.450	76.504	26.763	0.000	0.000
51312	99.683	0.000	184.930	0.000	212.040	12.201	76.504	26.081	0.000	0.000
51313	99.683	0.000	204.176	0.000	228.748	16.176	76.504	26.879	0.000	0.000
51314	99.683	0.000	212.419	0.000	237.396	17.791	76.504	28.833	0.000	0.000
51315	99.362	0.000	212.908	0.000	235.108	17.327	76.504	31.730	0.000	0.000
51316	96.460	0.000	208.973	0.000	229.725	15.779	76.504	31.636	0.000	0.000
51317	84.742	0.000	185.644	0.000	216.656	12.839	76.504	30.905	0.000	0.000
51318	55.756	0.000	106.856	0.000	173.845	8.296	76.504	25.000	0.000	0.000
51319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	237.396	17.791	76.504	31.730	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2180.980	122.714	918.051	334.117	0.000	0.000
AV	53.189	0.000	116.048	0.000	90.874	5.113	38.252	13.922	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE134 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
514 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
514 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
514 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
514 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
514 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
514 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
514 7	81.785	0.000	168.037	0.000	114.792	0.273	76.504	24.186	0.000	0.000
514 8	98.066	0.000	208.826	0.000	58.671	0.000	76.504	29.081	0.000	0.000
514 9	99.683	0.000	213.339	0.000	218.119	15.097	76.504	26.348	0.000	0.000
51410	99.683	0.000	208.758	0.000	231.266	17.297	76.504	28.379	0.000	0.000
51411	99.683	0.000	185.850	0.000	217.578	13.777	76.504	26.951	0.000	0.000
51412	99.683	0.000	184.930	0.000	214.073	12.413	76.504	27.414	0.000	0.000
51413	99.683	0.000	204.176	0.000	230.550	16.602	76.504	27.870	0.000	0.000
51414	99.683	0.000	212.419	0.000	229.587	16.267	76.504	31.745	0.000	0.000
51415	99.362	0.000	212.908	0.000	232.318	16.862	76.504	33.163	0.000	0.000
51416	96.460	0.000	208.973	0.000	220.610	13.653	76.504	34.254	0.000	0.000
51417	84.742	0.000	185.644	0.000	225.582	15.051	76.504	28.362	0.000	0.000
51418	55.756	0.000	106.856	0.000	167.164	7.783	76.504	24.834	0.000	0.000
51419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	232.318	17.297	76.504	34.254	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2360.312	145.074	918.051	342.587	0.000	0.000
AV	53.189	0.000	116.048	0.000	98.346	6.045	38.252	14.274	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE135 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
515 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
515 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
515 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
515 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
515 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
515 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
515 7	81.785	0.000	168.037	0.000	114.486	0.096	76.504	24.110	0.000	0.000
515 8	98.066	0.000	208.826	0.000	76.317	0.000	76.504	26.510	0.000	0.000
515 9	99.683	0.000	213.339	0.000	205.122	11.185	76.504	24.550	0.000	0.000
51510	99.683	0.000	208.758	0.000	213.227	12.008	76.504	26.946	0.000	0.000
51511	99.683	0.000	185.850	0.000	217.421	13.086	76.504	26.253	0.000	0.000
51512	99.683	0.000	184.930	0.000	217.943	13.172	76.504	26.670	0.000	0.000
51513	99.683	0.000	204.176	0.000	220.800	13.773	76.504	28.498	0.000	0.000
51514	99.683	0.000	212.419	0.000	223.768	14.642	76.504	30.832	0.000	0.000
51515	99.362	0.000	212.908	0.000	215.432	12.151	76.504	33.484	0.000	0.000
51516	96.460	0.000	208.973	0.000	143.447	5.136	76.504	33.796	0.000	0.000
51517	84.742	0.000	185.644	0.000	61.008	0.000	76.504	29.471	0.000	0.000
51518	55.756	0.000	106.856	0.000	58.082	0.000	76.504	23.996	0.000	0.000
51519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	223.768	14.642	76.504	33.796	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1967.052	95.250	918.051	335.115	0.000	0.000
AV	53.189	0.000	116.048	0.000	81.960	3.969	38.252	13.963	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE136 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
516 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
516 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
516 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
516 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
516 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
516 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
516 7	5.538	0.000	31.745	0.000	113.410	0.000	76.504	23.949	0.000	0.000
516 8	5.538	0.000	31.745	0.000	95.681	0.900	76.504	23.949	0.000	0.000
516 9	5.538	0.000	31.745	0.000	158.166	6.350	76.504	23.949	0.000	0.000
51610	5.538	0.000	31.745	0.000	158.297	6.377	76.504	23.949	0.000	0.000
51611	5.538	0.000	31.745	0.000	171.076	7.560	76.504	23.949	0.000	0.000
51612	5.538	0.000	31.745	0.000	170.509	7.521	76.504	23.949	0.000	0.000
51613	5.538	0.000	31.745	0.000	170.538	7.535	76.504	23.949	0.000	0.000
51614	5.538	0.000	31.745	0.000	170.537	7.535	76.504	23.949	0.000	0.000
51615	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51616	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51617	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51618	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51619	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51620	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51621	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51622	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51623	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51624	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 16)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	171.076	7.560	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1208.214	43.778	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	50.342	1.824	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE138 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
518 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
518 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
518 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
518 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
518 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
518 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
518 7	81.785	0.000	168.037	0.000	114.456	0.000	76.504	23.949	0.000	0.000
518 8	98.066	0.000	208.826	0.000	58.405	0.000	76.504	25.312	0.000	0.000
518 9	99.683	0.000	213.339	0.000	57.998	0.000	76.504	27.192	0.000	0.000
51810	99.683	0.000	208.758	0.000	142.026	4.377	76.504	24.877	0.000	0.000
51811	99.683	0.000	185.850	0.000	92.554	0.597	76.504	25.802	0.000	0.000
51812	99.683	0.000	184.930	0.000	96.088	1.069	76.504	26.365	0.000	0.000
51813	99.683	0.000	204.176	0.000	204.381	9.645	76.504	25.805	0.000	0.000
51814	99.683	0.000	212.419	0.000	209.897	10.897	76.504	28.562	0.000	0.000
51815	99.362	0.000	212.908	0.000	156.048	5.649	76.504	30.580	0.000	0.000
51816	96.460	0.000	208.973	0.000	182.417	7.393	76.504	30.446	0.000	0.000
51817	84.742	0.000	185.644	0.000	89.976	0.486	76.504	31.239	0.000	0.000
51818	55.756	0.000	106.856	0.000	59.033	0.000	76.504	24.771	0.000	0.000
51819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	209.897	10.897	76.504	31.239	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1463.280	40.112	918.051	324.901	0.000	0.000
AV	53.189	0.000	116.048	0.000	60.970	1.671	38.252	13.538	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE139 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
519 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
519 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
519 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
519 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
519 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
519 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
519 7	81.785	0.000	168.037	0.000	112.039	0.000	76.504	24.191	0.000	0.000
519 8	98.066	0.000	208.826	0.000	58.101	0.000	76.504	25.653	0.000	0.000
519 9	99.683	0.000	213.339	0.000	57.825	0.000	76.504	26.633	0.000	0.000
51910	99.683	0.000	208.758	0.000	57.766	0.000	76.504	25.733	0.000	0.000
51911	99.683	0.000	185.850	0.000	57.812	0.000	76.504	25.998	0.000	0.000
51912	99.683	0.000	184.930	0.000	67.016	0.000	76.504	25.920	0.000	0.000
51913	99.683	0.000	204.176	0.000	88.070	0.000	76.504	26.978	0.000	0.000
51914	99.683	0.000	212.419	0.000	66.844	0.000	76.504	30.132	0.000	0.000
51915	99.362	0.000	212.908	0.000	67.765	0.000	76.504	28.912	0.000	0.000
51916	96.460	0.000	208.973	0.000	58.159	0.000	76.504	29.638	0.000	0.000
51917	84.742	0.000	185.644	0.000	57.824	0.000	76.504	27.653	0.000	0.000
51918	55.756	0.000	106.856	0.000	57.814	0.000	76.504	23.949	0.000	0.000
51919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
51924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.039	0.000	76.504	30.132	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	807.034	0.000	918.051	321.389	0.000	0.000
AV	53.189	0.000	116.048	0.000	33.626	0.000	38.252	13.391	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE140 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
520 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
520 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
520 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
520 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
520 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
520 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
520 7	81.785	0.000	168.037	0.000	112.102	0.000	76.504	23.949	0.000	0.000
520 8	98.066	0.000	208.826	0.000	58.174	0.000	76.504	25.923	0.000	0.000
520 9	99.683	0.000	213.339	0.000	57.828	0.000	76.504	29.570	0.000	0.000
52010	99.683	0.000	208.758	0.000	68.277	0.000	76.504	29.314	0.000	0.000
52011	99.683	0.000	185.850	0.000	144.706	3.655	76.504	25.308	0.000	0.000
52012	99.683	0.000	184.930	0.000	144.441	3.381	76.504	25.923	0.000	0.000
52013	99.683	0.000	204.176	0.000	171.085	5.779	76.504	27.033	0.000	0.000
52014	99.683	0.000	212.419	0.000	155.296	4.799	76.504	29.615	0.000	0.000
52015	99.362	0.000	212.908	0.000	159.324	4.716	76.504	30.872	0.000	0.000
52016	96.460	0.000	208.973	0.000	137.798	3.135	76.504	32.600	0.000	0.000
52017	84.742	0.000	185.644	0.000	134.453	2.915	76.504	29.823	0.000	0.000
52018	55.756	0.000	106.856	0.000	82.878	0.000	76.504	24.773	0.000	0.000
52019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	171.085	5.779	76.504	32.600	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1426.363	28.381	918.051	334.701	0.000	0.000
AV	53.189	0.000	116.048	0.000	59.432	1.183	38.252	13.946	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE141 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
521 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
521 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
521 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
521 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
521 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
521 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
521 7	81.785	0.000	168.037	0.000	112.495	0.000	76.504	24.841	0.000	0.000
521 8	98.066	0.000	208.826	0.000	68.389	0.000	76.504	28.259	0.000	0.000
521 9	99.683	0.000	213.339	0.000	111.673	1.563	76.504	28.122	0.000	0.000
52110	99.683	0.000	208.758	0.000	132.549	3.141	76.504	28.234	0.000	0.000
52111	99.683	0.000	185.850	0.000	147.700	4.250	76.504	26.276	0.000	0.000
52112	99.683	0.000	184.930	0.000	164.475	5.664	76.504	25.553	0.000	0.000
52113	99.683	0.000	204.176	0.000	185.247	7.502	76.504	27.117	0.000	0.000
52114	99.683	0.000	212.419	0.000	196.710	8.268	76.504	29.115	0.000	0.000
52115	99.362	0.000	212.908	0.000	202.308	8.639	76.504	30.729	0.000	0.000
52116	96.460	0.000	208.973	0.000	184.547	7.507	76.504	32.259	0.000	0.000
52117	84.742	0.000	185.644	0.000	156.795	5.660	76.504	30.509	0.000	0.000
52118	55.756	0.000	106.856	0.000	91.118	0.769	76.504	25.190	0.000	0.000
52119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	202.308	8.639	76.504	32.259	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1754.006	52.962	918.051	336.205	0.000	0.000
AV	53.189	0.000	116.048	0.000	73.084	2.207	38.252	14.009	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE142 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
522 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
522 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
522 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
522 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
522 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
522 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
522 7	81.785	0.000	168.037	0.000	112.964	0.000	76.504	25.492	0.000	0.000
522 8	98.066	0.000	208.826	0.000	93.393	0.522	76.504	28.312	0.000	0.000
522 9	99.683	0.000	213.339	0.000	200.546	8.425	76.504	26.502	0.000	0.000
52210	99.683	0.000	208.758	0.000	222.508	14.043	76.504	27.398	0.000	0.000
52211	99.683	0.000	185.850	0.000	221.093	13.746	76.504	26.164	0.000	0.000
52212	99.683	0.000	184.930	0.000	215.453	12.187	76.504	25.785	0.000	0.000
52213	99.683	0.000	204.176	0.000	219.888	13.132	76.504	26.646	0.000	0.000
52214	99.683	0.000	212.419	0.000	220.327	13.165	76.504	29.242	0.000	0.000
52215	99.362	0.000	212.908	0.000	228.012	15.489	76.504	30.616	0.000	0.000
52216	96.460	0.000	208.973	0.000	224.484	14.728	76.504	32.126	0.000	0.000
52217	84.742	0.000	185.644	0.000	212.330	11.502	76.504	30.661	0.000	0.000
52218	55.756	0.000	106.856	0.000	151.896	5.734	76.504	25.285	0.000	0.000
52219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	228.012	15.489	76.504	32.126	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2322.895	122.674	918.051	334.229	0.000	0.000
AV	53.189	0.000	116.048	0.000	96.787	5.111	38.252	13.926	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE143 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
523 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
523 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
523 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
523 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
523 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
523 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
523 7	5.538	0.000	31.745	0.000	115.117	0.231	76.504	23.949	0.000	0.000
523 8	5.538	0.000	31.745	0.000	123.976	3.455	76.504	23.949	0.000	0.000
523 9	5.538	0.000	31.745	0.000	197.359	9.668	76.504	23.949	0.000	0.000
52310	5.538	0.000	31.745	0.000	208.899	11.920	76.504	23.949	0.000	0.000
52311	5.538	0.000	31.745	0.000	205.771	10.543	76.504	23.949	0.000	0.000
52312	5.538	0.000	31.745	0.000	207.511	10.983	76.504	23.949	0.000	0.000
52313	5.538	0.000	31.745	0.000	193.937	9.655	76.504	23.949	0.000	0.000
52314	5.538	0.000	31.745	0.000	194.856	9.728	76.504	23.949	0.000	0.000
52315	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52316	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52317	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52318	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52319	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52320	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52321	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52322	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52323	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52324	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 23)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	208.899	11.920	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1447.427	66.182	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	60.309	2.758	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE146 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
526 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
526 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
526 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
526 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
526 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
526 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
526 7	81.785	0.000	168.037	0.000	114.924	0.000	76.504	23.949	0.000	0.000
526 8	98.066	0.000	208.826	0.000	58.415	0.000	76.504	25.263	0.000	0.000
526 9	99.683	0.000	213.339	0.000	70.209	0.000	76.504	25.237	0.000	0.000
52610	99.683	0.000	208.758	0.000	129.233	3.452	76.504	26.652	0.000	0.000
52611	99.683	0.000	185.850	0.000	195.928	8.422	76.504	25.200	0.000	0.000
52612	99.683	0.000	184.930	0.000	193.823	8.440	76.504	25.364	0.000	0.000
52613	99.683	0.000	204.176	0.000	201.387	8.995	76.504	26.398	0.000	0.000
52614	99.683	0.000	212.419	0.000	205.798	9.506	76.504	28.573	0.000	0.000
52615	99.362	0.000	212.908	0.000	207.293	9.813	76.504	30.220	0.000	0.000
52616	96.460	0.000	208.973	0.000	207.270	9.800	76.504	30.199	0.000	0.000
52617	84.742	0.000	185.644	0.000	153.539	5.464	76.504	29.338	0.000	0.000
52618	55.756	0.000	106.856	0.000	94.937	1.264	76.504	24.560	0.000	0.000
52619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	207.293	9.813	76.504	30.220	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1832.757	65.156	918.051	320.955	0.000	0.000
AV	53.189	0.000	116.048	0.000	76.365	2.715	38.252	13.373	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE147 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
527 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
527 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
527 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
527 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
527 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
527 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
527 7	81.785	0.000	168.037	0.000	113.328	0.000	76.504	23.949	0.000	0.000
527 8	98.066	0.000	208.826	0.000	74.028	0.000	76.504	26.894	0.000	0.000
527 9	99.683	0.000	213.339	0.000	73.280	0.000	76.504	27.715	0.000	0.000
52710	99.683	0.000	208.758	0.000	155.515	5.780	76.504	25.132	0.000	0.000
52711	99.683	0.000	185.850	0.000	213.213	12.189	76.504	24.887	0.000	0.000
52712	99.683	0.000	184.930	0.000	233.892	17.178	76.504	24.327	0.000	0.000
52713	99.683	0.000	204.176	0.000	237.294	17.731	76.504	24.133	0.000	0.000
52714	99.683	0.000	212.419	0.000	230.737	16.491	76.504	28.829	0.000	0.000
52715	99.362	0.000	212.908	0.000	236.998	17.763	76.504	29.106	0.000	0.000
52716	96.460	0.000	208.973	0.000	230.510	15.898	76.504	29.227	0.000	0.000
52717	84.742	0.000	185.644	0.000	224.342	14.720	76.504	28.585	0.000	0.000
52718	55.756	0.000	106.856	0.000	208.916	11.169	76.504	24.781	0.000	0.000
52719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	237.294	17.763	76.504	29.227	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2232.052	128.919	918.051	317.565	0.000	0.000
AV	53.189	0.000	116.048	0.000	93.002	5.372	38.252	13.232	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE148 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
528 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
528 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
528 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
528 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
528 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
528 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
528 7	81.785	0.000	168.037	0.000	212.127	11.381	76.504	24.935	0.000	0.000
528 8	98.066	0.000	208.826	0.000	253.537	22.872	76.504	26.348	0.000	0.000
528 9	99.683	0.000	213.339	0.000	248.234	21.267	76.504	25.789	0.000	0.000
52810	99.683	0.000	208.758	0.000	256.596	25.401	76.504	25.188	0.000	0.000
52811	99.683	0.000	185.850	0.000	260.472	24.015	76.504	25.924	0.000	0.000
52812	99.683	0.000	184.930	0.000	264.126	25.319	76.504	25.747	0.000	0.000
52813	99.683	0.000	204.176	0.000	253.000	21.529	76.504	26.998	0.000	0.000
52814	99.683	0.000	212.419	0.000	256.178	22.111	76.504	28.611	0.000	0.000
52815	99.362	0.000	212.908	0.000	256.791	22.167	76.504	30.614	0.000	0.000
52816	96.460	0.000	208.973	0.000	257.194	22.238	76.504	30.797	0.000	0.000
52817	84.742	0.000	185.644	0.000	245.221	19.120	76.504	28.865	0.000	0.000
52818	55.756	0.000	106.856	0.000	225.978	14.996	76.504	24.315	0.000	0.000
52819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	264.126	25.401	76.504	30.797	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2989.453	252.417	918.051	324.130	0.000	0.000
AV	53.189	0.000	116.048	0.000	124.561	10.517	38.252	13.505	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE149 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
529 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
529 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
529 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
529 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
529 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
529 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
529 7	81.785	0.000	168.037	0.000	197.030	7.830	76.504	24.712	0.000	0.000
529 8	98.066	0.000	208.826	0.000	239.493	19.506	76.504	28.550	0.000	0.000
529 9	99.683	0.000	213.339	0.000	266.211	25.642	76.504	27.732	0.000	0.000
52910	99.683	0.000	208.758	0.000	275.779	27.123	76.504	27.353	0.000	0.000
52911	99.683	0.000	185.850	0.000	252.945	24.550	76.504	24.954	0.000	0.000
52912	99.683	0.000	184.930	0.000	254.564	25.914	76.504	24.531	0.000	0.000
52913	99.683	0.000	204.176	0.000	262.718	28.782	76.504	25.074	0.000	0.000
52914	99.683	0.000	212.419	0.000	263.541	28.012	76.504	26.309	0.000	0.000
52915	99.362	0.000	212.908	0.000	283.418	28.944	76.504	30.330	0.000	0.000
52916	96.460	0.000	208.973	0.000	283.192	28.738	76.504	31.362	0.000	0.000
52917	84.742	0.000	185.644	0.000	265.724	24.754	76.504	30.928	0.000	0.000
52918	55.756	0.000	106.856	0.000	242.937	19.731	76.504	25.380	0.000	0.000
52919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
52924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	283.418	28.944	76.504	31.362	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3087.552	289.528	918.051	327.214	0.000	0.000
AV	53.189	0.000	116.048	0.000	128.648	12.064	38.252	13.634	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE150 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
530 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
530 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
530 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
530 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
530 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
530 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
530 7	5.538	0.000	31.745	0.000	217.981	13.282	76.504	23.949	0.000	0.000
530 8	5.538	0.000	31.745	0.000	240.431	22.496	76.504	23.949	0.000	0.000
530 9	5.538	0.000	31.745	0.000	229.597	20.574	76.504	23.949	0.000	0.000
53010	5.538	0.000	31.745	0.000	224.225	19.564	76.504	23.949	0.000	0.000
53011	5.538	0.000	31.745	0.000	224.458	19.647	76.504	23.949	0.000	0.000
53012	5.538	0.000	31.745	0.000	242.713	23.752	76.504	23.949	0.000	0.000
53013	5.538	0.000	31.745	0.000	244.093	23.842	76.504	23.949	0.000	0.000
53014	5.538	0.000	31.745	0.000	235.618	21.312	76.504	23.949	0.000	0.000
53015	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53016	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53017	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53018	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53019	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53020	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53021	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53022	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53023	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53024	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 30)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	244.093	23.842	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1859.116	164.470	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	77.463	6.853	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE151 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
531 1	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 2	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 3	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 4	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 5	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 6	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 7	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 8	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
531 9	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53110	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53111	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53112	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53113	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53114	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53115	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53116	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53117	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53118	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53119	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53120	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53121	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53122	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53123	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
53124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (MAY 31)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SM	43.750	0.000	250.789	0.000	0.000	0.000	0.000	0.000	0.000	0.000
AV	1.823	0.000	10.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MONTHLY SUMMARY (MAY)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	283.418	28.944	76.504	34.254	0.000	0.000
SM	26434.471	0.000	60883.961	0.000	45351.277	2300.368	21421.191	7511.648	0.000	0.000
AV	35.530	0.000	81.833	0.000	60.956	3.092	28.792	10.096	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE152 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 1 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 1 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 1 7	81.785	0.000	168.037	0.000	119.790	0.280	76.504	28.551	0.000	0.000
6 1 8	98.066	0.000	208.826	0.000	71.438	0.000	76.504	35.756	0.000	0.000
6 1 9	99.683	0.000	213.339	0.000	69.764	0.000	76.504	35.372	0.000	0.000
6 110	99.683	0.000	208.758	0.000	187.329	7.595	76.504	30.827	0.000	0.000
6 111	99.683	0.000	185.850	0.000	144.717	4.220	76.504	31.250	0.000	0.000
6 112	99.683	0.000	184.930	0.000	160.563	5.464	76.504	28.495	0.000	0.000
6 113	99.683	0.000	204.176	0.000	200.527	8.488	76.504	29.871	0.000	0.000
6 114	99.683	0.000	212.419	0.000	187.037	7.639	76.504	33.223	0.000	0.000
6 115	99.362	0.000	212.908	0.000	174.221	6.372	76.504	34.443	0.000	0.000
6 116	96.460	0.000	208.973	0.000	153.586	5.011	76.504	36.549	0.000	0.000
6 117	84.742	0.000	185.644	0.000	118.202	2.345	76.504	34.522	0.000	0.000
6 118	55.756	0.000	106.856	0.000	65.063	0.000	76.504	27.779	0.000	0.000
6 119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	200.527	8.488	76.504	36.549	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1652.238	47.415	918.051	386.637	0.000	0.000
AV	53.189	0.000	116.048	0.000	68.843	1.976	38.252	16.110	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE153 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 2 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 2 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 2 7	81.785	0.000	168.037	0.000	112.725	0.000	76.504	25.568	0.000	0.000
6 2 8	98.066	0.000	208.826	0.000	93.461	0.541	76.504	28.085	0.000	0.000
6 2 9	99.683	0.000	213.339	0.000	157.847	5.565	76.504	28.979	0.000	0.000
6 210	99.683	0.000	208.758	0.000	159.013	5.648	76.504	30.653	0.000	0.000
6 211	99.683	0.000	185.850	0.000	191.443	8.303	76.504	28.106	0.000	0.000
6 212	99.683	0.000	184.930	0.000	153.853	5.435	76.504	28.784	0.000	0.000
6 213	99.683	0.000	204.176	0.000	199.512	8.863	76.504	30.007	0.000	0.000
6 214	99.683	0.000	212.419	0.000	204.670	9.233	76.504	33.147	0.000	0.000
6 215	99.362	0.000	212.908	0.000	168.211	6.445	76.504	35.749	0.000	0.000
6 216	96.460	0.000	208.973	0.000	141.787	4.531	76.504	35.274	0.000	0.000
6 217	84.742	0.000	185.644	0.000	106.117	2.016	76.504	31.074	0.000	0.000
6 218	55.756	0.000	106.856	0.000	68.774	0.000	76.504	24.622	0.000	0.000
6 219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	204.670	9.233	76.504	35.749	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1757.412	56.580	918.051	360.047	0.000	0.000
AV	53.189	0.000	116.048	0.000	73.225	2.357	38.252	15.002	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE154 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 3 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 3 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 3 7	81.785	0.000	168.037	0.000	112.705	0.000	76.504	24.447	0.000	0.000
6 3 8	98.066	0.000	208.826	0.000	142.411	4.815	76.504	27.097	0.000	0.000
6 3 9	99.683	0.000	213.339	0.000	191.492	8.154	76.504	27.647	0.000	0.000
6 310	99.683	0.000	208.758	0.000	192.359	8.357	76.504	28.968	0.000	0.000
6 311	99.683	0.000	185.850	0.000	208.067	10.690	76.504	26.423	0.000	0.000
6 312	99.683	0.000	184.930	0.000	211.444	11.375	76.504	25.774	0.000	0.000
6 313	99.683	0.000	204.176	0.000	209.626	10.963	76.504	27.900	0.000	0.000
6 314	99.683	0.000	212.419	0.000	195.606	8.658	76.504	30.171	0.000	0.000
6 315	99.362	0.000	212.908	0.000	212.986	11.779	76.504	30.883	0.000	0.000
6 316	96.460	0.000	208.973	0.000	209.131	10.818	76.504	32.954	0.000	0.000
6 317	84.742	0.000	185.644	0.000	146.772	5.341	76.504	32.903	0.000	0.000
6 318	55.756	0.000	106.856	0.000	68.175	0.000	76.504	26.250	0.000	0.000
6 319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	212.986	11.779	76.504	32.954	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2100.773	90.950	918.051	341.417	0.000	0.000
AV	53.189	0.000	116.048	0.000	87.532	3.790	38.252	14.226	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE155 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 4 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 4 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 4 7	81.785	0.000	168.037	0.000	112.673	0.000	76.504	24.578	0.000	0.000
6 4 8	98.066	0.000	208.826	0.000	58.424	0.000	76.504	28.215	0.000	0.000
6 4 9	99.683	0.000	213.339	0.000	58.039	0.000	76.504	27.909	0.000	0.000
6 410	99.683	0.000	208.758	0.000	58.019	0.000	76.504	29.427	0.000	0.000
6 411	99.683	0.000	185.850	0.000	73.540	0.000	76.504	26.962	0.000	0.000
6 412	99.683	0.000	184.930	0.000	138.362	4.478	76.504	26.313	0.000	0.000
6 413	99.683	0.000	204.176	0.000	209.611	11.020	76.504	27.802	0.000	0.000
6 414	99.683	0.000	212.419	0.000	211.802	11.379	76.504	29.778	0.000	0.000
6 415	99.362	0.000	212.908	0.000	207.203	10.424	76.504	30.349	0.000	0.000
6 416	96.460	0.000	208.973	0.000	173.058	7.161	76.504	30.561	0.000	0.000
6 417	84.742	0.000	185.644	0.000	64.866	0.000	76.504	29.119	0.000	0.000
6 418	55.756	0.000	106.856	0.000	58.265	0.000	76.504	23.949	0.000	0.000
6 419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	211.802	11.379	76.504	30.561	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1423.864	44.463	918.051	334.961	0.000	0.000
AV	53.189	0.000	116.048	0.000	59.328	1.853	38.252	13.957	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE156 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 5 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 5 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 5 7	81.785	0.000	168.037	0.000	112.652	0.000	76.504	23.993	0.000	0.000
6 5 8	98.066	0.000	208.826	0.000	58.370	0.000	76.504	25.939	0.000	0.000
6 5 9	99.683	0.000	213.339	0.000	57.996	0.000	76.504	26.299	0.000	0.000
6 510	99.683	0.000	208.758	0.000	58.017	0.000	76.504	27.660	0.000	0.000
6 511	99.683	0.000	185.850	0.000	58.018	0.000	76.504	26.412	0.000	0.000
6 512	99.683	0.000	184.930	0.000	58.018	0.000	76.504	26.788	0.000	0.000
6 513	99.683	0.000	204.176	0.000	72.159	0.000	76.504	28.562	0.000	0.000
6 514	99.683	0.000	212.419	0.000	145.677	5.012	76.504	28.803	0.000	0.000
6 515	99.362	0.000	212.908	0.000	199.186	8.646	76.504	29.776	0.000	0.000
6 516	96.460	0.000	208.973	0.000	202.619	9.028	76.504	31.512	0.000	0.000
6 517	84.742	0.000	185.644	0.000	63.513	0.000	76.504	31.329	0.000	0.000
6 518	55.756	0.000	106.856	0.000	69.824	0.000	76.504	24.083	0.000	0.000
6 519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	202.619	9.028	76.504	31.512	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1156.049	22.686	918.051	331.156	0.000	0.000
AV	53.189	0.000	116.048	0.000	48.169	0.945	38.252	13.798	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE157 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 6 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 6 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 6 7	5.538	0.000	31.745	0.000	112.852	0.000	76.504	23.949	0.000	0.000
6 6 8	5.538	0.000	31.745	0.000	58.429	0.000	76.504	23.949	0.000	0.000
6 6 9	5.538	0.000	31.745	0.000	66.335	0.000	76.504	23.949	0.000	0.000
6 610	5.538	0.000	31.745	0.000	85.737	0.310	76.504	23.949	0.000	0.000
6 611	5.538	0.000	31.745	0.000	114.238	2.397	76.504	23.949	0.000	0.000
6 612	5.538	0.000	31.745	0.000	114.168	2.425	76.504	23.949	0.000	0.000
6 613	5.538	0.000	31.745	0.000	183.315	8.367	76.504	23.949	0.000	0.000
6 614	5.538	0.000	31.745	0.000	182.627	8.727	76.504	23.949	0.000	0.000
6 615	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 616	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 617	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 618	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 619	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 620	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 621	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 622	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 623	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 624	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 6)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	183.315	8.727	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	917.700	22.225	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	38.237	0.926	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE159 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 8 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 8 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 8 7	81.785	0.000	168.037	0.000	114.742	0.047	76.504	23.950	0.000	0.000
6 8 8	98.066	0.000	208.826	0.000	58.529	0.000	76.504	25.098	0.000	0.000
6 8 9	99.683	0.000	213.339	0.000	72.763	0.000	76.504	25.753	0.000	0.000
6 810	99.683	0.000	208.758	0.000	107.928	2.219	76.504	25.987	0.000	0.000
6 811	99.683	0.000	185.850	0.000	106.284	2.114	76.504	25.673	0.000	0.000
6 812	99.683	0.000	184.930	0.000	171.960	7.573	76.504	25.394	0.000	0.000
6 813	99.683	0.000	204.176	0.000	108.184	2.382	76.504	28.734	0.000	0.000
6 814	99.683	0.000	212.419	0.000	171.277	7.020	76.504	27.959	0.000	0.000
6 815	99.362	0.000	212.908	0.000	142.297	4.845	76.504	29.734	0.000	0.000
6 816	96.460	0.000	208.973	0.000	137.415	4.209	76.504	31.019	0.000	0.000
6 817	84.742	0.000	185.644	0.000	132.588	3.833	76.504	28.968	0.000	0.000
6 818	55.756	0.000	106.856	0.000	66.333	0.000	76.504	24.408	0.000	0.000
6 819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	171.960	7.573	76.504	31.019	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1390.301	34.243	918.051	322.676	0.000	0.000
AV	53.189	0.000	116.048	0.000	57.929	1.427	38.252	13.445	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE160 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
6 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 9 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 9 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 9 7	81.785	0.000	168.037	0.000	113.522	0.000	76.504	23.992	0.000	0.000
6 9 8	98.066	0.000	208.826	0.000	95.161	0.864	76.504	25.102	0.000	0.000
6 9 9	99.683	0.000	213.339	0.000	142.284	4.391	76.504	24.838	0.000	0.000
6 910	99.683	0.000	208.758	0.000	163.990	5.993	76.504	25.369	0.000	0.000
6 911	99.683	0.000	185.850	0.000	195.671	8.567	76.504	25.494	0.000	0.000
6 912	99.683	0.000	184.930	0.000	205.811	9.502	76.504	25.366	0.000	0.000
6 913	99.683	0.000	204.176	0.000	217.533	13.134	76.504	26.746	0.000	0.000
6 914	99.683	0.000	212.419	0.000	215.685	12.221	76.504	28.423	0.000	0.000
6 915	99.362	0.000	212.908	0.000	208.365	10.003	76.504	31.067	0.000	0.000
6 916	96.460	0.000	208.973	0.000	201.752	9.051	76.504	32.222	0.000	0.000
6 917	84.742	0.000	185.644	0.000	158.375	5.796	76.504	30.722	0.000	0.000
6 918	55.756	0.000	106.856	0.000	91.420	0.806	76.504	25.187	0.000	0.000
6 919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6 924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	217.533	13.134	76.504	32.222	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2009.569	80.330	918.051	324.529	0.000	0.000
AV	53.189	0.000	116.048	0.000	83.732	3.347	38.252	13.522	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE161 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
610 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
610 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
610 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
610 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
610 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
610 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
610 7	81.785	0.000	168.037	0.000	113.206	0.000	76.504	24.038	0.000	0.000
610 8	98.066	0.000	208.826	0.000	58.436	0.000	76.504	26.114	0.000	0.000
610 9	99.683	0.000	213.339	0.000	101.849	1.564	76.504	25.669	0.000	0.000
61010	99.683	0.000	208.758	0.000	147.043	4.659	76.504	25.731	0.000	0.000
61011	99.683	0.000	185.850	0.000	189.136	8.700	76.504	25.045	0.000	0.000
61012	99.683	0.000	184.930	0.000	214.782	12.585	76.504	25.208	0.000	0.000
61013	99.683	0.000	204.176	0.000	224.153	14.726	76.504	25.806	0.000	0.000
61014	99.683	0.000	212.419	0.000	207.407	9.728	76.504	30.216	0.000	0.000
61015	99.362	0.000	212.908	0.000	212.630	11.688	76.504	30.768	0.000	0.000
61016	96.460	0.000	208.973	0.000	213.386	11.766	76.504	31.224	0.000	0.000
61017	84.742	0.000	185.644	0.000	206.263	10.201	76.504	29.751	0.000	0.000
61018	55.756	0.000	106.856	0.000	99.243	1.910	76.504	24.905	0.000	0.000
61019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	224.153	14.726	76.504	31.224	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1987.533	87.527	918.051	324.475	0.000	0.000
AV	53.189	0.000	116.048	0.000	82.814	3.647	38.252	13.520	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE162 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
611 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
611 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
611 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
611 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
611 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
611 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
611 7	81.785	0.000	168.037	0.000	113.305	0.000	76.504	24.352	0.000	0.000
611 8	98.066	0.000	208.826	0.000	71.630	0.000	76.504	26.095	0.000	0.000
611 9	99.683	0.000	213.339	0.000	135.996	4.363	76.504	25.635	0.000	0.000
61110	99.683	0.000	208.758	0.000	160.194	6.000	76.504	26.014	0.000	0.000
61111	99.683	0.000	185.850	0.000	205.883	10.255	76.504	25.086	0.000	0.000
61112	99.683	0.000	184.930	0.000	219.336	13.495	76.504	25.277	0.000	0.000
61113	99.683	0.000	204.176	0.000	218.484	13.246	76.504	27.276	0.000	0.000
61114	99.683	0.000	212.419	0.000	220.669	13.747	76.504	28.661	0.000	0.000
61115	99.362	0.000	212.908	0.000	212.878	11.629	76.504	30.818	0.000	0.000
61116	96.460	0.000	208.973	0.000	177.899	7.510	76.504	34.230	0.000	0.000
61117	84.742	0.000	185.644	0.000	141.571	4.947	76.504	28.982	0.000	0.000
61118	55.756	0.000	106.856	0.000	69.174	0.000	76.504	24.384	0.000	0.000
61119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	220.669	13.747	76.504	34.230	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1947.017	85.192	918.051	326.809	0.000	0.000
AV	53.189	0.000	116.048	0.000	81.126	3.550	38.252	13.617	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE163 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
612 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
612 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
612 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
612 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
612 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
612 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
612 7	81.785	0.000	168.037	0.000	113.739	0.000	76.504	24.043	0.000	0.000
612 8	98.066	0.000	208.826	0.000	108.194	2.296	76.504	25.465	0.000	0.000
612 9	99.683	0.000	213.339	0.000	134.640	4.214	76.504	25.635	0.000	0.000
61210	99.683	0.000	208.758	0.000	135.812	4.368	76.504	26.225	0.000	0.000
61211	99.683	0.000	185.850	0.000	158.076	6.028	76.504	25.344	0.000	0.000
61212	99.683	0.000	184.930	0.000	217.184	13.178	76.504	24.771	0.000	0.000
61213	99.683	0.000	204.176	0.000	218.402	13.200	76.504	27.080	0.000	0.000
61214	99.683	0.000	212.419	0.000	220.764	13.763	76.504	28.462	0.000	0.000
61215	99.362	0.000	212.908	0.000	223.073	14.501	76.504	30.251	0.000	0.000
61216	96.460	0.000	208.973	0.000	218.456	13.246	76.504	31.672	0.000	0.000
61217	84.742	0.000	185.644	0.000	180.090	8.304	76.504	29.888	0.000	0.000
61218	55.756	0.000	106.856	0.000	65.462	0.000	76.504	25.322	0.000	0.000
61219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	223.073	14.501	76.504	31.672	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1993.892	93.097	918.051	324.158	0.000	0.000
AV	53.189	0.000	116.048	0.000	83.079	3.879	38.252	13.507	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE164 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
613 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
613 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
613 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
613 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
613 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
613 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
613 7	5.538	0.000	31.745	0.000	113.911	0.198	76.504	23.949	0.000	0.000
613 8	5.538	0.000	31.745	0.000	114.909	3.160	76.504	23.949	0.000	0.000
613 9	5.538	0.000	31.745	0.000	140.519	5.482	76.504	23.949	0.000	0.000
61310	5.538	0.000	31.745	0.000	156.871	6.858	76.504	23.949	0.000	0.000
61311	5.538	0.000	31.745	0.000	171.771	8.018	76.504	23.949	0.000	0.000
61312	5.538	0.000	31.745	0.000	197.566	10.554	76.504	23.949	0.000	0.000
61313	5.538	0.000	31.745	0.000	197.209	10.556	76.504	23.949	0.000	0.000
61314	5.538	0.000	31.745	0.000	170.589	8.005	76.504	23.949	0.000	0.000
61315	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61316	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61317	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61318	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61319	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61320	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61321	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61322	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61323	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61324	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 13)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	197.566	10.556	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1263.346	52.830	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	52.639	2.201	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE166 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
615 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
615 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
615 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
615 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
615 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
615 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
615 7	81.785	0.000	168.037	0.000	115.722	0.503	76.504	23.949	0.000	0.000
615 8	98.066	0.000	208.826	0.000	203.167	10.682	76.504	25.741	0.000	0.000
615 9	99.683	0.000	213.339	0.000	213.486	12.099	76.504	27.220	0.000	0.000
61510	99.683	0.000	208.758	0.000	210.293	11.520	76.504	29.335	0.000	0.000
61511	99.683	0.000	185.850	0.000	223.067	15.109	76.504	26.458	0.000	0.000
61512	99.683	0.000	184.930	0.000	222.615	14.892	76.504	26.405	0.000	0.000
61513	99.683	0.000	204.176	0.000	225.107	15.457	76.504	27.825	0.000	0.000
61514	99.683	0.000	212.419	0.000	227.978	16.018	76.504	29.970	0.000	0.000
61515	99.362	0.000	212.908	0.000	230.380	16.479	76.504	31.857	0.000	0.000
61516	96.460	0.000	208.973	0.000	230.702	16.529	76.504	32.163	0.000	0.000
61517	84.742	0.000	185.644	0.000	227.879	15.967	76.504	29.960	0.000	0.000
61518	55.756	0.000	106.856	0.000	212.780	12.729	76.504	24.676	0.000	0.000
61519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	230.702	16.529	76.504	32.163	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2543.177	157.984	918.051	335.558	0.000	0.000
AV	53.189	0.000	116.048	0.000	105.966	6.583	38.252	13.982	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE167 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
616 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
616 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
616 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
616 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
616 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
616 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
616 7	81.785	0.000	168.037	0.000	116.851	0.744	76.504	24.451	0.000	0.000
616 8	98.066	0.000	208.826	0.000	117.419	3.352	76.504	26.652	0.000	0.000
616 9	99.683	0.000	213.339	0.000	191.382	9.281	76.504	26.473	0.000	0.000
61610	99.683	0.000	208.758	0.000	247.518	21.477	76.504	25.615	0.000	0.000
61611	99.683	0.000	185.850	0.000	242.621	20.259	76.504	25.928	0.000	0.000
61612	99.683	0.000	184.930	0.000	244.565	20.803	76.504	25.183	0.000	0.000
61613	99.683	0.000	204.176	0.000	249.227	22.064	76.504	26.456	0.000	0.000
61614	99.683	0.000	212.419	0.000	248.921	21.974	76.504	28.566	0.000	0.000
61615	99.362	0.000	212.908	0.000	241.585	19.532	76.504	31.355	0.000	0.000
61616	96.460	0.000	208.973	0.000	242.499	19.739	76.504	31.840	0.000	0.000
61617	84.742	0.000	185.644	0.000	228.824	17.003	76.504	32.142	0.000	0.000
61618	55.756	0.000	106.856	0.000	210.203	12.175	76.504	25.896	0.000	0.000
61619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	249.227	22.064	76.504	32.142	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2581.616	188.403	918.051	330.557	0.000	0.000
AV	53.189	0.000	116.048	0.000	107.567	7.850	38.252	13.773	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE168 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
617 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
617 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
617 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
617 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
617 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
617 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
617 7	81.785	0.000	168.037	0.000	153.370	4.230	76.504	24.491	0.000	0.000
617 8	98.066	0.000	208.826	0.000	204.007	11.013	76.504	26.470	0.000	0.000
617 9	99.683	0.000	213.339	0.000	234.972	18.402	76.504	26.976	0.000	0.000
61710	99.683	0.000	208.758	0.000	248.246	21.408	76.504	27.848	0.000	0.000
61711	99.683	0.000	185.850	0.000	245.656	20.926	76.504	26.938	0.000	0.000
61712	99.683	0.000	184.930	0.000	248.609	21.521	76.504	26.105	0.000	0.000
61713	99.683	0.000	204.176	0.000	248.172	21.410	76.504	28.000	0.000	0.000
61714	99.683	0.000	212.419	0.000	257.074	23.450	76.504	29.190	0.000	0.000
61715	99.362	0.000	212.908	0.000	255.693	23.139	76.504	31.797	0.000	0.000
61716	96.460	0.000	208.973	0.000	238.533	18.913	76.504	34.434	0.000	0.000
61717	84.742	0.000	185.644	0.000	215.667	13.373	76.504	31.192	0.000	0.000
61718	55.756	0.000	106.856	0.000	148.266	6.844	76.504	24.351	0.000	0.000
61719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	257.074	23.450	76.504	34.434	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2698.264	204.628	918.051	337.792	0.000	0.000
AV	53.189	0.000	116.048	0.000	112.428	8.526	38.252	14.075	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE169 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
618 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
618 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
618 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
618 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
618 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
618 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
618 7	81.785	0.000	168.037	0.000	117.397	0.877	76.504	24.393	0.000	0.000
618 8	98.066	0.000	208.826	0.000	158.384	7.087	76.504	25.775	0.000	0.000
618 9	99.683	0.000	213.339	0.000	214.748	13.295	76.504	25.284	0.000	0.000
61810	99.683	0.000	208.758	0.000	233.208	17.998	76.504	26.309	0.000	0.000
61811	99.683	0.000	185.850	0.000	233.371	17.952	76.504	26.583	0.000	0.000
61812	99.683	0.000	184.930	0.000	232.746	17.876	76.504	26.381	0.000	0.000
61813	99.683	0.000	204.176	0.000	226.829	15.765	76.504	29.075	0.000	0.000
61814	99.683	0.000	212.419	0.000	223.793	15.168	76.504	32.018	0.000	0.000
61815	99.362	0.000	212.908	0.000	213.485	12.209	76.504	33.218	0.000	0.000
61816	96.460	0.000	208.973	0.000	154.715	6.371	76.504	32.614	0.000	0.000
61817	84.742	0.000	185.644	0.000	113.221	2.913	76.504	30.396	0.000	0.000
61818	55.756	0.000	106.856	0.000	104.948	2.222	76.504	24.734	0.000	0.000
61819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	233.371	17.998	76.504	33.218	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2226.845	129.732	918.051	336.780	0.000	0.000
AV	53.189	0.000	116.048	0.000	92.785	5.406	38.252	14.032	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE170 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
619 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
619 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
619 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
619 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
619 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
619 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
619 7	81.785	0.000	168.037	0.000	118.875	0.816	76.504	24.320	0.000	0.000
619 8	98.066	0.000	208.826	0.000	188.087	9.148	76.504	25.800	0.000	0.000
619 9	99.683	0.000	213.339	0.000	228.118	16.046	76.504	26.349	0.000	0.000
61910	99.683	0.000	208.758	0.000	243.402	19.870	76.504	26.634	0.000	0.000
61911	99.683	0.000	185.850	0.000	223.470	14.958	76.504	27.368	0.000	0.000
61912	99.683	0.000	184.930	0.000	231.372	17.696	76.504	25.957	0.000	0.000
61913	99.683	0.000	204.176	0.000	239.541	19.203	76.504	27.001	0.000	0.000
61914	99.683	0.000	212.419	0.000	228.220	15.981	76.504	30.806	0.000	0.000
61915	99.362	0.000	212.908	0.000	230.140	16.467	76.504	31.798	0.000	0.000
61916	96.460	0.000	208.973	0.000	220.386	13.622	76.504	33.625	0.000	0.000
61917	84.742	0.000	185.644	0.000	217.981	13.197	76.504	30.930	0.000	0.000
61918	55.756	0.000	106.856	0.000	179.717	8.689	76.504	25.937	0.000	0.000
61919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
61924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	243.402	19.870	76.504	33.625	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2549.310	165.693	918.051	336.526	0.000	0.000
AV	53.189	0.000	116.048	0.000	106.221	6.904	38.252	14.022	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE171 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
620 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
620 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
620 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
620 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
620 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
620 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
620 7	5.538	0.000	31.745	0.000	115.155	0.506	76.504	23.949	0.000	0.000
620 8	5.538	0.000	31.745	0.000	71.297	0.000	76.504	23.949	0.000	0.000
620 9	5.538	0.000	31.745	0.000	139.940	5.545	76.504	23.949	0.000	0.000
62010	5.538	0.000	31.745	0.000	183.378	9.291	76.504	23.949	0.000	0.000
62011	5.538	0.000	31.745	0.000	216.776	15.186	76.504	23.949	0.000	0.000
62012	5.538	0.000	31.745	0.000	217.209	15.154	76.504	23.949	0.000	0.000
62013	5.538	0.000	31.745	0.000	217.066	15.181	76.504	23.949	0.000	0.000
62014	5.538	0.000	31.745	0.000	210.552	12.817	76.504	23.949	0.000	0.000
62015	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62016	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62017	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62018	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62019	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62020	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62021	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62022	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62023	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62024	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 20)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	217.209	15.186	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1371.374	73.680	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	57.141	3.070	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE173 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
622 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
622 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
622 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
622 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
622 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
622 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
622 7	81.785	0.000	168.037	0.000	182.472	6.534	76.504	24.290	0.000	0.000
622 8	98.066	0.000	208.826	0.000	218.038	14.061	76.504	27.071	0.000	0.000
622 9	99.683	0.000	213.339	0.000	215.581	13.327	76.504	25.887	0.000	0.000
62210	99.683	0.000	208.758	0.000	238.662	19.150	76.504	26.536	0.000	0.000
62211	99.683	0.000	185.850	0.000	237.687	18.758	76.504	26.494	0.000	0.000
62212	99.683	0.000	184.930	0.000	240.699	19.411	76.504	25.859	0.000	0.000
62213	99.683	0.000	204.176	0.000	244.997	20.182	76.504	27.372	0.000	0.000
62214	99.683	0.000	212.419	0.000	249.301	20.932	76.504	29.270	0.000	0.000
62215	99.362	0.000	212.908	0.000	247.950	20.667	76.504	31.750	0.000	0.000
62216	96.460	0.000	208.973	0.000	232.013	16.712	76.504	34.327	0.000	0.000
62217	84.742	0.000	185.644	0.000	228.741	16.174	76.504	30.765	0.000	0.000
62218	55.756	0.000	106.856	0.000	209.210	11.883	76.504	25.539	0.000	0.000
62219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	249.301	20.932	76.504	34.327	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2745.351	197.791	918.051	335.162	0.000	0.000
AV	53.189	0.000	116.048	0.000	114.390	8.241	38.252	13.965	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE174 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
623 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
623 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
623 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
623 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
623 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
623 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
623 7	81.785	0.000	168.037	0.000	160.716	4.963	76.504	24.266	0.000	0.000
623 8	98.066	0.000	208.826	0.000	171.225	8.623	76.504	26.413	0.000	0.000
623 9	99.683	0.000	213.339	0.000	204.165	11.010	76.504	26.460	0.000	0.000
62310	99.683	0.000	208.758	0.000	260.193	24.939	76.504	25.597	0.000	0.000
62311	99.683	0.000	185.850	0.000	275.207	28.360	76.504	24.740	0.000	0.000
62312	99.683	0.000	184.930	0.000	245.469	20.797	76.504	26.544	0.000	0.000
62313	99.683	0.000	204.176	0.000	254.514	23.083	76.504	26.539	0.000	0.000
62314	99.683	0.000	212.419	0.000	259.695	23.840	76.504	28.430	0.000	0.000
62315	99.362	0.000	212.908	0.000	272.115	26.609	76.504	30.036	0.000	0.000
62316	96.460	0.000	208.973	0.000	273.506	26.775	76.504	30.424	0.000	0.000
62317	84.742	0.000	185.644	0.000	252.751	22.576	76.504	30.211	0.000	0.000
62318	55.756	0.000	106.856	0.000	218.747	14.513	76.504	25.637	0.000	0.000
62319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	275.207	28.360	76.504	30.424	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2848.303	236.090	918.051	325.300	0.000	0.000
AV	53.189	0.000	116.048	0.000	118.679	9.837	38.252	13.554	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE175 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
624 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
624 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
624 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
624 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
624 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
624 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
624 7	81.785	0.000	168.037	0.000	124.166	1.912	76.504	24.735	0.000	0.000
624 8	98.066	0.000	208.826	0.000	174.598	8.937	76.504	26.999	0.000	0.000
624 9	99.683	0.000	213.339	0.000	228.956	17.204	76.504	26.787	0.000	0.000
62410	99.683	0.000	208.758	0.000	230.965	17.437	76.504	28.284	0.000	0.000
62411	99.683	0.000	185.850	0.000	240.019	19.970	76.504	26.720	0.000	0.000
62412	99.683	0.000	184.930	0.000	243.831	20.642	76.504	25.980	0.000	0.000
62413	99.683	0.000	204.176	0.000	247.294	21.276	76.504	27.430	0.000	0.000
62414	99.683	0.000	212.419	0.000	251.698	22.495	76.504	29.356	0.000	0.000
62415	99.362	0.000	212.908	0.000	254.790	23.020	76.504	30.955	0.000	0.000
62416	96.460	0.000	208.973	0.000	254.589	22.971	76.504	30.901	0.000	0.000
62417	84.742	0.000	185.644	0.000	236.833	18.584	76.504	28.542	0.000	0.000
62418	55.756	0.000	106.856	0.000	217.754	14.368	76.504	24.935	0.000	0.000
62419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	254.790	23.020	76.504	30.955	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2705.495	208.815	918.051	331.626	0.000	0.000
AV	53.189	0.000	116.048	0.000	112.729	8.701	38.252	13.818	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE176 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
625 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
625 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
625 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
625 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
625 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
625 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
625 7	81.785	0.000	168.037	0.000	121.568	1.468	76.504	24.487	0.000	0.000
625 8	98.066	0.000	208.826	0.000	160.498	7.127	76.504	26.530	0.000	0.000
625 9	99.683	0.000	213.339	0.000	213.756	13.073	76.504	28.399	0.000	0.000
62510	99.683	0.000	208.758	0.000	231.026	17.568	76.504	27.902	0.000	0.000
62511	99.683	0.000	185.850	0.000	233.477	17.991	76.504	26.474	0.000	0.000
62512	99.683	0.000	184.930	0.000	241.939	20.320	76.504	25.774	0.000	0.000
62513	99.683	0.000	204.176	0.000	246.850	21.193	76.504	27.185	0.000	0.000
62514	99.683	0.000	212.419	0.000	254.647	23.021	76.504	28.362	0.000	0.000
62515	99.362	0.000	212.908	0.000	247.464	20.565	76.504	31.044	0.000	0.000
62516	96.460	0.000	208.973	0.000	241.327	19.485	76.504	31.539	0.000	0.000
62517	84.742	0.000	185.644	0.000	216.160	13.435	76.504	31.865	0.000	0.000
62518	55.756	0.000	106.856	0.000	142.540	6.027	76.504	24.544	0.000	0.000
62519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 25)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	254.647	23.021	76.504	31.865	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2551.253	181.272	918.051	334.104	0.000	0.000
AV	53.189	0.000	116.048	0.000	106.302	7.553	38.252	13.921	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE177 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
626 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
626 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
626 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
626 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
626 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
626 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
626 7	81.785	0.000	168.037	0.000	115.542	0.486	76.504	24.482	0.000	0.000
626 8	98.066	0.000	208.826	0.000	149.396	5.790	76.504	26.332	0.000	0.000
626 9	99.683	0.000	213.339	0.000	208.904	11.276	76.504	27.819	0.000	0.000
62610	99.683	0.000	208.758	0.000	225.665	15.579	76.504	27.793	0.000	0.000
62611	99.683	0.000	185.850	0.000	233.223	17.955	76.504	26.429	0.000	0.000
62612	99.683	0.000	184.930	0.000	240.298	19.339	76.504	25.428	0.000	0.000
62613	99.683	0.000	204.176	0.000	247.125	21.235	76.504	27.621	0.000	0.000
62614	99.683	0.000	212.419	0.000	239.832	19.192	76.504	30.305	0.000	0.000
62615	99.362	0.000	212.908	0.000	229.613	16.300	76.504	31.761	0.000	0.000
62616	96.460	0.000	208.973	0.000	230.339	16.494	76.504	31.985	0.000	0.000
62617	84.742	0.000	185.644	0.000	222.051	14.757	76.504	30.082	0.000	0.000
62618	55.756	0.000	106.856	0.000	98.860	2.326	76.504	24.238	0.000	0.000
62619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	247.125	21.235	76.504	31.985	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2440.850	160.728	918.051	334.275	0.000	0.000
AV	53.189	0.000	116.048	0.000	101.702	6.697	38.252	13.928	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE178 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
627 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
627 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
627 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
627 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
627 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
627 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
627 7	5.538	0.000	31.745	0.000	122.332	1.292	76.504	23.949	0.000	0.000
627 8	5.538	0.000	31.745	0.000	182.900	9.404	76.504	23.949	0.000	0.000
627 9	5.538	0.000	31.745	0.000	209.712	12.548	76.504	23.949	0.000	0.000
62710	5.538	0.000	31.745	0.000	196.411	10.521	76.504	23.949	0.000	0.000
62711	5.538	0.000	31.745	0.000	209.748	12.720	76.504	23.949	0.000	0.000
62712	5.538	0.000	31.745	0.000	210.020	12.702	76.504	23.949	0.000	0.000
62713	5.538	0.000	31.745	0.000	212.963	13.425	76.504	23.949	0.000	0.000
62714	5.538	0.000	31.745	0.000	209.905	12.659	76.504	23.949	0.000	0.000
62715	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62716	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62717	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62718	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62719	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62720	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62721	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62722	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62723	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62724	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 27)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	212.963	13.425	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1553.991	85.270	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	64.750	3.553	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE180 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
629 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
629 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
629 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
629 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
629 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
629 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
629 7	81.785	0.000	168.037	0.000	216.637	12.817	76.504	27.107	0.000	0.000
629 8	98.066	0.000	208.826	0.000	268.245	25.335	76.504	28.976	0.000	0.000
629 9	99.683	0.000	213.339	0.000	271.908	25.640	76.504	29.401	0.000	0.000
62910	99.683	0.000	208.758	0.000	264.660	23.403	76.504	29.707	0.000	0.000
62911	99.683	0.000	185.850	0.000	256.826	22.154	76.504	28.572	0.000	0.000
62912	99.683	0.000	184.930	0.000	249.305	19.850	76.504	27.199	0.000	0.000
62913	99.683	0.000	204.176	0.000	260.941	22.889	76.504	28.537	0.000	0.000
62914	99.683	0.000	212.419	0.000	266.301	23.668	76.504	29.117	0.000	0.000
62915	99.362	0.000	212.908	0.000	269.682	24.181	76.504	30.593	0.000	0.000
62916	96.460	0.000	208.973	0.000	261.320	22.188	76.504	30.861	0.000	0.000
62917	84.742	0.000	185.644	0.000	251.852	20.241	76.504	30.537	0.000	0.000
62918	55.756	0.000	106.856	0.000	231.739	16.090	76.504	24.929	0.000	0.000
62919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
62924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	271.908	25.640	76.504	30.861	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3069.415	258.455	918.051	345.535	0.000	0.000
AV	53.189	0.000	116.048	0.000	127.892	10.769	38.252	14.397	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE181 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
630 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
630 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
630 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
630 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
630 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
630 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
630 7	81.785	0.000	168.037	0.000	209.494	8.087	76.504	26.967	0.000	0.000
630 8	98.066	0.000	208.826	0.000	251.263	20.449	76.504	28.119	0.000	0.000
630 9	99.683	0.000	213.339	0.000	255.526	21.184	76.504	28.168	0.000	0.000
63010	99.683	0.000	208.758	0.000	248.816	19.730	76.504	27.908	0.000	0.000
63011	99.683	0.000	185.850	0.000	246.487	20.410	76.504	26.230	0.000	0.000
63012	99.683	0.000	184.930	0.000	246.770	21.156	76.504	26.037	0.000	0.000
63013	99.683	0.000	204.176	0.000	251.204	22.417	76.504	27.078	0.000	0.000
63014	99.683	0.000	212.419	0.000	274.539	26.252	76.504	29.098	0.000	0.000
63015	99.362	0.000	212.908	0.000	256.766	22.055	76.504	29.629	0.000	0.000
63016	96.460	0.000	208.973	0.000	270.295	24.361	76.504	31.076	0.000	0.000
63017	84.742	0.000	185.644	0.000	261.597	22.872	76.504	30.500	0.000	0.000
63018	55.756	0.000	106.856	0.000	240.843	19.317	76.504	25.850	0.000	0.000
63019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
63020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
63021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
63022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
63023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
63024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUN 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	274.539	26.252	76.504	31.076	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3013.599	248.289	918.051	336.661	0.000	0.000
AV	53.189	0.000	116.048	0.000	125.567	10.345	38.252	14.028	0.000	0.000
MONTHLY SUMMARY (JUN)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	275.207	28.360	76.504	36.549	0.000	0.000
SM	28774.879	0.000	65235.250	0.000	54498.543	3214.367	22645.262	8163.098	0.000	0.000
AV	39.965	0.000	90.605	0.000	75.692	4.464	31.452	11.338	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE182 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 1 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 1 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 1 7	81.785	0.000	168.037	0.000	121.216	0.913	76.504	26.390	0.000	0.000
7 1 8	98.066	0.000	208.826	0.000	79.160	0.090	76.504	34.846	0.000	0.000
7 1 9	99.683	0.000	213.339	0.000	156.360	5.864	76.504	33.280	0.000	0.000
7 110	99.683	0.000	208.758	0.000	212.616	11.629	76.504	30.357	0.000	0.000
7 111	99.683	0.000	185.850	0.000	212.412	11.499	76.504	30.384	0.000	0.000
7 112	99.683	0.000	184.930	0.000	212.211	11.534	76.504	30.049	0.000	0.000
7 113	99.683	0.000	204.176	0.000	213.135	11.732	76.504	31.032	0.000	0.000
7 114	99.683	0.000	212.419	0.000	220.519	13.730	76.504	33.165	0.000	0.000
7 115	99.362	0.000	212.908	0.000	221.973	13.977	76.504	34.404	0.000	0.000
7 116	96.460	0.000	208.973	0.000	221.838	13.957	76.504	34.506	0.000	0.000
7 117	84.742	0.000	185.644	0.000	190.726	9.033	76.504	33.360	0.000	0.000
7 118	55.756	0.000	106.856	0.000	101.116	2.066	76.504	25.125	0.000	0.000
7 119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	221.973	13.977	76.504	34.846	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2163.282	106.024	918.051	376.897	0.000	0.000
AV	53.189	0.000	116.048	0.000	90.137	4.418	38.252	15.704	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE183 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 2 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 2 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 2 7	81.785	0.000	168.037	0.000	113.597	0.000	76.504	25.001	0.000	0.000
7 2 8	98.066	0.000	208.826	0.000	74.806	0.000	76.504	28.126	0.000	0.000
7 2 9	99.683	0.000	213.339	0.000	140.990	4.735	76.504	27.123	0.000	0.000
7 210	99.683	0.000	208.758	0.000	195.906	8.441	76.504	28.858	0.000	0.000
7 211	99.683	0.000	185.850	0.000	208.904	10.821	76.504	27.219	0.000	0.000
7 212	99.683	0.000	184.930	0.000	209.537	10.950	76.504	27.606	0.000	0.000
7 213	99.683	0.000	204.176	0.000	216.052	12.819	76.504	28.898	0.000	0.000
7 214	99.683	0.000	212.419	0.000	218.867	13.368	76.504	31.119	0.000	0.000
7 215	99.362	0.000	212.908	0.000	225.364	14.980	76.504	31.868	0.000	0.000
7 216	96.460	0.000	208.973	0.000	225.660	14.987	76.504	32.578	0.000	0.000
7 217	84.742	0.000	185.644	0.000	217.647	13.064	76.504	30.895	0.000	0.000
7 218	55.756	0.000	106.856	0.000	209.185	11.287	76.504	24.623	0.000	0.000
7 219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 224	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 2)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	225.660	14.987	76.504	32.578	0.000	0.000
SM	1272.657	0.000	2762.933	0.000	2256.515	115.452	918.051	343.913	0.000	0.000
AV	53.027	0.000	115.122	0.000	94.021	4.811	38.252	14.330	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE185 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 4 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 4 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 4 7	5.538	0.000	31.745	0.000	115.791	0.899	76.504	23.949	0.000	0.000
7 4 8	5.538	0.000	31.745	0.000	73.422	0.000	76.504	23.949	0.000	0.000
7 4 9	5.538	0.000	31.745	0.000	145.384	5.970	76.504	23.949	0.000	0.000
7 410	5.538	0.000	31.745	0.000	144.111	5.732	76.504	23.949	0.000	0.000
7 411	5.538	0.000	31.745	0.000	145.840	6.076	76.504	23.949	0.000	0.000
7 412	5.538	0.000	31.745	0.000	172.689	8.697	76.504	23.949	0.000	0.000
7 413	5.538	0.000	31.745	0.000	170.676	8.561	76.504	23.949	0.000	0.000
7 414	5.538	0.000	31.745	0.000	188.423	9.922	76.504	23.949	0.000	0.000
7 415	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 424	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 4)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	188.423	9.922	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1156.336	45.857	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	48.181	1.911	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE187 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 6 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 6 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 6 7	81.785	0.000	168.037	0.000	120.266	1.168	76.504	24.782	0.000	0.000
7 6 8	98.066	0.000	208.826	0.000	122.175	3.713	76.504	28.455	0.000	0.000
7 6 9	99.683	0.000	213.339	0.000	118.781	3.427	76.504	28.280	0.000	0.000
7 610	99.683	0.000	208.758	0.000	166.254	7.589	76.504	28.158	0.000	0.000
7 611	99.683	0.000	185.850	0.000	211.463	12.622	76.504	26.315	0.000	0.000
7 612	99.683	0.000	184.930	0.000	213.111	12.863	76.504	27.509	0.000	0.000
7 613	99.683	0.000	204.176	0.000	231.358	17.710	76.504	27.932	0.000	0.000
7 614	99.683	0.000	212.419	0.000	234.126	18.114	76.504	29.974	0.000	0.000
7 615	99.362	0.000	212.908	0.000	228.350	16.057	76.504	30.218	0.000	0.000
7 616	96.460	0.000	208.973	0.000	227.822	16.884	76.504	31.267	0.000	0.000
7 617	84.742	0.000	185.644	0.000	220.691	14.510	76.504	28.846	0.000	0.000
7 618	55.756	0.000	106.856	0.000	207.380	11.520	76.504	24.587	0.000	0.000
7 619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	234.126	18.114	76.504	31.267	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2301.778	136.177	918.051	336.323	0.000	0.000
AV	53.189	0.000	116.048	0.000	95.907	5.674	38.252	14.013	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE188 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 7	81.785	0.000	168.037	0.000	158.243	4.914	76.504	24.467	0.000	0.000
7 7 8	98.066	0.000	208.826	0.000	203.959	10.952	76.504	26.123	0.000	0.000
7 7 9	99.683	0.000	213.339	0.000	226.008	16.577	76.504	25.427	0.000	0.000
7 7 10	99.683	0.000	208.758	0.000	228.284	16.940	76.504	26.516	0.000	0.000
7 7 11	99.683	0.000	185.850	0.000	227.125	16.739	76.504	26.055	0.000	0.000
7 7 12	99.683	0.000	184.930	0.000	242.995	20.570	76.504	25.723	0.000	0.000
7 7 13	99.683	0.000	204.176	0.000	267.395	25.919	76.504	26.423	0.000	0.000
7 7 14	99.683	0.000	212.419	0.000	273.178	26.720	76.504	28.194	0.000	0.000
7 7 15	99.362	0.000	212.908	0.000	263.297	24.388	76.504	29.829	0.000	0.000
7 7 16	96.460	0.000	208.973	0.000	250.806	21.155	76.504	30.095	0.000	0.000
7 7 17	84.742	0.000	185.644	0.000	246.660	21.132	76.504	27.642	0.000	0.000
7 7 18	55.756	0.000	106.856	0.000	220.308	14.860	76.504	24.173	0.000	0.000
7 7 19	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 20	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 21	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 22	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 23	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 7 24	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	273.178	26.720	76.504	30.095	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2808.258	220.867	918.051	320.667	0.000	0.000
AV	53.189	0.000	116.048	0.000	117.011	9.203	38.252	13.361	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE189 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 8 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 8 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 8 7	81.785	0.000	168.037	0.000	213.915	11.642	76.504	24.383	0.000	0.000
7 8 8	98.066	0.000	208.826	0.000	221.838	15.709	76.504	26.497	0.000	0.000
7 8 9	99.683	0.000	213.339	0.000	237.727	19.533	76.504	25.951	0.000	0.000
7 810	99.683	0.000	208.758	0.000	245.135	20.883	76.504	26.589	0.000	0.000
7 811	99.683	0.000	185.850	0.000	242.835	20.428	76.504	26.042	0.000	0.000
7 812	99.683	0.000	184.930	0.000	249.321	22.103	76.504	26.309	0.000	0.000
7 813	99.683	0.000	204.176	0.000	250.963	22.343	76.504	29.251	0.000	0.000
7 814	99.683	0.000	212.419	0.000	272.865	26.777	76.504	28.180	0.000	0.000
7 815	99.362	0.000	212.908	0.000	269.502	25.358	76.504	29.997	0.000	0.000
7 816	96.460	0.000	208.973	0.000	268.746	25.284	76.504	30.027	0.000	0.000
7 817	84.742	0.000	185.644	0.000	255.294	21.885	76.504	27.956	0.000	0.000
7 818	55.756	0.000	106.856	0.000	231.929	17.602	76.504	24.729	0.000	0.000
7 819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	272.865	26.777	76.504	30.027	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2960.070	249.544	918.051	325.910	0.000	0.000
AV	53.189	0.000	116.048	0.000	123.336	10.398	38.252	13.580	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE190 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
7 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 9 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 9 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 9 7	81.785	0.000	168.037	0.000	223.801	14.437	76.504	26.526	0.000	0.000
7 9 8	98.066	0.000	208.826	0.000	276.104	28.028	76.504	26.424	0.000	0.000
7 9 9	99.683	0.000	213.339	0.000	262.375	27.494	76.504	25.760	0.000	0.000
7 910	99.683	0.000	208.758	0.000	277.560	28.109	76.504	28.417	0.000	0.000
7 911	99.683	0.000	185.850	0.000	274.624	26.914	76.504	26.133	0.000	0.000
7 912	99.683	0.000	184.930	0.000	270.711	26.358	76.504	26.197	0.000	0.000
7 913	99.683	0.000	204.176	0.000	275.731	27.155	76.504	26.538	0.000	0.000
7 914	99.683	0.000	212.419	0.000	257.131	24.066	76.504	27.633	0.000	0.000
7 915	99.362	0.000	212.908	0.000	258.876	24.521	76.504	29.007	0.000	0.000
7 916	96.460	0.000	208.973	0.000	272.562	25.940	76.504	29.614	0.000	0.000
7 917	84.742	0.000	185.644	0.000	260.548	22.712	76.504	28.043	0.000	0.000
7 918	55.756	0.000	106.856	0.000	237.874	18.757	76.504	25.035	0.000	0.000
7 919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7 924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	277.560	28.109	76.504	29.614	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3147.897	294.493	918.051	325.327	0.000	0.000
AV	53.189	0.000	116.048	0.000	131.162	12.271	38.252	13.555	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE191 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
710 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
710 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
710 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
710 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
710 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
710 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
710 7	81.785	0.000	168.037	0.000	219.484	12.053	76.504	26.155	0.000	0.000
710 8	98.066	0.000	208.826	0.000	247.475	20.830	76.504	26.486	0.000	0.000
710 9	99.683	0.000	213.339	0.000	260.591	27.350	76.504	27.320	0.000	0.000
71010	99.683	0.000	208.758	0.000	266.501	29.399	76.504	26.636	0.000	0.000
71011	99.683	0.000	185.850	0.000	254.780	25.045	76.504	26.068	0.000	0.000
71012	99.683	0.000	184.930	0.000	250.057	22.966	76.504	25.669	0.000	0.000
71013	99.683	0.000	204.176	0.000	254.331	23.728	76.504	26.529	0.000	0.000
71014	99.683	0.000	212.419	0.000	258.622	24.440	76.504	27.790	0.000	0.000
71015	99.362	0.000	212.908	0.000	260.150	23.934	76.504	27.269	0.000	0.000
71016	96.460	0.000	208.973	0.000	260.720	24.004	76.504	27.636	0.000	0.000
71017	84.742	0.000	185.644	0.000	258.063	24.293	76.504	27.285	0.000	0.000
71018	55.756	0.000	106.856	0.000	239.931	19.843	76.504	24.420	0.000	0.000
71019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	266.501	29.399	76.504	27.790	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3030.706	277.884	918.051	319.261	0.000	0.000
AV	53.189	0.000	116.048	0.000	126.279	11.579	38.252	13.303	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE192 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
711 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
711 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
711 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
711 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
711 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
711 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
711 7	5.538	0.000	31.745	0.000	215.275	12.311	76.504	23.949	0.000	0.000
711 8	5.538	0.000	31.745	0.000	245.547	23.619	76.504	23.949	0.000	0.000
711 9	5.538	0.000	31.745	0.000	229.188	20.405	76.504	23.949	0.000	0.000
71110	5.538	0.000	31.745	0.000	224.990	18.693	76.504	23.949	0.000	0.000
71111	5.538	0.000	31.745	0.000	224.343	18.494	76.504	23.949	0.000	0.000
71112	5.538	0.000	31.745	0.000	222.167	17.969	76.504	23.949	0.000	0.000
71113	5.538	0.000	31.745	0.000	221.896	17.929	76.504	23.949	0.000	0.000
71114	5.538	0.000	31.745	0.000	234.048	19.986	76.504	23.949	0.000	0.000
71115	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71124	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 11)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	245.547	23.619	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1817.453	149.408	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	75.727	6.225	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE194 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
713 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
713 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
713 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
713 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
713 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
713 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
713 7	81.785	0.000	168.037	0.000	202.959	7.917	76.504	27.785	0.000	0.000
713 8	98.066	0.000	208.826	0.000	229.437	16.550	76.504	34.980	0.000	0.000
713 9	99.683	0.000	213.339	0.000	250.638	21.150	76.504	32.385	0.000	0.000
71310	99.683	0.000	208.758	0.000	251.517	21.254	76.504	34.000	0.000	0.000
71311	99.683	0.000	185.850	0.000	261.434	24.150	76.504	29.242	0.000	0.000
71312	99.683	0.000	184.930	0.000	260.725	23.981	76.504	28.763	0.000	0.000
71313	99.683	0.000	204.176	0.000	260.779	24.017	76.504	31.015	0.000	0.000
71314	99.683	0.000	212.419	0.000	256.387	22.106	76.504	33.009	0.000	0.000
71315	99.362	0.000	212.908	0.000	246.631	19.382	76.504	35.789	0.000	0.000
71316	96.460	0.000	208.973	0.000	246.373	19.378	76.504	35.658	0.000	0.000
71317	84.742	0.000	185.644	0.000	227.772	15.320	76.504	35.801	0.000	0.000
71318	55.756	0.000	106.856	0.000	214.312	12.382	76.504	28.034	0.000	0.000
71319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	261.434	24.150	76.504	35.801	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2908.964	227.587	918.051	386.461	0.000	0.000
AV	53.189	0.000	116.048	0.000	121.207	9.483	38.252	16.103	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE195 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
714 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
714 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
714 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
714 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
714 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
714 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
714 7	81.785	0.000	168.037	0.000	156.540	3.896	76.504	25.565	0.000	0.000
714 8	98.066	0.000	208.826	0.000	175.801	7.315	76.504	29.131	0.000	0.000
714 9	99.683	0.000	213.339	0.000	220.026	13.691	76.504	27.877	0.000	0.000
71410	99.683	0.000	208.758	0.000	230.775	15.981	76.504	28.929	0.000	0.000
71411	99.683	0.000	185.850	0.000	236.971	17.696	76.504	27.176	0.000	0.000
71412	99.683	0.000	184.930	0.000	242.951	18.789	76.504	26.160	0.000	0.000
71413	99.683	0.000	204.176	0.000	251.922	21.379	76.504	28.245	0.000	0.000
71414	99.683	0.000	212.419	0.000	256.585	22.143	76.504	30.070	0.000	0.000
71415	99.362	0.000	212.908	0.000	247.754	19.558	76.504	32.847	0.000	0.000
71416	96.460	0.000	208.973	0.000	244.357	19.015	76.504	34.158	0.000	0.000
71417	84.742	0.000	185.644	0.000	241.045	18.424	76.504	31.487	0.000	0.000
71418	55.756	0.000	106.856	0.000	216.692	12.789	76.504	26.198	0.000	0.000
71419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	256.585	22.143	76.504	34.158	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2721.418	190.676	918.051	347.843	0.000	0.000
AV	53.189	0.000	116.048	0.000	113.392	7.945	38.252	14.493	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE196 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
715 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
715 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
715 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
715 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
715 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
715 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
715 7	81.785	0.000	168.037	0.000	172.761	4.818	76.504	24.943	0.000	0.000
715 8	98.066	0.000	208.826	0.000	171.279	6.916	76.504	27.968	0.000	0.000
715 9	99.683	0.000	213.339	0.000	167.760	6.702	76.504	28.018	0.000	0.000
71510	99.683	0.000	208.758	0.000	209.009	10.962	76.504	27.172	0.000	0.000
71511	99.683	0.000	185.850	0.000	221.227	13.861	76.504	26.100	0.000	0.000
71512	99.683	0.000	184.930	0.000	245.368	20.307	76.504	24.963	0.000	0.000
71513	99.683	0.000	204.176	0.000	251.473	21.264	76.504	26.437	0.000	0.000
71514	99.683	0.000	212.419	0.000	255.717	22.006	76.504	28.222	0.000	0.000
71515	99.362	0.000	212.908	0.000	259.104	22.553	76.504	29.619	0.000	0.000
71516	96.460	0.000	208.973	0.000	254.301	21.732	76.504	31.969	0.000	0.000
71517	84.742	0.000	185.644	0.000	246.622	20.422	76.504	30.958	0.000	0.000
71518	55.756	0.000	106.856	0.000	229.812	17.205	76.504	25.555	0.000	0.000
71519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	259.104	22.553	76.504	31.969	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2684.431	188.748	918.051	331.924	0.000	0.000
AV	53.189	0.000	116.048	0.000	111.851	7.864	38.252	13.830	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE197 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
716 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
716 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
716 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
716 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
716 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
716 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
716 7	81.785	0.000	168.037	0.000	154.300	3.900	76.504	25.055	0.000	0.000
716 8	98.066	0.000	208.826	0.000	158.633	6.536	76.504	29.123	0.000	0.000
716 9	99.683	0.000	213.339	0.000	222.113	14.988	76.504	26.046	0.000	0.000
71610	99.683	0.000	208.758	0.000	231.751	16.702	76.504	28.642	0.000	0.000
71611	99.683	0.000	185.850	0.000	232.903	16.935	76.504	26.970	0.000	0.000
71612	99.683	0.000	184.930	0.000	241.395	19.544	76.504	26.262	0.000	0.000
71613	99.683	0.000	204.176	0.000	245.361	20.232	76.504	27.604	0.000	0.000
71614	99.683	0.000	212.419	0.000	249.083	20.892	76.504	29.390	0.000	0.000
71615	99.362	0.000	212.908	0.000	260.294	23.964	76.504	31.059	0.000	0.000
71616	96.460	0.000	208.973	0.000	232.833	17.722	76.504	36.544	0.000	0.000
71617	84.742	0.000	185.644	0.000	230.131	16.498	76.504	31.205	0.000	0.000
71618	55.756	0.000	106.856	0.000	220.119	14.879	76.504	26.060	0.000	0.000
71619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	260.294	23.964	76.504	36.544	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2678.916	192.792	918.051	343.960	0.000	0.000
AV	53.189	0.000	116.048	0.000	111.621	8.033	38.252	14.332	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE198 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
717 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
717 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
717 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
717 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
717 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
717 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
717 7	81.785	0.000	168.037	0.000	159.983	4.688	76.504	27.112	0.000	0.000
717 8	98.066	0.000	208.826	0.000	210.804	12.661	76.504	32.512	0.000	0.000
717 9	99.683	0.000	213.339	0.000	251.845	22.621	76.504	28.416	0.000	0.000
71710	99.683	0.000	208.758	0.000	258.030	23.493	76.504	29.675	0.000	0.000
71711	99.683	0.000	185.850	0.000	252.923	22.653	76.504	27.801	0.000	0.000
71712	99.683	0.000	184.930	0.000	251.523	22.453	76.504	27.214	0.000	0.000
71713	99.683	0.000	204.176	0.000	255.061	23.082	76.504	28.562	0.000	0.000
71714	99.683	0.000	212.419	0.000	259.199	23.768	76.504	30.427	0.000	0.000
71715	99.362	0.000	212.908	0.000	262.454	24.294	76.504	32.093	0.000	0.000
71716	96.460	0.000	208.973	0.000	263.938	24.526	76.504	32.642	0.000	0.000
71717	84.742	0.000	185.644	0.000	255.100	23.017	76.504	31.532	0.000	0.000
71718	55.756	0.000	106.856	0.000	212.210	12.946	76.504	25.781	0.000	0.000
71719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	263.938	24.526	76.504	32.642	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2893.070	240.201	918.051	353.767	0.000	0.000
AV	53.189	0.000	116.048	0.000	120.545	10.008	38.252	14.740	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE199 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
718 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
718 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
718 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
718 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
718 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
718 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
718 7	5.538	0.000	31.745	0.000	149.616	4.238	76.504	23.949	0.000	0.000
718 8	5.538	0.000	31.745	0.000	132.120	5.385	76.504	23.949	0.000	0.000
718 9	5.538	0.000	31.745	0.000	170.772	8.340	76.504	23.949	0.000	0.000
71810	5.538	0.000	31.745	0.000	201.585	11.366	76.504	23.949	0.000	0.000
71811	5.538	0.000	31.745	0.000	203.097	11.528	76.504	23.949	0.000	0.000
71812	5.538	0.000	31.745	0.000	208.374	12.365	76.504	23.949	0.000	0.000
71813	5.538	0.000	31.745	0.000	208.253	12.295	76.504	23.949	0.000	0.000
71814	5.538	0.000	31.745	0.000	200.987	11.415	76.504	23.949	0.000	0.000
71815	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71816	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71817	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71818	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71819	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71820	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71821	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71822	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71823	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
71824	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 18)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	208.374	12.365	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1474.804	76.932	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	61.450	3.206	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE201 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
720 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
720 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
720 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
720 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
720 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
720 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
720 7	81.785	0.000	168.037	0.000	211.480	11.061	76.504	26.191	0.000	0.000
720 8	98.066	0.000	208.826	0.000	235.687	19.234	76.504	31.352	0.000	0.000
720 9	99.683	0.000	213.339	0.000	253.093	21.587	76.504	28.439	0.000	0.000
72010	99.683	0.000	208.758	0.000	261.289	27.505	76.504	27.624	0.000	0.000
72011	99.683	0.000	185.850	0.000	256.810	26.237	76.504	26.616	0.000	0.000
72012	99.683	0.000	184.930	0.000	252.406	24.649	76.504	26.135	0.000	0.000
72013	99.683	0.000	204.176	0.000	256.821	25.462	76.504	27.164	0.000	0.000
72014	99.683	0.000	212.419	0.000	294.406	31.332	76.504	29.102	0.000	0.000
72015	99.362	0.000	212.908	0.000	308.597	34.540	76.504	31.040	0.000	0.000
72016	96.460	0.000	208.973	0.000	295.080	31.228	76.504	32.606	0.000	0.000
72017	84.742	0.000	185.644	0.000	275.444	27.048	76.504	31.452	0.000	0.000
72018	55.756	0.000	106.856	0.000	243.634	20.494	76.504	26.311	0.000	0.000
72019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	308.597	34.540	76.504	32.606	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3144.747	300.377	918.051	344.032	0.000	0.000
AV	53.189	0.000	116.048	0.000	131.031	12.516	38.252	14.335	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE202 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
721 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
721 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
721 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
721 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
721 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
721 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
721 7	81.785	0.000	168.037	0.000	207.200	9.680	76.504	25.763	0.000	0.000
721 8	98.066	0.000	208.826	0.000	222.380	15.991	76.504	31.082	0.000	0.000
721 9	99.683	0.000	213.339	0.000	260.800	24.897	76.504	29.196	0.000	0.000
72110	99.683	0.000	208.758	0.000	272.276	26.577	76.504	29.556	0.000	0.000
72111	99.683	0.000	185.850	0.000	279.553	29.086	76.504	27.455	0.000	0.000
72112	99.683	0.000	184.930	0.000	279.439	29.067	76.504	27.255	0.000	0.000
72113	99.683	0.000	204.176	0.000	271.451	26.471	76.504	29.591	0.000	0.000
72114	99.683	0.000	212.419	0.000	265.423	24.772	76.504	30.846	0.000	0.000
72115	99.362	0.000	212.908	0.000	280.426	28.434	76.504	31.021	0.000	0.000
72116	96.460	0.000	208.973	0.000	258.167	22.307	76.504	33.863	0.000	0.000
72117	84.742	0.000	185.644	0.000	241.976	18.582	76.504	32.416	0.000	0.000
72118	55.756	0.000	106.856	0.000	226.050	15.560	76.504	26.144	0.000	0.000
72119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	280.426	29.086	76.504	33.863	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3065.141	271.424	918.051	354.187	0.000	0.000
AV	53.189	0.000	116.048	0.000	127.714	11.309	38.252	14.758	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE203 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
722 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
722 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
722 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
722 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
722 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
722 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
722 7	81.785	0.000	168.037	0.000	199.107	8.045	76.504	25.723	0.000	0.000
722 8	98.066	0.000	208.826	0.000	230.002	17.606	76.504	30.757	0.000	0.000
722 9	99.683	0.000	213.339	0.000	256.719	23.368	76.504	28.649	0.000	0.000
72210	99.683	0.000	208.758	0.000	270.839	26.377	76.504	29.236	0.000	0.000
72211	99.683	0.000	185.850	0.000	267.095	25.760	76.504	27.863	0.000	0.000
72212	99.683	0.000	184.930	0.000	266.794	25.766	76.504	26.413	0.000	0.000
72213	99.683	0.000	204.176	0.000	260.126	23.899	76.504	28.477	0.000	0.000
72214	99.683	0.000	212.419	0.000	263.815	24.537	76.504	30.217	0.000	0.000
72215	99.362	0.000	212.908	0.000	267.262	25.058	76.504	31.702	0.000	0.000
72216	96.460	0.000	208.973	0.000	267.874	25.141	76.504	32.032	0.000	0.000
72217	84.742	0.000	185.644	0.000	255.555	23.079	76.504	31.868	0.000	0.000
72218	55.756	0.000	106.856	0.000	231.664	17.570	76.504	26.171	0.000	0.000
72219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	270.839	26.377	76.504	32.032	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3036.852	266.205	918.051	349.109	0.000	0.000
AV	53.189	0.000	116.048	0.000	126.535	11.092	38.252	14.546	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE204 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
723 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
723 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
723 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
723 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
723 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
723 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
723 7	81.785	0.000	168.037	0.000	217.626	12.360	76.504	25.894	0.000	0.000
723 8	98.066	0.000	208.826	0.000	246.666	21.349	76.504	29.239	0.000	0.000
723 9	99.683	0.000	213.339	0.000	264.773	25.409	76.504	29.089	0.000	0.000
72310	99.683	0.000	208.758	0.000	284.739	29.883	76.504	28.795	0.000	0.000
72311	99.683	0.000	185.850	0.000	283.762	29.670	76.504	27.222	0.000	0.000
72312	99.683	0.000	184.930	0.000	284.852	29.876	76.504	27.427	0.000	0.000
72313	99.683	0.000	204.176	0.000	262.318	27.626	76.504	27.444	0.000	0.000
72314	99.683	0.000	212.419	0.000	295.542	31.537	76.504	29.743	0.000	0.000
72315	99.362	0.000	212.908	0.000	301.281	32.040	76.504	30.519	0.000	0.000
72316	96.460	0.000	208.973	0.000	295.416	31.289	76.504	32.978	0.000	0.000
72317	84.742	0.000	185.644	0.000	262.650	24.230	76.504	31.823	0.000	0.000
72318	55.756	0.000	106.856	0.000	240.673	20.000	76.504	25.461	0.000	0.000
72319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	301.281	32.040	76.504	32.978	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3240.299	315.269	918.051	345.634	0.000	0.000
AV	53.189	0.000	116.048	0.000	135.012	13.136	38.252	14.401	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE205 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
724 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
724 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
724 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
724 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
724 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
724 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
724 7	81.785	0.000	168.037	0.000	227.545	15.332	76.504	24.774	0.000	0.000
724 8	98.066	0.000	208.826	0.000	254.581	23.181	76.504	28.133	0.000	0.000
724 9	99.683	0.000	213.339	0.000	288.177	30.358	76.504	27.219	0.000	0.000
72410	99.683	0.000	208.758	0.000	264.412	27.914	76.504	27.091	0.000	0.000
72411	99.683	0.000	185.850	0.000	258.309	27.097	76.504	26.392	0.000	0.000
72412	99.683	0.000	184.930	0.000	253.783	24.901	76.504	26.356	0.000	0.000
72413	99.683	0.000	204.176	0.000	258.573	25.770	76.504	27.691	0.000	0.000
72414	99.683	0.000	212.419	0.000	297.338	31.719	76.504	29.923	0.000	0.000
72415	99.362	0.000	212.908	0.000	300.981	31.986	76.504	30.394	0.000	0.000
72416	96.460	0.000	208.973	0.000	285.190	29.021	76.504	32.761	0.000	0.000
72417	84.742	0.000	185.644	0.000	249.903	22.034	76.504	28.985	0.000	0.000
72418	55.756	0.000	106.856	0.000	228.907	17.087	76.504	25.162	0.000	0.000
72419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	300.981	31.986	76.504	32.761	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3167.698	306.399	918.051	334.882	0.000	0.000
AV	53.189	0.000	116.048	0.000	131.987	12.767	38.252	13.953	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE206 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
725 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
725 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
725 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
725 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
725 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
725 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
725 7	5.538	0.000	31.745	0.000	209.561	9.943	76.504	23.949	0.000	0.000
725 8	5.538	0.000	31.745	0.000	209.647	12.796	76.504	23.949	0.000	0.000
725 9	5.538	0.000	31.745	0.000	215.636	14.840	76.504	23.949	0.000	0.000
72510	5.538	0.000	31.745	0.000	219.602	15.770	76.504	23.949	0.000	0.000
72511	5.538	0.000	31.745	0.000	221.884	16.265	76.504	23.949	0.000	0.000
72512	5.538	0.000	31.745	0.000	221.104	16.074	76.504	23.949	0.000	0.000
72513	5.538	0.000	31.745	0.000	222.507	16.409	76.504	23.949	0.000	0.000
72514	5.538	0.000	31.745	0.000	223.842	16.690	76.504	23.949	0.000	0.000
72515	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72516	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72517	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72518	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72519	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72520	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72521	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72522	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72523	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72524	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 25)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	223.842	16.690	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1743.783	118.786	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	72.658	4.949	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE208 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
727 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
727 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
727 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
727 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
727 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
727 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
727 7	81.785	0.000	168.037	0.000	222.819	13.418	76.504	28.860	0.000	0.000
727 8	98.066	0.000	208.826	0.000	244.089	20.164	76.504	36.767	0.000	0.000
727 9	99.683	0.000	213.339	0.000	242.050	19.538	76.504	36.733	0.000	0.000
72710	99.683	0.000	208.758	0.000	261.149	24.161	76.504	33.898	0.000	0.000
72711	99.683	0.000	185.850	0.000	273.029	26.714	76.504	30.100	0.000	0.000
72712	99.683	0.000	184.930	0.000	272.719	26.651	76.504	29.892	0.000	0.000
72713	99.683	0.000	204.176	0.000	276.748	27.294	76.504	31.906	0.000	0.000
72714	99.683	0.000	212.419	0.000	271.161	25.639	76.504	33.616	0.000	0.000
72715	99.362	0.000	212.908	0.000	270.578	25.568	76.504	36.871	0.000	0.000
72716	96.460	0.000	208.973	0.000	265.760	24.792	76.504	33.776	0.000	0.000
72717	84.742	0.000	185.644	0.000	249.008	21.486	76.504	28.536	0.000	0.000
72718	55.756	0.000	106.856	0.000	225.251	16.270	76.504	24.173	0.000	0.000
72719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	276.748	27.294	76.504	36.871	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3074.359	271.694	918.051	385.129	0.000	0.000
AV	53.189	0.000	116.048	0.000	128.098	11.321	38.252	16.047	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE209 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
728 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
728 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
728 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
728 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
728 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
728 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
728 7	81.785	0.000	168.037	0.000	228.353	15.338	76.504	24.682	0.000	0.000
728 8	98.066	0.000	208.826	0.000	255.451	25.373	76.504	27.743	0.000	0.000
728 9	99.683	0.000	213.339	0.000	254.168	23.585	76.504	27.080	0.000	0.000
72810	99.683	0.000	208.758	0.000	262.834	26.488	76.504	26.273	0.000	0.000
72811	99.683	0.000	185.850	0.000	252.659	23.351	76.504	25.356	0.000	0.000
72812	99.683	0.000	184.930	0.000	260.139	24.744	76.504	25.941	0.000	0.000
72813	99.683	0.000	204.176	0.000	266.002	25.645	76.504	27.554	0.000	0.000
72814	99.683	0.000	212.419	0.000	272.525	26.664	76.504	30.085	0.000	0.000
72815	99.362	0.000	212.908	0.000	262.977	24.335	76.504	29.696	0.000	0.000
72816	96.460	0.000	208.973	0.000	261.468	24.140	76.504	29.250	0.000	0.000
72817	84.742	0.000	185.644	0.000	256.294	23.245	76.504	27.220	0.000	0.000
72818	55.756	0.000	106.856	0.000	237.900	19.433	76.504	23.949	0.000	0.000
72819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	272.525	26.664	76.504	30.085	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3070.770	282.341	918.051	324.829	0.000	0.000
AV	53.189	0.000	116.048	0.000	127.949	11.764	38.252	13.535	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE210 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
729 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
729 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
729 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
729 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
729 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
729 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
729 7	81.785	0.000	168.037	0.000	239.571	18.818	76.504	26.020	0.000	0.000
729 8	98.066	0.000	208.826	0.000	255.345	23.260	76.504	28.675	0.000	0.000
729 9	99.683	0.000	213.339	0.000	289.928	30.628	76.504	27.698	0.000	0.000
72910	99.683	0.000	208.758	0.000	273.218	31.859	76.504	26.068	0.000	0.000
72911	99.683	0.000	185.850	0.000	263.256	28.885	76.504	25.381	0.000	0.000
72912	99.683	0.000	184.930	0.000	256.813	26.296	76.504	26.441	0.000	0.000
72913	99.683	0.000	204.176	0.000	259.566	25.963	76.504	27.139	0.000	0.000
72914	99.683	0.000	212.419	0.000	264.644	28.176	76.504	28.606	0.000	0.000
72915	99.362	0.000	212.908	0.000	264.277	26.717	76.504	29.727	0.000	0.000
72916	96.460	0.000	208.973	0.000	263.859	26.630	76.504	29.647	0.000	0.000
72917	84.742	0.000	185.644	0.000	284.805	29.955	76.504	27.676	0.000	0.000
72918	55.756	0.000	106.856	0.000	253.131	23.295	76.504	24.384	0.000	0.000
72919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
72924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	289.928	31.859	76.504	29.727	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3168.412	320.482	918.051	327.462	0.000	0.000
AV	53.189	0.000	116.048	0.000	132.017	13.353	38.252	13.644	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE211 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
730 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
730 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
730 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
730 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
730 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
730 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
730 7	81.785	0.000	168.037	0.000	229.130	15.525	76.504	26.393	0.000	0.000
730 8	98.066	0.000	208.826	0.000	249.294	22.277	76.504	30.787	0.000	0.000
730 9	99.683	0.000	213.339	0.000	263.220	25.158	76.504	31.147	0.000	0.000
73010	99.683	0.000	208.758	0.000	287.091	30.240	76.504	29.697	0.000	0.000
73011	99.683	0.000	185.850	0.000	282.986	29.537	76.504	28.467	0.000	0.000
73012	99.683	0.000	184.930	0.000	275.279	27.058	76.504	27.229	0.000	0.000
73013	99.683	0.000	204.176	0.000	279.351	28.253	76.504	28.555	0.000	0.000
73014	99.683	0.000	212.419	0.000	284.591	28.993	76.504	30.222	0.000	0.000
73015	99.362	0.000	212.908	0.000	288.440	29.524	76.504	31.657	0.000	0.000
73016	96.460	0.000	208.973	0.000	279.579	28.210	76.504	33.331	0.000	0.000
73017	84.742	0.000	185.644	0.000	260.796	23.969	76.504	30.992	0.000	0.000
73018	55.756	0.000	106.856	0.000	229.432	17.089	76.504	25.151	0.000	0.000
73019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	288.440	30.240	76.504	33.331	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3209.189	305.833	918.051	353.628	0.000	0.000
AV	53.189	0.000	116.048	0.000	133.716	12.743	38.252	14.735	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE212 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
731 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
731 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
731 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
731 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
731 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
731 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
731 7	81.785	0.000	168.037	0.000	221.322	12.878	76.504	24.843	0.000	0.000
731 8	98.066	0.000	208.826	0.000	232.527	18.012	76.504	29.032	0.000	0.000
731 9	99.683	0.000	213.339	0.000	249.650	22.136	76.504	26.398	0.000	0.000
73110	99.683	0.000	208.758	0.000	257.797	23.526	76.504	29.609	0.000	0.000
73111	99.683	0.000	185.850	0.000	268.919	26.107	76.504	26.886	0.000	0.000
73112	99.683	0.000	184.930	0.000	269.241	26.121	76.504	26.818	0.000	0.000
73113	99.683	0.000	204.176	0.000	275.887	27.178	76.504	27.613	0.000	0.000
73114	99.683	0.000	212.419	0.000	281.680	28.573	76.504	29.433	0.000	0.000
73115	99.362	0.000	212.908	0.000	286.198	29.214	76.504	30.815	0.000	0.000
73116	96.460	0.000	208.973	0.000	283.362	28.784	76.504	32.033	0.000	0.000
73117	84.742	0.000	185.644	0.000	271.114	26.381	76.504	29.644	0.000	0.000
73118	55.756	0.000	106.856	0.000	235.941	18.997	76.504	24.267	0.000	0.000
73119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
73124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (JUL 31)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	286.198	29.214	76.504	32.033	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3133.639	287.906	918.051	337.390	0.000	0.000
AV	53.189	0.000	116.048	0.000	130.568	11.996	38.252	14.058	0.000	0.000
MONTHLY SUMMARY (JUL)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	308.597	34.540	76.504	36.871	0.000	0.000
SM	28814.752	0.000	65463.816	0.000	70058.781	5759.358	22645.258	8334.893	0.000	0.000
AV	38.730	0.000	87.989	0.000	94.165	7.741	30.437	11.203	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE213 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 1 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 1 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 1 7	5.538	0.000	31.745	0.000	206.608	8.452	76.504	23.949	0.000	0.000
8 1 8	5.538	0.000	31.745	0.000	217.266	14.539	76.504	23.949	0.000	0.000
8 1 9	5.538	0.000	31.745	0.000	217.670	15.221	76.504	23.949	0.000	0.000
8 110	5.538	0.000	31.745	0.000	233.890	19.933	76.504	23.949	0.000	0.000
8 111	5.538	0.000	31.745	0.000	235.340	20.090	76.504	23.949	0.000	0.000
8 112	5.538	0.000	31.745	0.000	227.617	17.451	76.504	23.949	0.000	0.000
8 113	5.538	0.000	31.745	0.000	227.199	17.415	76.504	23.949	0.000	0.000
8 114	5.538	0.000	31.745	0.000	227.262	17.410	76.504	23.949	0.000	0.000
8 115	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 124	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 1)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	235.340	20.090	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1792.852	130.510	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	74.702	5.438	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE215 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 3 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 3 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 3 7	81.785	0.000	168.037	0.000	199.422	7.660	76.504	27.028	0.000	0.000
8 3 8	98.066	0.000	208.826	0.000	234.479	18.489	76.504	29.596	0.000	0.000
8 3 9	99.683	0.000	213.339	0.000	272.100	26.623	76.504	29.247	0.000	0.000
8 310	99.683	0.000	208.758	0.000	276.296	27.151	76.504	31.268	0.000	0.000
8 311	99.683	0.000	185.850	0.000	272.374	26.599	76.504	29.946	0.000	0.000
8 312	99.683	0.000	184.930	0.000	270.788	26.381	76.504	29.288	0.000	0.000
8 313	99.683	0.000	204.176	0.000	275.269	27.080	76.504	31.031	0.000	0.000
8 314	99.683	0.000	212.419	0.000	280.447	28.395	76.504	33.379	0.000	0.000
8 315	99.362	0.000	212.908	0.000	267.979	25.118	76.504	35.312	0.000	0.000
8 316	96.460	0.000	208.973	0.000	238.881	18.937	76.504	35.791	0.000	0.000
8 317	84.742	0.000	185.644	0.000	214.520	13.142	76.504	30.226	0.000	0.000
8 318	55.756	0.000	106.856	0.000	172.742	8.261	76.504	24.586	0.000	0.000
8 319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	280.447	28.395	76.504	35.791	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2975.297	253.836	918.051	366.699	0.000	0.000
AV	53.189	0.000	116.048	0.000	123.971	10.577	38.252	15.279	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE216 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 4 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 4 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 4 7	81.785	0.000	168.037	0.000	178.390	5.422	76.504	24.622	0.000	0.000
8 4 8	98.066	0.000	208.826	0.000	214.756	12.747	76.504	27.693	0.000	0.000
8 4 9	99.683	0.000	213.339	0.000	244.378	20.118	76.504	26.810	0.000	0.000
8 410	99.683	0.000	208.758	0.000	249.111	20.840	76.504	28.949	0.000	0.000
8 411	99.683	0.000	185.850	0.000	257.111	23.419	76.504	27.579	0.000	0.000
8 412	99.683	0.000	184.930	0.000	258.811	23.682	76.504	27.644	0.000	0.000
8 413	99.683	0.000	204.176	0.000	263.140	24.415	76.504	29.324	0.000	0.000
8 414	99.683	0.000	212.419	0.000	254.486	21.763	76.504	32.210	0.000	0.000
8 415	99.362	0.000	212.908	0.000	259.780	23.875	76.504	34.978	0.000	0.000
8 416	96.460	0.000	208.973	0.000	259.604	23.809	76.504	34.327	0.000	0.000
8 417	84.742	0.000	185.644	0.000	230.646	16.397	76.504	32.653	0.000	0.000
8 418	55.756	0.000	106.856	0.000	187.569	8.930	76.504	25.784	0.000	0.000
8 419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	263.140	24.415	76.504	34.978	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2857.782	225.417	918.051	352.574	0.000	0.000
AV	53.189	0.000	116.048	0.000	119.074	9.392	38.252	14.691	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE217 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 5 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 5 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 5 7	81.785	0.000	168.037	0.000	118.320	0.665	76.504	24.859	0.000	0.000
8 5 8	98.066	0.000	208.826	0.000	119.508	3.675	76.504	27.316	0.000	0.000
8 5 9	99.683	0.000	213.339	0.000	118.967	3.440	76.504	28.484	0.000	0.000
8 510	99.683	0.000	208.758	0.000	206.929	11.121	76.504	26.698	0.000	0.000
8 511	99.683	0.000	185.850	0.000	220.385	14.445	76.504	25.422	0.000	0.000
8 512	99.683	0.000	184.930	0.000	222.083	14.799	76.504	26.272	0.000	0.000
8 513	99.683	0.000	204.176	0.000	225.515	15.539	76.504	28.275	0.000	0.000
8 514	99.683	0.000	212.419	0.000	239.948	19.310	76.504	29.795	0.000	0.000
8 515	99.362	0.000	212.908	0.000	216.268	13.410	76.504	32.306	0.000	0.000
8 516	96.460	0.000	208.973	0.000	198.258	10.065	76.504	29.921	0.000	0.000
8 517	84.742	0.000	185.644	0.000	187.036	9.202	76.504	26.441	0.000	0.000
8 518	55.756	0.000	106.856	0.000	101.870	2.416	76.504	23.949	0.000	0.000
8 519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	239.948	19.310	76.504	32.306	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2175.086	118.088	918.051	329.737	0.000	0.000
AV	53.189	0.000	116.048	0.000	90.629	4.920	38.252	13.739	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE218 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 6 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 6 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 6 7	81.785	0.000	168.037	0.000	113.759	0.239	76.504	24.248	0.000	0.000
8 6 8	98.066	0.000	208.826	0.000	58.648	0.000	76.504	26.252	0.000	0.000
8 6 9	99.683	0.000	213.339	0.000	114.360	3.155	76.504	25.822	0.000	0.000
8 610	99.683	0.000	208.758	0.000	188.779	9.029	76.504	25.909	0.000	0.000
8 611	99.683	0.000	185.850	0.000	210.536	12.309	76.504	26.066	0.000	0.000
8 612	99.683	0.000	184.930	0.000	230.487	17.521	76.504	25.267	0.000	0.000
8 613	99.683	0.000	204.176	0.000	236.063	18.500	76.504	27.795	0.000	0.000
8 614	99.683	0.000	212.419	0.000	233.835	18.063	76.504	30.489	0.000	0.000
8 615	99.362	0.000	212.908	0.000	234.466	18.224	76.504	30.564	0.000	0.000
8 616	96.460	0.000	208.973	0.000	215.312	13.273	76.504	30.856	0.000	0.000
8 617	84.742	0.000	185.644	0.000	201.161	10.948	76.504	27.058	0.000	0.000
8 618	55.756	0.000	106.856	0.000	103.344	2.592	76.504	24.119	0.000	0.000
8 619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	236.063	18.500	76.504	30.856	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2140.750	123.853	918.051	324.446	0.000	0.000
AV	53.189	0.000	116.048	0.000	89.198	5.161	38.252	13.519	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE219 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 7	81.785	0.000	168.037	0.000	217.943	13.930	76.504	23.976	0.000	0.000
8 7 8	98.066	0.000	208.826	0.000	254.887	23.826	76.504	25.077	0.000	0.000
8 7 9	99.683	0.000	213.339	0.000	277.623	28.787	76.504	25.167	0.000	0.000
8 7 10	99.683	0.000	208.758	0.000	256.438	26.009	76.504	25.563	0.000	0.000
8 7 11	99.683	0.000	185.850	0.000	255.495	27.483	76.504	25.008	0.000	0.000
8 7 12	99.683	0.000	184.930	0.000	253.033	25.615	76.504	24.719	0.000	0.000
8 7 13	99.683	0.000	204.176	0.000	262.774	28.813	76.504	25.098	0.000	0.000
8 7 14	99.683	0.000	212.419	0.000	267.381	29.574	76.504	26.529	0.000	0.000
8 7 15	99.362	0.000	212.908	0.000	296.139	31.570	76.504	29.631	0.000	0.000
8 7 16	96.460	0.000	208.973	0.000	297.683	31.570	76.504	29.519	0.000	0.000
8 7 17	84.742	0.000	185.644	0.000	281.064	28.427	76.504	27.847	0.000	0.000
8 7 18	55.756	0.000	106.856	0.000	250.089	22.091	76.504	24.041	0.000	0.000
8 7 19	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 20	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 21	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 22	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 23	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 7 24	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	297.683	31.570	76.504	29.631	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3170.550	317.694	918.051	312.176	0.000	0.000
AV	53.189	0.000	116.048	0.000	132.106	13.237	38.252	13.007	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE220 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
8 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 8 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 8 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 8 7	5.538	0.000	31.745	0.000	235.454	19.834	76.504	23.949	0.000	0.000
8 8 8	5.538	0.000	31.745	0.000	232.757	24.076	76.504	23.949	0.000	0.000
8 8 9	5.538	0.000	31.745	0.000	237.745	26.678	76.504	23.949	0.000	0.000
8 810	5.538	0.000	31.745	0.000	241.270	29.021	76.504	23.949	0.000	0.000
8 811	5.538	0.000	31.745	0.000	241.272	29.043	76.504	23.949	0.000	0.000
8 812	5.538	0.000	31.745	0.000	241.253	29.050	76.504	23.949	0.000	0.000
8 813	5.538	0.000	31.745	0.000	238.093	26.808	76.504	23.949	0.000	0.000
8 814	5.538	0.000	31.745	0.000	238.119	26.803	76.504	23.949	0.000	0.000
8 815	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 816	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 817	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 818	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 819	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 820	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 821	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 822	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 823	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8 824	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 8)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	241.272	29.050	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1905.961	211.313	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	79.415	8.805	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE222 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
810 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
810 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
810 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
810 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
810 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
810 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
810 7	81.785	0.000	168.037	0.000	128.365	2.688	76.504	27.987	0.000	0.000
810 8	98.066	0.000	208.826	0.000	223.330	16.901	76.504	33.176	0.000	0.000
810 9	99.683	0.000	213.339	0.000	252.612	22.558	76.504	32.804	0.000	0.000
81010	99.683	0.000	208.758	0.000	268.103	25.958	76.504	33.860	0.000	0.000
81011	99.683	0.000	185.850	0.000	257.160	23.351	76.504	32.495	0.000	0.000
81012	99.683	0.000	184.930	0.000	255.414	23.135	76.504	31.812	0.000	0.000
81013	99.683	0.000	204.176	0.000	259.062	23.754	76.504	33.748	0.000	0.000
81014	99.683	0.000	212.419	0.000	262.219	24.256	76.504	35.866	0.000	0.000
81015	99.362	0.000	212.908	0.000	263.147	24.396	76.504	36.961	0.000	0.000
81016	96.460	0.000	208.973	0.000	242.420	19.608	76.504	38.827	0.000	0.000
81017	84.742	0.000	185.644	0.000	228.026	16.892	76.504	31.191	0.000	0.000
81018	55.756	0.000	106.856	0.000	101.325	2.576	76.504	25.659	0.000	0.000
81019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	268.103	25.958	76.504	38.827	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2741.181	226.074	918.051	394.387	0.000	0.000
AV	53.189	0.000	116.048	0.000	114.216	9.420	38.252	16.433	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE223 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
811 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
811 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
811 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
811 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
811 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
811 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
811 7	81.785	0.000	168.037	0.000	210.806	11.219	76.504	24.459	0.000	0.000
811 8	98.066	0.000	208.826	0.000	246.969	21.316	76.504	27.083	0.000	0.000
811 9	99.683	0.000	213.339	0.000	280.215	29.202	76.504	27.774	0.000	0.000
81110	99.683	0.000	208.758	0.000	262.347	27.583	76.504	27.429	0.000	0.000
81111	99.683	0.000	185.850	0.000	295.337	33.038	76.504	26.954	0.000	0.000
81112	99.683	0.000	184.930	0.000	296.714	32.987	76.504	26.479	0.000	0.000
81113	99.683	0.000	204.176	0.000	298.571	33.300	76.504	28.513	0.000	0.000
81114	99.683	0.000	212.419	0.000	304.628	34.099	76.504	30.196	0.000	0.000
81115	99.362	0.000	212.908	0.000	309.319	34.674	76.504	31.674	0.000	0.000
81116	96.460	0.000	208.973	0.000	309.804	34.722	76.504	31.862	0.000	0.000
81117	84.742	0.000	185.644	0.000	277.064	27.239	76.504	31.440	0.000	0.000
81118	55.756	0.000	106.856	0.000	248.422	22.548	76.504	25.870	0.000	0.000
81119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	309.804	34.722	76.504	31.862	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3340.197	341.928	918.051	339.733	0.000	0.000
AV	53.189	0.000	116.048	0.000	139.175	14.247	38.252	14.156	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE224 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
812 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
812 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
812 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
812 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
812 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
812 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
812 7	81.785	0.000	168.037	0.000	236.382	18.417	76.504	24.950	0.000	0.000
812 8	98.066	0.000	208.826	0.000	310.026	36.688	76.504	27.457	0.000	0.000
812 9	99.683	0.000	213.339	0.000	276.047	33.798	76.504	26.965	0.000	0.000
81210	99.683	0.000	208.758	0.000	275.503	34.242	76.504	27.125	0.000	0.000
81211	99.683	0.000	185.850	0.000	266.228	30.911	76.504	26.770	0.000	0.000
81212	99.683	0.000	184.930	0.000	307.184	36.275	76.504	27.097	0.000	0.000
81213	99.683	0.000	204.176	0.000	315.255	37.024	76.504	28.140	0.000	0.000
81214	99.683	0.000	212.419	0.000	322.251	37.906	76.504	30.256	0.000	0.000
81215	99.362	0.000	212.908	0.000	327.485	38.492	76.504	31.704	0.000	0.000
81216	96.460	0.000	208.973	0.000	327.599	38.492	76.504	31.766	0.000	0.000
81217	84.742	0.000	185.644	0.000	301.628	33.629	76.504	31.468	0.000	0.000
81218	55.756	0.000	106.856	0.000	262.964	26.369	76.504	26.103	0.000	0.000
81219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	327.599	38.492	76.504	31.766	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3528.551	402.243	918.051	339.801	0.000	0.000
AV	53.189	0.000	116.048	0.000	147.023	16.760	38.252	14.158	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE225 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
813 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
813 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
813 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
813 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
813 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
813 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
813 7	81.785	0.000	168.037	0.000	248.578	21.951	76.504	26.771	0.000	0.000
813 8	98.066	0.000	208.826	0.000	315.280	37.326	76.504	29.700	0.000	0.000
813 9	99.683	0.000	213.339	0.000	332.608	40.738	76.504	29.701	0.000	0.000
81310	99.683	0.000	208.758	0.000	335.201	41.107	76.504	30.283	0.000	0.000
81311	99.683	0.000	185.850	0.000	270.811	31.391	76.504	28.031	0.000	0.000
81312	99.683	0.000	184.930	0.000	265.682	30.944	76.504	26.910	0.000	0.000
81313	99.683	0.000	204.176	0.000	270.913	31.773	76.504	27.929	0.000	0.000
81314	99.683	0.000	212.419	0.000	274.414	32.322	76.504	30.185	0.000	0.000
81315	99.362	0.000	212.908	0.000	329.230	38.883	76.504	32.259	0.000	0.000
81316	96.460	0.000	208.973	0.000	332.916	39.009	76.504	32.469	0.000	0.000
81317	84.742	0.000	185.644	0.000	314.446	36.905	76.504	32.320	0.000	0.000
81318	55.756	0.000	106.856	0.000	252.662	23.218	76.504	26.994	0.000	0.000
81319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	335.201	41.107	76.504	32.469	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3542.740	405.569	918.051	353.552	0.000	0.000
AV	53.189	0.000	116.048	0.000	147.614	16.899	38.252	14.731	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE226 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
814 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
814 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
814 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
814 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
814 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
814 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
814 7	81.785	0.000	168.037	0.000	240.257	18.909	76.504	26.476	0.000	0.000
814 8	98.066	0.000	208.826	0.000	308.229	36.499	76.504	30.030	0.000	0.000
814 9	99.683	0.000	213.339	0.000	269.991	29.627	76.504	28.598	0.000	0.000
81410	99.683	0.000	208.758	0.000	318.806	37.738	76.504	30.125	0.000	0.000
81411	99.683	0.000	185.850	0.000	326.339	40.055	76.504	28.176	0.000	0.000
81412	99.683	0.000	184.930	0.000	323.879	39.838	76.504	27.964	0.000	0.000
81413	99.683	0.000	204.176	0.000	319.656	37.608	76.504	29.360	0.000	0.000
81414	99.683	0.000	212.419	0.000	326.713	38.427	76.504	31.352	0.000	0.000
81415	99.362	0.000	212.908	0.000	327.001	38.423	76.504	33.710	0.000	0.000
81416	96.460	0.000	208.973	0.000	297.108	33.015	76.504	32.500	0.000	0.000
81417	84.742	0.000	185.644	0.000	267.010	27.090	76.504	29.776	0.000	0.000
81418	55.756	0.000	106.856	0.000	211.307	12.763	76.504	24.832	0.000	0.000
81419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	327.001	40.055	76.504	33.710	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3536.298	389.992	918.051	352.899	0.000	0.000
AV	53.189	0.000	116.048	0.000	147.346	16.250	38.252	14.704	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE227 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
815 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
815 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
815 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
815 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
815 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
815 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
815 7	5.538	0.000	31.745	0.000	218.554	12.767	76.504	23.949	0.000	0.000
815 8	5.538	0.000	31.745	0.000	235.947	21.657	76.504	23.949	0.000	0.000
815 9	5.538	0.000	31.745	0.000	229.494	21.781	76.504	23.949	0.000	0.000
81510	5.538	0.000	31.745	0.000	227.237	21.493	76.504	23.949	0.000	0.000
81511	5.538	0.000	31.745	0.000	227.918	21.663	76.504	23.949	0.000	0.000
81512	5.538	0.000	31.745	0.000	232.375	24.017	76.504	23.949	0.000	0.000
81513	5.538	0.000	31.745	0.000	231.371	23.752	76.504	23.949	0.000	0.000
81514	5.538	0.000	31.745	0.000	251.455	26.886	76.504	23.949	0.000	0.000
81515	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81516	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81517	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81518	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81519	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81520	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81521	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81522	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81523	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81524	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 15)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	251.455	26.886	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1854.351	174.016	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	77.265	7.251	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE229 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
817 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
817 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
817 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
817 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
817 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
817 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
817 7	81.785	0.000	168.037	0.000	245.162	20.231	76.504	29.417	0.000	0.000
817 8	98.066	0.000	208.826	0.000	303.850	32.612	76.504	36.164	0.000	0.000
817 9	99.683	0.000	213.339	0.000	333.752	39.105	76.504	33.500	0.000	0.000
81710	99.683	0.000	208.758	0.000	279.364	31.210	76.504	33.055	0.000	0.000
81711	99.683	0.000	185.850	0.000	274.187	32.328	76.504	30.340	0.000	0.000
81712	99.683	0.000	184.930	0.000	268.014	29.686	76.504	29.622	0.000	0.000
81713	99.683	0.000	204.176	0.000	272.152	30.395	76.504	30.904	0.000	0.000
81714	99.683	0.000	212.419	0.000	332.936	39.276	76.504	33.561	0.000	0.000
81715	99.362	0.000	212.908	0.000	314.965	34.340	76.504	34.866	0.000	0.000
81716	96.460	0.000	208.973	0.000	313.228	34.257	76.504	35.621	0.000	0.000
81717	84.742	0.000	185.644	0.000	308.328	34.506	76.504	34.242	0.000	0.000
81718	55.756	0.000	106.856	0.000	260.626	24.602	76.504	27.434	0.000	0.000
81719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	333.752	39.276	76.504	36.164	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3506.564	382.549	918.051	388.726	0.000	0.000
AV	53.189	0.000	116.048	0.000	146.107	15.940	38.252	16.197	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE230 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
818 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
818 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
818 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
818 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
818 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
818 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
818 7	81.785	0.000	168.037	0.000	206.048	8.928	76.504	26.503	0.000	0.000
818 8	98.066	0.000	208.826	0.000	229.944	17.664	76.504	30.629	0.000	0.000
818 9	99.683	0.000	213.339	0.000	234.439	18.135	76.504	29.681	0.000	0.000
81810	99.683	0.000	208.758	0.000	245.701	21.017	76.504	29.253	0.000	0.000
81811	99.683	0.000	185.850	0.000	245.492	20.913	76.504	29.283	0.000	0.000
81812	99.683	0.000	184.930	0.000	252.702	22.696	76.504	29.545	0.000	0.000
81813	99.683	0.000	204.176	0.000	252.084	22.525	76.504	29.856	0.000	0.000
81814	99.683	0.000	212.419	0.000	258.961	23.753	76.504	33.576	0.000	0.000
81815	99.362	0.000	212.908	0.000	267.331	25.847	76.504	34.038	0.000	0.000
81816	96.460	0.000	208.973	0.000	243.434	20.439	76.504	33.153	0.000	0.000
81817	84.742	0.000	185.644	0.000	218.762	14.591	76.504	29.686	0.000	0.000
81818	55.756	0.000	106.856	0.000	178.549	9.343	76.504	24.151	0.000	0.000
81819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	267.331	25.847	76.504	34.038	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2833.448	225.852	918.051	359.355	0.000	0.000
AV	53.189	0.000	116.048	0.000	118.060	9.411	38.252	14.973	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE231 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
819 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
819 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
819 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
819 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
819 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
819 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
819 7	81.785	0.000	168.037	0.000	119.251	1.241	76.504	25.025	0.000	0.000
819 8	98.066	0.000	208.826	0.000	136.187	5.829	76.504	28.002	0.000	0.000
819 9	99.683	0.000	213.339	0.000	220.849	15.588	76.504	25.796	0.000	0.000
81910	99.683	0.000	208.758	0.000	234.976	18.925	76.504	27.182	0.000	0.000
81911	99.683	0.000	185.850	0.000	251.738	23.283	76.504	26.265	0.000	0.000
81912	99.683	0.000	184.930	0.000	263.731	26.611	76.504	26.377	0.000	0.000
81913	99.683	0.000	204.176	0.000	275.966	28.594	76.504	27.974	0.000	0.000
81914	99.683	0.000	212.419	0.000	281.061	29.319	76.504	29.993	0.000	0.000
81915	99.362	0.000	212.908	0.000	277.954	28.836	76.504	31.252	0.000	0.000
81916	96.460	0.000	208.973	0.000	261.814	24.910	76.504	30.924	0.000	0.000
81917	84.742	0.000	185.644	0.000	229.097	17.035	76.504	27.588	0.000	0.000
81918	55.756	0.000	106.856	0.000	212.905	13.346	76.504	23.949	0.000	0.000
81919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
81924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	281.061	29.319	76.504	31.252	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2765.529	233.516	918.051	330.326	0.000	0.000
AV	53.189	0.000	116.048	0.000	115.230	9.730	38.252	13.764	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE232 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
820 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
820 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
820 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
820 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
820 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
820 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
820 7	81.785	0.000	168.037	0.000	155.852	4.794	76.504	24.376	0.000	0.000
820 8	98.066	0.000	208.826	0.000	203.859	10.953	76.504	26.102	0.000	0.000
820 9	99.683	0.000	213.339	0.000	215.011	13.826	76.504	26.254	0.000	0.000
82010	99.683	0.000	208.758	0.000	222.318	15.770	76.504	26.380	0.000	0.000
82011	99.683	0.000	185.850	0.000	247.309	22.537	76.504	25.087	0.000	0.000
82012	99.683	0.000	184.930	0.000	265.929	26.989	76.504	25.550	0.000	0.000
82013	99.683	0.000	204.176	0.000	272.821	28.070	76.504	27.255	0.000	0.000
82014	99.683	0.000	212.419	0.000	258.903	24.415	76.504	29.527	0.000	0.000
82015	99.362	0.000	212.908	0.000	258.093	24.365	76.504	29.265	0.000	0.000
82016	96.460	0.000	208.973	0.000	243.374	20.498	76.504	28.772	0.000	0.000
82017	84.742	0.000	185.644	0.000	211.914	12.498	76.504	27.701	0.000	0.000
82018	55.756	0.000	106.856	0.000	135.020	5.450	76.504	23.949	0.000	0.000
82019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	272.821	28.070	76.504	29.527	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2690.402	210.165	918.051	320.218	0.000	0.000
AV	53.189	0.000	116.048	0.000	112.100	8.757	38.252	13.342	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE233 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
821 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
821 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
821 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
821 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
821 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
821 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
821 7	81.785	0.000	168.037	0.000	184.231	6.736	76.504	24.088	0.000	0.000
821 8	98.066	0.000	208.826	0.000	218.782	14.891	76.504	25.127	0.000	0.000
821 9	99.683	0.000	213.339	0.000	240.969	20.144	76.504	25.219	0.000	0.000
82110	99.683	0.000	208.758	0.000	242.288	20.310	76.504	25.816	0.000	0.000
82111	99.683	0.000	185.850	0.000	244.175	20.714	76.504	26.447	0.000	0.000
82112	99.683	0.000	184.930	0.000	244.474	20.756	76.504	26.559	0.000	0.000
82113	99.683	0.000	204.176	0.000	252.726	22.704	76.504	27.449	0.000	0.000
82114	99.683	0.000	212.419	0.000	269.130	26.165	76.504	28.852	0.000	0.000
82115	99.362	0.000	212.908	0.000	283.542	29.688	76.504	30.454	0.000	0.000
82116	96.460	0.000	208.973	0.000	257.875	23.431	76.504	32.747	0.000	0.000
82117	84.742	0.000	185.644	0.000	233.299	17.920	76.504	30.653	0.000	0.000
82118	55.756	0.000	106.856	0.000	207.611	11.548	76.504	24.640	0.000	0.000
82119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	283.542	29.688	76.504	32.747	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2879.101	235.007	918.051	328.051	0.000	0.000
AV	53.189	0.000	116.048	0.000	119.963	9.792	38.252	13.669	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE234 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
822 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
822 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
822 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
822 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
822 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
822 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
822 7	5.538	0.000	31.745	0.000	123.895	1.467	76.504	23.949	0.000	0.000
822 8	5.538	0.000	31.745	0.000	168.806	8.341	76.504	23.949	0.000	0.000
822 9	5.538	0.000	31.745	0.000	207.029	11.952	76.504	23.949	0.000	0.000
82210	5.538	0.000	31.745	0.000	217.333	15.259	76.504	23.949	0.000	0.000
82211	5.538	0.000	31.745	0.000	217.396	15.224	76.504	23.949	0.000	0.000
82212	5.538	0.000	31.745	0.000	220.123	15.894	76.504	23.949	0.000	0.000
82213	5.538	0.000	31.745	0.000	220.181	15.875	76.504	23.949	0.000	0.000
82214	5.538	0.000	31.745	0.000	226.991	18.401	76.504	23.949	0.000	0.000
82215	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82216	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82217	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82218	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82219	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82220	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82221	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82222	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82223	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82224	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 22)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	226.991	18.401	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1601.753	102.413	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	66.740	4.267	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE236 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
824 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
824 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
824 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
824 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
824 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
824 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
824 7	81.785	0.000	168.037	0.000	220.603	13.849	76.504	26.548	0.000	0.000
824 8	98.066	0.000	208.826	0.000	274.080	26.989	76.504	29.806	0.000	0.000
824 9	99.683	0.000	213.339	0.000	296.342	31.379	76.504	29.001	0.000	0.000
82410	99.683	0.000	208.758	0.000	296.671	31.451	76.504	30.899	0.000	0.000
82411	99.683	0.000	185.850	0.000	261.367	27.395	76.504	27.556	0.000	0.000
82412	99.683	0.000	184.930	0.000	258.177	27.115	76.504	27.406	0.000	0.000
82413	99.683	0.000	204.176	0.000	316.676	37.444	76.504	29.010	0.000	0.000
82414	99.683	0.000	212.419	0.000	273.997	30.329	76.504	30.236	0.000	0.000
82415	99.362	0.000	212.908	0.000	291.004	30.090	76.504	34.011	0.000	0.000
82416	96.460	0.000	208.973	0.000	269.703	25.319	76.504	35.830	0.000	0.000
82417	84.742	0.000	185.644	0.000	244.006	18.911	76.504	33.955	0.000	0.000
82418	55.756	0.000	106.856	0.000	231.052	17.497	76.504	26.181	0.000	0.000
82419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	316.676	37.444	76.504	35.830	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3233.680	317.767	918.051	360.438	0.000	0.000
AV	53.189	0.000	116.048	0.000	134.737	13.240	38.252	15.018	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE237 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
825 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
825 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
825 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
825 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
825 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
825 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
825 7	81.785	0.000	168.037	0.000	231.752	16.093	76.504	25.344	0.000	0.000
825 8	98.066	0.000	208.826	0.000	257.665	23.696	76.504	29.729	0.000	0.000
825 9	99.683	0.000	213.339	0.000	275.782	27.111	76.504	29.248	0.000	0.000
82510	99.683	0.000	208.758	0.000	296.388	31.475	76.504	29.237	0.000	0.000
82511	99.683	0.000	185.850	0.000	293.693	31.044	76.504	28.256	0.000	0.000
82512	99.683	0.000	184.930	0.000	282.497	28.664	76.504	28.048	0.000	0.000
82513	99.683	0.000	204.176	0.000	277.546	26.617	76.504	29.682	0.000	0.000
82514	99.683	0.000	212.419	0.000	278.908	26.805	76.504	32.362	0.000	0.000
82515	99.362	0.000	212.908	0.000	281.146	27.117	76.504	33.253	0.000	0.000
82516	96.460	0.000	208.973	0.000	280.096	26.953	76.504	32.787	0.000	0.000
82517	84.742	0.000	185.644	0.000	247.262	19.396	76.504	32.060	0.000	0.000
82518	55.756	0.000	106.856	0.000	226.920	15.745	76.504	24.893	0.000	0.000
82519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 25)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	296.388	31.475	76.504	33.253	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3229.656	300.716	918.051	354.897	0.000	0.000
AV	53.189	0.000	116.048	0.000	134.569	12.530	38.252	14.787	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE238 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
826 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
826 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
826 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
826 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
826 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
826 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
826 7	81.785	0.000	168.037	0.000	222.832	13.120	76.504	25.346	0.000	0.000
826 8	98.066	0.000	208.826	0.000	245.042	21.078	76.504	28.929	0.000	0.000
826 9	99.683	0.000	213.339	0.000	260.512	23.968	76.504	28.472	0.000	0.000
82610	99.683	0.000	208.758	0.000	281.740	28.612	76.504	28.165	0.000	0.000
82611	99.683	0.000	185.850	0.000	269.351	25.299	76.504	28.113	0.000	0.000
82612	99.683	0.000	184.930	0.000	264.593	24.633	76.504	28.388	0.000	0.000
82613	99.683	0.000	204.176	0.000	260.860	22.838	76.504	30.253	0.000	0.000
82614	99.683	0.000	212.419	0.000	261.358	22.912	76.504	33.202	0.000	0.000
82615	99.362	0.000	212.908	0.000	259.930	22.669	76.504	35.455	0.000	0.000
82616	96.460	0.000	208.973	0.000	259.095	22.543	76.504	34.939	0.000	0.000
82617	84.742	0.000	185.644	0.000	245.090	19.090	76.504	31.178	0.000	0.000
82618	55.756	0.000	106.856	0.000	226.469	15.623	76.504	24.641	0.000	0.000
82619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	281.740	28.612	76.504	35.455	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3056.873	262.385	918.051	357.079	0.000	0.000
AV	53.189	0.000	116.048	0.000	127.370	10.933	38.252	14.878	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE239 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
827 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
827 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
827 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
827 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
827 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
827 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
827 7	81.785	0.000	168.037	0.000	224.415	13.605	76.504	25.608	0.000	0.000
827 8	98.066	0.000	208.826	0.000	268.383	26.265	76.504	28.397	0.000	0.000
827 9	99.683	0.000	213.339	0.000	259.807	25.730	76.504	27.493	0.000	0.000
82710	99.683	0.000	208.758	0.000	263.396	27.987	76.504	28.596	0.000	0.000
82711	99.683	0.000	185.850	0.000	259.157	27.191	76.504	27.284	0.000	0.000
82712	99.683	0.000	184.930	0.000	257.775	26.980	76.504	26.903	0.000	0.000
82713	99.683	0.000	204.176	0.000	315.715	37.326	76.504	28.875	0.000	0.000
82714	99.683	0.000	212.419	0.000	291.082	29.760	76.504	31.609	0.000	0.000
82715	99.362	0.000	212.908	0.000	292.579	30.130	76.504	33.681	0.000	0.000
82716	96.460	0.000	208.973	0.000	274.132	26.036	76.504	35.328	0.000	0.000
82717	84.742	0.000	185.644	0.000	263.004	24.358	76.504	32.460	0.000	0.000
82718	55.756	0.000	106.856	0.000	225.844	15.427	76.504	25.737	0.000	0.000
82719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	315.715	37.326	76.504	35.328	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3195.289	310.797	918.051	351.971	0.000	0.000
AV	53.189	0.000	116.048	0.000	133.137	12.950	38.252	14.665	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE240 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
828 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
828 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
828 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
828 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
828 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
828 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
828 7	81.785	0.000	168.037	0.000	210.779	9.895	76.504	25.792	0.000	0.000
828 8	98.066	0.000	208.826	0.000	245.831	21.303	76.504	28.823	0.000	0.000
828 9	99.683	0.000	213.339	0.000	267.100	25.777	76.504	29.694	0.000	0.000
82810	99.683	0.000	208.758	0.000	283.175	29.635	76.504	30.283	0.000	0.000
82811	99.683	0.000	185.850	0.000	270.042	26.200	76.504	29.005	0.000	0.000
82812	99.683	0.000	184.930	0.000	267.849	25.941	76.504	28.460	0.000	0.000
82813	99.683	0.000	204.176	0.000	274.078	26.911	76.504	30.246	0.000	0.000
82814	99.683	0.000	212.419	0.000	273.221	26.734	76.504	33.273	0.000	0.000
82815	99.362	0.000	212.908	0.000	267.150	25.029	76.504	34.684	0.000	0.000
82816	96.460	0.000	208.973	0.000	260.100	23.880	76.504	35.192	0.000	0.000
82817	84.742	0.000	185.644	0.000	253.459	22.765	76.504	30.913	0.000	0.000
82818	55.756	0.000	106.856	0.000	223.681	15.871	76.504	25.158	0.000	0.000
82819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	283.175	29.635	76.504	35.192	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3096.463	279.942	918.051	361.521	0.000	0.000
AV	53.189	0.000	116.048	0.000	129.019	11.664	38.252	15.063	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE241 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
829 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
829 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
829 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
829 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
829 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
829 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
829 7	5.538	0.000	31.745	0.000	151.929	4.389	76.504	23.949	0.000	0.000
829 8	5.538	0.000	31.745	0.000	205.572	12.128	76.504	23.949	0.000	0.000
829 9	5.538	0.000	31.745	0.000	214.870	14.600	76.504	23.949	0.000	0.000
82910	5.538	0.000	31.745	0.000	218.890	15.602	76.504	23.949	0.000	0.000
82911	5.538	0.000	31.745	0.000	218.996	15.607	76.504	23.949	0.000	0.000
82912	5.538	0.000	31.745	0.000	218.287	15.453	76.504	23.949	0.000	0.000
82913	5.538	0.000	31.745	0.000	218.895	15.604	76.504	23.949	0.000	0.000
82914	5.538	0.000	31.745	0.000	217.729	14.472	76.504	23.949	0.000	0.000
82915	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82916	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82917	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82918	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82919	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82920	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82921	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82922	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82923	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
82924	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 29)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	218.996	15.607	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1665.167	107.854	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	69.382	4.494	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE243 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
831 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
831 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
831 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
831 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
831 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
831 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
831 7	81.785	0.000	168.037	0.000	203.346	8.432	76.504	26.785	0.000	0.000
831 8	98.066	0.000	208.826	0.000	253.830	23.129	76.504	29.433	0.000	0.000
831 9	99.683	0.000	213.339	0.000	277.433	27.318	76.504	29.651	0.000	0.000
83110	99.683	0.000	208.758	0.000	290.827	30.693	76.504	31.152	0.000	0.000
83111	99.683	0.000	185.850	0.000	278.265	28.007	76.504	29.894	0.000	0.000
83112	99.683	0.000	184.930	0.000	276.276	27.221	76.504	29.423	0.000	0.000
83113	99.683	0.000	204.176	0.000	281.459	28.555	76.504	31.247	0.000	0.000
83114	99.683	0.000	212.419	0.000	274.399	26.117	76.504	34.728	0.000	0.000
83115	99.362	0.000	212.908	0.000	266.648	23.721	76.504	35.908	0.000	0.000
83116	96.460	0.000	208.973	0.000	260.617	22.773	76.504	36.704	0.000	0.000
83117	84.742	0.000	185.644	0.000	250.535	21.090	76.504	33.285	0.000	0.000
83118	55.756	0.000	106.856	0.000	220.172	14.271	76.504	25.831	0.000	0.000
83119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
83120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
83121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
83122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
83123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
83124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (AUG 31)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	290.827	30.693	76.504	36.704	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3133.808	281.326	918.051	374.041	0.000	0.000
AV	53.189	0.000	116.048	0.000	130.575	11.722	38.252	15.585	0.000	0.000
MONTHLY SUMMARY (AUG)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	335.201	41.107	76.504	38.827	0.000	0.000
SM	27671.131	0.000	63440.551	0.000	72449.328	6570.822	22339.242	8310.572	0.000	0.000
AV	37.192	0.000	85.270	0.000	97.378	8.832	30.026	11.170	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE244 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 1 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 1 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 1 7	81.785	0.000	168.037	0.000	125.084	1.918	76.504	24.872	0.000	0.000
9 1 8	98.066	0.000	208.826	0.000	129.057	4.876	76.504	28.470	0.000	0.000
9 1 9	99.683	0.000	213.339	0.000	172.052	8.336	76.504	27.220	0.000	0.000
9 110	99.683	0.000	208.758	0.000	229.289	17.389	76.504	26.723	0.000	0.000
9 111	99.683	0.000	185.850	0.000	257.839	24.323	76.504	26.467	0.000	0.000
9 112	99.683	0.000	184.930	0.000	259.978	24.600	76.504	27.252	0.000	0.000
9 113	99.683	0.000	204.176	0.000	269.275	26.190	76.504	28.835	0.000	0.000
9 114	99.683	0.000	212.419	0.000	288.492	30.421	76.504	30.356	0.000	0.000
9 115	99.362	0.000	212.908	0.000	279.381	28.175	76.504	32.687	0.000	0.000
9 116	96.460	0.000	208.973	0.000	273.993	26.860	76.504	33.942	0.000	0.000
9 117	84.742	0.000	185.644	0.000	245.090	20.746	76.504	29.677	0.000	0.000
9 118	55.756	0.000	106.856	0.000	210.271	12.606	76.504	24.493	0.000	0.000
9 119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	288.492	30.421	76.504	33.942	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2739.800	226.439	918.051	340.995	0.000	0.000
AV	53.189	0.000	116.048	0.000	114.158	9.435	38.252	14.208	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE245 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 2 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 2 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 2 7	81.785	0.000	168.037	0.000	206.234	10.319	76.504	24.351	0.000	0.000
9 2 8	98.066	0.000	208.826	0.000	221.117	15.199	76.504	26.042	0.000	0.000
9 2 9	99.683	0.000	213.339	0.000	226.327	16.549	76.504	25.771	0.000	0.000
9 210	99.683	0.000	208.758	0.000	243.456	20.647	76.504	25.987	0.000	0.000
9 211	99.683	0.000	185.850	0.000	258.650	24.451	76.504	25.691	0.000	0.000
9 212	99.683	0.000	184.930	0.000	268.959	26.116	76.504	25.758	0.000	0.000
9 213	99.683	0.000	204.176	0.000	275.751	27.138	76.504	27.448	0.000	0.000
9 214	99.683	0.000	212.419	0.000	279.119	28.189	76.504	30.320	0.000	0.000
9 215	99.362	0.000	212.908	0.000	282.238	28.649	76.504	31.844	0.000	0.000
9 216	96.460	0.000	208.973	0.000	269.811	25.406	76.504	32.655	0.000	0.000
9 217	84.742	0.000	185.644	0.000	257.254	23.393	76.504	29.773	0.000	0.000
9 218	55.756	0.000	106.856	0.000	230.872	18.006	76.504	24.302	0.000	0.000
9 219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	282.238	28.649	76.504	32.655	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3019.788	264.062	918.051	329.943	0.000	0.000
AV	53.189	0.000	116.048	0.000	125.825	11.003	38.252	13.748	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE246 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 3 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 3 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 3 7	81.785	0.000	168.037	0.000	215.173	11.231	76.504	24.499	0.000	0.000
9 3 8	98.066	0.000	208.826	0.000	229.341	16.428	76.504	27.296	0.000	0.000
9 3 9	99.683	0.000	213.339	0.000	230.831	16.496	76.504	25.964	0.000	0.000
9 310	99.683	0.000	208.758	0.000	245.863	21.056	76.504	27.159	0.000	0.000
9 311	99.683	0.000	185.850	0.000	244.073	20.637	76.504	26.276	0.000	0.000
9 312	99.683	0.000	184.930	0.000	247.783	21.378	76.504	25.847	0.000	0.000
9 313	99.683	0.000	204.176	0.000	252.074	22.559	76.504	27.219	0.000	0.000
9 314	99.683	0.000	212.419	0.000	256.219	23.269	76.504	31.959	0.000	0.000
9 315	99.362	0.000	212.908	0.000	256.907	23.367	76.504	32.501	0.000	0.000
9 316	96.460	0.000	208.973	0.000	251.454	22.404	76.504	29.608	0.000	0.000
9 317	84.742	0.000	185.644	0.000	228.690	16.960	76.504	27.342	0.000	0.000
9 318	55.756	0.000	106.856	0.000	218.509	14.613	76.504	23.949	0.000	0.000
9 319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	256.907	23.367	76.504	32.501	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2876.915	230.399	918.051	329.620	0.000	0.000
AV	53.189	0.000	116.048	0.000	119.871	9.600	38.252	13.734	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE247 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 4 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 4 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 4 7	81.785	0.000	168.037	0.000	207.688	9.144	76.504	24.187	0.000	0.000
9 4 8	98.066	0.000	208.826	0.000	210.697	12.516	76.504	25.819	0.000	0.000
9 4 9	99.683	0.000	213.339	0.000	210.911	12.374	76.504	26.081	0.000	0.000
9 410	99.683	0.000	208.758	0.000	226.177	16.651	76.504	25.451	0.000	0.000
9 411	99.683	0.000	185.850	0.000	230.349	17.388	76.504	25.317	0.000	0.000
9 412	99.683	0.000	184.930	0.000	240.859	20.128	76.504	25.348	0.000	0.000
9 413	99.683	0.000	204.176	0.000	263.473	25.301	76.504	26.893	0.000	0.000
9 414	99.683	0.000	212.419	0.000	259.486	23.755	76.504	30.137	0.000	0.000
9 415	99.362	0.000	212.908	0.000	249.662	20.961	76.504	32.854	0.000	0.000
9 416	96.460	0.000	208.973	0.000	243.364	19.859	76.504	33.377	0.000	0.000
9 417	84.742	0.000	185.644	0.000	227.633	15.876	76.504	30.059	0.000	0.000
9 418	55.756	0.000	106.856	0.000	203.955	11.161	76.504	24.261	0.000	0.000
9 419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	263.473	25.301	76.504	33.377	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2774.256	205.114	918.051	329.784	0.000	0.000
AV	53.189	0.000	116.048	0.000	115.594	8.546	38.252	13.741	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE248 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 5 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 5 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 5 7	5.538	0.000	31.745	0.000	119.784	1.336	76.504	23.949	0.000	0.000
9 5 8	5.538	0.000	31.745	0.000	149.519	6.904	76.504	23.949	0.000	0.000
9 5 9	5.538	0.000	31.745	0.000	197.553	10.918	76.504	23.949	0.000	0.000
9 510	5.538	0.000	31.745	0.000	219.794	15.867	76.504	23.949	0.000	0.000
9 511	5.538	0.000	31.745	0.000	220.226	15.841	76.504	23.949	0.000	0.000
9 512	5.538	0.000	31.745	0.000	220.197	15.887	76.504	23.949	0.000	0.000
9 513	5.538	0.000	31.745	0.000	226.991	18.401	76.504	23.949	0.000	0.000
9 514	5.538	0.000	31.745	0.000	228.790	18.755	76.504	23.949	0.000	0.000
9 515	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 516	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 517	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 518	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 519	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 520	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 521	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 522	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 523	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 524	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 5)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	228.790	18.755	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1582.855	103.909	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	65.952	4.330	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE251 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 8 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 8 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 8 7	81.785	0.000	168.037	0.000	227.236	16.339	76.504	30.515	0.000	0.000
9 8 8	98.066	0.000	208.826	0.000	301.167	32.196	76.504	37.568	0.000	0.000
9 8 9	99.683	0.000	213.339	0.000	276.579	29.803	76.504	34.004	0.000	0.000
9 810	99.683	0.000	208.758	0.000	279.488	32.188	76.504	32.893	0.000	0.000
9 811	99.683	0.000	185.850	0.000	273.154	30.481	76.504	31.243	0.000	0.000
9 812	99.683	0.000	184.930	0.000	270.780	30.137	76.504	30.227	0.000	0.000
9 813	99.683	0.000	204.176	0.000	269.648	27.632	76.504	31.790	0.000	0.000
9 814	99.683	0.000	212.419	0.000	270.524	26.369	76.504	33.652	0.000	0.000
9 815	99.362	0.000	212.908	0.000	304.674	31.765	76.504	37.093	0.000	0.000
9 816	96.460	0.000	208.973	0.000	292.231	28.539	76.504	37.702	0.000	0.000
9 817	84.742	0.000	185.644	0.000	282.247	27.249	76.504	34.012	0.000	0.000
9 818	55.756	0.000	106.856	0.000	247.584	20.487	76.504	26.603	0.000	0.000
9 819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	304.674	32.196	76.504	37.702	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3295.312	333.187	918.051	397.301	0.000	0.000
AV	53.189	0.000	116.048	0.000	137.305	13.883	38.252	16.554	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE252 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
9 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 7	81.785	0.000	168.037	0.000	225.120	13.791	76.504	27.575	0.000	0.000
9 9 8	98.066	0.000	208.826	0.000	285.428	29.421	76.504	30.081	0.000	0.000
9 9 9	99.683	0.000	213.339	0.000	303.488	32.264	76.504	31.137	0.000	0.000
9 9 10	99.683	0.000	208.758	0.000	277.609	31.015	76.504	28.689	0.000	0.000
9 9 11	99.683	0.000	185.850	0.000	274.584	32.352	76.504	28.009	0.000	0.000
9 9 12	99.683	0.000	184.930	0.000	269.019	29.854	76.504	27.659	0.000	0.000
9 9 13	99.683	0.000	204.176	0.000	268.544	27.465	76.504	28.529	0.000	0.000
9 9 14	99.683	0.000	212.419	0.000	272.572	28.056	76.504	30.211	0.000	0.000
9 9 15	99.362	0.000	212.908	0.000	270.783	26.388	76.504	32.622	0.000	0.000
9 9 16	96.460	0.000	208.973	0.000	300.658	31.254	76.504	35.012	0.000	0.000
9 9 17	84.742	0.000	185.644	0.000	279.530	26.766	76.504	31.873	0.000	0.000
9 9 18	55.756	0.000	106.856	0.000	237.744	18.673	76.504	26.389	0.000	0.000
9 9 19	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 20	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 21	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 22	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 23	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9 9 24	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	303.488	32.352	76.504	35.012	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3265.080	327.298	918.051	357.788	0.000	0.000
AV	53.189	0.000	116.048	0.000	136.045	13.637	38.252	14.908	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE253 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
910 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
910 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
910 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
910 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
910 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
910 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
910 7	81.785	0.000	168.037	0.000	223.362	13.465	76.504	26.846	0.000	0.000
910 8	98.066	0.000	208.826	0.000	262.761	24.600	76.504	31.437	0.000	0.000
910 9	99.683	0.000	213.339	0.000	278.339	28.005	76.504	32.423	0.000	0.000
91010	99.683	0.000	208.758	0.000	266.403	26.935	76.504	29.507	0.000	0.000
91011	99.683	0.000	185.850	0.000	257.604	24.264	76.504	28.579	0.000	0.000
91012	99.683	0.000	184.930	0.000	275.306	26.385	76.504	29.202	0.000	0.000
91013	99.683	0.000	204.176	0.000	278.676	26.737	76.504	31.743	0.000	0.000
91014	99.683	0.000	212.419	0.000	283.588	27.467	76.504	34.387	0.000	0.000
91015	99.362	0.000	212.908	0.000	283.083	27.372	76.504	36.538	0.000	0.000
91016	96.460	0.000	208.973	0.000	281.756	27.192	76.504	35.781	0.000	0.000
91017	84.742	0.000	185.644	0.000	256.409	22.015	76.504	33.551	0.000	0.000
91018	55.756	0.000	106.856	0.000	220.792	14.405	76.504	26.103	0.000	0.000
91019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	283.588	28.005	76.504	36.538	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3168.079	288.843	918.051	376.098	0.000	0.000
AV	53.189	0.000	116.048	0.000	132.003	12.035	38.252	15.671	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE254 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
911 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
911 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
911 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
911 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
911 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
911 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
911 7	81.785	0.000	168.037	0.000	204.122	8.542	76.504	27.040	0.000	0.000
911 8	98.066	0.000	208.826	0.000	230.992	17.832	76.504	32.009	0.000	0.000
911 9	99.683	0.000	213.339	0.000	264.146	25.378	76.504	31.358	0.000	0.000
91110	99.683	0.000	208.758	0.000	272.771	26.653	76.504	32.726	0.000	0.000
91111	99.683	0.000	185.850	0.000	273.522	26.784	76.504	30.358	0.000	0.000
91112	99.683	0.000	184.930	0.000	275.304	27.069	76.504	29.159	0.000	0.000
91113	99.683	0.000	204.176	0.000	272.838	25.910	76.504	31.259	0.000	0.000
91114	99.683	0.000	212.419	0.000	273.341	25.983	76.504	34.726	0.000	0.000
91115	99.362	0.000	212.908	0.000	270.839	25.588	76.504	37.614	0.000	0.000
91116	96.460	0.000	208.973	0.000	269.918	25.461	76.504	37.032	0.000	0.000
91117	84.742	0.000	185.644	0.000	258.752	23.626	76.504	33.899	0.000	0.000
91118	55.756	0.000	106.856	0.000	219.896	13.428	76.504	25.453	0.000	0.000
91119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	275.304	27.069	76.504	37.614	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3086.442	272.253	918.051	382.635	0.000	0.000
AV	53.189	0.000	116.048	0.000	128.602	11.344	38.252	15.943	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE255 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
912 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
912 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
912 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
912 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
912 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
912 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
912 7	5.538	0.000	31.745	0.000	151.321	4.308	76.504	23.949	0.000	0.000
912 8	5.538	0.000	31.745	0.000	149.693	6.847	76.504	23.949	0.000	0.000
912 9	5.538	0.000	31.745	0.000	217.401	15.423	76.504	23.949	0.000	0.000
91210	5.538	0.000	31.745	0.000	222.398	16.310	76.504	23.949	0.000	0.000
91211	5.538	0.000	31.745	0.000	222.353	16.348	76.504	23.949	0.000	0.000
91212	5.538	0.000	31.745	0.000	222.941	16.494	76.504	23.949	0.000	0.000
91213	5.538	0.000	31.745	0.000	229.867	19.018	76.504	23.949	0.000	0.000
91214	5.538	0.000	31.745	0.000	231.336	19.293	76.504	23.949	0.000	0.000
91215	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91216	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91217	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91218	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91219	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91220	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91221	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91222	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91223	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91224	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 12)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	231.336	19.293	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1647.309	114.041	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	68.638	4.752	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE257 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
914 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
914 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
914 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
914 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
914 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
914 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
914 7	81.785	0.000	168.037	0.000	181.882	6.015	76.504	24.861	0.000	0.000
914 8	98.066	0.000	208.826	0.000	204.778	10.028	76.504	27.515	0.000	0.000
914 9	99.683	0.000	213.339	0.000	220.992	13.834	76.504	26.108	0.000	0.000
91410	99.683	0.000	208.758	0.000	233.407	17.062	76.504	25.659	0.000	0.000
91411	99.683	0.000	185.850	0.000	232.575	16.852	76.504	25.388	0.000	0.000
91412	99.683	0.000	184.930	0.000	235.386	18.390	76.504	25.773	0.000	0.000
91413	99.683	0.000	204.176	0.000	239.139	19.116	76.504	26.997	0.000	0.000
91414	99.683	0.000	212.419	0.000	249.335	20.972	76.504	29.234	0.000	0.000
91415	99.362	0.000	212.908	0.000	251.476	21.277	76.504	30.386	0.000	0.000
91416	96.460	0.000	208.973	0.000	241.491	18.477	76.504	31.692	0.000	0.000
91417	84.742	0.000	185.644	0.000	230.643	16.479	76.504	28.650	0.000	0.000
91418	55.756	0.000	106.856	0.000	213.364	12.865	76.504	23.949	0.000	0.000
91419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	251.476	21.277	76.504	31.692	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2734.468	191.365	918.051	326.212	0.000	0.000
AV	53.189	0.000	116.048	0.000	113.936	7.974	38.252	13.592	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE258 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
915 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
915 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
915 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
915 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
915 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
915 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
915 7	81.785	0.000	168.037	0.000	208.528	9.027	76.504	24.300	0.000	0.000
915 8	98.066	0.000	208.826	0.000	212.460	12.119	76.504	26.384	0.000	0.000
915 9	99.683	0.000	213.339	0.000	220.891	15.114	76.504	26.252	0.000	0.000
91510	99.683	0.000	208.758	0.000	238.127	19.650	76.504	25.920	0.000	0.000
91511	99.683	0.000	185.850	0.000	236.440	19.195	76.504	25.652	0.000	0.000
91512	99.683	0.000	184.930	0.000	237.301	19.432	76.504	25.957	0.000	0.000
91513	99.683	0.000	204.176	0.000	240.986	20.138	76.504	27.385	0.000	0.000
91514	99.683	0.000	212.419	0.000	243.622	20.610	76.504	28.634	0.000	0.000
91515	99.362	0.000	212.908	0.000	242.635	20.410	76.504	28.196	0.000	0.000
91516	96.460	0.000	208.973	0.000	241.305	20.171	76.504	27.569	0.000	0.000
91517	84.742	0.000	185.644	0.000	229.776	17.241	76.504	25.131	0.000	0.000
91518	55.756	0.000	106.856	0.000	213.641	13.456	76.504	23.949	0.000	0.000
91519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	243.622	20.610	76.504	28.634	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2765.710	206.563	918.051	315.329	0.000	0.000
AV	53.189	0.000	116.048	0.000	115.238	8.607	38.252	13.139	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE259 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
916 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
916 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
916 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
916 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
916 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
916 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
916 7	81.785	0.000	168.037	0.000	160.332	4.940	76.504	24.171	0.000	0.000
916 8	98.066	0.000	208.826	0.000	208.625	12.249	76.504	25.084	0.000	0.000
916 9	99.683	0.000	213.339	0.000	233.777	18.139	76.504	26.637	0.000	0.000
91610	99.683	0.000	208.758	0.000	254.412	22.981	76.504	27.917	0.000	0.000
91611	99.683	0.000	185.850	0.000	267.792	25.915	76.504	26.672	0.000	0.000
91612	99.683	0.000	184.930	0.000	268.784	26.049	76.504	26.885	0.000	0.000
91613	99.683	0.000	204.176	0.000	278.072	28.072	76.504	28.101	0.000	0.000
91614	99.683	0.000	212.419	0.000	276.873	27.270	76.504	31.984	0.000	0.000
91615	99.362	0.000	212.908	0.000	279.306	28.228	76.504	33.123	0.000	0.000
91616	96.460	0.000	208.973	0.000	265.886	24.791	76.504	33.721	0.000	0.000
91617	84.742	0.000	185.644	0.000	252.354	22.549	76.504	30.252	0.000	0.000
91618	55.756	0.000	106.856	0.000	216.434	13.468	76.504	24.278	0.000	0.000
91619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	279.306	28.228	76.504	33.721	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2962.647	254.651	918.051	338.826	0.000	0.000
AV	53.189	0.000	116.048	0.000	123.444	10.610	38.252	14.118	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE260 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
917 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
917 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
917 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
917 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
917 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
917 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
917 7	81.785	0.000	168.037	0.000	158.666	4.589	76.504	25.971	0.000	0.000
917 8	98.066	0.000	208.826	0.000	232.523	18.237	76.504	28.198	0.000	0.000
917 9	99.683	0.000	213.339	0.000	244.913	20.726	76.504	28.747	0.000	0.000
91710	99.683	0.000	208.758	0.000	246.778	21.158	76.504	29.948	0.000	0.000
91711	99.683	0.000	185.850	0.000	241.802	20.235	76.504	27.639	0.000	0.000
91712	99.683	0.000	184.930	0.000	241.173	20.161	76.504	27.294	0.000	0.000
91713	99.683	0.000	204.176	0.000	242.533	20.414	76.504	28.088	0.000	0.000
91714	99.683	0.000	212.419	0.000	243.910	20.661	76.504	28.780	0.000	0.000
91715	99.362	0.000	212.908	0.000	232.464	17.770	76.504	29.241	0.000	0.000
91716	96.460	0.000	208.973	0.000	230.378	17.427	76.504	27.851	0.000	0.000
91717	84.742	0.000	185.644	0.000	210.852	12.281	76.504	26.489	0.000	0.000
91718	55.756	0.000	106.856	0.000	166.417	8.208	76.504	23.949	0.000	0.000
91719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	246.778	21.158	76.504	29.948	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2692.409	201.866	918.051	332.195	0.000	0.000
AV	53.189	0.000	116.048	0.000	112.184	8.411	38.252	13.841	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE261 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
918 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
918 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
918 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
918 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
918 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
918 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
918 7	81.785	0.000	168.037	0.000	152.773	3.948	76.504	24.143	0.000	0.000
918 8	98.066	0.000	208.826	0.000	186.671	9.101	76.504	25.400	0.000	0.000
918 9	99.683	0.000	213.339	0.000	187.578	9.103	76.504	26.302	0.000	0.000
91810	99.683	0.000	208.758	0.000	189.100	9.300	76.504	26.915	0.000	0.000
91811	99.683	0.000	185.850	0.000	215.258	13.483	76.504	25.511	0.000	0.000
91812	99.683	0.000	184.930	0.000	223.300	15.085	76.504	26.730	0.000	0.000
91813	99.683	0.000	204.176	0.000	238.018	18.942	76.504	28.495	0.000	0.000
91814	99.683	0.000	212.419	0.000	231.024	16.534	76.504	32.481	0.000	0.000
91815	99.362	0.000	212.908	0.000	232.348	16.873	76.504	33.788	0.000	0.000
91816	96.460	0.000	208.973	0.000	224.415	15.240	76.504	32.281	0.000	0.000
91817	84.742	0.000	185.644	0.000	209.438	11.315	76.504	28.516	0.000	0.000
91818	55.756	0.000	106.856	0.000	161.316	7.366	76.504	23.949	0.000	0.000
91819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	238.018	18.942	76.504	33.788	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2451.239	146.291	918.051	334.510	0.000	0.000
AV	53.189	0.000	116.048	0.000	102.135	6.095	38.252	13.938	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE262 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
919 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
919 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
919 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
919 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
919 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
919 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
919 7	5.538	0.000	31.745	0.000	143.206	2.850	76.504	23.949	0.000	0.000
919 8	5.538	0.000	31.745	0.000	115.240	3.292	76.504	23.949	0.000	0.000
919 9	5.538	0.000	31.745	0.000	147.164	5.632	76.504	23.949	0.000	0.000
91910	5.538	0.000	31.745	0.000	146.525	5.588	76.504	23.949	0.000	0.000
91911	5.538	0.000	31.745	0.000	156.064	6.841	76.504	23.949	0.000	0.000
91912	5.538	0.000	31.745	0.000	156.313	6.879	76.504	23.949	0.000	0.000
91913	5.538	0.000	31.745	0.000	146.703	5.687	76.504	23.949	0.000	0.000
91914	5.538	0.000	31.745	0.000	156.724	6.902	76.504	23.949	0.000	0.000
91915	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91916	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91917	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91918	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91919	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91920	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91921	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91922	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91923	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
91924	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 19)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	156.724	6.902	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1167.939	43.671	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	48.664	1.820	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE264 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
921 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
921 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
921 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
921 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
921 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
921 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
921 7	81.785	0.000	168.037	0.000	115.073	0.000	76.504	24.306	0.000	0.000
921 8	98.066	0.000	208.826	0.000	92.855	0.554	76.504	27.202	0.000	0.000
921 9	99.683	0.000	213.339	0.000	183.600	7.691	76.504	26.051	0.000	0.000
92110	99.683	0.000	208.758	0.000	190.981	7.785	76.504	27.841	0.000	0.000
92111	99.683	0.000	185.850	0.000	227.583	15.508	76.504	25.802	0.000	0.000
92112	99.683	0.000	184.930	0.000	229.481	15.675	76.504	26.430	0.000	0.000
92113	99.683	0.000	204.176	0.000	233.542	16.519	76.504	28.440	0.000	0.000
92114	99.683	0.000	212.419	0.000	234.137	16.601	76.504	31.843	0.000	0.000
92115	99.362	0.000	212.908	0.000	243.249	18.852	76.504	33.141	0.000	0.000
92116	96.460	0.000	208.973	0.000	238.372	17.908	76.504	33.821	0.000	0.000
92117	84.742	0.000	185.644	0.000	227.344	15.823	76.504	30.011	0.000	0.000
92118	55.756	0.000	106.856	0.000	175.556	8.048	76.504	24.169	0.000	0.000
92119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	243.249	18.852	76.504	33.821	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2391.772	140.964	918.051	339.057	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.657	5.874	38.252	14.127	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE265 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
922 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
922 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
922 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
922 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
922 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
922 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
922 7	81.785	0.000	168.037	0.000	114.625	0.097	76.504	25.426	0.000	0.000
922 8	98.066	0.000	208.826	0.000	191.101	8.238	76.504	27.071	0.000	0.000
922 9	99.683	0.000	213.339	0.000	226.418	13.075	76.504	25.680	0.000	0.000
92210	99.683	0.000	208.758	0.000	245.981	19.267	76.504	28.040	0.000	0.000
92211	99.683	0.000	185.850	0.000	247.068	19.439	76.504	26.608	0.000	0.000
92212	99.683	0.000	184.930	0.000	248.964	19.802	76.504	26.239	0.000	0.000
92213	99.683	0.000	204.176	0.000	263.149	23.228	76.504	27.987	0.000	0.000
92214	99.683	0.000	212.419	0.000	247.649	17.966	76.504	29.264	0.000	0.000
92215	99.362	0.000	212.908	0.000	246.639	17.290	76.504	29.652	0.000	0.000
92216	96.460	0.000	208.973	0.000	257.600	23.452	76.504	29.921	0.000	0.000
92217	84.742	0.000	185.644	0.000	261.969	23.020	76.504	27.523	0.000	0.000
92218	55.756	0.000	106.856	0.000	227.729	15.760	76.504	24.096	0.000	0.000
92219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	263.149	23.452	76.504	29.921	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2778.892	200.634	918.051	327.506	0.000	0.000
AV	53.189	0.000	116.048	0.000	115.787	8.360	38.252	13.646	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE266 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
923 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
923 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
923 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
923 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
923 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
923 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
923 7	81.785	0.000	168.037	0.000	135.459	0.696	76.504	24.979	0.000	0.000
923 8	98.066	0.000	208.826	0.000	218.220	10.038	76.504	25.214	0.000	0.000
923 9	99.683	0.000	213.339	0.000	233.957	12.420	76.504	25.510	0.000	0.000
92310	99.683	0.000	208.758	0.000	244.323	15.562	76.504	26.163	0.000	0.000
92311	99.683	0.000	185.850	0.000	245.431	15.305	76.504	25.990	0.000	0.000
92312	99.683	0.000	184.930	0.000	245.619	18.545	76.504	25.798	0.000	0.000
92313	99.683	0.000	204.176	0.000	249.381	17.730	76.504	27.385	0.000	0.000
92314	99.683	0.000	212.419	0.000	255.382	18.615	76.504	29.161	0.000	0.000
92315	99.362	0.000	212.908	0.000	256.020	18.685	76.504	29.881	0.000	0.000
92316	96.460	0.000	208.973	0.000	254.688	19.484	76.504	29.262	0.000	0.000
92317	84.742	0.000	185.644	0.000	246.325	17.180	76.504	26.441	0.000	0.000
92318	55.756	0.000	106.856	0.000	234.827	17.204	76.504	24.003	0.000	0.000
92319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	256.020	19.484	76.504	29.881	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2819.630	181.466	918.051	319.787	0.000	0.000
AV	53.189	0.000	116.048	0.000	117.485	7.561	38.252	13.324	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE267 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
924 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
924 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
924 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
924 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
924 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
924 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
924 7	81.785	0.000	168.037	0.000	210.953	6.596	76.504	24.698	0.000	0.000
924 8	98.066	0.000	208.826	0.000	236.962	13.364	76.504	24.994	0.000	0.000
924 9	99.683	0.000	213.339	0.000	247.088	16.748	76.504	26.367	0.000	0.000
92410	99.683	0.000	208.758	0.000	255.187	18.063	76.504	28.068	0.000	0.000
92411	99.683	0.000	185.850	0.000	258.854	20.117	76.504	28.000	0.000	0.000
92412	99.683	0.000	184.930	0.000	256.448	22.041	76.504	27.629	0.000	0.000
92413	99.683	0.000	204.176	0.000	258.343	20.720	76.504	29.323	0.000	0.000
92414	99.683	0.000	212.419	0.000	260.728	21.037	76.504	30.876	0.000	0.000
92415	99.362	0.000	212.908	0.000	260.418	19.365	76.504	31.590	0.000	0.000
92416	96.460	0.000	208.973	0.000	257.875	19.971	76.504	30.686	0.000	0.000
92417	84.742	0.000	185.644	0.000	246.944	17.270	76.504	27.147	0.000	0.000
92418	55.756	0.000	106.856	0.000	237.001	17.620	76.504	24.295	0.000	0.000
92419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	260.728	22.041	76.504	31.590	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2986.800	212.913	918.051	333.673	0.000	0.000
AV	53.189	0.000	116.048	0.000	124.450	8.871	38.252	13.903	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE268 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
925 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
925 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
925 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
925 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
925 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
925 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
925 7	81.785	0.000	168.037	0.000	215.720	7.636	76.504	25.573	0.000	0.000
925 8	98.066	0.000	208.826	0.000	236.745	14.089	76.504	27.696	0.000	0.000
925 9	99.683	0.000	213.339	0.000	248.588	17.504	76.504	27.171	0.000	0.000
92510	99.683	0.000	208.758	0.000	257.883	22.302	76.504	27.712	0.000	0.000
92511	99.683	0.000	185.850	0.000	252.376	20.331	76.504	27.278	0.000	0.000
92512	99.683	0.000	184.930	0.000	253.535	20.983	76.504	27.472	0.000	0.000
92513	99.683	0.000	204.176	0.000	258.380	21.769	76.504	29.153	0.000	0.000
92514	99.683	0.000	212.419	0.000	267.753	25.120	76.504	30.676	0.000	0.000
92515	99.362	0.000	212.908	0.000	278.409	30.373	76.504	31.283	0.000	0.000
92516	96.460	0.000	208.973	0.000	276.779	30.135	76.504	31.269	0.000	0.000
92517	84.742	0.000	185.644	0.000	260.628	24.739	76.504	29.819	0.000	0.000
92518	55.756	0.000	106.856	0.000	247.456	21.280	76.504	24.834	0.000	0.000
92519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 25)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	278.409	30.373	76.504	31.283	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	3054.252	256.259	918.051	339.937	0.000	0.000
AV	53.189	0.000	116.048	0.000	127.261	10.677	38.252	14.164	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE269 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
926 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
926 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
926 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
926 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
926 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
926 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
926 7	5.538	0.000	31.745	0.000	121.857	1.520	76.504	23.949	0.000	0.000
926 8	5.538	0.000	31.745	0.000	75.524	0.810	76.504	23.949	0.000	0.000
926 9	5.538	0.000	31.745	0.000	143.310	6.788	76.504	23.949	0.000	0.000
92610	5.538	0.000	31.745	0.000	216.927	15.228	76.504	23.949	0.000	0.000
92611	5.538	0.000	31.745	0.000	225.799	18.045	76.504	23.949	0.000	0.000
92612	5.538	0.000	31.745	0.000	218.412	15.429	76.504	23.949	0.000	0.000
92613	5.538	0.000	31.745	0.000	226.192	18.259	76.504	23.949	0.000	0.000
92614	5.538	0.000	31.745	0.000	221.557	16.152	76.504	23.949	0.000	0.000
92615	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92616	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92617	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92618	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92619	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92620	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92621	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92622	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92623	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92624	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 26)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	226.192	18.259	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1449.578	92.231	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	60.399	3.843	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE271 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
928 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
928 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
928 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
928 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
928 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
928 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
928 7	81.785	0.000	168.037	0.000	121.092	1.135	76.504	25.015	0.000	0.000
928 8	98.066	0.000	208.826	0.000	114.236	2.768	76.504	28.269	0.000	0.000
928 9	99.683	0.000	213.339	0.000	182.891	8.261	76.504	27.821	0.000	0.000
92810	99.683	0.000	208.758	0.000	217.702	13.179	76.504	26.577	0.000	0.000
92811	99.683	0.000	185.850	0.000	234.590	17.297	76.504	27.576	0.000	0.000
92812	99.683	0.000	184.930	0.000	245.880	20.325	76.504	27.930	0.000	0.000
92813	99.683	0.000	204.176	0.000	248.571	20.781	76.504	31.623	0.000	0.000
92814	99.683	0.000	212.419	0.000	244.825	20.108	76.504	33.868	0.000	0.000
92815	99.362	0.000	212.908	0.000	224.642	15.244	76.504	33.350	0.000	0.000
92816	96.460	0.000	208.973	0.000	222.311	14.909	76.504	30.241	0.000	0.000
92817	84.742	0.000	185.644	0.000	187.257	9.253	76.504	27.848	0.000	0.000
92818	55.756	0.000	106.856	0.000	161.794	7.398	76.504	23.949	0.000	0.000
92819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	248.571	20.781	76.504	33.868	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2405.791	150.658	918.051	344.067	0.000	0.000
AV	53.189	0.000	116.048	0.000	100.241	6.277	38.252	14.336	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE272 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
929 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
929 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
929 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
929 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
929 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
929 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
929 7	81.785	0.000	168.037	0.000	166.640	4.294	76.504	24.267	0.000	0.000
929 8	98.066	0.000	208.826	0.000	162.787	6.226	76.504	26.147	0.000	0.000
929 9	99.683	0.000	213.339	0.000	198.351	9.417	76.504	26.135	0.000	0.000
92910	99.683	0.000	208.758	0.000	201.737	9.685	76.504	26.946	0.000	0.000
92911	99.683	0.000	185.850	0.000	207.084	10.460	76.504	25.846	0.000	0.000
92912	99.683	0.000	184.930	0.000	211.469	11.399	76.504	25.912	0.000	0.000
92913	99.683	0.000	204.176	0.000	226.897	15.316	76.504	26.984	0.000	0.000
92914	99.683	0.000	212.419	0.000	234.490	17.234	76.504	27.671	0.000	0.000
92915	99.362	0.000	212.908	0.000	231.367	16.622	76.504	28.712	0.000	0.000
92916	96.460	0.000	208.973	0.000	223.948	15.163	76.504	27.617	0.000	0.000
92917	84.742	0.000	185.644	0.000	214.420	12.424	76.504	27.791	0.000	0.000
92918	55.756	0.000	106.856	0.000	148.732	5.941	76.504	23.949	0.000	0.000
92919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
92924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	234.490	17.234	76.504	28.712	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2427.922	134.182	918.051	317.978	0.000	0.000
AV	53.189	0.000	116.048	0.000	101.163	5.591	38.252	13.249	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE273 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
930 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
930 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
930 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
930 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
930 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
930 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
930 7	81.785	0.000	168.037	0.000	145.074	2.598	76.504	23.949	0.000	0.000
930 8	98.066	0.000	208.826	0.000	133.304	4.281	76.504	24.993	0.000	0.000
930 9	99.683	0.000	213.339	0.000	157.276	5.913	76.504	25.153	0.000	0.000
93010	99.683	0.000	208.758	0.000	178.262	7.416	76.504	25.446	0.000	0.000
93011	99.683	0.000	185.850	0.000	194.027	9.146	76.504	25.535	0.000	0.000
93012	99.683	0.000	184.930	0.000	214.542	12.545	76.504	25.090	0.000	0.000
93013	99.683	0.000	204.176	0.000	217.009	12.967	76.504	26.308	0.000	0.000
93014	99.683	0.000	212.419	0.000	217.432	12.616	76.504	26.721	0.000	0.000
93015	99.362	0.000	212.908	0.000	213.430	11.756	76.504	27.364	0.000	0.000
93016	96.460	0.000	208.973	0.000	201.910	9.080	76.504	26.710	0.000	0.000
93017	84.742	0.000	185.644	0.000	171.515	7.043	76.504	24.929	0.000	0.000
93018	55.756	0.000	106.856	0.000	107.514	2.171	76.504	23.949	0.000	0.000
93019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
93020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
93021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
93022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
93023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
93024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (SEP 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	217.432	12.967	76.504	27.364	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2151.296	97.531	918.051	306.147	0.000	0.000
AV	53.189	0.000	116.048	0.000	89.637	4.064	38.252	12.756	0.000	0.000
MONTHLY SUMMARY (SEP)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	304.674	32.352	76.504	37.702	0.000	0.000
SM	27538.219	0.000	62678.660	0.000	64696.180	4876.791	21727.207	7885.743	0.000	0.000
AV	38.248	0.000	87.054	0.000	89.856	6.773	30.177	10.952	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE274 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 1 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 1 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 1 7	81.785	0.000	168.037	0.000	115.245	0.537	76.504	23.949	0.000	0.000
10 1 8	98.066	0.000	208.826	0.000	112.462	3.091	76.504	24.960	0.000	0.000
10 1 9	99.683	0.000	213.339	0.000	209.816	11.749	76.504	25.473	0.000	0.000
10 110	99.683	0.000	208.758	0.000	232.788	16.929	76.504	26.519	0.000	0.000
10 111	99.683	0.000	185.850	0.000	247.519	20.618	76.504	25.609	0.000	0.000
10 112	99.683	0.000	184.930	0.000	251.283	21.244	76.504	25.529	0.000	0.000
10 113	99.683	0.000	204.176	0.000	260.187	22.754	76.504	26.955	0.000	0.000
10 114	99.683	0.000	212.419	0.000	260.501	22.751	76.504	30.241	0.000	0.000
10 115	99.362	0.000	212.908	0.000	245.766	19.200	76.504	34.871	0.000	0.000
10 116	96.460	0.000	208.973	0.000	232.860	16.352	76.504	35.115	0.000	0.000
10 117	84.742	0.000	185.644	0.000	217.276	12.969	76.504	31.625	0.000	0.000
10 118	55.756	0.000	106.856	0.000	167.361	7.834	76.504	24.278	0.000	0.000
10 119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	260.501	22.754	76.504	35.115	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2553.064	176.027	918.051	335.125	0.000	0.000
AV	53.189	0.000	116.048	0.000	106.378	7.334	38.252	13.964	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE275 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 2 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 2 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 2 7	81.785	0.000	168.037	0.000	188.631	6.402	76.504	24.097	0.000	0.000
10 2 8	98.066	0.000	208.826	0.000	211.714	11.891	76.504	25.996	0.000	0.000
10 2 9	99.683	0.000	213.339	0.000	212.913	12.065	76.504	26.637	0.000	0.000
10 210	99.683	0.000	208.758	0.000	182.760	8.886	76.504	26.710	0.000	0.000
10 211	99.683	0.000	185.850	0.000	218.492	14.788	76.504	24.975	0.000	0.000
10 212	99.683	0.000	184.930	0.000	231.895	17.744	76.504	25.811	0.000	0.000
10 213	99.683	0.000	204.176	0.000	225.790	15.519	76.504	28.660	0.000	0.000
10 214	99.683	0.000	212.419	0.000	219.086	13.403	76.504	32.261	0.000	0.000
10 215	99.362	0.000	212.908	0.000	217.459	13.087	76.504	30.447	0.000	0.000
10 216	96.460	0.000	208.973	0.000	217.167	13.023	76.504	29.989	0.000	0.000
10 217	84.742	0.000	185.644	0.000	175.854	7.993	76.504	28.263	0.000	0.000
10 218	55.756	0.000	106.856	0.000	96.759	1.722	76.504	23.949	0.000	0.000
10 219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	231.895	17.744	76.504	32.261	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2398.519	136.523	918.051	327.793	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.938	5.688	38.252	13.658	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE276 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 3 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 3 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 3 7	5.538	0.000	31.745	0.000	115.593	0.000	76.504	23.949	0.000	0.000
10 3 8	5.538	0.000	31.745	0.000	117.186	2.565	76.504	23.949	0.000	0.000
10 3 9	5.538	0.000	31.745	0.000	158.955	5.941	76.504	23.949	0.000	0.000
10 310	5.538	0.000	31.745	0.000	165.014	6.137	76.504	23.949	0.000	0.000
10 311	5.538	0.000	31.745	0.000	190.609	8.900	76.504	23.949	0.000	0.000
10 312	5.538	0.000	31.745	0.000	191.393	8.986	76.504	23.949	0.000	0.000
10 313	5.538	0.000	31.745	0.000	180.892	8.282	76.504	23.949	0.000	0.000
10 314	5.538	0.000	31.745	0.000	164.492	6.544	76.504	23.949	0.000	0.000
10 315	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 316	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 317	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 318	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 319	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 320	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 321	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 322	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 323	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 324	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 3)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	191.393	8.986	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1284.134	47.355	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	53.506	1.973	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE278 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 5 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 5 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 5 7	81.785	0.000	168.037	0.000	114.271	0.000	76.504	26.645	0.000	0.000
10 5 8	98.066	0.000	208.826	0.000	167.710	6.272	76.504	31.409	0.000	0.000
10 5 9	99.683	0.000	213.339	0.000	240.604	19.471	76.504	30.415	0.000	0.000
10 510	99.683	0.000	208.758	0.000	282.244	28.679	76.504	29.133	0.000	0.000
10 511	99.683	0.000	185.850	0.000	255.589	23.680	76.504	27.144	0.000	0.000
10 512	99.683	0.000	184.930	0.000	248.586	20.867	76.504	26.279	0.000	0.000
10 513	99.683	0.000	204.176	0.000	253.171	20.538	76.504	27.556	0.000	0.000
10 514	99.683	0.000	212.419	0.000	262.040	24.212	76.504	30.165	0.000	0.000
10 515	99.362	0.000	212.908	0.000	258.416	21.762	76.504	31.716	0.000	0.000
10 516	96.460	0.000	208.973	0.000	279.541	26.941	76.504	35.490	0.000	0.000
10 517	84.742	0.000	185.644	0.000	264.289	24.467	76.504	32.410	0.000	0.000
10 518	55.756	0.000	106.856	0.000	227.329	15.739	76.504	24.709	0.000	0.000
10 519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	282.244	28.679	76.504	35.490	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2853.791	232.625	918.051	353.070	0.000	0.000
AV	53.189	0.000	116.048	0.000	118.908	9.693	38.252	14.711	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE279 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 6 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 6 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 6 7	81.785	0.000	168.037	0.000	185.390	6.918	76.504	24.713	0.000	0.000
10 6 8	98.066	0.000	208.826	0.000	216.907	13.801	76.504	26.243	0.000	0.000
10 6 9	99.683	0.000	213.339	0.000	222.731	14.903	76.504	26.212	0.000	0.000
10 610	99.683	0.000	208.758	0.000	233.741	18.112	76.504	26.547	0.000	0.000
10 611	99.683	0.000	185.850	0.000	242.575	19.755	76.504	26.258	0.000	0.000
10 612	99.683	0.000	184.930	0.000	254.841	23.047	76.504	26.650	0.000	0.000
10 613	99.683	0.000	204.176	0.000	257.477	23.455	76.504	29.496	0.000	0.000
10 614	99.683	0.000	212.419	0.000	263.092	24.412	76.504	32.415	0.000	0.000
10 615	99.362	0.000	212.908	0.000	261.621	24.133	76.504	35.193	0.000	0.000
10 616	96.460	0.000	208.973	0.000	246.541	20.384	76.504	35.197	0.000	0.000
10 617	84.742	0.000	185.644	0.000	226.989	16.629	76.504	30.947	0.000	0.000
10 618	55.756	0.000	106.856	0.000	208.961	12.379	76.504	24.023	0.000	0.000
10 619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	263.092	24.412	76.504	35.197	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2820.866	217.927	918.051	343.894	0.000	0.000
AV	53.189	0.000	116.048	0.000	117.536	9.080	38.252	14.329	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE280 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 7 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 7 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 7 7	81.785	0.000	168.037	0.000	162.012	5.076	76.504	24.624	0.000	0.000
10 7 8	98.066	0.000	208.826	0.000	228.864	17.504	76.504	26.635	0.000	0.000
10 7 9	99.683	0.000	213.339	0.000	249.611	22.070	76.504	28.225	0.000	0.000
10 710	99.683	0.000	208.758	0.000	253.589	22.782	76.504	30.722	0.000	0.000
10 711	99.683	0.000	185.850	0.000	263.465	25.247	76.504	28.917	0.000	0.000
10 712	99.683	0.000	184.930	0.000	272.299	27.992	76.504	29.082	0.000	0.000
10 713	99.683	0.000	204.176	0.000	284.140	29.802	76.504	30.737	0.000	0.000
10 714	99.683	0.000	212.419	0.000	284.788	29.839	76.504	34.607	0.000	0.000
10 715	99.362	0.000	212.908	0.000	286.750	30.144	76.504	35.360	0.000	0.000
10 716	96.460	0.000	208.973	0.000	254.430	23.565	76.504	37.782	0.000	0.000
10 717	84.742	0.000	185.644	0.000	236.818	20.388	76.504	29.846	0.000	0.000
10 718	55.756	0.000	106.856	0.000	153.912	7.994	76.504	24.391	0.000	0.000
10 719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	286.750	30.144	76.504	37.782	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2930.677	262.403	918.051	360.928	0.000	0.000
AV	53.189	0.000	116.048	0.000	122.112	10.933	38.252	15.039	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE281 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 8 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 8 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 8 7	81.785	0.000	168.037	0.000	116.684	0.904	76.504	24.485	0.000	0.000
10 8 8	98.066	0.000	208.826	0.000	58.817	0.000	76.504	27.489	0.000	0.000
10 8 9	99.683	0.000	213.339	0.000	206.954	13.194	76.504	29.112	0.000	0.000
10 810	99.683	0.000	208.758	0.000	257.882	23.521	76.504	26.991	0.000	0.000
10 811	99.683	0.000	185.850	0.000	252.404	24.416	76.504	25.430	0.000	0.000
10 812	99.683	0.000	184.930	0.000	253.272	22.827	76.504	28.319	0.000	0.000
10 813	99.683	0.000	204.176	0.000	255.160	23.083	76.504	30.801	0.000	0.000
10 814	99.683	0.000	212.419	0.000	241.140	19.407	76.504	36.303	0.000	0.000
10 815	99.362	0.000	212.908	0.000	232.872	17.885	76.504	35.914	0.000	0.000
10 816	96.460	0.000	208.973	0.000	211.275	12.380	76.504	35.990	0.000	0.000
10 817	84.742	0.000	185.644	0.000	124.543	4.955	76.504	28.990	0.000	0.000
10 818	55.756	0.000	106.856	0.000	75.695	0.612	76.504	23.985	0.000	0.000
10 819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	257.882	24.416	76.504	36.303	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2286.699	163.183	918.051	353.809	0.000	0.000
AV	53.189	0.000	116.048	0.000	95.279	6.799	38.252	14.742	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE282 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
10 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 9 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 9 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 9 7	81.785	0.000	168.037	0.000	118.273	0.818	76.504	24.174	0.000	0.000
10 9 8	98.066	0.000	208.826	0.000	181.196	8.648	76.504	24.855	0.000	0.000
10 9 9	99.683	0.000	213.339	0.000	213.581	12.224	76.504	27.007	0.000	0.000
10 910	99.683	0.000	208.758	0.000	255.415	23.264	76.504	26.396	0.000	0.000
10 911	99.683	0.000	185.850	0.000	242.705	19.598	76.504	27.891	0.000	0.000
10 912	99.683	0.000	184.930	0.000	237.036	18.704	76.504	28.790	0.000	0.000
10 913	99.683	0.000	204.176	0.000	240.941	19.469	76.504	30.618	0.000	0.000
10 914	99.683	0.000	212.419	0.000	233.245	16.980	76.504	34.429	0.000	0.000
10 915	99.362	0.000	212.908	0.000	239.092	19.125	76.504	33.753	0.000	0.000
10 916	96.460	0.000	208.973	0.000	217.953	13.817	76.504	33.046	0.000	0.000
10 917	84.742	0.000	185.644	0.000	166.320	8.224	76.504	28.589	0.000	0.000
10 918	55.756	0.000	106.856	0.000	145.656	6.576	76.504	23.949	0.000	0.000
10 919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	255.415	23.264	76.504	34.429	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2491.413	167.448	918.051	343.496	0.000	0.000
AV	53.189	0.000	116.048	0.000	103.809	6.977	38.252	14.312	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE283 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1010 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1010 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1010 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1010 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1010 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1010 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1010 7	5.538	0.000	31.745	0.000	122.446	1.290	76.504	23.949	0.000	0.000
1010 8	5.538	0.000	31.745	0.000	114.450	3.141	76.504	23.949	0.000	0.000
1010 9	5.538	0.000	31.745	0.000	139.790	5.458	76.504	23.949	0.000	0.000
101010	5.538	0.000	31.745	0.000	171.491	7.943	76.504	23.949	0.000	0.000
101011	5.538	0.000	31.745	0.000	228.901	18.960	76.504	23.949	0.000	0.000
101012	5.538	0.000	31.745	0.000	220.607	15.822	76.504	23.949	0.000	0.000
101013	5.538	0.000	31.745	0.000	219.874	15.839	76.504	23.949	0.000	0.000
101014	5.538	0.000	31.745	0.000	195.981	10.580	76.504	23.949	0.000	0.000
101015	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101016	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101017	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101018	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101019	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101020	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101021	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101022	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101023	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101024	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 10)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	228.901	18.960	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1413.542	79.033	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	58.898	3.293	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE286 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1013 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1013 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1013 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1013 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1013 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1013 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1013 7	81.785	0.000	168.037	0.000	116.497	0.645	76.504	24.001	0.000	0.000
1013 8	98.066	0.000	208.826	0.000	112.959	3.039	76.504	25.355	0.000	0.000
1013 9	99.683	0.000	213.339	0.000	153.906	6.532	76.504	25.414	0.000	0.000
101310	99.683	0.000	208.758	0.000	222.122	15.004	76.504	26.071	0.000	0.000
101311	99.683	0.000	185.850	0.000	216.774	13.562	76.504	26.516	0.000	0.000
101312	99.683	0.000	184.930	0.000	211.339	12.492	76.504	26.561	0.000	0.000
101313	99.683	0.000	204.176	0.000	233.045	18.083	76.504	26.184	0.000	0.000
101314	99.683	0.000	212.419	0.000	241.071	19.446	76.504	30.896	0.000	0.000
101315	99.362	0.000	212.908	0.000	228.451	16.916	76.504	32.211	0.000	0.000
101316	96.460	0.000	208.973	0.000	215.966	13.503	76.504	30.635	0.000	0.000
101317	84.742	0.000	185.644	0.000	108.091	3.001	76.504	28.018	0.000	0.000
101318	55.756	0.000	106.856	0.000	71.429	0.000	76.504	23.949	0.000	0.000
101319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	241.071	19.446	76.504	32.211	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2131.651	122.223	918.051	325.811	0.000	0.000
AV	53.189	0.000	116.048	0.000	88.819	5.093	38.252	13.575	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE287 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1014 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1014 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1014 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1014 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1014 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1014 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1014 7	81.785	0.000	168.037	0.000	141.757	2.225	76.504	23.949	0.000	0.000
1014 8	98.066	0.000	208.826	0.000	143.784	4.503	76.504	24.809	0.000	0.000
1014 9	99.683	0.000	213.339	0.000	175.123	7.126	76.504	25.159	0.000	0.000
101410	99.683	0.000	208.758	0.000	192.018	8.341	76.504	24.949	0.000	0.000
101411	99.683	0.000	185.850	0.000	210.796	11.281	76.504	24.325	0.000	0.000
101412	99.683	0.000	184.930	0.000	205.640	10.049	76.504	25.239	0.000	0.000
101413	99.683	0.000	204.176	0.000	212.807	12.164	76.504	26.514	0.000	0.000
101414	99.683	0.000	212.419	0.000	204.101	9.895	76.504	27.764	0.000	0.000
101415	99.362	0.000	212.908	0.000	223.131	14.636	76.504	29.924	0.000	0.000
101416	96.460	0.000	208.973	0.000	207.754	10.434	76.504	31.435	0.000	0.000
101417	84.742	0.000	185.644	0.000	181.746	8.829	76.504	26.211	0.000	0.000
101418	55.756	0.000	106.856	0.000	99.708	2.264	76.504	23.949	0.000	0.000
101419	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101420	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101421	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101422	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101423	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	223.131	14.636	76.504	31.435	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2198.365	101.745	918.051	314.227	0.000	0.000
AV	53.189	0.000	116.048	0.000	91.599	4.239	38.252	13.093	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE288 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1015 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1015 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1015 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1015 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1015 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1015 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1015 7	81.785	0.000	168.037	0.000	115.467	0.122	76.504	23.949	0.000	0.000
1015 8	98.066	0.000	208.826	0.000	104.379	2.102	76.504	24.661	0.000	0.000
1015 9	99.683	0.000	213.339	0.000	155.950	5.772	76.504	25.015	0.000	0.000
101510	99.683	0.000	208.758	0.000	175.586	7.163	76.504	24.973	0.000	0.000
101511	99.683	0.000	185.850	0.000	212.387	12.101	76.504	24.500	0.000	0.000
101512	99.683	0.000	184.930	0.000	216.681	12.901	76.504	25.934	0.000	0.000
101513	99.683	0.000	204.176	0.000	220.839	13.781	76.504	28.526	0.000	0.000
101514	99.683	0.000	212.419	0.000	224.725	14.834	76.504	31.657	0.000	0.000
101515	99.362	0.000	212.908	0.000	220.976	13.755	76.504	34.474	0.000	0.000
101516	96.460	0.000	208.973	0.000	209.961	11.008	76.504	34.616	0.000	0.000
101517	84.742	0.000	185.644	0.000	151.894	6.141	76.504	30.852	0.000	0.000
101518	55.756	0.000	106.856	0.000	70.476	0.000	76.504	24.063	0.000	0.000
101519	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101520	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101521	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101522	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101523	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	224.725	14.834	76.504	34.616	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2079.321	99.681	918.051	333.220	0.000	0.000
AV	53.189	0.000	116.048	0.000	86.638	4.153	38.252	13.884	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE289 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1016 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1016 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1016 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1016 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1016 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1016 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1016 7	81.785	0.000	168.037	0.000	112.679	0.000	76.504	24.378	0.000	0.000
1016 8	98.066	0.000	208.826	0.000	142.039	4.786	76.504	27.330	0.000	0.000
1016 9	99.683	0.000	213.339	0.000	205.836	10.172	76.504	29.009	0.000	0.000
101610	99.683	0.000	208.758	0.000	222.372	14.098	76.504	29.398	0.000	0.000
101611	99.683	0.000	185.850	0.000	230.791	16.541	76.504	28.089	0.000	0.000
101612	99.683	0.000	184.930	0.000	224.404	14.714	76.504	27.998	0.000	0.000
101613	99.683	0.000	204.176	0.000	233.704	17.157	76.504	30.319	0.000	0.000
101614	99.683	0.000	212.419	0.000	238.598	18.004	76.504	33.775	0.000	0.000
101615	99.362	0.000	212.908	0.000	234.681	17.248	76.504	36.909	0.000	0.000
101616	96.460	0.000	208.973	0.000	228.452	16.069	76.504	36.946	0.000	0.000
101617	84.742	0.000	185.644	0.000	163.489	7.577	76.504	33.975	0.000	0.000
101618	55.756	0.000	106.856	0.000	111.875	3.594	76.504	24.256	0.000	0.000
101619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	238.598	18.004	76.504	36.946	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2348.920	139.958	918.051	362.380	0.000	0.000
AV	53.189	0.000	116.048	0.000	97.872	5.832	38.252	15.099	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE290 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1017 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1017 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1017 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1017 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1017 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1017 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1017 7	5.538	0.000	31.745	0.000	113.764	0.257	76.504	23.949	0.000	0.000
1017 8	5.538	0.000	31.745	0.000	120.974	3.993	76.504	23.949	0.000	0.000
1017 9	5.538	0.000	31.745	0.000	205.925	11.891	76.504	23.949	0.000	0.000
101710	5.538	0.000	31.745	0.000	217.090	15.146	76.504	23.949	0.000	0.000
101711	5.538	0.000	31.745	0.000	207.301	11.984	76.504	23.949	0.000	0.000
101712	5.538	0.000	31.745	0.000	195.418	11.033	76.504	23.949	0.000	0.000
101713	5.538	0.000	31.745	0.000	217.397	15.375	76.504	23.949	0.000	0.000
101714	5.538	0.000	31.745	0.000	219.565	15.715	76.504	23.949	0.000	0.000
101715	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101716	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101717	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101718	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101719	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101720	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101721	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101722	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101723	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101724	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 17)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	219.565	15.715	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1497.435	85.394	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	62.393	3.558	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE292 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1019 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1019 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1019 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1019 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1019 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1019 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1019 7	81.785	0.000	168.037	0.000	190.770	3.851	76.504	23.949	0.000	0.000
1019 8	98.066	0.000	208.826	0.000	217.008	9.262	76.504	24.829	0.000	0.000
1019 9	99.683	0.000	213.339	0.000	228.249	11.570	76.504	25.314	0.000	0.000
101910	99.683	0.000	208.758	0.000	238.120	14.595	76.504	25.026	0.000	0.000
101911	99.683	0.000	185.850	0.000	241.602	15.152	76.504	25.051	0.000	0.000
101912	99.683	0.000	184.930	0.000	253.711	24.752	76.504	24.945	0.000	0.000
101913	99.683	0.000	204.176	0.000	253.465	22.811	76.504	27.358	0.000	0.000
101914	99.683	0.000	212.419	0.000	256.617	23.340	76.504	29.362	0.000	0.000
101915	99.362	0.000	212.908	0.000	253.802	22.821	76.504	27.868	0.000	0.000
101916	96.460	0.000	208.973	0.000	250.528	22.986	76.504	34.214	0.000	0.000
101917	84.742	0.000	185.644	0.000	174.154	9.575	76.504	30.167	0.000	0.000
101918	55.756	0.000	106.856	0.000	115.846	4.344	76.504	24.021	0.000	0.000
101919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
101924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	256.617	24.752	76.504	34.214	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2673.871	185.058	918.051	322.105	0.000	0.000
AV	53.189	0.000	116.048	0.000	111.411	7.711	38.252	13.421	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE293 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1020 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1020 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1020 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1020 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1020 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1020 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1020 7	81.785	0.000	168.037	0.000	204.782	7.843	76.504	24.058	0.000	0.000
1020 8	98.066	0.000	208.826	0.000	205.536	10.604	76.504	25.243	0.000	0.000
1020 9	99.683	0.000	213.339	0.000	204.366	10.341	76.504	25.008	0.000	0.000
102010	99.683	0.000	208.758	0.000	182.064	8.820	76.504	25.647	0.000	0.000
102011	99.683	0.000	185.850	0.000	176.981	8.456	76.504	24.719	0.000	0.000
102012	99.683	0.000	184.930	0.000	159.422	7.559	76.504	25.130	0.000	0.000
102013	99.683	0.000	204.176	0.000	230.199	17.660	76.504	25.174	0.000	0.000
102014	99.683	0.000	212.419	0.000	243.372	18.832	76.504	26.346	0.000	0.000
102015	99.362	0.000	212.908	0.000	230.075	15.762	76.504	26.935	0.000	0.000
102016	96.460	0.000	208.973	0.000	212.645	11.558	76.504	26.886	0.000	0.000
102017	84.742	0.000	185.644	0.000	185.446	7.665	76.504	24.505	0.000	0.000
102018	55.756	0.000	106.856	0.000	143.835	5.092	76.504	23.949	0.000	0.000
102019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	243.372	18.832	76.504	26.935	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2378.723	130.191	918.051	303.600	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.113	5.425	38.252	12.650	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE294 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1021 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1021 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1021 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1021 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1021 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1021 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1021 7	81.785	0.000	168.037	0.000	117.287	0.695	76.504	23.949	0.000	0.000
1021 8	98.066	0.000	208.826	0.000	75.948	0.054	76.504	26.234	0.000	0.000
1021 9	99.683	0.000	213.339	0.000	185.128	8.952	76.504	25.397	0.000	0.000
102110	99.683	0.000	208.758	0.000	210.455	11.499	76.504	25.263	0.000	0.000
102111	99.683	0.000	185.850	0.000	212.653	12.054	76.504	24.473	0.000	0.000
102112	99.683	0.000	184.930	0.000	221.182	13.884	76.504	24.650	0.000	0.000
102113	99.683	0.000	204.176	0.000	229.252	16.264	76.504	25.689	0.000	0.000
102114	99.683	0.000	212.419	0.000	226.493	15.674	76.504	26.378	0.000	0.000
102115	99.362	0.000	212.908	0.000	225.167	14.926	76.504	25.966	0.000	0.000
102116	96.460	0.000	208.973	0.000	221.682	13.910	76.504	26.710	0.000	0.000
102117	84.742	0.000	185.644	0.000	213.189	12.139	76.504	24.772	0.000	0.000
102118	55.756	0.000	106.856	0.000	196.429	9.870	76.504	23.949	0.000	0.000
102119	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102120	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102121	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102122	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102123	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	229.252	16.264	76.504	26.710	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2334.865	129.920	918.051	303.429	0.000	0.000
AV	53.189	0.000	116.048	0.000	97.286	5.413	38.252	12.643	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE295 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1022 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1022 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1022 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1022 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1022 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1022 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1022 7	81.785	0.000	168.037	0.000	121.116	1.525	76.504	23.949	0.000	0.000
1022 8	98.066	0.000	208.826	0.000	123.786	4.573	76.504	24.669	0.000	0.000
1022 9	99.683	0.000	213.339	0.000	122.479	4.442	76.504	24.815	0.000	0.000
102210	99.683	0.000	208.758	0.000	167.992	8.810	76.504	24.568	0.000	0.000
102211	99.683	0.000	185.850	0.000	162.158	8.341	76.504	24.251	0.000	0.000
102212	99.683	0.000	184.930	0.000	215.626	15.945	76.504	24.018	0.000	0.000
102213	99.683	0.000	204.176	0.000	261.684	27.853	76.504	24.383	0.000	0.000
102214	99.683	0.000	212.419	0.000	289.577	33.666	76.504	25.629	0.000	0.000
102215	99.362	0.000	212.908	0.000	252.961	23.290	76.504	26.889	0.000	0.000
102216	96.460	0.000	208.973	0.000	251.114	24.444	76.504	26.570	0.000	0.000
102217	84.742	0.000	185.644	0.000	221.539	16.023	76.504	24.664	0.000	0.000
102218	55.756	0.000	106.856	0.000	208.379	13.617	76.504	23.949	0.000	0.000
102219	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102220	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102221	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102222	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102223	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	289.577	33.666	76.504	26.889	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2398.412	182.530	918.051	298.354	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.934	7.605	38.252	12.431	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE296 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1023 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1023 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1023 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1023 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1023 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1023 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1023 7	81.785	0.000	168.037	0.000	122.325	2.059	76.504	23.949	0.000	0.000
1023 8	98.066	0.000	208.826	0.000	168.362	8.811	76.504	24.479	0.000	0.000
1023 9	99.683	0.000	213.339	0.000	204.160	11.422	76.504	24.701	0.000	0.000
102310	99.683	0.000	208.758	0.000	226.870	17.440	76.504	26.116	0.000	0.000
102311	99.683	0.000	185.850	0.000	215.418	13.813	76.504	26.636	0.000	0.000
102312	99.683	0.000	184.930	0.000	228.439	17.150	76.504	26.307	0.000	0.000
102313	99.683	0.000	204.176	0.000	233.362	17.993	76.504	29.505	0.000	0.000
102314	99.683	0.000	212.419	0.000	242.223	19.708	76.504	30.829	0.000	0.000
102315	99.362	0.000	212.908	0.000	231.129	17.463	76.504	34.647	0.000	0.000
102316	96.460	0.000	208.973	0.000	218.021	13.936	76.504	32.987	0.000	0.000
102317	84.742	0.000	185.644	0.000	155.112	6.946	76.504	28.350	0.000	0.000
102318	55.756	0.000	106.856	0.000	102.043	2.462	76.504	23.949	0.000	0.000
102319	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102320	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102321	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102322	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102323	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102324	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	242.223	19.708	76.504	34.647	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2347.463	149.203	918.051	332.454	0.000	0.000
AV	53.189	0.000	116.048	0.000	97.811	6.217	38.252	13.852	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE297 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1024 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1024 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1024 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1024 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1024 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1024 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1024 7	5.538	0.000	31.745	0.000	113.851	0.021	76.504	23.949	0.000	0.000
1024 8	5.538	0.000	31.745	0.000	90.555	0.983	76.504	23.949	0.000	0.000
1024 9	5.538	0.000	31.745	0.000	139.975	5.485	76.504	23.949	0.000	0.000
102410	5.538	0.000	31.745	0.000	205.958	11.330	76.504	23.949	0.000	0.000
102411	5.538	0.000	31.745	0.000	210.275	12.720	76.504	23.949	0.000	0.000
102412	5.538	0.000	31.745	0.000	217.057	15.202	76.504	23.949	0.000	0.000
102413	5.538	0.000	31.745	0.000	214.059	14.435	76.504	23.949	0.000	0.000
102414	5.538	0.000	31.745	0.000	193.829	10.934	76.504	23.949	0.000	0.000
102415	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102424	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 24)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	217.057	15.202	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1385.559	71.110	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	57.732	2.963	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE299 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1026 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1026 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1026 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1026 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1026 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1026 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1026 7	81.785	0.000	168.037	0.000	114.045	0.000	76.504	23.949	0.000	0.000
1026 8	98.066	0.000	208.826	0.000	58.099	0.000	76.504	25.571	0.000	0.000
1026 9	99.683	0.000	213.339	0.000	108.751	0.542	76.504	26.644	0.000	0.000
102610	99.683	0.000	208.758	0.000	172.168	4.485	76.504	27.172	0.000	0.000
102611	99.683	0.000	185.850	0.000	207.110	7.787	76.504	25.826	0.000	0.000
102612	99.683	0.000	184.930	0.000	204.740	8.007	76.504	26.887	0.000	0.000
102613	99.683	0.000	204.176	0.000	179.859	6.405	76.504	30.735	0.000	0.000
102614	99.683	0.000	212.419	0.000	164.877	5.084	76.504	34.094	0.000	0.000
102615	99.362	0.000	212.908	0.000	167.778	5.229	76.504	34.938	0.000	0.000
102616	96.460	0.000	208.973	0.000	140.583	3.535	76.504	34.568	0.000	0.000
102617	84.742	0.000	185.644	0.000	61.456	0.000	76.504	30.204	0.000	0.000
102618	55.756	0.000	106.856	0.000	58.057	0.000	76.504	23.949	0.000	0.000
102619	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102620	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102621	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102622	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102623	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	207.110	8.007	76.504	34.938	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1637.523	41.075	918.051	344.537	0.000	0.000
AV	53.189	0.000	116.048	0.000	68.230	1.711	38.252	14.356	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE300 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1027 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1027 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1027 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1027 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1027 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1027 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1027 7	81.785	0.000	168.037	0.000	111.921	0.000	76.504	23.949	0.000	0.000
1027 8	98.066	0.000	208.826	0.000	58.065	0.000	76.504	25.306	0.000	0.000
1027 9	99.683	0.000	213.339	0.000	67.459	0.000	76.504	27.071	0.000	0.000
102710	99.683	0.000	208.758	0.000	169.930	4.980	76.504	26.337	0.000	0.000
102711	99.683	0.000	185.850	0.000	168.729	6.205	76.504	27.356	0.000	0.000
102712	99.683	0.000	184.930	0.000	187.658	7.686	76.504	26.901	0.000	0.000
102713	99.683	0.000	204.176	0.000	206.906	9.756	76.504	29.857	0.000	0.000
102714	99.683	0.000	212.419	0.000	204.762	8.890	76.504	32.380	0.000	0.000
102715	99.362	0.000	212.908	0.000	188.745	7.294	76.504	33.200	0.000	0.000
102716	96.460	0.000	208.973	0.000	148.064	4.663	76.504	33.265	0.000	0.000
102717	84.742	0.000	185.644	0.000	63.159	0.000	76.504	28.536	0.000	0.000
102718	55.756	0.000	106.856	0.000	58.160	0.000	76.504	23.949	0.000	0.000
102719	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102720	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102721	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102722	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102723	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	206.906	9.756	76.504	33.265	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1633.557	49.474	918.051	338.105	0.000	0.000
AV	53.189	0.000	116.048	0.000	68.065	2.061	38.252	14.088	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE301 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1028 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1028 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1028 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1028 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1028 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1028 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1028 7	81.785	0.000	168.037	0.000	111.973	0.000	76.504	23.949	0.000	0.000
1028 8	98.066	0.000	208.826	0.000	58.134	0.000	76.504	26.101	0.000	0.000
1028 9	99.683	0.000	213.339	0.000	89.306	0.000	76.504	27.719	0.000	0.000
102810	99.683	0.000	208.758	0.000	173.603	5.170	76.504	27.373	0.000	0.000
102811	99.683	0.000	185.850	0.000	210.855	8.179	76.504	25.718	0.000	0.000
102812	99.683	0.000	184.930	0.000	219.713	9.970	76.504	25.527	0.000	0.000
102813	99.683	0.000	204.176	0.000	221.080	11.658	76.504	27.991	0.000	0.000
102814	99.683	0.000	212.419	0.000	214.599	11.931	76.504	35.404	0.000	0.000
102815	99.362	0.000	212.908	0.000	171.844	6.754	76.504	37.923	0.000	0.000
102816	96.460	0.000	208.973	0.000	155.671	5.202	76.504	35.198	0.000	0.000
102817	84.742	0.000	185.644	0.000	91.056	0.547	76.504	30.484	0.000	0.000
102818	55.756	0.000	106.856	0.000	69.586	0.000	76.504	23.949	0.000	0.000
102819	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102820	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102821	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102822	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102823	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	221.080	11.931	76.504	37.923	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1787.420	59.411	918.051	347.336	0.000	0.000
AV	53.189	0.000	116.048	0.000	74.476	2.475	38.252	14.472	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE302 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1029 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1029 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1029 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1029 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1029 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1029 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1029 7	81.785	0.000	168.037	0.000	112.152	0.000	76.504	23.949	0.000	0.000
1029 8	98.066	0.000	208.826	0.000	58.137	0.000	76.504	26.195	0.000	0.000
1029 9	99.683	0.000	213.339	0.000	148.126	2.778	76.504	26.123	0.000	0.000
102910	99.683	0.000	208.758	0.000	211.276	7.585	76.504	26.094	0.000	0.000
102911	99.683	0.000	185.850	0.000	223.047	9.443	76.504	25.354	0.000	0.000
102912	99.683	0.000	184.930	0.000	227.984	10.681	76.504	24.784	0.000	0.000
102913	99.683	0.000	204.176	0.000	233.160	11.479	76.504	26.260	0.000	0.000
102914	99.683	0.000	212.419	0.000	238.012	11.889	76.504	27.306	0.000	0.000
102915	99.362	0.000	212.908	0.000	240.673	12.547	76.504	28.171	0.000	0.000
102916	96.460	0.000	208.973	0.000	232.618	11.654	76.504	29.388	0.000	0.000
102917	84.742	0.000	185.644	0.000	212.818	8.189	76.504	26.502	0.000	0.000
102918	55.756	0.000	106.856	0.000	142.421	2.473	76.504	23.949	0.000	0.000
102919	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102920	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102921	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102922	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102923	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
102924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	240.673	12.547	76.504	29.388	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2280.423	88.717	918.051	314.076	0.000	0.000
AV	53.189	0.000	116.048	0.000	95.018	3.697	38.252	13.086	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE303 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1030 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1030 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1030 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1030 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1030 5	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1030 6	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1030 7	81.785	0.000	168.037	0.000	113.017	0.000	76.504	23.949	0.000	0.000
1030 8	98.066	0.000	208.826	0.000	105.144	0.000	76.504	25.117	0.000	0.000
1030 9	99.683	0.000	213.339	0.000	203.167	5.393	76.504	24.895	0.000	0.000
103010	99.683	0.000	208.758	0.000	219.320	8.198	76.504	25.807	0.000	0.000
103011	99.683	0.000	185.850	0.000	226.161	9.904	76.504	24.846	0.000	0.000
103012	99.683	0.000	184.930	0.000	230.213	11.024	76.504	24.391	0.000	0.000
103013	99.683	0.000	204.176	0.000	236.205	11.929	76.504	25.189	0.000	0.000
103014	99.683	0.000	212.419	0.000	232.293	11.314	76.504	25.836	0.000	0.000
103015	99.362	0.000	212.908	0.000	222.446	10.370	76.504	29.305	0.000	0.000
103016	96.460	0.000	208.973	0.000	207.109	7.727	76.504	29.492	0.000	0.000
103017	84.742	0.000	185.644	0.000	163.147	4.518	76.504	26.319	0.000	0.000
103018	55.756	0.000	106.856	0.000	124.423	1.923	76.504	23.949	0.000	0.000
103019	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103020	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103021	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103022	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103023	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103024	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	236.205	11.929	76.504	29.492	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2282.645	82.300	918.051	309.095	0.000	0.000
AV	53.189	0.000	116.048	0.000	95.110	3.429	38.252	12.879	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE304 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1031 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1031 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1031 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1031 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1031 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1031 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1031 7	5.538	0.000	31.745	0.000	112.807	0.000	76.504	23.949	0.000	0.000
1031 8	5.538	0.000	31.745	0.000	101.396	0.000	76.504	23.949	0.000	0.000
1031 9	5.538	0.000	31.745	0.000	175.472	4.206	76.504	23.949	0.000	0.000
103110	5.538	0.000	31.745	0.000	206.383	6.546	76.504	23.949	0.000	0.000
103111	5.538	0.000	31.745	0.000	205.308	7.387	76.504	23.949	0.000	0.000
103112	5.538	0.000	31.745	0.000	175.179	5.183	76.504	23.949	0.000	0.000
103113	5.538	0.000	31.745	0.000	175.096	5.164	76.504	23.949	0.000	0.000
103114	5.538	0.000	31.745	0.000	175.044	5.382	76.504	23.949	0.000	0.000
103115	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
103124	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (OCT 31)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	206.383	7.387	76.504	23.949	0.000	0.000
SM	129.035	0.000	739.669	0.000	1326.685	33.867	612.034	191.589	0.000	0.000
AV	5.376	0.000	30.820	0.000	55.279	1.411	25.501	7.983	0.000	0.000
MONTHLY SUMMARY (OCT)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	289.577	33.666	76.504	37.923	0.000	0.000
SM	27667.252	0.000	63418.328	0.000	55755.543	3234.381	22339.242	7924.787	0.000	0.000
AV	37.187	0.000	85.240	0.000	74.940	4.347	30.026	10.652	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE306 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 2 8	81.785	0.000	168.037	0.000	114.195	0.000	76.504	23.949	0.000	0.000
11 2 9	98.066	0.000	208.826	0.000	58.346	0.000	76.504	27.305	0.000	0.000
11 210	99.683	0.000	213.339	0.000	156.677	5.137	76.504	26.669	0.000	0.000
11 211	99.683	0.000	208.758	0.000	190.843	7.172	76.504	26.817	0.000	0.000
11 212	99.683	0.000	185.850	0.000	196.076	8.203	76.504	26.355	0.000	0.000
11 213	99.683	0.000	184.930	0.000	202.205	8.637	76.504	27.334	0.000	0.000
11 214	99.683	0.000	204.176	0.000	211.318	10.670	76.504	29.890	0.000	0.000
11 215	99.683	0.000	212.419	0.000	201.653	9.012	76.504	33.363	0.000	0.000
11 216	99.362	0.000	212.908	0.000	145.891	5.255	76.504	32.653	0.000	0.000
11 217	96.460	0.000	208.973	0.000	108.838	2.545	76.504	28.023	0.000	0.000
11 218	84.742	0.000	185.644	0.000	99.285	1.534	76.504	25.063	0.000	0.000
11 219	55.756	0.000	106.856	0.000	67.189	0.000	76.504	23.949	0.000	0.000
11 220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	211.318	10.670	76.504	33.363	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1752.516	58.165	918.051	331.369	0.000	0.000
AV	53.189	0.000	116.048	0.000	73.022	2.424	38.252	13.807	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE307 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 3 8	81.785	0.000	168.037	0.000	112.740	0.000	76.504	24.005	0.000	0.000
11 3 9	98.066	0.000	208.826	0.000	111.519	2.008	76.504	24.466	0.000	0.000
11 310	99.683	0.000	213.339	0.000	136.683	3.969	76.504	24.458	0.000	0.000
11 311	99.683	0.000	208.758	0.000	182.621	8.276	76.504	24.412	0.000	0.000
11 312	99.683	0.000	185.850	0.000	180.120	8.177	76.504	24.265	0.000	0.000
11 313	99.683	0.000	184.930	0.000	182.226	8.369	76.504	24.424	0.000	0.000
11 314	99.683	0.000	204.176	0.000	190.466	8.938	76.504	25.150	0.000	0.000
11 315	99.683	0.000	212.419	0.000	169.088	7.441	76.504	25.770	0.000	0.000
11 316	99.362	0.000	212.908	0.000	70.484	0.000	76.504	26.200	0.000	0.000
11 317	96.460	0.000	208.973	0.000	74.474	0.000	76.504	25.031	0.000	0.000
11 318	84.742	0.000	185.644	0.000	74.677	0.000	76.504	24.113	0.000	0.000
11 319	55.756	0.000	106.856	0.000	71.172	0.000	76.504	23.949	0.000	0.000
11 320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	190.466	8.938	76.504	26.200	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1556.270	47.177	918.051	296.242	0.000	0.000
AV	53.189	0.000	116.048	0.000	64.845	1.966	38.252	12.343	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE308 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 4 8	81.785	0.000	168.037	0.000	113.264	0.203	76.504	23.949	0.000	0.000
11 4 9	98.066	0.000	208.826	0.000	79.055	0.576	76.504	24.995	0.000	0.000
11 410	99.683	0.000	213.339	0.000	157.513	6.895	76.504	25.865	0.000	0.000
11 411	99.683	0.000	208.758	0.000	197.340	9.228	76.504	25.571	0.000	0.000
11 412	99.683	0.000	185.850	0.000	211.108	11.760	76.504	25.553	0.000	0.000
11 413	99.683	0.000	184.930	0.000	203.065	9.817	76.504	27.469	0.000	0.000
11 414	99.683	0.000	204.176	0.000	211.641	11.485	76.504	29.598	0.000	0.000
11 415	99.683	0.000	212.419	0.000	208.903	10.789	76.504	32.607	0.000	0.000
11 416	99.362	0.000	212.908	0.000	148.150	5.435	76.504	34.013	0.000	0.000
11 417	96.460	0.000	208.973	0.000	61.131	0.000	76.504	31.775	0.000	0.000
11 418	84.742	0.000	185.644	0.000	58.129	0.000	76.504	26.113	0.000	0.000
11 419	55.756	0.000	106.856	0.000	57.948	0.000	76.504	23.949	0.000	0.000
11 420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	211.641	11.760	76.504	34.013	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1707.247	66.188	918.051	331.456	0.000	0.000
AV	53.189	0.000	116.048	0.000	71.135	2.758	38.252	13.811	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE309 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 5 8	81.785	0.000	168.037	0.000	112.359	0.000	76.504	23.949	0.000	0.000
11 5 9	98.066	0.000	208.826	0.000	58.361	0.000	76.504	28.226	0.000	0.000
11 510	99.683	0.000	213.339	0.000	106.652	1.900	76.504	28.492	0.000	0.000
11 511	99.683	0.000	208.758	0.000	189.696	8.021	76.504	27.362	0.000	0.000
11 512	99.683	0.000	185.850	0.000	184.701	7.780	76.504	27.169	0.000	0.000
11 513	99.683	0.000	184.930	0.000	209.236	10.972	76.504	27.489	0.000	0.000
11 514	99.683	0.000	204.176	0.000	208.401	10.018	76.504	31.175	0.000	0.000
11 515	99.683	0.000	212.419	0.000	205.738	9.465	76.504	34.764	0.000	0.000
11 516	99.362	0.000	212.908	0.000	140.857	4.497	76.504	36.675	0.000	0.000
11 517	96.460	0.000	208.973	0.000	60.961	0.000	76.504	33.833	0.000	0.000
11 518	84.742	0.000	185.644	0.000	58.080	0.000	76.504	27.006	0.000	0.000
11 519	55.756	0.000	106.856	0.000	57.982	0.000	76.504	23.949	0.000	0.000
11 520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	209.236	10.972	76.504	36.675	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1593.024	52.653	918.051	350.090	0.000	0.000
AV	53.189	0.000	116.048	0.000	66.376	2.194	38.252	14.587	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE310 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 6 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 6 8	81.785	0.000	168.037	0.000	112.106	0.000	76.504	23.949	0.000	0.000
11 6 9	98.066	0.000	208.826	0.000	58.258	0.000	76.504	26.213	0.000	0.000
11 610	99.683	0.000	213.339	0.000	107.474	1.116	76.504	26.059	0.000	0.000
11 611	99.683	0.000	208.758	0.000	181.894	6.320	76.504	25.168	0.000	0.000
11 612	99.683	0.000	185.850	0.000	217.059	11.379	76.504	24.504	0.000	0.000
11 613	99.683	0.000	184.930	0.000	226.290	15.079	76.504	25.653	0.000	0.000
11 614	99.683	0.000	204.176	0.000	220.913	13.719	76.504	29.379	0.000	0.000
11 615	99.683	0.000	212.419	0.000	213.410	11.764	76.504	31.507	0.000	0.000
11 616	99.362	0.000	212.908	0.000	148.003	4.750	76.504	32.939	0.000	0.000
11 617	96.460	0.000	208.973	0.000	67.325	0.000	76.504	30.128	0.000	0.000
11 618	84.742	0.000	185.644	0.000	72.606	0.000	76.504	25.212	0.000	0.000
11 619	55.756	0.000	106.856	0.000	58.643	0.000	76.504	23.949	0.000	0.000
11 620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 6)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	226.290	15.079	76.504	32.939	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1683.980	64.127	918.051	324.658	0.000	0.000
AV	53.189	0.000	116.048	0.000	70.166	2.672	38.252	13.527	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE311 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 7 8	5.538	0.000	31.745	0.000	112.434	0.000	76.504	23.949	0.000	0.000
11 7 9	5.538	0.000	31.745	0.000	69.871	0.000	76.504	23.949	0.000	0.000
11 710	5.538	0.000	31.745	0.000	171.600	7.958	76.504	23.949	0.000	0.000
11 711	5.538	0.000	31.745	0.000	205.272	10.335	76.504	23.949	0.000	0.000
11 712	5.538	0.000	31.745	0.000	209.077	11.296	76.504	23.949	0.000	0.000
11 713	5.538	0.000	31.745	0.000	212.583	13.287	76.504	23.949	0.000	0.000
11 714	5.538	0.000	31.745	0.000	196.092	10.535	76.504	23.949	0.000	0.000
11 715	5.538	0.000	31.745	0.000	184.668	9.046	76.504	23.949	0.000	0.000
11 716	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 717	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 718	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 719	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 720	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 721	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 722	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 723	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 724	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	212.583	13.287	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	1361.598	62.457	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	56.733	2.602	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE313 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
11 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 9 8	81.785	0.000	168.037	0.000	121.166	0.000	76.504	24.442	0.000	0.000
11 9 9	98.066	0.000	208.826	0.000	184.747	5.254	76.504	25.408	0.000	0.000
11 910	99.683	0.000	213.339	0.000	212.835	8.764	76.504	26.633	0.000	0.000
11 911	99.683	0.000	208.758	0.000	229.472	12.535	76.504	25.518	0.000	0.000
11 912	99.683	0.000	185.850	0.000	232.547	15.381	76.504	25.133	0.000	0.000
11 913	99.683	0.000	184.930	0.000	239.283	17.547	76.504	25.982	0.000	0.000
11 914	99.683	0.000	204.176	0.000	236.482	14.804	76.504	27.768	0.000	0.000
11 915	99.683	0.000	212.419	0.000	228.008	14.026	76.504	31.896	0.000	0.000
11 916	99.362	0.000	212.908	0.000	241.802	18.616	76.504	32.754	0.000	0.000
11 917	96.460	0.000	208.973	0.000	207.669	10.327	76.504	31.899	0.000	0.000
11 918	84.742	0.000	185.644	0.000	142.723	5.533	76.504	26.762	0.000	0.000
11 919	55.756	0.000	106.856	0.000	102.506	2.439	76.504	23.949	0.000	0.000
11 920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	241.802	18.616	76.504	32.754	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2379.242	125.226	918.051	328.145	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.135	5.218	38.252	13.673	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE314 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1110 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1110 8	81.785	0.000	168.037	0.000	113.391	0.000	76.504	24.949	0.000	0.000
1110 9	98.066	0.000	208.826	0.000	169.754	5.674	76.504	26.175	0.000	0.000
111010	99.683	0.000	213.339	0.000	217.479	11.430	76.504	26.088	0.000	0.000
111011	99.683	0.000	208.758	0.000	234.127	15.182	76.504	25.367	0.000	0.000
111012	99.683	0.000	185.850	0.000	232.852	16.289	76.504	26.791	0.000	0.000
111013	99.683	0.000	184.930	0.000	244.063	19.011	76.504	26.648	0.000	0.000
111014	99.683	0.000	204.176	0.000	239.568	17.550	76.504	27.800	0.000	0.000
111015	99.683	0.000	212.419	0.000	239.170	16.638	76.504	28.709	0.000	0.000
111016	99.362	0.000	212.908	0.000	224.973	12.769	76.504	30.448	0.000	0.000
111017	96.460	0.000	208.973	0.000	206.258	9.480	76.504	30.168	0.000	0.000
111018	84.742	0.000	185.644	0.000	144.711	4.805	76.504	26.147	0.000	0.000
111019	55.756	0.000	106.856	0.000	103.622	1.659	76.504	23.949	0.000	0.000
111020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	244.063	19.011	76.504	30.448	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2369.968	130.489	918.051	323.238	0.000	0.000
AV	53.189	0.000	116.048	0.000	98.749	5.437	38.252	13.468	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE316 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1112 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1112 8	81.785	0.000	168.037	0.000	113.666	0.148	76.504	23.949	0.000	0.000
1112 9	98.066	0.000	208.826	0.000	146.254	5.122	76.504	24.274	0.000	0.000
111210	99.683	0.000	213.339	0.000	149.420	4.850	76.504	26.327	0.000	0.000
111211	99.683	0.000	208.758	0.000	152.463	5.626	76.504	24.943	0.000	0.000
111212	99.683	0.000	185.850	0.000	161.838	6.305	76.504	26.449	0.000	0.000
111213	99.683	0.000	184.930	0.000	183.919	7.815	76.504	26.215	0.000	0.000
111214	99.683	0.000	204.176	0.000	205.468	10.107	76.504	28.681	0.000	0.000
111215	99.683	0.000	212.419	0.000	185.669	8.606	76.504	30.237	0.000	0.000
111216	99.362	0.000	212.908	0.000	108.852	2.584	76.504	29.225	0.000	0.000
111217	96.460	0.000	208.973	0.000	59.933	0.000	76.504	27.600	0.000	0.000
111218	84.742	0.000	185.644	0.000	58.090	0.000	76.504	25.261	0.000	0.000
111219	55.756	0.000	106.856	0.000	58.022	0.000	76.504	23.949	0.000	0.000
111220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	205.468	10.107	76.504	30.237	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1583.595	51.162	918.051	317.110	0.000	0.000
AV	53.189	0.000	116.048	0.000	65.983	2.132	38.252	13.213	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE317 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1113 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1113 8	81.785	0.000	168.037	0.000	111.888	0.000	76.504	24.059	0.000	0.000
1113 9	98.066	0.000	208.826	0.000	67.218	0.000	76.504	25.819	0.000	0.000
111310	99.683	0.000	213.339	0.000	147.048	2.933	76.504	26.047	0.000	0.000
111311	99.683	0.000	208.758	0.000	187.460	5.334	76.504	26.562	0.000	0.000
111312	99.683	0.000	185.850	0.000	206.353	7.397	76.504	25.747	0.000	0.000
111313	99.683	0.000	184.930	0.000	215.266	8.961	76.504	25.859	0.000	0.000
111314	99.683	0.000	204.176	0.000	212.245	9.131	76.504	29.702	0.000	0.000
111315	99.683	0.000	212.419	0.000	186.363	6.381	76.504	35.042	0.000	0.000
111316	99.362	0.000	212.908	0.000	139.883	3.545	76.504	35.395	0.000	0.000
111317	96.460	0.000	208.973	0.000	64.570	0.000	76.504	32.770	0.000	0.000
111318	84.742	0.000	185.644	0.000	86.210	0.000	76.504	25.468	0.000	0.000
111319	55.756	0.000	106.856	0.000	78.767	0.000	76.504	23.949	0.000	0.000
111320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 13)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	215.266	9.131	76.504	35.395	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1703.271	43.682	918.051	336.418	0.000	0.000
AV	53.189	0.000	116.048	0.000	70.970	1.820	38.252	14.017	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE318 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1114 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1114 8	5.538	0.000	31.745	0.000	112.159	0.000	76.504	23.949	0.000	0.000
1114 9	5.538	0.000	31.745	0.000	58.038	0.000	76.504	23.949	0.000	0.000
111410	5.538	0.000	31.745	0.000	76.468	0.000	76.504	23.949	0.000	0.000
111411	5.538	0.000	31.745	0.000	117.474	2.356	76.504	23.949	0.000	0.000
111412	5.538	0.000	31.745	0.000	117.565	2.387	76.504	23.949	0.000	0.000
111413	5.538	0.000	31.745	0.000	135.700	4.007	76.504	23.949	0.000	0.000
111414	5.538	0.000	31.745	0.000	126.557	3.118	76.504	23.949	0.000	0.000
111415	5.538	0.000	31.745	0.000	113.606	2.005	76.504	23.949	0.000	0.000
111416	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111417	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111418	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111419	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111420	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111421	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111422	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111423	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111424	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	135.700	4.007	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	857.567	13.874	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	35.732	0.578	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE320 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1116 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1116 8	81.785	0.000	168.037	0.000	113.578	0.000	76.504	23.949	0.000	0.000
1116 9	98.066	0.000	208.826	0.000	90.343	0.926	76.504	23.949	0.000	0.000
111610	99.683	0.000	213.339	0.000	135.252	4.291	76.504	23.949	0.000	0.000
111611	99.683	0.000	208.758	0.000	187.026	8.534	76.504	23.953	0.000	0.000
111612	99.683	0.000	185.850	0.000	173.141	7.681	76.504	24.053	0.000	0.000
111613	99.683	0.000	184.930	0.000	181.545	8.326	76.504	24.444	0.000	0.000
111614	99.683	0.000	204.176	0.000	179.411	7.544	76.504	25.818	0.000	0.000
111615	99.683	0.000	212.419	0.000	164.759	6.537	76.504	27.806	0.000	0.000
111616	99.362	0.000	212.908	0.000	106.595	2.366	76.504	28.182	0.000	0.000
111617	96.460	0.000	208.973	0.000	59.855	0.000	76.504	25.695	0.000	0.000
111618	84.742	0.000	185.644	0.000	58.132	0.000	76.504	24.147	0.000	0.000
111619	55.756	0.000	106.856	0.000	58.067	0.000	76.504	23.949	0.000	0.000
111620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	187.026	8.534	76.504	28.182	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1507.705	46.206	918.051	299.892	0.000	0.000
AV	53.189	0.000	116.048	0.000	62.821	1.925	38.252	12.496	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE321 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1117 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1117 8	81.785	0.000	168.037	0.000	112.297	0.000	76.504	23.949	0.000	0.000
1117 9	98.066	0.000	208.826	0.000	58.309	0.000	76.504	24.875	0.000	0.000
111710	99.683	0.000	213.339	0.000	100.966	1.481	76.504	25.344	0.000	0.000
111711	99.683	0.000	208.758	0.000	175.443	7.671	76.504	25.993	0.000	0.000
111712	99.683	0.000	185.850	0.000	190.893	8.837	76.504	25.141	0.000	0.000
111713	99.683	0.000	184.930	0.000	195.519	9.276	76.504	26.071	0.000	0.000
111714	99.683	0.000	204.176	0.000	152.647	6.134	76.504	30.060	0.000	0.000
111715	99.683	0.000	212.419	0.000	159.980	6.665	76.504	30.997	0.000	0.000
111716	99.362	0.000	212.908	0.000	113.371	2.852	76.504	31.171	0.000	0.000
111717	96.460	0.000	208.973	0.000	60.304	0.000	76.504	27.458	0.000	0.000
111718	84.742	0.000	185.644	0.000	58.151	0.000	76.504	24.929	0.000	0.000
111719	55.756	0.000	106.856	0.000	58.025	0.000	76.504	23.949	0.000	0.000
111720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	195.519	9.276	76.504	31.171	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1435.907	42.916	918.051	319.937	0.000	0.000
AV	53.189	0.000	116.048	0.000	59.829	1.788	38.252	13.331	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE322 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1118 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1118 8	81.785	0.000	168.037	0.000	112.260	0.000	76.504	23.949	0.000	0.000
1118 9	98.066	0.000	208.826	0.000	58.359	0.000	76.504	24.496	0.000	0.000
111810	99.683	0.000	213.339	0.000	58.079	0.000	76.504	27.476	0.000	0.000
111811	99.683	0.000	208.758	0.000	58.064	0.000	76.504	29.180	0.000	0.000
111812	99.683	0.000	185.850	0.000	72.992	0.000	76.504	25.936	0.000	0.000
111813	99.683	0.000	184.930	0.000	110.464	2.405	76.504	26.972	0.000	0.000
111814	99.683	0.000	204.176	0.000	115.834	2.818	76.504	30.917	0.000	0.000
111815	99.683	0.000	212.419	0.000	76.712	0.000	76.504	33.692	0.000	0.000
111816	99.362	0.000	212.908	0.000	58.732	0.000	76.504	29.889	0.000	0.000
111817	96.460	0.000	208.973	0.000	58.046	0.000	76.504	27.483	0.000	0.000
111818	84.742	0.000	185.644	0.000	58.020	0.000	76.504	24.629	0.000	0.000
111819	55.756	0.000	106.856	0.000	58.018	0.000	76.504	23.949	0.000	0.000
111820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	115.834	2.818	76.504	33.692	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	895.580	5.222	918.051	328.569	0.000	0.000
AV	53.189	0.000	116.048	0.000	37.316	0.218	38.252	13.690	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE323 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1119 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1119 8	81.785	0.000	168.037	0.000	112.348	0.000	76.504	23.949	0.000	0.000
1119 9	98.066	0.000	208.826	0.000	58.264	0.000	76.504	23.949	0.000	0.000
111910	99.683	0.000	213.339	0.000	57.991	0.000	76.504	26.686	0.000	0.000
111911	99.683	0.000	208.758	0.000	157.903	5.924	76.504	25.410	0.000	0.000
111912	99.683	0.000	185.850	0.000	189.728	8.613	76.504	25.201	0.000	0.000
111913	99.683	0.000	184.930	0.000	173.942	7.757	76.504	26.618	0.000	0.000
111914	99.683	0.000	204.176	0.000	205.741	10.238	76.504	28.264	0.000	0.000
111915	99.683	0.000	212.419	0.000	207.714	10.558	76.504	30.570	0.000	0.000
111916	99.362	0.000	212.908	0.000	107.286	2.481	76.504	31.051	0.000	0.000
111917	96.460	0.000	208.973	0.000	60.039	0.000	76.504	27.906	0.000	0.000
111918	84.742	0.000	185.644	0.000	58.142	0.000	76.504	25.088	0.000	0.000
111919	55.756	0.000	106.856	0.000	58.068	0.000	76.504	23.949	0.000	0.000
111920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
111924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	207.714	10.558	76.504	31.051	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1447.164	45.571	918.051	318.640	0.000	0.000
AV	53.189	0.000	116.048	0.000	60.299	1.899	38.252	13.277	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE324 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1120 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1120 8	81.785	0.000	168.037	0.000	112.340	0.000	76.504	23.949	0.000	0.000
1120 9	98.066	0.000	208.826	0.000	173.442	6.195	76.504	24.317	0.000	0.000
112010	99.683	0.000	213.339	0.000	221.152	12.128	76.504	24.509	0.000	0.000
112011	99.683	0.000	208.758	0.000	231.463	14.675	76.504	24.309	0.000	0.000
112012	99.683	0.000	185.850	0.000	232.145	15.353	76.504	24.089	0.000	0.000
112013	99.683	0.000	184.930	0.000	235.152	15.935	76.504	24.338	0.000	0.000
112014	99.683	0.000	204.176	0.000	238.820	15.998	76.504	25.318	0.000	0.000
112015	99.683	0.000	212.419	0.000	238.798	15.170	76.504	27.276	0.000	0.000
112016	99.362	0.000	212.908	0.000	228.556	13.392	76.504	29.055	0.000	0.000
112017	96.460	0.000	208.973	0.000	193.968	7.685	76.504	28.816	0.000	0.000
112018	84.742	0.000	185.644	0.000	174.108	6.875	76.504	25.119	0.000	0.000
112019	55.756	0.000	106.856	0.000	108.868	1.773	76.504	23.949	0.000	0.000
112020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 20)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	238.820	15.998	76.504	29.055	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2388.811	125.178	918.051	305.042	0.000	0.000
AV	53.189	0.000	116.048	0.000	99.534	5.216	38.252	12.710	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE325 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1121 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1121 8	5.538	0.000	31.745	0.000	124.800	0.000	76.504	23.949	0.000	0.000
1121 9	5.538	0.000	31.745	0.000	152.433	4.158	76.504	23.949	0.000	0.000
112110	5.538	0.000	31.745	0.000	177.158	6.374	76.504	23.949	0.000	0.000
112111	5.538	0.000	31.745	0.000	182.390	7.679	76.504	23.949	0.000	0.000
112112	5.538	0.000	31.745	0.000	190.196	8.249	76.504	23.949	0.000	0.000
112113	5.538	0.000	31.745	0.000	206.997	10.859	76.504	23.949	0.000	0.000
112114	5.538	0.000	31.745	0.000	207.590	10.960	76.504	23.949	0.000	0.000
112115	5.538	0.000	31.745	0.000	206.405	10.701	76.504	23.949	0.000	0.000
112116	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112117	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112118	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112119	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112120	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112121	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112122	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112123	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112124	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	207.590	10.960	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	1447.969	58.980	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	60.332	2.457	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE327 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1123 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1123 8	81.785	0.000	168.037	0.000	115.356	0.000	76.504	23.949	0.000	0.000
1123 9	98.066	0.000	208.826	0.000	58.324	0.000	76.504	23.949	0.000	0.000
112310	99.683	0.000	213.339	0.000	57.994	0.000	76.504	25.112	0.000	0.000
112311	99.683	0.000	208.758	0.000	105.715	2.055	76.504	25.258	0.000	0.000
112312	99.683	0.000	185.850	0.000	204.575	10.151	76.504	24.184	0.000	0.000
112313	99.683	0.000	184.930	0.000	210.631	11.099	76.504	24.391	0.000	0.000
112314	99.683	0.000	204.176	0.000	142.265	5.398	76.504	28.435	0.000	0.000
112315	99.683	0.000	212.419	0.000	72.694	0.000	76.504	27.972	0.000	0.000
112316	99.362	0.000	212.908	0.000	58.692	0.000	76.504	27.887	0.000	0.000
112317	96.460	0.000	208.973	0.000	58.046	0.000	76.504	25.773	0.000	0.000
112318	84.742	0.000	185.644	0.000	58.020	0.000	76.504	24.313	0.000	0.000
112319	55.756	0.000	106.856	0.000	58.018	0.000	76.504	23.949	0.000	0.000
112320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	210.631	11.099	76.504	28.435	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1200.330	28.703	918.051	305.171	0.000	0.000
AV	53.189	0.000	116.048	0.000	50.014	1.196	38.252	12.715	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE328 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1124 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1124 8	81.785	0.000	168.037	0.000	112.760	0.000	76.504	23.949	0.000	0.000
1124 9	98.066	0.000	208.826	0.000	58.428	0.000	76.504	23.949	0.000	0.000
112410	99.683	0.000	213.339	0.000	58.039	0.000	76.504	24.324	0.000	0.000
112411	99.683	0.000	208.758	0.000	95.276	1.024	76.504	24.088	0.000	0.000
112412	99.683	0.000	185.850	0.000	128.607	3.706	76.504	24.540	0.000	0.000
112413	99.683	0.000	184.930	0.000	171.640	6.868	76.504	24.598	0.000	0.000
112414	99.683	0.000	204.176	0.000	178.752	7.442	76.504	25.800	0.000	0.000
112415	99.683	0.000	212.419	0.000	103.197	1.840	76.504	31.312	0.000	0.000
112416	99.362	0.000	212.908	0.000	71.413	0.000	76.504	30.013	0.000	0.000
112417	96.460	0.000	208.973	0.000	86.523	0.000	76.504	25.700	0.000	0.000
112418	84.742	0.000	185.644	0.000	82.150	0.000	76.504	24.169	0.000	0.000
112419	55.756	0.000	106.856	0.000	58.516	0.000	76.504	23.949	0.000	0.000
112420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	178.752	7.442	76.504	31.312	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1205.301	20.880	918.051	306.390	0.000	0.000
AV	53.189	0.000	116.048	0.000	50.221	0.870	38.252	12.766	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE329 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1125 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1125 8	81.785	0.000	168.037	0.000	111.764	0.000	76.504	23.949	0.000	0.000
1125 9	98.066	0.000	208.826	0.000	58.003	0.000	76.504	25.431	0.000	0.000
112510	99.683	0.000	213.339	0.000	57.731	0.000	76.504	28.096	0.000	0.000
112511	99.683	0.000	208.758	0.000	57.741	0.000	76.504	28.490	0.000	0.000
112512	99.683	0.000	185.850	0.000	106.805	0.265	76.504	25.814	0.000	0.000
112513	99.683	0.000	184.930	0.000	165.091	3.616	76.504	25.774	0.000	0.000
112514	99.683	0.000	204.176	0.000	174.441	4.188	76.504	28.758	0.000	0.000
112515	99.683	0.000	212.419	0.000	179.885	4.531	76.504	30.614	0.000	0.000
112516	99.362	0.000	212.908	0.000	110.817	0.516	76.504	32.984	0.000	0.000
112517	96.460	0.000	208.973	0.000	59.416	0.000	76.504	30.402	0.000	0.000
112518	84.742	0.000	185.644	0.000	57.724	0.000	76.504	25.277	0.000	0.000
112519	55.756	0.000	106.856	0.000	57.702	0.000	76.504	23.949	0.000	0.000
112520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 25)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	179.885	4.531	76.504	32.984	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1197.120	13.117	918.051	329.537	0.000	0.000
AV	53.189	0.000	116.048	0.000	49.880	0.547	38.252	13.731	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE331 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1127 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1127 8	81.785	0.000	168.037	0.000	111.626	0.000	76.504	23.949	0.000	0.000
1127 9	98.066	0.000	208.826	0.000	57.949	0.000	76.504	25.056	0.000	0.000
112710	99.683	0.000	213.339	0.000	86.470	0.000	76.504	25.664	0.000	0.000
112711	99.683	0.000	208.758	0.000	159.703	3.343	76.504	24.946	0.000	0.000
112712	99.683	0.000	185.850	0.000	178.721	5.216	76.504	25.121	0.000	0.000
112713	99.683	0.000	184.930	0.000	166.537	5.495	76.504	26.412	0.000	0.000
112714	99.683	0.000	204.176	0.000	155.984	4.277	76.504	29.895	0.000	0.000
112715	99.683	0.000	212.419	0.000	129.944	2.642	76.504	28.256	0.000	0.000
112716	99.362	0.000	212.908	0.000	89.457	0.376	76.504	28.158	0.000	0.000
112717	96.460	0.000	208.973	0.000	59.150	0.000	76.504	28.187	0.000	0.000
112718	84.742	0.000	185.644	0.000	58.019	0.000	76.504	24.942	0.000	0.000
112719	55.756	0.000	106.856	0.000	57.979	0.000	76.504	23.949	0.000	0.000
112720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 27)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	178.721	5.495	76.504	29.895	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1311.540	21.350	918.051	314.532	0.000	0.000
AV	53.189	0.000	116.048	0.000	54.647	0.890	38.252	13.105	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE332 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1128 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1128 8	5.538	0.000	31.745	0.000	111.705	0.000	76.504	23.949	0.000	0.000
1128 9	5.538	0.000	31.745	0.000	58.002	0.000	76.504	23.949	0.000	0.000
112810	5.538	0.000	31.745	0.000	63.723	0.000	76.504	23.949	0.000	0.000
112811	5.538	0.000	31.745	0.000	113.768	0.789	76.504	23.949	0.000	0.000
112812	5.538	0.000	31.745	0.000	150.988	2.857	76.504	23.949	0.000	0.000
112813	5.538	0.000	31.745	0.000	163.373	4.073	76.504	23.949	0.000	0.000
112814	5.538	0.000	31.745	0.000	125.697	2.346	76.504	23.949	0.000	0.000
112815	5.538	0.000	31.745	0.000	126.181	1.991	76.504	23.949	0.000	0.000
112816	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112817	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112818	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112819	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112820	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112821	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112822	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112823	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
112824	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	163.373	4.073	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	913.437	12.055	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	38.060	0.502	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE334 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1130 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1130 8	81.785	0.000	168.037	0.000	113.008	0.000	76.504	23.949	0.000	0.000
1130 9	98.066	0.000	208.826	0.000	58.082	0.000	76.504	23.949	0.000	0.000
113010	99.683	0.000	213.339	0.000	57.825	0.000	76.504	23.949	0.000	0.000
113011	99.683	0.000	208.758	0.000	65.162	0.000	76.504	23.949	0.000	0.000
113012	99.683	0.000	185.850	0.000	80.169	0.000	76.504	23.949	0.000	0.000
113013	99.683	0.000	184.930	0.000	80.212	0.000	76.504	23.949	0.000	0.000
113014	99.683	0.000	204.176	0.000	65.430	0.000	76.504	24.516	0.000	0.000
113015	99.683	0.000	212.419	0.000	58.176	0.000	76.504	24.977	0.000	0.000
113016	99.362	0.000	212.908	0.000	57.882	0.000	76.504	25.207	0.000	0.000
113017	96.460	0.000	208.973	0.000	57.872	0.000	76.504	24.510	0.000	0.000
113018	84.742	0.000	185.644	0.000	57.843	0.000	76.504	23.949	0.000	0.000
113019	55.756	0.000	106.856	0.000	57.841	0.000	76.504	23.949	0.000	0.000
113020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
113024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (NOV 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	113.008	0.000	76.504	25.207	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	809.502	0.000	918.051	290.799	0.000	0.000
AV	53.189	0.000	116.048	0.000	33.729	0.000	38.252	12.117	0.000	0.000
MONTHLY SUMMARY (NOV)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	244.063	19.011	76.504	36.675	0.000	0.000
SM	25064.891	0.000	57565.492	0.000	34308.645	1135.378	19891.109	6823.590	0.000	0.000
AV	34.812	0.000	79.952	0.000	47.651	1.577	27.627	9.477	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE335 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 1 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 1 8	81.785	0.000	168.037	0.000	112.141	0.000	76.504	23.949	0.000	0.000
12 1 9	98.066	0.000	208.826	0.000	58.138	0.000	76.504	23.949	0.000	0.000
12 110	99.683	0.000	213.339	0.000	57.854	0.000	76.504	23.949	0.000	0.000
12 111	99.683	0.000	208.758	0.000	57.842	0.000	76.504	24.586	0.000	0.000
12 112	99.683	0.000	185.850	0.000	57.870	0.000	76.504	24.262	0.000	0.000
12 113	99.683	0.000	184.930	0.000	57.871	0.000	76.504	24.365	0.000	0.000
12 114	99.683	0.000	204.176	0.000	57.902	0.000	76.504	25.739	0.000	0.000
12 115	99.683	0.000	212.419	0.000	57.873	0.000	76.504	25.611	0.000	0.000
12 116	99.362	0.000	212.908	0.000	57.872	0.000	76.504	24.863	0.000	0.000
12 117	96.460	0.000	208.973	0.000	57.843	0.000	76.504	24.222	0.000	0.000
12 118	84.742	0.000	185.644	0.000	57.815	0.000	76.504	23.949	0.000	0.000
12 119	55.756	0.000	106.856	0.000	57.814	0.000	76.504	23.949	0.000	0.000
12 120	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 121	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 122	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 123	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 124	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 1)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.141	0.000	76.504	25.739	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.834	0.000	918.051	293.393	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.201	0.000	38.252	12.225	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE336 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 2 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 2 8	81.785	0.000	168.037	0.000	112.181	0.000	76.504	23.949	0.000	0.000
12 2 9	98.066	0.000	208.826	0.000	58.176	0.000	76.504	23.949	0.000	0.000
12 210	99.683	0.000	213.339	0.000	57.885	0.000	76.504	23.949	0.000	0.000
12 211	99.683	0.000	208.758	0.000	57.843	0.000	76.504	23.949	0.000	0.000
12 212	99.683	0.000	185.850	0.000	57.815	0.000	76.504	23.949	0.000	0.000
12 213	99.683	0.000	184.930	0.000	57.814	0.000	76.504	23.949	0.000	0.000
12 214	99.683	0.000	204.176	0.000	57.840	0.000	76.504	23.949	0.000	0.000
12 215	99.683	0.000	212.419	0.000	57.841	0.000	76.504	23.949	0.000	0.000
12 216	99.362	0.000	212.908	0.000	57.841	0.000	76.504	23.949	0.000	0.000
12 217	96.460	0.000	208.973	0.000	57.841	0.000	76.504	23.949	0.000	0.000
12 218	84.742	0.000	185.644	0.000	57.870	0.000	76.504	23.949	0.000	0.000
12 219	55.756	0.000	106.856	0.000	57.871	0.000	76.504	23.949	0.000	0.000
12 220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 2)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.181	0.000	76.504	23.949	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.820	0.000	918.051	287.384	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.201	0.000	38.252	11.974	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE337 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 3 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 3 8	81.785	0.000	168.037	0.000	112.439	0.000	76.504	23.949	0.000	0.000
12 3 9	98.066	0.000	208.826	0.000	58.364	0.000	76.504	23.949	0.000	0.000
12 310	99.683	0.000	213.339	0.000	89.931	0.677	76.504	23.949	0.000	0.000
12 311	99.683	0.000	208.758	0.000	125.755	3.175	76.504	23.949	0.000	0.000
12 312	99.683	0.000	185.850	0.000	114.481	2.748	76.504	23.949	0.000	0.000
12 313	99.683	0.000	184.930	0.000	118.633	3.188	76.504	23.949	0.000	0.000
12 314	99.683	0.000	204.176	0.000	129.661	3.950	76.504	24.702	0.000	0.000
12 315	99.683	0.000	212.419	0.000	71.820	0.000	76.504	26.737	0.000	0.000
12 316	99.362	0.000	212.908	0.000	58.542	0.000	76.504	26.102	0.000	0.000
12 317	96.460	0.000	208.973	0.000	57.999	0.000	76.504	24.706	0.000	0.000
12 318	84.742	0.000	185.644	0.000	57.978	0.000	76.504	23.949	0.000	0.000
12 319	55.756	0.000	106.856	0.000	57.977	0.000	76.504	23.949	0.000	0.000
12 320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 3)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	129.661	3.950	76.504	26.737	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1053.578	13.738	918.051	293.836	0.000	0.000
AV	53.189	0.000	116.048	0.000	43.899	0.572	38.252	12.243	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE338 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 4 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 4 8	81.785	0.000	168.037	0.000	112.182	0.000	76.504	23.949	0.000	0.000
12 4 9	98.066	0.000	208.826	0.000	76.889	0.000	76.504	23.949	0.000	0.000
12 410	99.683	0.000	213.339	0.000	147.911	4.232	76.504	23.949	0.000	0.000
12 411	99.683	0.000	208.758	0.000	208.991	10.159	76.504	24.156	0.000	0.000
12 412	99.683	0.000	185.850	0.000	214.569	11.254	76.504	23.994	0.000	0.000
12 413	99.683	0.000	184.930	0.000	209.512	11.308	76.504	25.542	0.000	0.000
12 414	99.683	0.000	204.176	0.000	148.283	5.883	76.504	28.661	0.000	0.000
12 415	99.683	0.000	212.419	0.000	143.086	5.061	76.504	28.238	0.000	0.000
12 416	99.362	0.000	212.908	0.000	69.971	0.000	76.504	28.080	0.000	0.000
12 417	96.460	0.000	208.973	0.000	58.522	0.000	76.504	25.982	0.000	0.000
12 418	84.742	0.000	185.644	0.000	58.039	0.000	76.504	24.233	0.000	0.000
12 419	55.756	0.000	106.856	0.000	58.019	0.000	76.504	23.949	0.000	0.000
12 420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 4)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	214.569	11.308	76.504	28.661	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1505.973	47.897	918.051	304.680	0.000	0.000
AV	53.189	0.000	116.048	0.000	62.749	1.996	38.252	12.695	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE339 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 5 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 5 8	5.538	0.000	31.745	0.000	112.539	0.000	76.504	23.949	0.000	0.000
12 5 9	5.538	0.000	31.745	0.000	58.480	0.000	76.504	23.949	0.000	0.000
12 510	5.538	0.000	31.745	0.000	107.217	2.241	76.504	23.949	0.000	0.000
12 511	5.538	0.000	31.745	0.000	127.332	3.271	76.504	23.949	0.000	0.000
12 512	5.538	0.000	31.745	0.000	156.778	6.781	76.504	23.949	0.000	0.000
12 513	5.538	0.000	31.745	0.000	113.699	3.214	76.504	23.949	0.000	0.000
12 514	5.538	0.000	31.745	0.000	108.412	2.495	76.504	23.949	0.000	0.000
12 515	5.538	0.000	31.745	0.000	89.780	1.010	76.504	23.949	0.000	0.000
12 516	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 517	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 518	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 519	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 520	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 521	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 522	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 523	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 524	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 5)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	156.778	6.781	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	874.237	19.011	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	36.427	0.792	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE341 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 7 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 7 8	81.785	0.000	168.037	0.000	112.436	0.000	76.504	23.949	0.000	0.000
12 7 9	98.066	0.000	208.826	0.000	58.106	0.000	76.504	23.949	0.000	0.000
12 710	99.683	0.000	213.339	0.000	81.600	0.000	76.504	24.226	0.000	0.000
12 711	99.683	0.000	208.758	0.000	170.910	5.280	76.504	24.356	0.000	0.000
12 712	99.683	0.000	185.850	0.000	168.492	5.797	76.504	24.310	0.000	0.000
12 713	99.683	0.000	184.930	0.000	140.650	4.404	76.504	25.649	0.000	0.000
12 714	99.683	0.000	204.176	0.000	148.573	4.406	76.504	26.286	0.000	0.000
12 715	99.683	0.000	212.419	0.000	122.660	2.874	76.504	30.487	0.000	0.000
12 716	99.362	0.000	212.908	0.000	105.854	1.962	76.504	30.593	0.000	0.000
12 717	96.460	0.000	208.973	0.000	59.846	0.000	76.504	28.040	0.000	0.000
12 718	84.742	0.000	185.644	0.000	58.086	0.000	76.504	24.526	0.000	0.000
12 719	55.756	0.000	106.856	0.000	57.982	0.000	76.504	23.949	0.000	0.000
12 720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 7)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	170.910	5.797	76.504	30.593	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1285.196	24.723	918.051	310.319	0.000	0.000
AV	53.189	0.000	116.048	0.000	53.550	1.030	38.252	12.930	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE342 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 8 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 8 8	81.785	0.000	168.037	0.000	112.056	0.000	76.504	23.949	0.000	0.000
12 8 9	98.066	0.000	208.826	0.000	58.256	0.000	76.504	23.949	0.000	0.000
12 810	99.683	0.000	213.339	0.000	57.832	0.000	76.504	25.468	0.000	0.000
12 811	99.683	0.000	208.758	0.000	57.870	0.000	76.504	26.425	0.000	0.000
12 812	99.683	0.000	185.850	0.000	57.871	0.000	76.504	25.703	0.000	0.000
12 813	99.683	0.000	184.930	0.000	57.902	0.000	76.504	26.624	0.000	0.000
12 814	99.683	0.000	204.176	0.000	57.873	0.000	76.504	30.041	0.000	0.000
12 815	99.683	0.000	212.419	0.000	57.872	0.000	76.504	29.390	0.000	0.000
12 816	99.362	0.000	212.908	0.000	57.871	0.000	76.504	28.438	0.000	0.000
12 817	96.460	0.000	208.973	0.000	57.673	0.000	76.504	25.346	0.000	0.000
12 818	84.742	0.000	185.644	0.000	57.700	0.000	76.504	24.167	0.000	0.000
12 819	55.756	0.000	106.856	0.000	57.683	0.000	76.504	23.949	0.000	0.000
12 820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 8)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.056	0.000	76.504	30.041	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	748.459	0.000	918.051	313.448	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.186	0.000	38.252	13.060	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE343 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
12 9 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 9 8	81.785	0.000	168.037	0.000	111.557	0.000	76.504	23.949	0.000	0.000
12 9 9	98.066	0.000	208.826	0.000	57.925	0.000	76.504	23.949	0.000	0.000
12 910	99.683	0.000	213.339	0.000	57.691	0.000	76.504	26.912	0.000	0.000
12 911	99.683	0.000	208.758	0.000	57.701	0.000	76.504	28.201	0.000	0.000
12 912	99.683	0.000	185.850	0.000	57.720	0.000	76.504	26.774	0.000	0.000
12 913	99.683	0.000	184.930	0.000	57.741	0.000	76.504	28.283	0.000	0.000
12 914	99.683	0.000	204.176	0.000	57.741	0.000	76.504	31.669	0.000	0.000
12 915	99.683	0.000	212.419	0.000	69.401	0.000	76.504	32.918	0.000	0.000
12 916	99.362	0.000	212.908	0.000	58.040	0.000	76.504	33.614	0.000	0.000
12 917	96.460	0.000	208.973	0.000	57.658	0.000	76.504	29.163	0.000	0.000
12 918	84.742	0.000	185.644	0.000	57.650	0.000	76.504	24.945	0.000	0.000
12 919	55.756	0.000	106.856	0.000	57.665	0.000	76.504	23.949	0.000	0.000
12 920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 9)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.557	0.000	76.504	33.614	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	758.489	0.000	918.051	334.327	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.604	0.000	38.252	13.930	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE344 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1210 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1210 8	81.785	0.000	168.037	0.000	111.552	0.000	76.504	23.949	0.000	0.000
1210 9	98.066	0.000	208.826	0.000	57.882	0.000	76.504	23.949	0.000	0.000
121010	99.683	0.000	213.339	0.000	57.690	0.000	76.504	23.949	0.000	0.000
121011	99.683	0.000	208.758	0.000	57.701	0.000	76.504	24.940	0.000	0.000
121012	99.683	0.000	185.850	0.000	57.720	0.000	76.504	24.723	0.000	0.000
121013	99.683	0.000	184.930	0.000	57.702	0.000	76.504	24.314	0.000	0.000
121014	99.683	0.000	204.176	0.000	57.701	0.000	76.504	24.440	0.000	0.000
121015	99.683	0.000	212.419	0.000	57.701	0.000	76.504	25.438	0.000	0.000
121016	99.362	0.000	212.908	0.000	57.701	0.000	76.504	26.073	0.000	0.000
121017	96.460	0.000	208.973	0.000	57.667	0.000	76.504	24.487	0.000	0.000
121018	84.742	0.000	185.644	0.000	57.650	0.000	76.504	23.949	0.000	0.000
121019	55.756	0.000	106.856	0.000	57.665	0.000	76.504	23.949	0.000	0.000
121020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 10)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.552	0.000	76.504	26.073	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	746.331	0.000	918.051	294.159	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.097	0.000	38.252	12.257	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE345 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1211 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1211 8	81.785	0.000	168.037	0.000	111.552	0.000	76.504	23.949	0.000	0.000
1211 9	98.066	0.000	208.826	0.000	57.863	0.000	76.504	23.949	0.000	0.000
121110	99.683	0.000	213.339	0.000	57.628	0.000	76.504	23.949	0.000	0.000
121111	99.683	0.000	208.758	0.000	57.634	0.000	76.504	24.913	0.000	0.000
121112	99.683	0.000	185.850	0.000	57.635	0.000	76.504	24.777	0.000	0.000
121113	99.683	0.000	184.930	0.000	57.635	0.000	76.504	26.189	0.000	0.000
121114	99.683	0.000	204.176	0.000	57.649	0.000	76.504	28.516	0.000	0.000
121115	99.683	0.000	212.419	0.000	57.650	0.000	76.504	31.083	0.000	0.000
121116	99.362	0.000	212.908	0.000	57.622	0.000	76.504	28.652	0.000	0.000
121117	96.460	0.000	208.973	0.000	57.608	0.000	76.504	25.392	0.000	0.000
121118	84.742	0.000	185.644	0.000	57.595	0.000	76.504	23.949	0.000	0.000
121119	55.756	0.000	106.856	0.000	57.595	0.000	76.504	23.949	0.000	0.000
121120	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121121	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121122	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121123	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121124	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 11)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.552	0.000	76.504	31.083	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	745.666	0.000	918.051	309.265	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.069	0.000	38.252	12.886	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE346 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1212 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1212 8	5.538	0.000	31.745	0.000	111.431	0.000	76.504	23.949	0.000	0.000
1212 9	5.538	0.000	31.745	0.000	57.810	0.000	76.504	23.949	0.000	0.000
121210	5.538	0.000	31.745	0.000	57.614	0.000	76.504	23.949	0.000	0.000
121211	5.538	0.000	31.745	0.000	57.634	0.000	76.504	23.949	0.000	0.000
121212	5.538	0.000	31.745	0.000	57.635	0.000	76.504	23.949	0.000	0.000
121213	5.538	0.000	31.745	0.000	57.649	0.000	76.504	23.949	0.000	0.000
121214	5.538	0.000	31.745	0.000	57.699	0.000	76.504	23.949	0.000	0.000
121215	5.538	0.000	31.745	0.000	57.683	0.000	76.504	23.949	0.000	0.000
121216	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121217	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121218	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121219	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121220	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121221	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121222	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121223	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121224	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 12)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	111.431	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	515.154	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	21.465	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE348 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1214 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1214 8	81.785	0.000	168.037	0.000	111.549	0.000	76.504	23.949	0.000	0.000
1214 9	98.066	0.000	208.826	0.000	57.882	0.000	76.504	23.949	0.000	0.000
121410	99.683	0.000	213.339	0.000	57.690	0.000	76.504	23.949	0.000	0.000
121411	99.683	0.000	208.758	0.000	80.297	0.000	76.504	23.949	0.000	0.000
121412	99.683	0.000	185.850	0.000	136.986	1.628	76.504	23.949	0.000	0.000
121413	99.683	0.000	184.930	0.000	111.300	0.533	76.504	24.140	0.000	0.000
121414	99.683	0.000	204.176	0.000	64.396	0.000	76.504	25.854	0.000	0.000
121415	99.683	0.000	212.419	0.000	67.156	0.000	76.504	27.137	0.000	0.000
121416	99.362	0.000	212.908	0.000	58.030	0.000	76.504	27.557	0.000	0.000
121417	96.460	0.000	208.973	0.000	57.691	0.000	76.504	25.077	0.000	0.000
121418	84.742	0.000	185.644	0.000	57.666	0.000	76.504	23.949	0.000	0.000
121419	55.756	0.000	106.856	0.000	57.650	0.000	76.504	23.949	0.000	0.000
121420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 14)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	136.986	1.628	76.504	27.557	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	918.295	2.160	918.051	297.405	0.000	0.000
AV	53.189	0.000	116.048	0.000	38.262	0.090	38.252	12.392	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE349 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1215 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1215 8	81.785	0.000	168.037	0.000	111.704	0.000	76.504	23.949	0.000	0.000
1215 9	98.066	0.000	208.826	0.000	57.951	0.000	76.504	23.949	0.000	0.000
121510	99.683	0.000	213.339	0.000	64.475	0.000	76.504	23.949	0.000	0.000
121511	99.683	0.000	208.758	0.000	126.397	1.359	76.504	23.949	0.000	0.000
121512	99.683	0.000	185.850	0.000	175.247	4.152	76.504	23.949	0.000	0.000
121513	99.683	0.000	184.930	0.000	166.337	4.263	76.504	24.190	0.000	0.000
121514	99.683	0.000	204.176	0.000	104.335	0.419	76.504	27.107	0.000	0.000
121515	99.683	0.000	212.419	0.000	65.420	0.000	76.504	27.924	0.000	0.000
121516	99.362	0.000	212.908	0.000	86.051	0.000	76.504	25.476	0.000	0.000
121517	96.460	0.000	208.973	0.000	65.000	0.000	76.504	24.675	0.000	0.000
121518	84.742	0.000	185.644	0.000	58.121	0.000	76.504	23.949	0.000	0.000
121519	55.756	0.000	106.856	0.000	57.879	0.000	76.504	23.949	0.000	0.000
121520	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121521	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121522	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121523	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121524	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 15)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	175.247	4.263	76.504	27.924	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1138.918	10.192	918.051	297.011	0.000	0.000
AV	53.189	0.000	116.048	0.000	47.455	0.425	38.252	12.375	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE350 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1216 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1216 8	81.785	0.000	168.037	0.000	111.800	0.000	76.504	23.949	0.000	0.000
1216 9	98.066	0.000	208.826	0.000	137.890	2.021	76.504	23.949	0.000	0.000
121610	99.683	0.000	213.339	0.000	202.549	6.330	76.504	23.949	0.000	0.000
121611	99.683	0.000	208.758	0.000	213.250	8.592	76.504	24.117	0.000	0.000
121612	99.683	0.000	185.850	0.000	219.654	9.398	76.504	23.949	0.000	0.000
121613	99.683	0.000	184.930	0.000	218.693	8.768	76.504	24.270	0.000	0.000
121614	99.683	0.000	204.176	0.000	212.331	7.733	76.504	26.381	0.000	0.000
121615	99.683	0.000	212.419	0.000	222.309	10.137	76.504	26.667	0.000	0.000
121616	99.362	0.000	212.908	0.000	218.432	9.713	76.504	26.833	0.000	0.000
121617	96.460	0.000	208.973	0.000	162.546	4.488	76.504	26.480	0.000	0.000
121618	84.742	0.000	185.644	0.000	149.102	2.964	76.504	24.059	0.000	0.000
121619	55.756	0.000	106.856	0.000	140.411	2.110	76.504	23.949	0.000	0.000
121620	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121621	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121622	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121623	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121624	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 16)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	222.309	10.137	76.504	26.833	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2208.967	72.253	918.051	298.549	0.000	0.000
AV	53.189	0.000	116.048	0.000	92.040	3.011	38.252	12.440	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE351 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1217 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1217 8	81.785	0.000	168.037	0.000	113.108	0.000	76.504	23.949	0.000	0.000
1217 9	98.066	0.000	208.826	0.000	112.143	0.338	76.504	23.949	0.000	0.000
121710	99.683	0.000	213.339	0.000	190.029	4.960	76.504	24.386	0.000	0.000
121711	99.683	0.000	208.758	0.000	221.651	9.272	76.504	24.200	0.000	0.000
121712	99.683	0.000	185.850	0.000	222.893	9.385	76.504	23.949	0.000	0.000
121713	99.683	0.000	184.930	0.000	227.410	10.611	76.504	23.952	0.000	0.000
121714	99.683	0.000	204.176	0.000	230.383	11.057	76.504	24.904	0.000	0.000
121715	99.683	0.000	212.419	0.000	212.785	8.415	76.504	29.909	0.000	0.000
121716	99.362	0.000	212.908	0.000	210.967	8.496	76.504	28.609	0.000	0.000
121717	96.460	0.000	208.973	0.000	125.126	2.408	76.504	28.525	0.000	0.000
121718	84.742	0.000	185.644	0.000	102.155	0.612	76.504	24.766	0.000	0.000
121719	55.756	0.000	106.856	0.000	91.929	0.000	76.504	23.949	0.000	0.000
121720	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121721	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121722	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121723	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121724	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 17)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	230.383	11.057	76.504	29.909	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2060.578	65.554	918.051	305.046	0.000	0.000
AV	53.189	0.000	116.048	0.000	85.857	2.731	38.252	12.710	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE352 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1218 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1218 8	81.785	0.000	168.037	0.000	112.364	0.000	76.504	23.949	0.000	0.000
1218 9	98.066	0.000	208.826	0.000	180.828	4.324	76.504	24.006	0.000	0.000
121810	99.683	0.000	213.339	0.000	209.063	7.164	76.504	25.090	0.000	0.000
121811	99.683	0.000	208.758	0.000	226.867	10.557	76.504	24.334	0.000	0.000
121812	99.683	0.000	185.850	0.000	229.783	11.798	76.504	24.035	0.000	0.000
121813	99.683	0.000	184.930	0.000	229.319	12.458	76.504	24.409	0.000	0.000
121814	99.683	0.000	204.176	0.000	232.495	13.017	76.504	26.399	0.000	0.000
121815	99.683	0.000	212.419	0.000	223.796	10.621	76.504	30.269	0.000	0.000
121816	99.362	0.000	212.908	0.000	218.569	9.777	76.504	30.506	0.000	0.000
121817	96.460	0.000	208.973	0.000	193.326	5.876	76.504	28.938	0.000	0.000
121818	84.742	0.000	185.644	0.000	157.962	3.891	76.504	25.028	0.000	0.000
121819	55.756	0.000	106.856	0.000	160.713	3.807	76.504	23.949	0.000	0.000
121820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 18)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	232.495	13.017	76.504	30.506	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	2375.084	93.290	918.051	310.912	0.000	0.000
AV	53.189	0.000	116.048	0.000	98.962	3.887	38.252	12.955	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE353 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1219 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1219 8	5.538	0.000	31.745	0.000	113.618	0.000	76.504	23.949	0.000	0.000
1219 9	5.538	0.000	31.745	0.000	139.512	2.267	76.504	23.949	0.000	0.000
121910	5.538	0.000	31.745	0.000	188.778	5.423	76.504	23.949	0.000	0.000
121911	5.538	0.000	31.745	0.000	205.565	7.495	76.504	23.949	0.000	0.000
121912	5.538	0.000	31.745	0.000	210.046	8.321	76.504	23.949	0.000	0.000
121913	5.538	0.000	31.745	0.000	212.477	9.223	76.504	23.949	0.000	0.000
121914	5.538	0.000	31.745	0.000	208.557	8.778	76.504	23.949	0.000	0.000
121915	5.538	0.000	31.745	0.000	208.329	8.485	76.504	23.949	0.000	0.000
121916	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121917	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121918	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121919	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121920	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121921	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121922	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121923	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
121924	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 19)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	212.477	9.223	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	1486.883	49.992	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	61.953	2.083	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE355 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1221 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1221 8	81.785	0.000	168.037	0.000	114.638	0.000	76.504	23.949	0.000	0.000
1221 9	98.066	0.000	208.826	0.000	119.993	1.023	76.504	24.860	0.000	0.000
122110	99.683	0.000	213.339	0.000	208.168	7.172	76.504	24.916	0.000	0.000
122111	99.683	0.000	208.758	0.000	219.517	9.330	76.504	25.608	0.000	0.000
122112	99.683	0.000	185.850	0.000	212.277	9.101	76.504	25.783	0.000	0.000
122113	99.683	0.000	184.930	0.000	208.903	8.120	76.504	26.917	0.000	0.000
122114	99.683	0.000	204.176	0.000	211.519	8.595	76.504	29.122	0.000	0.000
122115	99.683	0.000	212.419	0.000	204.237	7.627	76.504	32.425	0.000	0.000
122116	99.362	0.000	212.908	0.000	203.688	7.878	76.504	30.802	0.000	0.000
122117	96.460	0.000	208.973	0.000	62.580	0.000	76.504	32.384	0.000	0.000
122118	84.742	0.000	185.644	0.000	58.042	0.000	76.504	26.060	0.000	0.000
122119	55.756	0.000	106.856	0.000	57.879	0.000	76.504	23.949	0.000	0.000
122120	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122121	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122122	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122123	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122124	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 21)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	219.517	9.330	76.504	32.425	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1881.441	58.845	918.051	326.773	0.000	0.000
AV	53.189	0.000	116.048	0.000	78.393	2.452	38.252	13.616	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE356 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1222 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1222 8	81.785	0.000	168.037	0.000	111.993	0.000	76.504	23.949	0.000	0.000
1222 9	98.066	0.000	208.826	0.000	58.100	0.000	76.504	24.914	0.000	0.000
122210	99.683	0.000	213.339	0.000	167.478	4.318	76.504	24.098	0.000	0.000
122211	99.683	0.000	208.758	0.000	204.817	7.024	76.504	25.009	0.000	0.000
122212	99.683	0.000	185.850	0.000	164.050	6.058	76.504	27.015	0.000	0.000
122213	99.683	0.000	184.930	0.000	197.553	7.506	76.504	24.823	0.000	0.000
122214	99.683	0.000	204.176	0.000	101.382	1.934	76.504	31.570	0.000	0.000
122215	99.683	0.000	212.419	0.000	101.951	1.560	76.504	30.307	0.000	0.000
122216	99.362	0.000	212.908	0.000	68.549	0.000	76.504	29.892	0.000	0.000
122217	96.460	0.000	208.973	0.000	58.285	0.000	76.504	28.673	0.000	0.000
122218	84.742	0.000	185.644	0.000	57.917	0.000	76.504	25.168	0.000	0.000
122219	55.756	0.000	106.856	0.000	57.873	0.000	76.504	23.949	0.000	0.000
122220	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122221	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122222	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122223	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122224	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 22)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	204.817	7.506	76.504	31.570	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1349.947	28.400	918.051	319.367	0.000	0.000
AV	53.189	0.000	116.048	0.000	56.248	1.183	38.252	13.307	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE357 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1223 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1223 8	81.785	0.000	168.037	0.000	111.759	0.000	76.504	23.949	0.000	0.000
1223 9	98.066	0.000	208.826	0.000	57.977	0.000	76.504	24.376	0.000	0.000
122310	99.683	0.000	213.339	0.000	85.194	0.000	76.504	25.091	0.000	0.000
122311	99.683	0.000	208.758	0.000	209.725	7.906	76.504	23.949	0.000	0.000
122312	99.683	0.000	185.850	0.000	216.786	8.372	76.504	23.949	0.000	0.000
122313	99.683	0.000	184.930	0.000	159.402	4.481	76.504	25.440	0.000	0.000
122314	99.683	0.000	204.176	0.000	124.528	2.364	76.504	26.193	0.000	0.000
122315	99.683	0.000	212.419	0.000	64.548	0.000	76.504	27.467	0.000	0.000
122316	99.362	0.000	212.908	0.000	66.849	0.000	76.504	25.791	0.000	0.000
122317	96.460	0.000	208.973	0.000	58.099	0.000	76.504	25.504	0.000	0.000
122318	84.742	0.000	185.644	0.000	57.797	0.000	76.504	24.318	0.000	0.000
122319	55.756	0.000	106.856	0.000	57.788	0.000	76.504	23.949	0.000	0.000
122320	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122321	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122322	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122323	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122324	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 23)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	216.786	8.372	76.504	27.467	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1270.450	23.122	918.051	299.974	0.000	0.000
AV	53.189	0.000	116.048	0.000	52.935	0.963	38.252	12.499	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE358 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1224 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1224 8	81.785	0.000	168.037	0.000	111.754	0.000	76.504	23.949	0.000	0.000
1224 9	98.066	0.000	208.826	0.000	58.003	0.000	76.504	23.949	0.000	0.000
122410	99.683	0.000	213.339	0.000	83.887	0.000	76.504	24.597	0.000	0.000
122411	99.683	0.000	208.758	0.000	209.421	8.301	76.504	23.949	0.000	0.000
122412	99.683	0.000	185.850	0.000	219.098	9.754	76.504	23.949	0.000	0.000
122413	99.683	0.000	184.930	0.000	227.469	12.184	76.504	23.949	0.000	0.000
122414	99.683	0.000	204.176	0.000	202.656	8.677	76.504	27.488	0.000	0.000
122415	99.683	0.000	212.419	0.000	194.579	7.705	76.504	27.931	0.000	0.000
122416	99.362	0.000	212.908	0.000	108.102	1.724	76.504	29.794	0.000	0.000
122417	96.460	0.000	208.973	0.000	59.750	0.000	76.504	27.550	0.000	0.000
122418	84.742	0.000	185.644	0.000	66.313	0.000	76.504	24.447	0.000	0.000
122419	55.756	0.000	106.856	0.000	64.236	0.000	76.504	23.949	0.000	0.000
122420	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122421	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122422	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122423	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122424	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 24)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	227.469	12.184	76.504	29.794	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1605.270	48.346	918.051	305.499	0.000	0.000
AV	53.189	0.000	116.048	0.000	66.886	2.014	38.252	12.729	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE360 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1226 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 6	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 7	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1226 8	5.538	0.000	31.745	0.000	112.213	0.000	76.504	23.949	0.000	0.000
1226 9	5.538	0.000	31.745	0.000	58.139	0.000	76.504	23.949	0.000	0.000
122610	5.538	0.000	31.745	0.000	57.883	0.000	76.504	23.949	0.000	0.000
122611	5.538	0.000	31.745	0.000	76.418	0.000	76.504	23.949	0.000	0.000
122612	5.538	0.000	31.745	0.000	58.682	0.000	76.504	23.949	0.000	0.000
122613	5.538	0.000	31.745	0.000	58.002	0.000	76.504	23.949	0.000	0.000
122614	5.538	0.000	31.745	0.000	57.978	0.000	76.504	23.949	0.000	0.000
122615	5.538	0.000	31.745	0.000	57.941	0.000	76.504	23.949	0.000	0.000
122616	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122617	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122618	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122619	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122620	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122621	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122622	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122623	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122624	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 26)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	5.538	0.000	31.745	0.000	112.213	0.000	76.504	23.949	0.000	0.000
SM	132.911	0.000	761.891	0.000	537.256	0.000	612.034	191.589	0.000	0.000
AV	5.538	0.000	31.745	0.000	22.386	0.000	25.501	7.983	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE362 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1228 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1228 8	81.785	0.000	168.037	0.000	111.923	0.000	76.504	23.949	0.000	0.000
1228 9	98.066	0.000	208.826	0.000	58.035	0.000	76.504	23.949	0.000	0.000
122810	99.683	0.000	213.339	0.000	57.798	0.000	76.504	23.949	0.000	0.000
122811	99.683	0.000	208.758	0.000	65.627	0.000	76.504	24.361	0.000	0.000
122812	99.683	0.000	185.850	0.000	82.711	0.000	76.504	24.215	0.000	0.000
122813	99.683	0.000	184.930	0.000	58.865	0.000	76.504	24.708	0.000	0.000
122814	99.683	0.000	204.176	0.000	57.936	0.000	76.504	25.435	0.000	0.000
122815	99.683	0.000	212.419	0.000	57.975	0.000	76.504	25.237	0.000	0.000
122816	99.362	0.000	212.908	0.000	57.977	0.000	76.504	24.734	0.000	0.000
122817	96.460	0.000	208.973	0.000	57.941	0.000	76.504	24.162	0.000	0.000
122818	84.742	0.000	185.644	0.000	57.975	0.000	76.504	23.949	0.000	0.000
122819	55.756	0.000	106.856	0.000	57.977	0.000	76.504	23.949	0.000	0.000
122820	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122821	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122822	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122823	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122824	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 28)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	111.923	0.000	76.504	25.435	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	782.739	0.000	918.051	292.597	0.000	0.000
AV	53.189	0.000	116.048	0.000	32.614	0.000	38.252	12.192	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE363 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1229 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1229 8	81.785	0.000	168.037	0.000	112.176	0.000	76.504	23.949	0.000	0.000
1229 9	98.066	0.000	208.826	0.000	58.411	0.000	76.504	23.949	0.000	0.000
122910	99.683	0.000	213.339	0.000	79.608	0.000	76.504	23.949	0.000	0.000
122911	99.683	0.000	208.758	0.000	121.346	2.136	76.504	23.949	0.000	0.000
122912	99.683	0.000	185.850	0.000	160.380	4.630	76.504	23.949	0.000	0.000
122913	99.683	0.000	184.930	0.000	187.307	6.344	76.504	23.949	0.000	0.000
122914	99.683	0.000	204.176	0.000	203.027	7.464	76.504	23.949	0.000	0.000
122915	99.683	0.000	212.419	0.000	204.987	7.832	76.504	23.949	0.000	0.000
122916	99.362	0.000	212.908	0.000	183.186	8.377	76.504	23.949	0.000	0.000
122917	96.460	0.000	208.973	0.000	169.724	6.918	76.504	23.949	0.000	0.000
122918	84.742	0.000	185.644	0.000	135.790	4.113	76.504	23.949	0.000	0.000
122919	55.756	0.000	106.856	0.000	101.740	1.085	76.504	23.949	0.000	0.000
122920	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122921	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122922	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122923	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
122924	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 29)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	204.987	8.377	76.504	23.949	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1717.682	48.899	918.051	287.384	0.000	0.000
AV	53.189	0.000	116.048	0.000	71.570	2.037	38.252	11.974	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE364 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1230 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1230 8	81.785	0.000	168.037	0.000	113.158	0.000	76.504	23.949	0.000	0.000
1230 9	98.066	0.000	208.826	0.000	64.328	0.000	76.504	23.949	0.000	0.000
123010	99.683	0.000	213.339	0.000	102.788	1.396	76.504	23.949	0.000	0.000
123011	99.683	0.000	208.758	0.000	143.974	4.178	76.504	24.633	0.000	0.000
123012	99.683	0.000	185.850	0.000	153.786	4.907	76.504	24.296	0.000	0.000
123013	99.683	0.000	184.930	0.000	159.309	5.348	76.504	24.884	0.000	0.000
123014	99.683	0.000	204.176	0.000	155.098	5.082	76.504	27.454	0.000	0.000
123015	99.683	0.000	212.419	0.000	101.922	1.700	76.504	31.007	0.000	0.000
123016	99.362	0.000	212.908	0.000	59.682	0.000	76.504	31.425	0.000	0.000
123017	96.460	0.000	208.973	0.000	58.126	0.000	76.504	26.752	0.000	0.000
123018	84.742	0.000	185.644	0.000	58.067	0.000	76.504	24.498	0.000	0.000
123019	55.756	0.000	106.856	0.000	58.021	0.000	76.504	23.949	0.000	0.000
123020	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123021	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123022	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123023	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123024	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 30)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	159.309	5.348	76.504	31.425	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	1228.258	22.611	918.051	310.744	0.000	0.000
AV	53.189	0.000	116.048	0.000	51.177	0.942	38.252	12.948	0.000	0.000

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE365 - 1

	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1	EM1
	LIGHT END USE KWH	TASK END USE KWH	EQUIP END USE KWH	HEAT END USE KWH	COOL END USE KWH	HTREJ END USE KWH	AUX END USE KWH	VENT END USE KWH	REFG END USE KWH	SUPP END USE KWH
	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)	----(9)	----(10)
1231 1	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 2	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 3	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 4	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 5	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 6	9.160	0.000	34.925	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 7	35.487	0.000	69.027	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1231 8	81.785	0.000	168.037	0.000	112.470	0.000	76.504	23.949	0.000	0.000
1231 9	98.066	0.000	208.826	0.000	58.314	0.000	76.504	23.949	0.000	0.000
123110	99.683	0.000	213.339	0.000	57.993	0.000	76.504	24.125	0.000	0.000
123111	99.683	0.000	208.758	0.000	57.941	0.000	76.504	24.346	0.000	0.000
123112	99.683	0.000	185.850	0.000	58.014	0.000	76.504	23.960	0.000	0.000
123113	99.683	0.000	184.930	0.000	58.018	0.000	76.504	24.327	0.000	0.000
123114	99.683	0.000	204.176	0.000	71.750	0.000	76.504	24.539	0.000	0.000
123115	99.683	0.000	212.419	0.000	58.554	0.000	76.504	25.555	0.000	0.000
123116	99.362	0.000	212.908	0.000	57.998	0.000	76.504	25.266	0.000	0.000
123117	96.460	0.000	208.973	0.000	58.017	0.000	76.504	24.506	0.000	0.000
123118	84.742	0.000	185.644	0.000	57.979	0.000	76.504	23.949	0.000	0.000
123119	55.756	0.000	106.856	0.000	57.977	0.000	76.504	23.949	0.000	0.000
123120	35.177	0.000	61.326	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123121	26.427	0.000	50.823	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123122	13.324	0.000	40.814	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123123	8.938	0.000	36.347	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123124	6.059	0.000	32.450	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DAILY SUMMARY (DEC 31)										
MN	5.538	0.000	31.745	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	112.470	0.000	76.504	25.555	0.000	0.000
SM	1276.534	0.000	2785.155	0.000	765.026	0.000	918.051	292.419	0.000	0.000
AV	53.189	0.000	116.048	0.000	31.876	0.000	38.252	12.184	0.000	0.000
MONTHLY SUMMARY (DEC)										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	232.495	13.017	76.504	33.614	0.000	0.000
SM	28814.744	0.000	65463.828	0.000	31057.527	629.034	22645.262	7450.844	0.000	0.000
AV	38.729	0.000	87.989	0.000	41.744	0.845	30.437	10.015	0.000	0.000
YEARLY SUMMARY										
MN	1.661	0.000	9.524	0.000	0.000	0.000	0.000	0.000	0.000	0.000
MX	99.683	0.000	213.339	0.000	335.201	41.107	76.504	41.245	0.000	0.000
SM	329793.438	0.000	752863.500	0.000	536821.625	29765.861	262256.594	92345.000	0.000	0.000
AV	37.648	0.000	85.943	0.000	61.281	3.398	29.938	10.542	0.000	0.000

WEATHER FILE- Los Angeles CA TMY2PAGE 1 - 2

MMDDHH		EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
		DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
		----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1	1 1 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 10	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 11	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 12	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 13	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 14	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 15	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 16	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 17	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 18	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 19	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 20	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 21	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 22	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 23	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
1	1 1 24	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 1)												
	MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
	MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
	SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
	AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 2 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 2 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 2 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1 2 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1 2 8	0.000	1.033	563.368	0.	0.	0.	0.	0.	0.	0.	0.
1 2 9	0.000	0.000	466.128	0.	0.	0.	0.	0.	0.	0.	0.
1 210	0.000	0.000	471.146	0.	0.	0.	0.	0.	0.	0.	0.
1 211	0.000	0.000	472.491	0.	0.	0.	0.	0.	0.	0.	0.
1 212	0.000	0.000	462.001	0.	0.	0.	0.	0.	0.	0.	0.
1 213	0.000	0.000	473.388	0.	0.	0.	0.	0.	0.	0.	0.
1 214	0.000	0.000	463.038	0.	0.	0.	0.	0.	0.	0.	0.
1 215	0.000	0.000	470.281	0.	0.	0.	0.	0.	0.	0.	0.
1 216	0.000	0.000	470.408	0.	0.	0.	0.	0.	0.	0.	0.
1 217	0.000	1.550	465.102	0.	0.	0.	0.	0.	0.	0.	0.
1 218	0.000	6.199	434.704	0.	0.	0.	0.	0.	0.	0.	0.
1 219	0.000	9.299	330.030	0.	0.	0.	0.	0.	0.	0.	0.
1 220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
1 221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
1 222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
1 223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
1 224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	563.368	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6272.476	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	261.353	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 3 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 3 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 3 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 3 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1 3 8	0.000	1.033	252.116	0.	0.	0.	0.	0.	0.	0.	0.
1 3 9	0.000	0.000	195.673	0.	0.	0.	0.	0.	0.	0.	0.
1 310	0.000	0.000	195.411	0.	0.	0.	0.	0.	0.	0.	0.
1 311	0.000	0.000	195.436	0.	0.	0.	0.	0.	0.	0.	0.
1 312	0.000	0.000	195.437	0.	0.	0.	0.	0.	0.	0.	0.
1 313	0.000	0.000	200.407	0.	0.	0.	0.	0.	0.	0.	0.
1 314	0.000	0.000	226.236	0.	0.	0.	0.	0.	0.	0.	0.
1 315	0.000	0.000	225.950	0.	0.	0.	0.	0.	0.	0.	0.
1 316	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
1 317	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
1 318	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 319	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
1 320	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
1 321	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
1 322	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
1 323	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
1 324	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 3)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	252.116	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2383.940	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	99.331	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 4 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 4 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 4 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 4 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 4 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 4 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 4 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 4 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1 4 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1 4 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 410	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 411	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 412	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 413	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 414	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 415	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 416	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1 417	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
1 418	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1 419	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1 420	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1 421	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1 422	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
1 423	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
1 424	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 4)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 5 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 5 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 5 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1 5 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1 5 8	0.000	1.033	463.762	0.	0.	0.	0.	0.	0.	0.	0.
1 5 9	0.000	0.000	465.419	0.	0.	0.	0.	0.	0.	0.	0.
1 510	0.000	0.000	471.229	0.	0.	0.	0.	0.	0.	0.	0.
1 511	0.000	0.000	466.657	0.	0.	0.	0.	0.	0.	0.	0.
1 512	0.000	0.000	443.773	0.	0.	0.	0.	0.	0.	0.	0.
1 513	0.000	0.000	442.831	0.	0.	0.	0.	0.	0.	0.	0.
1 514	0.000	0.000	462.099	0.	0.	0.	0.	0.	0.	0.	0.
1 515	0.000	0.000	470.343	0.	0.	0.	0.	0.	0.	0.	0.
1 516	0.000	0.000	470.536	0.	0.	0.	0.	0.	0.	0.	0.
1 517	0.000	1.550	465.249	0.	0.	0.	0.	0.	0.	0.	0.
1 518	0.000	6.199	434.878	0.	0.	0.	0.	0.	0.	0.	0.
1 519	0.000	9.299	330.179	0.	0.	0.	0.	0.	0.	0.	0.
1 520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
1 521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
1 522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
1 523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
1 524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	471.229	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6117.346	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	254.889	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 6 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 6 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 6 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1 6 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1 6 8	0.000	1.033	463.078	0.	0.	0.	0.	0.	0.	0.	0.
1 6 9	0.000	0.000	465.377	0.	0.	0.	0.	0.	0.	0.	0.
1 610	0.000	0.000	471.273	0.	0.	0.	0.	0.	0.	0.	0.
1 611	0.000	0.000	466.733	0.	0.	0.	0.	0.	0.	0.	0.
1 612	0.000	0.000	443.828	0.	0.	0.	0.	0.	0.	0.	0.
1 613	0.000	0.000	442.881	0.	0.	0.	0.	0.	0.	0.	0.
1 614	0.000	0.000	462.674	0.	0.	0.	0.	0.	0.	0.	0.
1 615	0.000	0.000	471.774	0.	0.	0.	0.	0.	0.	0.	0.
1 616	0.000	0.000	471.710	0.	0.	0.	0.	0.	0.	0.	0.
1 617	0.000	1.550	465.277	0.	0.	0.	0.	0.	0.	0.	0.
1 618	0.000	6.199	434.853	0.	0.	0.	0.	0.	0.	0.	0.
1 619	0.000	9.299	330.178	0.	0.	0.	0.	0.	0.	0.	0.
1 620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
1 621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
1 622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
1 623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
1 624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	471.774	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6120.026	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.001	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 7 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 7 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 7 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1 7 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1 7 8	0.000	1.033	463.112	0.	0.	0.	0.	0.	0.	0.	0.
1 7 9	0.000	0.000	465.378	0.	0.	0.	0.	0.	0.	0.	0.
1 710	0.000	0.000	471.273	0.	0.	0.	0.	0.	0.	0.	0.
1 711	0.000	0.000	467.197	0.	0.	0.	0.	0.	0.	0.	0.
1 712	0.000	0.000	444.043	0.	0.	0.	0.	0.	0.	0.	0.
1 713	0.000	0.000	443.336	0.	0.	0.	0.	0.	0.	0.	0.
1 714	0.000	0.000	463.807	0.	0.	0.	0.	0.	0.	0.	0.
1 715	0.000	0.000	473.741	0.	0.	0.	0.	0.	0.	0.	0.
1 716	0.000	0.000	473.818	0.	0.	0.	0.	0.	0.	0.	0.
1 717	0.000	1.550	466.620	0.	0.	0.	0.	0.	0.	0.	0.
1 718	0.000	6.199	434.854	0.	0.	0.	0.	0.	0.	0.	0.
1 719	0.000	9.299	330.205	0.	0.	0.	0.	0.	0.	0.	0.
1 720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
1 721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
1 722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
1 723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
1 724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 7)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	473.818	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6127.773	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.324	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 8 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
1 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 8 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 8 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1 8 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1 8 8	0.000	1.033	463.218	0.	0.	0.	0.	0.	0.	0.	0.
1 8 9	0.000	0.000	465.410	0.	0.	0.	0.	0.	0.	0.	0.
1 810	0.000	0.000	471.274	0.	0.	0.	0.	0.	0.	0.	0.
1 811	0.000	0.000	466.881	0.	0.	0.	0.	0.	0.	0.	0.
1 812	0.000	0.000	444.322	0.	0.	0.	0.	0.	0.	0.	0.
1 813	0.000	0.000	443.844	0.	0.	0.	0.	0.	0.	0.	0.
1 814	0.000	0.000	464.606	0.	0.	0.	0.	0.	0.	0.	0.
1 815	0.000	0.000	473.449	0.	0.	0.	0.	0.	0.	0.	0.
1 816	0.000	0.000	474.502	0.	0.	0.	0.	0.	0.	0.	0.
1 817	0.000	1.550	466.660	0.	0.	0.	0.	0.	0.	0.	0.
1 818	0.000	6.199	434.881	0.	0.	0.	0.	0.	0.	0.	0.
1 819	0.000	9.299	330.234	0.	0.	0.	0.	0.	0.	0.	0.
1 820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
1 821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
1 822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
1 823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
1 824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	474.502	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6129.670	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.403	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 9 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 9 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1 9 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1 9 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1 9 8	0.000	1.033	463.164	0.	0.	0.	0.	0.	0.	0.	0.
1 9 9	0.000	0.000	465.409	0.	0.	0.	0.	0.	0.	0.	0.
1 910	0.000	0.000	471.547	0.	0.	0.	0.	0.	0.	0.	0.
1 911	0.000	0.000	467.966	0.	0.	0.	0.	0.	0.	0.	0.
1 912	0.000	0.000	470.272	0.	0.	0.	0.	0.	0.	0.	0.
1 913	0.000	0.000	445.699	0.	0.	0.	0.	0.	0.	0.	0.
1 914	0.000	0.000	466.771	0.	0.	0.	0.	0.	0.	0.	0.
1 915	0.000	0.000	478.010	0.	0.	0.	0.	0.	0.	0.	0.
1 916	0.000	0.000	477.829	0.	0.	0.	0.	0.	0.	0.	0.
1 917	0.000	1.550	467.836	0.	0.	0.	0.	0.	0.	0.	0.
1 918	0.000	6.199	435.090	0.	0.	0.	0.	0.	0.	0.	0.
1 919	0.000	9.299	330.237	0.	0.	0.	0.	0.	0.	0.	0.
1 920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
1 921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
1 922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
1 923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
1 924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	478.010	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6170.222	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	257.093	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 10 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
110 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
110 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
110 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
110 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
110 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
110 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
110 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
110 8	0.000	1.033	250.677	0.	0.	0.	0.	0.	0.	0.	0.
110 9	0.000	0.000	195.869	0.	0.	0.	0.	0.	0.	0.	0.
11010	0.000	0.000	240.038	0.	0.	0.	0.	0.	0.	0.	0.
11011	0.000	0.000	292.844	0.	0.	0.	0.	0.	0.	0.	0.
11012	0.000	0.000	297.221	0.	0.	0.	0.	0.	0.	0.	0.
11013	0.000	0.000	238.997	0.	0.	0.	0.	0.	0.	0.	0.
11014	0.000	0.000	240.229	0.	0.	0.	0.	0.	0.	0.	0.
11015	0.000	0.000	201.199	0.	0.	0.	0.	0.	0.	0.	0.
11016	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
11017	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
11018	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11019	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11020	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11021	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11022	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11023	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
11024	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 10)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	297.221	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2654.346	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	110.598	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 11 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
111 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
111 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
111 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11116	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11117	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
11118	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11119	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11120	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11122	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11123	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
11124	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 11)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 12 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
112 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
112 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
112 8	0.000	1.033	463.233	0.	0.	0.	0.	0.	0.	0.	0.
112 9	0.000	0.000	465.410	0.	0.	0.	0.	0.	0.	0.	0.
11210	0.000	0.000	471.355	0.	0.	0.	0.	0.	0.	0.	0.
11211	0.000	0.000	467.454	0.	0.	0.	0.	0.	0.	0.	0.
11212	0.000	0.000	469.039	0.	0.	0.	0.	0.	0.	0.	0.
11213	0.000	0.000	445.018	0.	0.	0.	0.	0.	0.	0.	0.
11214	0.000	0.000	465.025	0.	0.	0.	0.	0.	0.	0.	0.
11215	0.000	0.000	475.624	0.	0.	0.	0.	0.	0.	0.	0.
11216	0.000	0.000	475.261	0.	0.	0.	0.	0.	0.	0.	0.
11217	0.000	1.550	467.249	0.	0.	0.	0.	0.	0.	0.	0.
11218	0.000	6.199	434.783	0.	0.	0.	0.	0.	0.	0.	0.
11219	0.000	9.299	330.032	0.	0.	0.	0.	0.	0.	0.	0.
11220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	475.624	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6159.875	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	256.661	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 13 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
113 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
113 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
113 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
113 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
113 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
113 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
113 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
113 8	0.000	1.033	462.865	0.	0.	0.	0.	0.	0.	0.	0.
113 9	0.000	0.000	465.248	0.	0.	0.	0.	0.	0.	0.	0.
11310	0.000	0.000	495.767	0.	0.	0.	0.	0.	0.	0.	0.
11311	0.000	0.000	549.514	0.	0.	0.	0.	0.	0.	0.	0.
11312	0.000	0.000	574.685	0.	0.	0.	0.	0.	0.	0.	0.
11313	0.000	0.000	593.039	0.	0.	0.	0.	0.	0.	0.	0.
11314	0.000	0.000	622.604	0.	0.	0.	0.	0.	0.	0.	0.
11315	0.000	0.000	597.214	0.	0.	0.	0.	0.	0.	0.	0.
11316	0.000	0.000	507.419	0.	0.	0.	0.	0.	0.	0.	0.
11317	0.000	1.550	471.098	0.	0.	0.	0.	0.	0.	0.	0.
11318	0.000	6.199	435.441	0.	0.	0.	0.	0.	0.	0.	0.
11319	0.000	9.299	330.154	0.	0.	0.	0.	0.	0.	0.	0.
11320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	622.604	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6835.438	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	284.810	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 14 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
114 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
114 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
114 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
114 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
114 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
114 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
114 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
114 8	0.000	1.033	463.013	0.	0.	0.	0.	0.	0.	0.	0.
114 9	0.000	0.000	488.474	0.	0.	0.	0.	0.	0.	0.	0.
11410	0.000	0.000	604.524	0.	0.	0.	0.	0.	0.	0.	0.
11411	0.000	0.000	623.083	0.	0.	0.	0.	0.	0.	0.	0.
11412	0.000	0.000	616.376	0.	0.	0.	0.	0.	0.	0.	0.
11413	0.000	0.000	599.761	0.	0.	0.	0.	0.	0.	0.	0.
11414	0.000	0.000	615.758	0.	0.	0.	0.	0.	0.	0.	0.
11415	0.000	0.000	632.908	0.	0.	0.	0.	0.	0.	0.	0.
11416	0.000	0.000	571.130	0.	0.	0.	0.	0.	0.	0.	0.
11417	0.000	1.550	474.856	0.	0.	0.	0.	0.	0.	0.	0.
11418	0.000	6.199	435.875	0.	0.	0.	0.	0.	0.	0.	0.
11419	0.000	9.299	330.155	0.	0.	0.	0.	0.	0.	0.	0.
11420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	632.908	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7186.303	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	299.429	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 15 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
115 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
115 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
115 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
115 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
115 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
115 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
115 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
115 8	0.000	1.033	463.063	0.	0.	0.	0.	0.	0.	0.	0.
115 9	0.000	0.000	465.348	0.	0.	0.	0.	0.	0.	0.	0.
11510	0.000	0.000	472.556	0.	0.	0.	0.	0.	0.	0.	0.
11511	0.000	0.000	467.063	0.	0.	0.	0.	0.	0.	0.	0.
11512	0.000	0.000	444.089	0.	0.	0.	0.	0.	0.	0.	0.
11513	0.000	0.000	443.357	0.	0.	0.	0.	0.	0.	0.	0.
11514	0.000	0.000	463.093	0.	0.	0.	0.	0.	0.	0.	0.
11515	0.000	0.000	471.576	0.	0.	0.	0.	0.	0.	0.	0.
11516	0.000	0.000	471.368	0.	0.	0.	0.	0.	0.	0.	0.
11517	0.000	1.550	465.561	0.	0.	0.	0.	0.	0.	0.	0.
11518	0.000	6.199	434.910	0.	0.	0.	0.	0.	0.	0.	0.
11519	0.000	9.299	330.207	0.	0.	0.	0.	0.	0.	0.	0.
11520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	472.556	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6122.582	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.108	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 16 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
116 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
116 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
116 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
116 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
116 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
116 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
116 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
116 8	0.000	1.033	463.275	0.	0.	0.	0.	0.	0.	0.	0.
116 9	0.000	0.000	465.479	0.	0.	0.	0.	0.	0.	0.	0.
11610	0.000	0.000	471.987	0.	0.	0.	0.	0.	0.	0.	0.
11611	0.000	0.000	467.848	0.	0.	0.	0.	0.	0.	0.	0.
11612	0.000	0.000	444.718	0.	0.	0.	0.	0.	0.	0.	0.
11613	0.000	0.000	444.111	0.	0.	0.	0.	0.	0.	0.	0.
11614	0.000	0.000	464.653	0.	0.	0.	0.	0.	0.	0.	0.
11615	0.000	0.000	472.632	0.	0.	0.	0.	0.	0.	0.	0.
11616	0.000	0.000	471.974	0.	0.	0.	0.	0.	0.	0.	0.
11617	0.000	1.550	465.642	0.	0.	0.	0.	0.	0.	0.	0.
11618	0.000	6.199	434.852	0.	0.	0.	0.	0.	0.	0.	0.
11619	0.000	9.299	330.178	0.	0.	0.	0.	0.	0.	0.	0.
11620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	472.632	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6127.739	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.322	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 17 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
117 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
117 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
117 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
117 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
117 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
117 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
117 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
117 8	0.000	1.033	251.102	0.	0.	0.	0.	0.	0.	0.	0.
117 9	0.000	0.000	196.000	0.	0.	0.	0.	0.	0.	0.	0.
11710	0.000	0.000	195.625	0.	0.	0.	0.	0.	0.	0.	0.
11711	0.000	0.000	195.528	0.	0.	0.	0.	0.	0.	0.	0.
11712	0.000	0.000	195.604	0.	0.	0.	0.	0.	0.	0.	0.
11713	0.000	0.000	195.552	0.	0.	0.	0.	0.	0.	0.	0.
11714	0.000	0.000	195.550	0.	0.	0.	0.	0.	0.	0.	0.
11715	0.000	0.000	195.550	0.	0.	0.	0.	0.	0.	0.	0.
11716	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
11717	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
11718	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11719	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11720	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11721	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11722	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11723	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
11724	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 17)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	251.102	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2317.783	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	96.574	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 18 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
118 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
118 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
118 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
118 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
118 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
118 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
118 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
118 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
118 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11810	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11811	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11812	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11813	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11814	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11815	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11816	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11817	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
11818	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11819	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11820	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11821	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11822	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11823	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
11824	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 18)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 19 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
119 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
119 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
119 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
119 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
119 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
119 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
119 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
119 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
119 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11910	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11911	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11912	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11913	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11914	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11915	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11916	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11917	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
11918	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11919	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11920	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11921	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11922	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11923	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
11924	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 19)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 20 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
120 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
120 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
120 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
120 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
120 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
120 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
120 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
120 8	0.000	1.033	462.773	0.	0.	0.	0.	0.	0.	0.	0.
120 9	0.000	0.000	465.172	0.	0.	0.	0.	0.	0.	0.	0.
12010	0.000	0.000	471.116	0.	0.	0.	0.	0.	0.	0.	0.
12011	0.000	0.000	466.543	0.	0.	0.	0.	0.	0.	0.	0.
12012	0.000	0.000	443.636	0.	0.	0.	0.	0.	0.	0.	0.
12013	0.000	0.000	442.716	0.	0.	0.	0.	0.	0.	0.	0.
12014	0.000	0.000	463.171	0.	0.	0.	0.	0.	0.	0.	0.
12015	0.000	0.000	472.433	0.	0.	0.	0.	0.	0.	0.	0.
12016	0.000	0.000	472.513	0.	0.	0.	0.	0.	0.	0.	0.
12017	0.000	1.550	465.452	0.	0.	0.	0.	0.	0.	0.	0.
12018	0.000	6.199	434.756	0.	0.	0.	0.	0.	0.	0.	0.
12019	0.000	9.299	330.105	0.	0.	0.	0.	0.	0.	0.	0.
12020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	472.513	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6120.776	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.032	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 21 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
121 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
121 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
121 8	0.000	1.033	462.794	0.	0.	0.	0.	0.	0.	0.	0.
121 9	0.000	0.000	465.247	0.	0.	0.	0.	0.	0.	0.	0.
12110	0.000	0.000	471.183	0.	0.	0.	0.	0.	0.	0.	0.
12111	0.000	0.000	466.946	0.	0.	0.	0.	0.	0.	0.	0.
12112	0.000	0.000	444.161	0.	0.	0.	0.	0.	0.	0.	0.
12113	0.000	0.000	443.752	0.	0.	0.	0.	0.	0.	0.	0.
12114	0.000	0.000	464.999	0.	0.	0.	0.	0.	0.	0.	0.
12115	0.000	0.000	474.069	0.	0.	0.	0.	0.	0.	0.	0.
12116	0.000	0.000	472.793	0.	0.	0.	0.	0.	0.	0.	0.
12117	0.000	1.550	465.849	0.	0.	0.	0.	0.	0.	0.	0.
12118	0.000	6.199	434.804	0.	0.	0.	0.	0.	0.	0.	0.
12119	0.000	9.299	330.151	0.	0.	0.	0.	0.	0.	0.	0.
12120	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12121	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12122	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12123	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12124	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	474.069	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6127.140	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.298	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 22 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
122 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
122 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
122 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
122 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
122 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
122 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
122 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
122 8	0.000	1.033	462.970	0.	0.	0.	0.	0.	0.	0.	0.
122 9	0.000	0.000	465.295	0.	0.	0.	0.	0.	0.	0.	0.
12210	0.000	0.000	471.222	0.	0.	0.	0.	0.	0.	0.	0.
12211	0.000	0.000	467.371	0.	0.	0.	0.	0.	0.	0.	0.
12212	0.000	0.000	485.404	0.	0.	0.	0.	0.	0.	0.	0.
12213	0.000	0.000	469.182	0.	0.	0.	0.	0.	0.	0.	0.
12214	0.000	0.000	513.327	0.	0.	0.	0.	0.	0.	0.	0.
12215	0.000	0.000	505.930	0.	0.	0.	0.	0.	0.	0.	0.
12216	0.000	0.000	485.043	0.	0.	0.	0.	0.	0.	0.	0.
12217	0.000	1.550	469.039	0.	0.	0.	0.	0.	0.	0.	0.
12218	0.000	6.199	435.020	0.	0.	0.	0.	0.	0.	0.	0.
12219	0.000	9.299	330.150	0.	0.	0.	0.	0.	0.	0.	0.
12220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	513.327	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6290.344	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	262.098	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 23 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
123 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
123 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
123 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
123 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
123 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
123 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
123 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
123 8	0.000	1.033	462.895	0.	0.	0.	0.	0.	0.	0.	0.
123 9	0.000	0.000	465.249	0.	0.	0.	0.	0.	0.	0.	0.
12310	0.000	0.000	471.502	0.	0.	0.	0.	0.	0.	0.	0.
12311	0.000	0.000	511.050	0.	0.	0.	0.	0.	0.	0.	0.
12312	0.000	0.000	554.417	0.	0.	0.	0.	0.	0.	0.	0.
12313	0.000	0.000	506.847	0.	0.	0.	0.	0.	0.	0.	0.
12314	0.000	0.000	494.905	0.	0.	0.	0.	0.	0.	0.	0.
12315	0.000	0.000	506.843	0.	0.	0.	0.	0.	0.	0.	0.
12316	0.000	0.000	477.289	0.	0.	0.	0.	0.	0.	0.	0.
12317	0.000	1.550	467.798	0.	0.	0.	0.	0.	0.	0.	0.
12318	0.000	6.199	435.130	0.	0.	0.	0.	0.	0.	0.	0.
12319	0.000	9.299	330.268	0.	0.	0.	0.	0.	0.	0.	0.
12320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	554.417	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6414.583	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	267.274	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 24 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
124 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
124 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
124 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
124 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
124 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
124 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
124 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
124 8	0.000	1.033	250.568	0.	0.	0.	0.	0.	0.	0.	0.
124 9	0.000	0.000	195.769	0.	0.	0.	0.	0.	0.	0.	0.
12410	0.000	0.000	252.840	0.	0.	0.	0.	0.	0.	0.	0.
12411	0.000	0.000	349.542	0.	0.	0.	0.	0.	0.	0.	0.
12412	0.000	0.000	214.468	0.	0.	0.	0.	0.	0.	0.	0.
12413	0.000	0.000	307.614	0.	0.	0.	0.	0.	0.	0.	0.
12414	0.000	0.000	351.497	0.	0.	0.	0.	0.	0.	0.	0.
12415	0.000	0.000	332.601	0.	0.	0.	0.	0.	0.	0.	0.
12416	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
12417	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
12418	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12419	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12420	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12422	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12423	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
12424	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 24)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	351.497	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2952.170	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	123.007	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 25 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
125 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
125 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
125 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
125 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
125 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
125 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
125 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
125 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
125 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12517	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
12518	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12519	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12522	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12523	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
12524	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 25)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 26 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
126 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
126 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
126 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
126 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
126 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
126 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
126 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
126 8	0.000	1.033	466.661	0.	0.	0.	0.	0.	0.	0.	0.
126 9	0.000	0.000	503.566	0.	0.	0.	0.	0.	0.	0.	0.
12610	0.000	0.000	621.593	0.	0.	0.	0.	0.	0.	0.	0.
12611	0.000	0.000	639.696	0.	0.	0.	0.	0.	0.	0.	0.
12612	0.000	0.000	615.996	0.	0.	0.	0.	0.	0.	0.	0.
12613	0.000	0.000	627.439	0.	0.	0.	0.	0.	0.	0.	0.
12614	0.000	0.000	650.812	0.	0.	0.	0.	0.	0.	0.	0.
12615	0.000	0.000	658.123	0.	0.	0.	0.	0.	0.	0.	0.
12616	0.000	0.000	641.262	0.	0.	0.	0.	0.	0.	0.	0.
12617	0.000	1.550	559.490	0.	0.	0.	0.	0.	0.	0.	0.
12618	0.000	6.199	564.962	0.	0.	0.	0.	0.	0.	0.	0.
12619	0.000	9.299	443.773	0.	0.	0.	0.	0.	0.	0.	0.
12620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	658.123	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7723.766	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	321.824	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 27 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
127 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
127 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
127 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
127 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
127 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
127 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
127 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
127 8	0.000	1.033	471.205	0.	0.	0.	0.	0.	0.	0.	0.
127 9	0.000	0.000	489.513	0.	0.	0.	0.	0.	0.	0.	0.
12710	0.000	0.000	585.788	0.	0.	0.	0.	0.	0.	0.	0.
12711	0.000	0.000	603.853	0.	0.	0.	0.	0.	0.	0.	0.
12712	0.000	0.000	617.407	0.	0.	0.	0.	0.	0.	0.	0.
12713	0.000	0.000	622.451	0.	0.	0.	0.	0.	0.	0.	0.
12714	0.000	0.000	646.125	0.	0.	0.	0.	0.	0.	0.	0.
12715	0.000	0.000	644.782	0.	0.	0.	0.	0.	0.	0.	0.
12716	0.000	0.000	537.573	0.	0.	0.	0.	0.	0.	0.	0.
12717	0.000	1.550	500.978	0.	0.	0.	0.	0.	0.	0.	0.
12718	0.000	6.199	438.467	0.	0.	0.	0.	0.	0.	0.	0.
12719	0.000	9.299	330.207	0.	0.	0.	0.	0.	0.	0.	0.
12720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	646.125	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7218.741	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	300.781	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 28 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
128 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
128 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
128 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
128 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
128 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
128 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
128 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
128 8	0.000	1.033	463.462	0.	0.	0.	0.	0.	0.	0.	0.
128 9	0.000	0.000	466.456	0.	0.	0.	0.	0.	0.	0.	0.
12810	0.000	0.000	577.044	0.	0.	0.	0.	0.	0.	0.	0.
12811	0.000	0.000	627.485	0.	0.	0.	0.	0.	0.	0.	0.
12812	0.000	0.000	617.229	0.	0.	0.	0.	0.	0.	0.	0.
12813	0.000	0.000	557.835	0.	0.	0.	0.	0.	0.	0.	0.
12814	0.000	0.000	570.822	0.	0.	0.	0.	0.	0.	0.	0.
12815	0.000	0.000	564.754	0.	0.	0.	0.	0.	0.	0.	0.
12816	0.000	0.000	531.848	0.	0.	0.	0.	0.	0.	0.	0.
12817	0.000	1.550	477.134	0.	0.	0.	0.	0.	0.	0.	0.
12818	0.000	6.199	462.741	0.	0.	0.	0.	0.	0.	0.	0.
12819	0.000	9.299	363.944	0.	0.	0.	0.	0.	0.	0.	0.
12820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	627.485	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7011.144	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	292.131	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 29 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
129 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
129 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
129 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
129 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
129 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
129 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
129 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
129 8	0.000	1.033	463.697	0.	0.	0.	0.	0.	0.	0.	0.
129 9	0.000	0.000	466.479	0.	0.	0.	0.	0.	0.	0.	0.
12910	0.000	0.000	474.568	0.	0.	0.	0.	0.	0.	0.	0.
12911	0.000	0.000	500.809	0.	0.	0.	0.	0.	0.	0.	0.
12912	0.000	0.000	450.718	0.	0.	0.	0.	0.	0.	0.	0.
12913	0.000	0.000	447.096	0.	0.	0.	0.	0.	0.	0.	0.
12914	0.000	0.000	468.469	0.	0.	0.	0.	0.	0.	0.	0.
12915	0.000	0.000	478.447	0.	0.	0.	0.	0.	0.	0.	0.
12916	0.000	0.000	478.272	0.	0.	0.	0.	0.	0.	0.	0.
12917	0.000	1.550	469.206	0.	0.	0.	0.	0.	0.	0.	0.
12918	0.000	6.199	435.510	0.	0.	0.	0.	0.	0.	0.	0.
12919	0.000	9.299	330.206	0.	0.	0.	0.	0.	0.	0.	0.
12920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	500.809	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6193.867	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	258.078	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 30 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
130 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
130 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
130 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
130 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
130 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
130 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
130 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
130 8	0.000	1.033	463.360	0.	0.	0.	0.	0.	0.	0.	0.
130 9	0.000	0.000	465.446	0.	0.	0.	0.	0.	0.	0.	0.
13010	0.000	0.000	473.174	0.	0.	0.	0.	0.	0.	0.	0.
13011	0.000	0.000	468.236	0.	0.	0.	0.	0.	0.	0.	0.
13012	0.000	0.000	446.263	0.	0.	0.	0.	0.	0.	0.	0.
13013	0.000	0.000	445.585	0.	0.	0.	0.	0.	0.	0.	0.
13014	0.000	0.000	468.583	0.	0.	0.	0.	0.	0.	0.	0.
13015	0.000	0.000	475.777	0.	0.	0.	0.	0.	0.	0.	0.
13016	0.000	0.000	476.262	0.	0.	0.	0.	0.	0.	0.	0.
13017	0.000	1.550	467.872	0.	0.	0.	0.	0.	0.	0.	0.
13018	0.000	6.199	435.104	0.	0.	0.	0.	0.	0.	0.	0.
13019	0.000	9.299	330.205	0.	0.	0.	0.	0.	0.	0.	0.
13020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
13021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
13022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
13023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
13024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	476.262	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6146.258	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	256.094	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 31 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
131 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
131 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
131 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
131 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
131 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
131 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
131 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
131 8	0.000	1.033	250.804	0.	0.	0.	0.	0.	0.	0.	0.
131 9	0.000	0.000	195.872	0.	0.	0.	0.	0.	0.	0.	0.
13110	0.000	0.000	195.619	0.	0.	0.	0.	0.	0.	0.	0.
13111	0.000	0.000	195.608	0.	0.	0.	0.	0.	0.	0.	0.
13112	0.000	0.000	195.579	0.	0.	0.	0.	0.	0.	0.	0.
13113	0.000	0.000	195.578	0.	0.	0.	0.	0.	0.	0.	0.
13114	0.000	0.000	195.578	0.	0.	0.	0.	0.	0.	0.	0.
13115	0.000	0.000	195.578	0.	0.	0.	0.	0.	0.	0.	0.
13116	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
13117	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
13118	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
13119	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
13120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
13121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
13122	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
13123	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
13124	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 31)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	250.804	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2317.487	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	96.562	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (JAN)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	658.123	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	3154.877	143463.078	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	192.827	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 32 - 2

		EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
		DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
		---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
2 1 1		0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 1 2		0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 1 3		0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 1 4		0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 1 5		0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 1 6		0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
2 1 7		0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
2 1 8		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 1 9		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 110		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 111		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 112		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 113		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 114		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 115		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 116		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 117		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 118		0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
2 119		0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
2 120		0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
2 121		0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
2 122		0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
2 123		0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
2 124		0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 1)												
MN		0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX		0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM		0.000	90.405	358.846	0.	0.	0.	0.	0.	0.	0.	0.
AV		0.000	3.767	14.952	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 33 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 2 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 2 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
2 2 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
2 2 8	0.000	0.000	462.379	0.	0.	0.	0.	0.	0.	0.	0.
2 2 9	0.000	0.000	465.447	0.	0.	0.	0.	0.	0.	0.	0.
2 210	0.000	0.000	471.276	0.	0.	0.	0.	0.	0.	0.	0.
2 211	0.000	0.000	466.682	0.	0.	0.	0.	0.	0.	0.	0.
2 212	0.000	0.000	443.799	0.	0.	0.	0.	0.	0.	0.	0.
2 213	0.000	0.000	442.880	0.	0.	0.	0.	0.	0.	0.	0.
2 214	0.000	0.000	462.153	0.	0.	0.	0.	0.	0.	0.	0.
2 215	0.000	0.000	470.425	0.	0.	0.	0.	0.	0.	0.	0.
2 216	0.000	0.000	470.595	0.	0.	0.	0.	0.	0.	0.	0.
2 217	0.000	0.000	463.702	0.	0.	0.	0.	0.	0.	0.	0.
2 218	0.000	2.583	431.236	0.	0.	0.	0.	0.	0.	0.	0.
2 219	0.000	7.232	328.111	0.	0.	0.	0.	0.	0.	0.	0.
2 220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
2 221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
2 222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
2 223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
2 224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	471.276	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6105.975	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	254.416	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 34 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 3 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 3 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
2 3 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
2 3 8	0.000	0.000	462.080	0.	0.	0.	0.	0.	0.	0.	0.
2 3 9	0.000	0.000	465.408	0.	0.	0.	0.	0.	0.	0.	0.
2 310	0.000	0.000	471.299	0.	0.	0.	0.	0.	0.	0.	0.
2 311	0.000	0.000	467.573	0.	0.	0.	0.	0.	0.	0.	0.
2 312	0.000	0.000	444.672	0.	0.	0.	0.	0.	0.	0.	0.
2 313	0.000	0.000	444.257	0.	0.	0.	0.	0.	0.	0.	0.
2 314	0.000	0.000	466.217	0.	0.	0.	0.	0.	0.	0.	0.
2 315	0.000	0.000	477.544	0.	0.	0.	0.	0.	0.	0.	0.
2 316	0.000	0.000	479.272	0.	0.	0.	0.	0.	0.	0.	0.
2 317	0.000	0.000	469.621	0.	0.	0.	0.	0.	0.	0.	0.
2 318	0.000	2.583	431.970	0.	0.	0.	0.	0.	0.	0.	0.
2 319	0.000	7.232	328.087	0.	0.	0.	0.	0.	0.	0.	0.
2 320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
2 321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
2 322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
2 323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
2 324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	479.272	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6135.291	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	255.637	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 35 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 4 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 4 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
2 4 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
2 4 8	0.000	0.000	462.029	0.	0.	0.	0.	0.	0.	0.	0.
2 4 9	0.000	0.000	465.348	0.	0.	0.	0.	0.	0.	0.	0.
2 410	0.000	0.000	471.411	0.	0.	0.	0.	0.	0.	0.	0.
2 411	0.000	0.000	468.153	0.	0.	0.	0.	0.	0.	0.	0.
2 412	0.000	0.000	471.029	0.	0.	0.	0.	0.	0.	0.	0.
2 413	0.000	0.000	471.269	0.	0.	0.	0.	0.	0.	0.	0.
2 414	0.000	0.000	468.645	0.	0.	0.	0.	0.	0.	0.	0.
2 415	0.000	0.000	477.583	0.	0.	0.	0.	0.	0.	0.	0.
2 416	0.000	0.000	477.225	0.	0.	0.	0.	0.	0.	0.	0.
2 417	0.000	0.000	467.456	0.	0.	0.	0.	0.	0.	0.	0.
2 418	0.000	2.583	431.602	0.	0.	0.	0.	0.	0.	0.	0.
2 419	0.000	7.232	328.141	0.	0.	0.	0.	0.	0.	0.	0.
2 420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
2 421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
2 422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
2 423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
2 424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	477.583	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6187.183	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.799	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 36 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 5 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 5 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
2 5 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
2 5 8	0.000	0.000	462.129	0.	0.	0.	0.	0.	0.	0.	0.
2 5 9	0.000	0.000	465.409	0.	0.	0.	0.	0.	0.	0.	0.
2 510	0.000	0.000	472.189	0.	0.	0.	0.	0.	0.	0.	0.
2 511	0.000	0.000	468.875	0.	0.	0.	0.	0.	0.	0.	0.
2 512	0.000	0.000	445.170	0.	0.	0.	0.	0.	0.	0.	0.
2 513	0.000	0.000	445.163	0.	0.	0.	0.	0.	0.	0.	0.
2 514	0.000	0.000	467.297	0.	0.	0.	0.	0.	0.	0.	0.
2 515	0.000	0.000	477.760	0.	0.	0.	0.	0.	0.	0.	0.
2 516	0.000	0.000	479.630	0.	0.	0.	0.	0.	0.	0.	0.
2 517	0.000	0.000	469.228	0.	0.	0.	0.	0.	0.	0.	0.
2 518	0.000	2.583	432.079	0.	0.	0.	0.	0.	0.	0.	0.
2 519	0.000	7.232	328.139	0.	0.	0.	0.	0.	0.	0.	0.
2 520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
2 521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
2 522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
2 523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
2 524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	479.630	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6140.358	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	255.848	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 37 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
2 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 6 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 6 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
2 6 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
2 6 8	0.000	0.000	462.311	0.	0.	0.	0.	0.	0.	0.	0.
2 6 9	0.000	0.000	465.446	0.	0.	0.	0.	0.	0.	0.	0.
2 610	0.000	0.000	472.127	0.	0.	0.	0.	0.	0.	0.	0.
2 611	0.000	0.000	469.201	0.	0.	0.	0.	0.	0.	0.	0.
2 612	0.000	0.000	445.885	0.	0.	0.	0.	0.	0.	0.	0.
2 613	0.000	0.000	445.154	0.	0.	0.	0.	0.	0.	0.	0.
2 614	0.000	0.000	467.220	0.	0.	0.	0.	0.	0.	0.	0.
2 615	0.000	0.000	479.713	0.	0.	0.	0.	0.	0.	0.	0.
2 616	0.000	0.000	480.238	0.	0.	0.	0.	0.	0.	0.	0.
2 617	0.000	0.000	469.161	0.	0.	0.	0.	0.	0.	0.	0.
2 618	0.000	2.583	432.007	0.	0.	0.	0.	0.	0.	0.	0.
2 619	0.000	7.232	328.141	0.	0.	0.	0.	0.	0.	0.	0.
2 620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
2 621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
2 622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
2 623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
2 624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	480.238	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6143.895	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	255.996	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 38 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 7 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 7 6	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
2 7 7	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
2 7 8	0.000	0.000	249.594	0.	0.	0.	0.	0.	0.	0.	0.
2 7 9	0.000	0.000	195.800	0.	0.	0.	0.	0.	0.	0.	0.
2 710	0.000	0.000	195.587	0.	0.	0.	0.	0.	0.	0.	0.
2 711	0.000	0.000	195.607	0.	0.	0.	0.	0.	0.	0.	0.
2 712	0.000	0.000	195.639	0.	0.	0.	0.	0.	0.	0.	0.
2 713	0.000	0.000	202.726	0.	0.	0.	0.	0.	0.	0.	0.
2 714	0.000	0.000	195.981	0.	0.	0.	0.	0.	0.	0.	0.
2 715	0.000	0.000	195.686	0.	0.	0.	0.	0.	0.	0.	0.
2 716	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
2 717	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
2 718	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
2 719	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
2 720	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
2 721	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
2 722	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
2 723	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
2 724	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 7)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.594	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2313.560	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	96.398	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 39 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 8 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 8 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 8 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 8 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 8 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
2 8 6	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
2 8 7	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
2 8 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 8 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 810	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 811	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 812	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 813	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 814	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 815	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 816	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 817	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
2 818	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
2 819	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
2 820	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
2 821	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
2 822	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
2 823	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
2 824	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 8)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	358.846	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	14.952	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 40 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
2 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 9 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
2 9 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
2 9 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
2 9 8	0.000	0.000	462.080	0.	0.	0.	0.	0.	0.	0.	0.
2 9 9	0.000	0.000	465.512	0.	0.	0.	0.	0.	0.	0.	0.
2 910	0.000	0.000	471.360	0.	0.	0.	0.	0.	0.	0.	0.
2 911	0.000	0.000	475.630	0.	0.	0.	0.	0.	0.	0.	0.
2 912	0.000	0.000	474.133	0.	0.	0.	0.	0.	0.	0.	0.
2 913	0.000	0.000	452.351	0.	0.	0.	0.	0.	0.	0.	0.
2 914	0.000	0.000	598.686	0.	0.	0.	0.	0.	0.	0.	0.
2 915	0.000	0.000	626.767	0.	0.	0.	0.	0.	0.	0.	0.
2 916	0.000	0.000	547.031	0.	0.	0.	0.	0.	0.	0.	0.
2 917	0.000	0.000	494.221	0.	0.	0.	0.	0.	0.	0.	0.
2 918	0.000	2.583	432.714	0.	0.	0.	0.	0.	0.	0.	0.
2 919	0.000	7.232	328.235	0.	0.	0.	0.	0.	0.	0.	0.
2 920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
2 921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
2 922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
2 923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
2 924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	626.767	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6556.010	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	273.167	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 41 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
210 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
210 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
210 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
210 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
210 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
210 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
210 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
210 8	0.000	0.000	461.982	0.	0.	0.	0.	0.	0.	0.	0.
210 9	0.000	0.000	522.067	0.	0.	0.	0.	0.	0.	0.	0.
21010	0.000	0.000	622.880	0.	0.	0.	0.	0.	0.	0.	0.
21011	0.000	0.000	638.333	0.	0.	0.	0.	0.	0.	0.	0.
21012	0.000	0.000	611.539	0.	0.	0.	0.	0.	0.	0.	0.
21013	0.000	0.000	608.812	0.	0.	0.	0.	0.	0.	0.	0.
21014	0.000	0.000	630.256	0.	0.	0.	0.	0.	0.	0.	0.
21015	0.000	0.000	634.628	0.	0.	0.	0.	0.	0.	0.	0.
21016	0.000	0.000	628.132	0.	0.	0.	0.	0.	0.	0.	0.
21017	0.000	0.000	588.644	0.	0.	0.	0.	0.	0.	0.	0.
21018	0.000	2.583	496.413	0.	0.	0.	0.	0.	0.	0.	0.
21019	0.000	7.232	333.843	0.	0.	0.	0.	0.	0.	0.	0.
21020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	638.333	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7504.820	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	312.701	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 42 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
211 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
211 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
211 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
211 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
211 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
211 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
211 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
211 8	0.000	0.000	462.366	0.	0.	0.	0.	0.	0.	0.	0.
211 9	0.000	0.000	489.861	0.	0.	0.	0.	0.	0.	0.	0.
21110	0.000	0.000	622.555	0.	0.	0.	0.	0.	0.	0.	0.
21111	0.000	0.000	634.220	0.	0.	0.	0.	0.	0.	0.	0.
21112	0.000	0.000	603.291	0.	0.	0.	0.	0.	0.	0.	0.
21113	0.000	0.000	603.514	0.	0.	0.	0.	0.	0.	0.	0.
21114	0.000	0.000	636.102	0.	0.	0.	0.	0.	0.	0.	0.
21115	0.000	0.000	650.012	0.	0.	0.	0.	0.	0.	0.	0.
21116	0.000	0.000	650.645	0.	0.	0.	0.	0.	0.	0.	0.
21117	0.000	0.000	612.961	0.	0.	0.	0.	0.	0.	0.	0.
21118	0.000	2.583	536.240	0.	0.	0.	0.	0.	0.	0.	0.
21119	0.000	7.232	331.469	0.	0.	0.	0.	0.	0.	0.	0.
21120	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21121	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21122	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21123	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21124	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	650.645	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7560.526	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	315.022	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 43 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
212 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
212 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
212 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
212 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
212 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
212 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
212 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
212 8	0.000	0.000	487.363	0.	0.	0.	0.	0.	0.	0.	0.
212 9	0.000	0.000	619.104	0.	0.	0.	0.	0.	0.	0.	0.
21210	0.000	0.000	646.626	0.	0.	0.	0.	0.	0.	0.	0.
21211	0.000	0.000	649.128	0.	0.	0.	0.	0.	0.	0.	0.
21212	0.000	0.000	628.529	0.	0.	0.	0.	0.	0.	0.	0.
21213	0.000	0.000	629.395	0.	0.	0.	0.	0.	0.	0.	0.
21214	0.000	0.000	662.067	0.	0.	0.	0.	0.	0.	0.	0.
21215	0.000	0.000	669.367	0.	0.	0.	0.	0.	0.	0.	0.
21216	0.000	0.000	671.567	0.	0.	0.	0.	0.	0.	0.	0.
21217	0.000	0.000	636.021	0.	0.	0.	0.	0.	0.	0.	0.
21218	0.000	2.583	500.620	0.	0.	0.	0.	0.	0.	0.	0.
21219	0.000	7.232	365.165	0.	0.	0.	0.	0.	0.	0.	0.
21220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	671.567	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7892.242	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	328.843	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 44 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
213 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
213 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
213 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
213 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
213 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
213 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
213 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
213 8	0.000	0.000	463.862	0.	0.	0.	0.	0.	0.	0.	0.
213 9	0.000	0.000	592.109	0.	0.	0.	0.	0.	0.	0.	0.
21310	0.000	0.000	638.110	0.	0.	0.	0.	0.	0.	0.	0.
21311	0.000	0.000	651.814	0.	0.	0.	0.	0.	0.	0.	0.
21312	0.000	0.000	633.047	0.	0.	0.	0.	0.	0.	0.	0.
21313	0.000	0.000	618.836	0.	0.	0.	0.	0.	0.	0.	0.
21314	0.000	0.000	639.095	0.	0.	0.	0.	0.	0.	0.	0.
21315	0.000	0.000	648.321	0.	0.	0.	0.	0.	0.	0.	0.
21316	0.000	0.000	639.994	0.	0.	0.	0.	0.	0.	0.	0.
21317	0.000	0.000	609.206	0.	0.	0.	0.	0.	0.	0.	0.
21318	0.000	2.583	442.567	0.	0.	0.	0.	0.	0.	0.	0.
21319	0.000	7.232	328.337	0.	0.	0.	0.	0.	0.	0.	0.
21320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	651.814	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7632.589	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	318.025	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 45 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
214 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
214 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
214 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
214 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
214 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
214 6	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
214 7	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
214 8	0.000	0.000	249.796	0.	0.	0.	0.	0.	0.	0.	0.
214 9	0.000	0.000	195.950	0.	0.	0.	0.	0.	0.	0.	0.
21410	0.000	0.000	195.688	0.	0.	0.	0.	0.	0.	0.	0.
21411	0.000	0.000	195.751	0.	0.	0.	0.	0.	0.	0.	0.
21412	0.000	0.000	254.006	0.	0.	0.	0.	0.	0.	0.	0.
21413	0.000	0.000	267.304	0.	0.	0.	0.	0.	0.	0.	0.
21414	0.000	0.000	222.757	0.	0.	0.	0.	0.	0.	0.	0.
21415	0.000	0.000	196.768	0.	0.	0.	0.	0.	0.	0.	0.
21416	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
21417	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
21418	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
21419	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
21420	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
21421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
21422	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
21423	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
21424	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 14)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	267.304	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2464.959	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	102.707	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 46 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
215 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
215 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
215 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
215 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
215 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
215 6	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
215 7	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
215 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
215 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21517	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21518	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
21519	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
21520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
21521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
21522	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
21523	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
21524	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 15)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	358.846	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	14.952	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 47 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
216 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
216 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
216 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
216 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
216 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
216 6	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
216 7	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
216 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
216 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21616	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21617	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
21618	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
21619	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
21620	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
21621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
21622	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
21623	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
21624	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 16)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	358.846	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	14.952	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 48 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
217 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
217 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
217 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
217 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
217 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
217 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
217 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
217 8	0.000	0.000	462.311	0.	0.	0.	0.	0.	0.	0.	0.
217 9	0.000	0.000	465.481	0.	0.	0.	0.	0.	0.	0.	0.
21710	0.000	0.000	471.329	0.	0.	0.	0.	0.	0.	0.	0.
21711	0.000	0.000	466.709	0.	0.	0.	0.	0.	0.	0.	0.
21712	0.000	0.000	443.855	0.	0.	0.	0.	0.	0.	0.	0.
21713	0.000	0.000	443.252	0.	0.	0.	0.	0.	0.	0.	0.
21714	0.000	0.000	463.947	0.	0.	0.	0.	0.	0.	0.	0.
21715	0.000	0.000	472.849	0.	0.	0.	0.	0.	0.	0.	0.
21716	0.000	0.000	472.860	0.	0.	0.	0.	0.	0.	0.	0.
21717	0.000	0.000	464.551	0.	0.	0.	0.	0.	0.	0.	0.
21718	0.000	2.583	431.293	0.	0.	0.	0.	0.	0.	0.	0.
21719	0.000	7.232	328.141	0.	0.	0.	0.	0.	0.	0.	0.
21720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	472.860	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6113.869	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	254.745	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 49 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
218 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
218 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
218 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
218 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
218 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
218 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
218 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
218 8	0.000	0.000	462.307	0.	0.	0.	0.	0.	0.	0.	0.
218 9	0.000	0.000	465.480	0.	0.	0.	0.	0.	0.	0.	0.
21810	0.000	0.000	471.381	0.	0.	0.	0.	0.	0.	0.	0.
21811	0.000	0.000	467.781	0.	0.	0.	0.	0.	0.	0.	0.
21812	0.000	0.000	452.948	0.	0.	0.	0.	0.	0.	0.	0.
21813	0.000	0.000	444.824	0.	0.	0.	0.	0.	0.	0.	0.
21814	0.000	0.000	466.188	0.	0.	0.	0.	0.	0.	0.	0.
21815	0.000	0.000	478.601	0.	0.	0.	0.	0.	0.	0.	0.
21816	0.000	0.000	479.857	0.	0.	0.	0.	0.	0.	0.	0.
21817	0.000	0.000	470.563	0.	0.	0.	0.	0.	0.	0.	0.
21818	0.000	2.583	432.327	0.	0.	0.	0.	0.	0.	0.	0.
21819	0.000	7.232	328.086	0.	0.	0.	0.	0.	0.	0.	0.
21820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	479.857	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6147.633	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	256.151	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 50 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
219 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
219 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
219 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
219 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
219 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
219 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
219 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
219 8	0.000	0.000	462.245	0.	0.	0.	0.	0.	0.	0.	0.
219 9	0.000	0.000	465.479	0.	0.	0.	0.	0.	0.	0.	0.
21910	0.000	0.000	471.302	0.	0.	0.	0.	0.	0.	0.	0.
21911	0.000	0.000	466.708	0.	0.	0.	0.	0.	0.	0.	0.
21912	0.000	0.000	443.827	0.	0.	0.	0.	0.	0.	0.	0.
21913	0.000	0.000	442.907	0.	0.	0.	0.	0.	0.	0.	0.
21914	0.000	0.000	463.066	0.	0.	0.	0.	0.	0.	0.	0.
21915	0.000	0.000	471.471	0.	0.	0.	0.	0.	0.	0.	0.
21916	0.000	0.000	473.123	0.	0.	0.	0.	0.	0.	0.	0.
21917	0.000	0.000	465.396	0.	0.	0.	0.	0.	0.	0.	0.
21918	0.000	2.583	431.164	0.	0.	0.	0.	0.	0.	0.	0.
21919	0.000	7.232	327.951	0.	0.	0.	0.	0.	0.	0.	0.
21920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
21921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
21922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
21923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
21924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	473.123	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6111.930	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	254.664	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 51 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
220 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
220 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
220 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
220 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
220 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
220 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
220 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
220 8	0.000	0.000	461.765	0.	0.	0.	0.	0.	0.	0.	0.
220 9	0.000	0.000	465.172	0.	0.	0.	0.	0.	0.	0.	0.
22010	0.000	0.000	471.568	0.	0.	0.	0.	0.	0.	0.	0.
22011	0.000	0.000	468.178	0.	0.	0.	0.	0.	0.	0.	0.
22012	0.000	0.000	445.204	0.	0.	0.	0.	0.	0.	0.	0.
22013	0.000	0.000	444.369	0.	0.	0.	0.	0.	0.	0.	0.
22014	0.000	0.000	467.105	0.	0.	0.	0.	0.	0.	0.	0.
22015	0.000	0.000	478.495	0.	0.	0.	0.	0.	0.	0.	0.
22016	0.000	0.000	479.086	0.	0.	0.	0.	0.	0.	0.	0.
22017	0.000	0.000	469.364	0.	0.	0.	0.	0.	0.	0.	0.
22018	0.000	2.583	432.009	0.	0.	0.	0.	0.	0.	0.	0.
22019	0.000	7.232	328.038	0.	0.	0.	0.	0.	0.	0.	0.
22020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
22021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
22022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
22023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
22024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	479.086	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6137.643	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	255.735	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 52 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
221 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
221 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
221 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
221 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
221 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
221 6	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
221 7	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
221 8	0.000	0.000	249.399	0.	0.	0.	0.	0.	0.	0.	0.
221 9	0.000	0.000	195.711	0.	0.	0.	0.	0.	0.	0.	0.
22110	0.000	0.000	195.508	0.	0.	0.	0.	0.	0.	0.	0.
22111	0.000	0.000	195.548	0.	0.	0.	0.	0.	0.	0.	0.
22112	0.000	0.000	195.550	0.	0.	0.	0.	0.	0.	0.	0.
22113	0.000	0.000	195.605	0.	0.	0.	0.	0.	0.	0.	0.
22114	0.000	0.000	195.608	0.	0.	0.	0.	0.	0.	0.	0.
22115	0.000	0.000	195.579	0.	0.	0.	0.	0.	0.	0.	0.
22116	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
22117	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
22118	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
22119	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
22120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
22121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
22122	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
22123	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
22124	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 21)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.399	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2305.448	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	96.060	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 53 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
222 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
222 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
222 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
222 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
222 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
222 6	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
222 7	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
222 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
222 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22216	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22217	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
22218	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
22219	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
22220	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
22221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
22222	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
22223	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
22224	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 22)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	358.846	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	14.952	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 54 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
223 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
223 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
223 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
223 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
223 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
223 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
223 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
223 8	0.000	0.000	462.078	0.	0.	0.	0.	0.	0.	0.	0.
223 9	0.000	0.000	465.378	0.	0.	0.	0.	0.	0.	0.	0.
22310	0.000	0.000	471.228	0.	0.	0.	0.	0.	0.	0.	0.
22311	0.000	0.000	467.377	0.	0.	0.	0.	0.	0.	0.	0.
22312	0.000	0.000	468.670	0.	0.	0.	0.	0.	0.	0.	0.
22313	0.000	0.000	485.920	0.	0.	0.	0.	0.	0.	0.	0.
22314	0.000	0.000	492.871	0.	0.	0.	0.	0.	0.	0.	0.
22315	0.000	0.000	484.606	0.	0.	0.	0.	0.	0.	0.	0.
22316	0.000	0.000	487.076	0.	0.	0.	0.	0.	0.	0.	0.
22317	0.000	0.000	478.958	0.	0.	0.	0.	0.	0.	0.	0.
22318	0.000	2.583	433.121	0.	0.	0.	0.	0.	0.	0.	0.
22319	0.000	7.232	328.098	0.	0.	0.	0.	0.	0.	0.	0.
22320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
22321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
22322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
22323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
22324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	492.871	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6252.672	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	260.528	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 55 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
224 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
224 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
224 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
224 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
224 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
224 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
224 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
224 8	0.000	0.000	462.075	0.	0.	0.	0.	0.	0.	0.	0.
224 9	0.000	0.000	465.378	0.	0.	0.	0.	0.	0.	0.	0.
22410	0.000	0.000	473.597	0.	0.	0.	0.	0.	0.	0.	0.
22411	0.000	0.000	537.132	0.	0.	0.	0.	0.	0.	0.	0.
22412	0.000	0.000	452.586	0.	0.	0.	0.	0.	0.	0.	0.
22413	0.000	0.000	454.712	0.	0.	0.	0.	0.	0.	0.	0.
22414	0.000	0.000	478.014	0.	0.	0.	0.	0.	0.	0.	0.
22415	0.000	0.000	489.797	0.	0.	0.	0.	0.	0.	0.	0.
22416	0.000	0.000	481.242	0.	0.	0.	0.	0.	0.	0.	0.
22417	0.000	0.000	472.041	0.	0.	0.	0.	0.	0.	0.	0.
22418	0.000	2.583	433.009	0.	0.	0.	0.	0.	0.	0.	0.
22419	0.000	7.232	328.110	0.	0.	0.	0.	0.	0.	0.	0.
22420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
22421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
22422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
22423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
22424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	537.132	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6254.983	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	260.624	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 56 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
225 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
225 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
225 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
225 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
225 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
225 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
225 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
225 8	0.000	0.000	462.304	0.	0.	0.	0.	0.	0.	0.	0.
225 9	0.000	0.000	465.781	0.	0.	0.	0.	0.	0.	0.	0.
22510	0.000	0.000	474.013	0.	0.	0.	0.	0.	0.	0.	0.
22511	0.000	0.000	470.931	0.	0.	0.	0.	0.	0.	0.	0.
22512	0.000	0.000	447.289	0.	0.	0.	0.	0.	0.	0.	0.
22513	0.000	0.000	447.087	0.	0.	0.	0.	0.	0.	0.	0.
22514	0.000	0.000	469.139	0.	0.	0.	0.	0.	0.	0.	0.
22515	0.000	0.000	553.869	0.	0.	0.	0.	0.	0.	0.	0.
22516	0.000	0.000	507.595	0.	0.	0.	0.	0.	0.	0.	0.
22517	0.000	0.000	469.511	0.	0.	0.	0.	0.	0.	0.	0.
22518	0.000	2.583	431.828	0.	0.	0.	0.	0.	0.	0.	0.
22519	0.000	7.232	327.906	0.	0.	0.	0.	0.	0.	0.	0.
22520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
22521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
22522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
22523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
22524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 25)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	553.869	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6254.543	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	260.606	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 57 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
226 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
226 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
226 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
226 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
226 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
226 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
226 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
226 8	0.000	0.000	461.766	0.	0.	0.	0.	0.	0.	0.	0.
226 9	0.000	0.000	465.397	0.	0.	0.	0.	0.	0.	0.	0.
22610	0.000	0.000	473.594	0.	0.	0.	0.	0.	0.	0.	0.
22611	0.000	0.000	478.901	0.	0.	0.	0.	0.	0.	0.	0.
22612	0.000	0.000	492.591	0.	0.	0.	0.	0.	0.	0.	0.
22613	0.000	0.000	530.486	0.	0.	0.	0.	0.	0.	0.	0.
22614	0.000	0.000	562.204	0.	0.	0.	0.	0.	0.	0.	0.
22615	0.000	0.000	578.227	0.	0.	0.	0.	0.	0.	0.	0.
22616	0.000	0.000	580.369	0.	0.	0.	0.	0.	0.	0.	0.
22617	0.000	0.000	522.311	0.	0.	0.	0.	0.	0.	0.	0.
22618	0.000	2.583	435.780	0.	0.	0.	0.	0.	0.	0.	0.
22619	0.000	7.232	327.938	0.	0.	0.	0.	0.	0.	0.	0.
22620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
22621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
22622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
22623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
22624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	580.369	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6636.855	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	276.536	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 58 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
227 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
227 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
227 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
227 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
227 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
227 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
227 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
227 8	0.000	0.000	461.705	0.	0.	0.	0.	0.	0.	0.	0.
227 9	0.000	0.000	465.661	0.	0.	0.	0.	0.	0.	0.	0.
22710	0.000	0.000	474.047	0.	0.	0.	0.	0.	0.	0.	0.
22711	0.000	0.000	471.830	0.	0.	0.	0.	0.	0.	0.	0.
22712	0.000	0.000	447.186	0.	0.	0.	0.	0.	0.	0.	0.
22713	0.000	0.000	446.522	0.	0.	0.	0.	0.	0.	0.	0.
22714	0.000	0.000	468.871	0.	0.	0.	0.	0.	0.	0.	0.
22715	0.000	0.000	480.485	0.	0.	0.	0.	0.	0.	0.	0.
22716	0.000	0.000	481.430	0.	0.	0.	0.	0.	0.	0.	0.
22717	0.000	0.000	472.294	0.	0.	0.	0.	0.	0.	0.	0.
22718	0.000	2.583	432.854	0.	0.	0.	0.	0.	0.	0.	0.
22719	0.000	7.232	328.038	0.	0.	0.	0.	0.	0.	0.	0.
22720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
22721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
22722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
22723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
22724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	481.430	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6158.214	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	256.592	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 59 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
228 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
228 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
228 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
228 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
228 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
228 6	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
228 7	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
228 8	0.000	0.000	249.253	0.	0.	0.	0.	0.	0.	0.	0.
228 9	0.000	0.000	195.599	0.	0.	0.	0.	0.	0.	0.	0.
22810	0.000	0.000	195.378	0.	0.	0.	0.	0.	0.	0.	0.
22811	0.000	0.000	195.401	0.	0.	0.	0.	0.	0.	0.	0.
22812	0.000	0.000	195.418	0.	0.	0.	0.	0.	0.	0.	0.
22813	0.000	0.000	195.455	0.	0.	0.	0.	0.	0.	0.	0.
22814	0.000	0.000	195.477	0.	0.	0.	0.	0.	0.	0.	0.
22815	0.000	0.000	195.499	0.	0.	0.	0.	0.	0.	0.	0.
22816	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
22817	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
22818	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
22819	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
22820	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
22821	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
22822	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
22823	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
22824	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 28)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.253	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2304.421	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	96.018	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (FEB)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	671.567	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	2531.341	135109.844	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	201.056	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 60 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
3 1 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 1 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 1 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 1 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 1 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 1 6	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
3 1 7	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
3 1 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 1 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 116	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 117	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 118	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
3 119	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
3 120	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
3 121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
3 122	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
3 123	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
3 124	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 1)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	358.846	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	14.952	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 61 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 2 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 2 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
3 2 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
3 2 8	0.000	0.000	462.309	0.	0.	0.	0.	0.	0.	0.	0.
3 2 9	0.000	0.000	465.446	0.	0.	0.	0.	0.	0.	0.	0.
3 210	0.000	0.000	471.364	0.	0.	0.	0.	0.	0.	0.	0.
3 211	0.000	0.000	474.416	0.	0.	0.	0.	0.	0.	0.	0.
3 212	0.000	0.000	452.056	0.	0.	0.	0.	0.	0.	0.	0.
3 213	0.000	0.000	444.102	0.	0.	0.	0.	0.	0.	0.	0.
3 214	0.000	0.000	494.006	0.	0.	0.	0.	0.	0.	0.	0.
3 215	0.000	0.000	476.771	0.	0.	0.	0.	0.	0.	0.	0.
3 216	0.000	0.000	477.221	0.	0.	0.	0.	0.	0.	0.	0.
3 217	0.000	0.000	468.924	0.	0.	0.	0.	0.	0.	0.	0.
3 218	0.000	2.583	432.087	0.	0.	0.	0.	0.	0.	0.	0.
3 219	0.000	7.232	328.111	0.	0.	0.	0.	0.	0.	0.	0.
3 220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
3 221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
3 222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
3 223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
3 224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	494.006	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6174.104	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.254	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 62 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 3 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 3 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
3 3 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
3 3 8	0.000	0.000	462.247	0.	0.	0.	0.	0.	0.	0.	0.
3 3 9	0.000	0.000	465.682	0.	0.	0.	0.	0.	0.	0.	0.
3 310	0.000	0.000	511.148	0.	0.	0.	0.	0.	0.	0.	0.
3 311	0.000	0.000	554.105	0.	0.	0.	0.	0.	0.	0.	0.
3 312	0.000	0.000	583.248	0.	0.	0.	0.	0.	0.	0.	0.
3 313	0.000	0.000	599.936	0.	0.	0.	0.	0.	0.	0.	0.
3 314	0.000	0.000	643.904	0.	0.	0.	0.	0.	0.	0.	0.
3 315	0.000	0.000	607.088	0.	0.	0.	0.	0.	0.	0.	0.
3 316	0.000	0.000	550.020	0.	0.	0.	0.	0.	0.	0.	0.
3 317	0.000	0.000	513.832	0.	0.	0.	0.	0.	0.	0.	0.
3 318	0.000	2.583	436.105	0.	0.	0.	0.	0.	0.	0.	0.
3 319	0.000	7.232	328.331	0.	0.	0.	0.	0.	0.	0.	0.
3 320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
3 321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
3 322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
3 323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
3 324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	643.904	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6982.936	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	290.956	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 63 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 4 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 4 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
3 4 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
3 4 8	0.000	0.000	463.670	0.	0.	0.	0.	0.	0.	0.	0.
3 4 9	0.000	0.000	547.335	0.	0.	0.	0.	0.	0.	0.	0.
3 410	0.000	0.000	622.084	0.	0.	0.	0.	0.	0.	0.	0.
3 411	0.000	0.000	635.816	0.	0.	0.	0.	0.	0.	0.	0.
3 412	0.000	0.000	616.119	0.	0.	0.	0.	0.	0.	0.	0.
3 413	0.000	0.000	620.292	0.	0.	0.	0.	0.	0.	0.	0.
3 414	0.000	0.000	642.004	0.	0.	0.	0.	0.	0.	0.	0.
3 415	0.000	0.000	656.232	0.	0.	0.	0.	0.	0.	0.	0.
3 416	0.000	0.000	654.188	0.	0.	0.	0.	0.	0.	0.	0.
3 417	0.000	0.000	606.423	0.	0.	0.	0.	0.	0.	0.	0.
3 418	0.000	2.583	515.419	0.	0.	0.	0.	0.	0.	0.	0.
3 419	0.000	7.232	391.320	0.	0.	0.	0.	0.	0.	0.	0.
3 420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
3 421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
3 422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
3 423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
3 424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	656.232	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7698.194	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	320.758	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 64 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 5 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 5 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
3 5 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
3 5 8	0.000	0.000	464.467	0.	0.	0.	0.	0.	0.	0.	0.
3 5 9	0.000	0.000	474.179	0.	0.	0.	0.	0.	0.	0.	0.
3 510	0.000	0.000	480.095	0.	0.	0.	0.	0.	0.	0.	0.
3 511	0.000	0.000	514.197	0.	0.	0.	0.	0.	0.	0.	0.
3 512	0.000	0.000	486.970	0.	0.	0.	0.	0.	0.	0.	0.
3 513	0.000	0.000	445.401	0.	0.	0.	0.	0.	0.	0.	0.
3 514	0.000	0.000	474.152	0.	0.	0.	0.	0.	0.	0.	0.
3 515	0.000	0.000	508.041	0.	0.	0.	0.	0.	0.	0.	0.
3 516	0.000	0.000	538.443	0.	0.	0.	0.	0.	0.	0.	0.
3 517	0.000	0.000	505.017	0.	0.	0.	0.	0.	0.	0.	0.
3 518	0.000	2.583	433.121	0.	0.	0.	0.	0.	0.	0.	0.
3 519	0.000	7.232	328.372	0.	0.	0.	0.	0.	0.	0.	0.
3 520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
3 521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
3 522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
3 523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
3 524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	538.443	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6379.745	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	265.823	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 65 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 6 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 6 6	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
3 6 7	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
3 6 8	0.000	0.000	462.883	0.	0.	0.	0.	0.	0.	0.	0.
3 6 9	0.000	0.000	465.883	0.	0.	0.	0.	0.	0.	0.	0.
3 610	0.000	0.000	472.113	0.	0.	0.	0.	0.	0.	0.	0.
3 611	0.000	0.000	581.064	0.	0.	0.	0.	0.	0.	0.	0.
3 612	0.000	0.000	557.498	0.	0.	0.	0.	0.	0.	0.	0.
3 613	0.000	0.000	479.120	0.	0.	0.	0.	0.	0.	0.	0.
3 614	0.000	0.000	465.856	0.	0.	0.	0.	0.	0.	0.	0.
3 615	0.000	0.000	473.550	0.	0.	0.	0.	0.	0.	0.	0.
3 616	0.000	0.000	473.958	0.	0.	0.	0.	0.	0.	0.	0.
3 617	0.000	0.000	465.734	0.	0.	0.	0.	0.	0.	0.	0.
3 618	0.000	2.583	431.700	0.	0.	0.	0.	0.	0.	0.	0.
3 619	0.000	7.232	328.277	0.	0.	0.	0.	0.	0.	0.	0.
3 620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
3 621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
3 622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
3 623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
3 624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	581.064	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6384.926	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	266.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 66 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 7 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 7 6	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
3 7 7	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
3 7 8	0.000	0.000	250.281	0.	0.	0.	0.	0.	0.	0.	0.
3 7 9	0.000	0.000	196.103	0.	0.	0.	0.	0.	0.	0.	0.
3 710	0.000	0.000	195.695	0.	0.	0.	0.	0.	0.	0.	0.
3 711	0.000	0.000	195.712	0.	0.	0.	0.	0.	0.	0.	0.
3 712	0.000	0.000	195.677	0.	0.	0.	0.	0.	0.	0.	0.
3 713	0.000	0.000	195.675	0.	0.	0.	0.	0.	0.	0.	0.
3 714	0.000	0.000	202.885	0.	0.	0.	0.	0.	0.	0.	0.
3 715	0.000	0.000	204.145	0.	0.	0.	0.	0.	0.	0.	0.
3 716	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
3 717	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
3 718	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
3 719	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
3 720	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
3 721	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
3 722	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
3 723	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
3 724	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 7)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	250.281	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2323.113	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	96.796	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 67 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 8 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 8 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 8 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 8 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
3 8 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
3 8 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
3 8 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 8 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 8 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 810	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 811	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 812	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 813	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 814	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 815	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 816	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
3 817	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
3 818	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
3 819	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
3 820	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
3 821	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
3 822	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
3 823	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
3 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 8)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 68 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
3 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
3 9 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
3 9 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
3 9 7	0.000	0.000	462.770	0.	0.	0.	0.	0.	0.	0.	0.
3 9 8	0.000	0.000	465.612	0.	0.	0.	0.	0.	0.	0.	0.
3 9 9	0.000	0.000	471.364	0.	0.	0.	0.	0.	0.	0.	0.
3 910	0.000	0.000	467.167	0.	0.	0.	0.	0.	0.	0.	0.
3 911	0.000	0.000	517.211	0.	0.	0.	0.	0.	0.	0.	0.
3 912	0.000	0.000	496.241	0.	0.	0.	0.	0.	0.	0.	0.
3 913	0.000	0.000	467.472	0.	0.	0.	0.	0.	0.	0.	0.
3 914	0.000	0.000	490.412	0.	0.	0.	0.	0.	0.	0.	0.
3 915	0.000	0.000	494.333	0.	0.	0.	0.	0.	0.	0.	0.
3 916	0.000	0.000	474.302	0.	0.	0.	0.	0.	0.	0.	0.
3 917	0.000	2.583	437.296	0.	0.	0.	0.	0.	0.	0.	0.
3 918	0.000	7.232	328.276	0.	0.	0.	0.	0.	0.	0.	0.
3 919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
3 920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
3 921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
3 922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
3 923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
3 924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	517.211	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6299.749	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	262.490	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 69 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
310 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
310 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
310 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
310 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
310 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
310 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
310 7	0.000	0.000	462.546	0.	0.	0.	0.	0.	0.	0.	0.
310 8	0.000	0.000	465.607	0.	0.	0.	0.	0.	0.	0.	0.
310 9	0.000	0.000	471.591	0.	0.	0.	0.	0.	0.	0.	0.
31010	0.000	0.000	467.732	0.	0.	0.	0.	0.	0.	0.	0.
31011	0.000	0.000	445.185	0.	0.	0.	0.	0.	0.	0.	0.
31012	0.000	0.000	481.884	0.	0.	0.	0.	0.	0.	0.	0.
31013	0.000	0.000	530.585	0.	0.	0.	0.	0.	0.	0.	0.
31014	0.000	0.000	486.074	0.	0.	0.	0.	0.	0.	0.	0.
31015	0.000	0.000	490.904	0.	0.	0.	0.	0.	0.	0.	0.
31016	0.000	0.000	472.637	0.	0.	0.	0.	0.	0.	0.	0.
31017	0.000	2.583	436.632	0.	0.	0.	0.	0.	0.	0.	0.
31018	0.000	7.232	328.239	0.	0.	0.	0.	0.	0.	0.	0.
31019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	530.585	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6266.907	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	261.121	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 70 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
311 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
311 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
311 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
311 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
311 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
311 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
311 7	0.000	0.000	462.534	0.	0.	0.	0.	0.	0.	0.	0.
311 8	0.000	0.000	465.825	0.	0.	0.	0.	0.	0.	0.	0.
311 9	0.000	0.000	473.301	0.	0.	0.	0.	0.	0.	0.	0.
31110	0.000	0.000	503.484	0.	0.	0.	0.	0.	0.	0.	0.
31111	0.000	0.000	496.986	0.	0.	0.	0.	0.	0.	0.	0.
31112	0.000	0.000	479.092	0.	0.	0.	0.	0.	0.	0.	0.
31113	0.000	0.000	504.201	0.	0.	0.	0.	0.	0.	0.	0.
31114	0.000	0.000	491.772	0.	0.	0.	0.	0.	0.	0.	0.
31115	0.000	0.000	498.555	0.	0.	0.	0.	0.	0.	0.	0.
31116	0.000	0.000	491.872	0.	0.	0.	0.	0.	0.	0.	0.
31117	0.000	2.583	436.359	0.	0.	0.	0.	0.	0.	0.	0.
31118	0.000	7.232	328.346	0.	0.	0.	0.	0.	0.	0.	0.
31119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	504.201	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6359.615	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	264.984	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 71 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
312 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
312 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
312 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
312 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
312 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
312 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
312 7	0.000	0.000	462.810	0.	0.	0.	0.	0.	0.	0.	0.
312 8	0.000	0.000	465.712	0.	0.	0.	0.	0.	0.	0.	0.
312 9	0.000	0.000	472.182	0.	0.	0.	0.	0.	0.	0.	0.
31210	0.000	0.000	467.809	0.	0.	0.	0.	0.	0.	0.	0.
31211	0.000	0.000	444.820	0.	0.	0.	0.	0.	0.	0.	0.
31212	0.000	0.000	444.111	0.	0.	0.	0.	0.	0.	0.	0.
31213	0.000	0.000	506.923	0.	0.	0.	0.	0.	0.	0.	0.
31214	0.000	0.000	477.196	0.	0.	0.	0.	0.	0.	0.	0.
31215	0.000	0.000	474.551	0.	0.	0.	0.	0.	0.	0.	0.
31216	0.000	0.000	467.168	0.	0.	0.	0.	0.	0.	0.	0.
31217	0.000	2.583	433.319	0.	0.	0.	0.	0.	0.	0.	0.
31218	0.000	7.232	328.202	0.	0.	0.	0.	0.	0.	0.	0.
31219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	506.923	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6172.093	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.171	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 72 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
313 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
313 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
313 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
313 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
313 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
313 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
313 7	0.000	0.000	462.540	0.	0.	0.	0.	0.	0.	0.	0.
313 8	0.000	0.000	465.607	0.	0.	0.	0.	0.	0.	0.	0.
313 9	0.000	0.000	471.429	0.	0.	0.	0.	0.	0.	0.	0.
31310	0.000	0.000	475.534	0.	0.	0.	0.	0.	0.	0.	0.
31311	0.000	0.000	475.547	0.	0.	0.	0.	0.	0.	0.	0.
31312	0.000	0.000	493.651	0.	0.	0.	0.	0.	0.	0.	0.
31313	0.000	0.000	546.185	0.	0.	0.	0.	0.	0.	0.	0.
31314	0.000	0.000	576.994	0.	0.	0.	0.	0.	0.	0.	0.
31315	0.000	0.000	489.872	0.	0.	0.	0.	0.	0.	0.	0.
31316	0.000	0.000	487.336	0.	0.	0.	0.	0.	0.	0.	0.
31317	0.000	2.583	440.282	0.	0.	0.	0.	0.	0.	0.	0.
31318	0.000	7.232	328.354	0.	0.	0.	0.	0.	0.	0.	0.
31319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	576.994	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6440.623	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	268.359	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 73 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
314 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
314 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
314 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
314 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
314 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
314 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
314 7	0.000	0.000	249.845	0.	0.	0.	0.	0.	0.	0.	0.
314 8	0.000	0.000	195.951	0.	0.	0.	0.	0.	0.	0.	0.
314 9	0.000	0.000	195.654	0.	0.	0.	0.	0.	0.	0.	0.
31410	0.000	0.000	195.710	0.	0.	0.	0.	0.	0.	0.	0.
31411	0.000	0.000	195.677	0.	0.	0.	0.	0.	0.	0.	0.
31412	0.000	0.000	195.675	0.	0.	0.	0.	0.	0.	0.	0.
31413	0.000	0.000	195.642	0.	0.	0.	0.	0.	0.	0.	0.
31414	0.000	0.000	195.674	0.	0.	0.	0.	0.	0.	0.	0.
31415	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
31416	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
31417	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
31418	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
31419	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
31420	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
31421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
31422	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
31423	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
31424	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 14)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.845	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2280.670	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	95.028	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 74 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
315 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
315 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
315 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
315 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
315 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
315 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
315 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
315 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
315 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
31517	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
31518	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
31519	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
31520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
31521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
31522	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
31523	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
31524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 15)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 75 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
316 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
316 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
316 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
316 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
316 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
316 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
316 7	0.000	0.000	461.987	0.	0.	0.	0.	0.	0.	0.	0.
316 8	0.000	0.000	465.348	0.	0.	0.	0.	0.	0.	0.	0.
316 9	0.000	0.000	471.319	0.	0.	0.	0.	0.	0.	0.	0.
31610	0.000	0.000	467.600	0.	0.	0.	0.	0.	0.	0.	0.
31611	0.000	0.000	470.040	0.	0.	0.	0.	0.	0.	0.	0.
31612	0.000	0.000	451.451	0.	0.	0.	0.	0.	0.	0.	0.
31613	0.000	0.000	473.407	0.	0.	0.	0.	0.	0.	0.	0.
31614	0.000	0.000	484.708	0.	0.	0.	0.	0.	0.	0.	0.
31615	0.000	0.000	487.666	0.	0.	0.	0.	0.	0.	0.	0.
31616	0.000	0.000	471.757	0.	0.	0.	0.	0.	0.	0.	0.
31617	0.000	2.583	436.028	0.	0.	0.	0.	0.	0.	0.	0.
31618	0.000	7.232	328.202	0.	0.	0.	0.	0.	0.	0.	0.
31619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	487.666	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6196.803	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	258.200	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 76 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
317 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
317 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
317 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
317 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
317 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
317 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
317 7	0.000	0.000	462.128	0.	0.	0.	0.	0.	0.	0.	0.
317 8	0.000	0.000	465.409	0.	0.	0.	0.	0.	0.	0.	0.
317 9	0.000	0.000	473.196	0.	0.	0.	0.	0.	0.	0.	0.
31710	0.000	0.000	470.600	0.	0.	0.	0.	0.	0.	0.	0.
31711	0.000	0.000	475.646	0.	0.	0.	0.	0.	0.	0.	0.
31712	0.000	0.000	537.656	0.	0.	0.	0.	0.	0.	0.	0.
31713	0.000	0.000	519.983	0.	0.	0.	0.	0.	0.	0.	0.
31714	0.000	0.000	521.725	0.	0.	0.	0.	0.	0.	0.	0.
31715	0.000	0.000	527.421	0.	0.	0.	0.	0.	0.	0.	0.
31716	0.000	0.000	487.639	0.	0.	0.	0.	0.	0.	0.	0.
31717	0.000	2.583	440.581	0.	0.	0.	0.	0.	0.	0.	0.
31718	0.000	7.232	328.356	0.	0.	0.	0.	0.	0.	0.	0.
31719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	537.656	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6437.632	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	268.235	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 77 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
318 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
318 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
318 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
318 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
318 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
318 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
318 7	0.000	0.000	462.311	0.	0.	0.	0.	0.	0.	0.	0.
318 8	0.000	0.000	465.657	0.	0.	0.	0.	0.	0.	0.	0.
318 9	0.000	0.000	472.861	0.	0.	0.	0.	0.	0.	0.	0.
31810	0.000	0.000	468.123	0.	0.	0.	0.	0.	0.	0.	0.
31811	0.000	0.000	444.552	0.	0.	0.	0.	0.	0.	0.	0.
31812	0.000	0.000	444.272	0.	0.	0.	0.	0.	0.	0.	0.
31813	0.000	0.000	464.843	0.	0.	0.	0.	0.	0.	0.	0.
31814	0.000	0.000	486.053	0.	0.	0.	0.	0.	0.	0.	0.
31815	0.000	0.000	478.570	0.	0.	0.	0.	0.	0.	0.	0.
31816	0.000	0.000	473.952	0.	0.	0.	0.	0.	0.	0.	0.
31817	0.000	2.583	437.345	0.	0.	0.	0.	0.	0.	0.	0.
31818	0.000	7.232	328.142	0.	0.	0.	0.	0.	0.	0.	0.
31819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	486.053	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6153.973	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	256.416	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 78 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
319 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
319 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
319 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
319 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
319 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
319 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
319 7	0.000	0.000	461.945	0.	0.	0.	0.	0.	0.	0.	0.
319 8	0.000	0.000	465.771	0.	0.	0.	0.	0.	0.	0.	0.
319 9	0.000	0.000	474.396	0.	0.	0.	0.	0.	0.	0.	0.
31910	0.000	0.000	471.975	0.	0.	0.	0.	0.	0.	0.	0.
31911	0.000	0.000	447.112	0.	0.	0.	0.	0.	0.	0.	0.
31912	0.000	0.000	447.101	0.	0.	0.	0.	0.	0.	0.	0.
31913	0.000	0.000	468.393	0.	0.	0.	0.	0.	0.	0.	0.
31914	0.000	0.000	480.007	0.	0.	0.	0.	0.	0.	0.	0.
31915	0.000	0.000	480.935	0.	0.	0.	0.	0.	0.	0.	0.
31916	0.000	0.000	473.948	0.	0.	0.	0.	0.	0.	0.	0.
31917	0.000	2.583	435.195	0.	0.	0.	0.	0.	0.	0.	0.
31918	0.000	7.232	328.063	0.	0.	0.	0.	0.	0.	0.	0.
31919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
31920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
31921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
31922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
31923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
31924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	480.935	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6162.132	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	256.755	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 79 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
320 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
320 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
320 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
320 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
320 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
320 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
320 7	0.000	0.000	462.028	0.	0.	0.	0.	0.	0.	0.	0.
320 8	0.000	0.000	465.348	0.	0.	0.	0.	0.	0.	0.	0.
320 9	0.000	0.000	471.881	0.	0.	0.	0.	0.	0.	0.	0.
32010	0.000	0.000	468.971	0.	0.	0.	0.	0.	0.	0.	0.
32011	0.000	0.000	445.280	0.	0.	0.	0.	0.	0.	0.	0.
32012	0.000	0.000	453.662	0.	0.	0.	0.	0.	0.	0.	0.
32013	0.000	0.000	467.105	0.	0.	0.	0.	0.	0.	0.	0.
32014	0.000	0.000	478.224	0.	0.	0.	0.	0.	0.	0.	0.
32015	0.000	0.000	480.322	0.	0.	0.	0.	0.	0.	0.	0.
32016	0.000	0.000	471.459	0.	0.	0.	0.	0.	0.	0.	0.
32017	0.000	2.583	463.362	0.	0.	0.	0.	0.	0.	0.	0.
32018	0.000	7.232	329.200	0.	0.	0.	0.	0.	0.	0.	0.
32019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
32020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
32021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
32022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
32023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
32024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	480.322	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6184.133	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.672	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 80 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
321 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
321 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
321 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
321 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
321 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
321 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
321 7	0.000	0.000	249.591	0.	0.	0.	0.	0.	0.	0.	0.
321 8	0.000	0.000	195.770	0.	0.	0.	0.	0.	0.	0.	0.
321 9	0.000	0.000	195.510	0.	0.	0.	0.	0.	0.	0.	0.
32110	0.000	0.000	195.524	0.	0.	0.	0.	0.	0.	0.	0.
32111	0.000	0.000	195.501	0.	0.	0.	0.	0.	0.	0.	0.
32112	0.000	0.000	195.500	0.	0.	0.	0.	0.	0.	0.	0.
32113	0.000	0.000	195.405	0.	0.	0.	0.	0.	0.	0.	0.
32114	0.000	0.000	195.402	0.	0.	0.	0.	0.	0.	0.	0.
32115	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
32116	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
32117	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
32118	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
32119	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
32120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
32121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
32122	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
32123	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
32124	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 21)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.591	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2279.044	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	94.960	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 81 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
322 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
322 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
322 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
322 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
322 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
322 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
322 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
322 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
322 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32216	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32217	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
32218	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
32219	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
32220	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
32221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
32222	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
32223	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
32224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 22)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 82 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
323 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
323 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
323 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
323 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
323 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
323 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
323 7	0.000	0.000	461.986	0.	0.	0.	0.	0.	0.	0.	0.
323 8	0.000	0.000	465.348	0.	0.	0.	0.	0.	0.	0.	0.
323 9	0.000	0.000	471.248	0.	0.	0.	0.	0.	0.	0.	0.
32310	0.000	0.000	466.732	0.	0.	0.	0.	0.	0.	0.	0.
32311	0.000	0.000	443.982	0.	0.	0.	0.	0.	0.	0.	0.
32312	0.000	0.000	443.462	0.	0.	0.	0.	0.	0.	0.	0.
32313	0.000	0.000	463.604	0.	0.	0.	0.	0.	0.	0.	0.
32314	0.000	0.000	471.488	0.	0.	0.	0.	0.	0.	0.	0.
32315	0.000	0.000	471.791	0.	0.	0.	0.	0.	0.	0.	0.
32316	0.000	0.000	464.318	0.	0.	0.	0.	0.	0.	0.	0.
32317	0.000	2.583	431.263	0.	0.	0.	0.	0.	0.	0.	0.
32318	0.000	7.232	328.139	0.	0.	0.	0.	0.	0.	0.	0.
32319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
32320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
32321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
32322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
32323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
32324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	471.791	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6110.650	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	254.610	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 83 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
324 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
324 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
324 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
324 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
324 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
324 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
324 7	0.000	0.000	462.183	0.	0.	0.	0.	0.	0.	0.	0.
324 8	0.000	0.000	465.410	0.	0.	0.	0.	0.	0.	0.	0.
324 9	0.000	0.000	472.161	0.	0.	0.	0.	0.	0.	0.	0.
32410	0.000	0.000	476.955	0.	0.	0.	0.	0.	0.	0.	0.
32411	0.000	0.000	453.371	0.	0.	0.	0.	0.	0.	0.	0.
32412	0.000	0.000	444.676	0.	0.	0.	0.	0.	0.	0.	0.
32413	0.000	0.000	474.538	0.	0.	0.	0.	0.	0.	0.	0.
32414	0.000	0.000	476.559	0.	0.	0.	0.	0.	0.	0.	0.
32415	0.000	0.000	488.066	0.	0.	0.	0.	0.	0.	0.	0.
32416	0.000	0.000	467.841	0.	0.	0.	0.	0.	0.	0.	0.
32417	0.000	2.583	442.452	0.	0.	0.	0.	0.	0.	0.	0.
32418	0.000	7.232	348.138	0.	0.	0.	0.	0.	0.	0.	0.
32419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
32420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
32421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
32422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
32423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
32424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	488.066	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6199.641	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	258.318	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 84 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
325 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
325 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
325 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
325 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
325 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
325 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
325 7	0.000	0.000	462.482	0.	0.	0.	0.	0.	0.	0.	0.
325 8	0.000	0.000	465.447	0.	0.	0.	0.	0.	0.	0.	0.
325 9	0.000	0.000	546.270	0.	0.	0.	0.	0.	0.	0.	0.
32510	0.000	0.000	618.432	0.	0.	0.	0.	0.	0.	0.	0.
32511	0.000	0.000	583.332	0.	0.	0.	0.	0.	0.	0.	0.
32512	0.000	0.000	566.439	0.	0.	0.	0.	0.	0.	0.	0.
32513	0.000	0.000	597.891	0.	0.	0.	0.	0.	0.	0.	0.
32514	0.000	0.000	627.839	0.	0.	0.	0.	0.	0.	0.	0.
32515	0.000	0.000	587.789	0.	0.	0.	0.	0.	0.	0.	0.
32516	0.000	0.000	572.722	0.	0.	0.	0.	0.	0.	0.	0.
32517	0.000	2.583	526.806	0.	0.	0.	0.	0.	0.	0.	0.
32518	0.000	7.232	332.011	0.	0.	0.	0.	0.	0.	0.	0.
32519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
32520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
32521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
32522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
32523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
32524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 25)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	627.839	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7214.752	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	300.615	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 85 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
326 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
326 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
326 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
326 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
326 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
326 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
326 7	0.000	0.000	462.213	0.	0.	0.	0.	0.	0.	0.	0.
326 8	0.000	0.000	465.752	0.	0.	0.	0.	0.	0.	0.	0.
326 9	0.000	0.000	571.583	0.	0.	0.	0.	0.	0.	0.	0.
32610	0.000	0.000	629.451	0.	0.	0.	0.	0.	0.	0.	0.
32611	0.000	0.000	609.191	0.	0.	0.	0.	0.	0.	0.	0.
32612	0.000	0.000	578.307	0.	0.	0.	0.	0.	0.	0.	0.
32613	0.000	0.000	605.781	0.	0.	0.	0.	0.	0.	0.	0.
32614	0.000	0.000	605.476	0.	0.	0.	0.	0.	0.	0.	0.
32615	0.000	0.000	593.397	0.	0.	0.	0.	0.	0.	0.	0.
32616	0.000	0.000	531.030	0.	0.	0.	0.	0.	0.	0.	0.
32617	0.000	2.583	465.193	0.	0.	0.	0.	0.	0.	0.	0.
32618	0.000	7.232	329.268	0.	0.	0.	0.	0.	0.	0.	0.
32619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
32620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
32621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
32622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
32623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
32624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	629.451	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7173.931	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	298.914	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 86 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
327 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
327 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
327 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
327 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
327 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
327 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
327 7	0.000	0.000	462.530	0.	0.	0.	0.	0.	0.	0.	0.
327 8	0.000	0.000	465.607	0.	0.	0.	0.	0.	0.	0.	0.
327 9	0.000	0.000	472.466	0.	0.	0.	0.	0.	0.	0.	0.
32710	0.000	0.000	478.156	0.	0.	0.	0.	0.	0.	0.	0.
32711	0.000	0.000	489.432	0.	0.	0.	0.	0.	0.	0.	0.
32712	0.000	0.000	504.584	0.	0.	0.	0.	0.	0.	0.	0.
32713	0.000	0.000	506.427	0.	0.	0.	0.	0.	0.	0.	0.
32714	0.000	0.000	529.550	0.	0.	0.	0.	0.	0.	0.	0.
32715	0.000	0.000	483.693	0.	0.	0.	0.	0.	0.	0.	0.
32716	0.000	0.000	475.459	0.	0.	0.	0.	0.	0.	0.	0.
32717	0.000	2.583	438.085	0.	0.	0.	0.	0.	0.	0.	0.
32718	0.000	7.232	328.239	0.	0.	0.	0.	0.	0.	0.	0.
32719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
32720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
32721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
32722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
32723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
32724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	529.550	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6361.517	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	265.063	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 87 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
328 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
328 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
328 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
328 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
328 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
328 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
328 7	0.000	0.000	249.916	0.	0.	0.	0.	0.	0.	0.	0.
328 8	0.000	0.000	196.042	0.	0.	0.	0.	0.	0.	0.	0.
328 9	0.000	0.000	239.342	0.	0.	0.	0.	0.	0.	0.	0.
32810	0.000	0.000	265.281	0.	0.	0.	0.	0.	0.	0.	0.
32811	0.000	0.000	332.039	0.	0.	0.	0.	0.	0.	0.	0.
32812	0.000	0.000	346.472	0.	0.	0.	0.	0.	0.	0.	0.
32813	0.000	0.000	277.742	0.	0.	0.	0.	0.	0.	0.	0.
32814	0.000	0.000	278.453	0.	0.	0.	0.	0.	0.	0.	0.
32815	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
32816	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
32817	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
32818	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
32819	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
32820	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
32821	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
32822	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
32823	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
32824	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 28)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	346.472	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2846.130	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	118.589	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 88 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
329 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
329 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
329 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
329 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
329 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
329 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
329 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
329 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
329 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32910	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32911	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32912	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32913	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32914	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32915	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32916	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
32917	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
32918	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
32919	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
32920	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
32921	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
32922	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
32923	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
32924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 29)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 89 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
330 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
330 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
330 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
330 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
330 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
330 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
330 7	0.000	0.000	463.343	0.	0.	0.	0.	0.	0.	0.	0.
330 8	0.000	0.000	508.343	0.	0.	0.	0.	0.	0.	0.	0.
330 9	0.000	0.000	611.459	0.	0.	0.	0.	0.	0.	0.	0.
33010	0.000	0.000	630.930	0.	0.	0.	0.	0.	0.	0.	0.
33011	0.000	0.000	616.896	0.	0.	0.	0.	0.	0.	0.	0.
33012	0.000	0.000	623.050	0.	0.	0.	0.	0.	0.	0.	0.
33013	0.000	0.000	647.846	0.	0.	0.	0.	0.	0.	0.	0.
33014	0.000	0.000	655.297	0.	0.	0.	0.	0.	0.	0.	0.
33015	0.000	0.000	640.341	0.	0.	0.	0.	0.	0.	0.	0.
33016	0.000	0.000	623.408	0.	0.	0.	0.	0.	0.	0.	0.
33017	0.000	2.583	534.960	0.	0.	0.	0.	0.	0.	0.	0.
33018	0.000	7.232	332.017	0.	0.	0.	0.	0.	0.	0.	0.
33019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
33020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
33021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
33022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
33023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
33024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	655.297	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7615.181	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	317.299	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 90 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
331 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
331 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
331 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
331 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
331 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
331 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
331 7	0.000	0.000	483.756	0.	0.	0.	0.	0.	0.	0.	0.
331 8	0.000	0.000	588.384	0.	0.	0.	0.	0.	0.	0.	0.
331 9	0.000	0.000	635.417	0.	0.	0.	0.	0.	0.	0.	0.
33110	0.000	0.000	648.640	0.	0.	0.	0.	0.	0.	0.	0.
33111	0.000	0.000	626.122	0.	0.	0.	0.	0.	0.	0.	0.
33112	0.000	0.000	625.874	0.	0.	0.	0.	0.	0.	0.	0.
33113	0.000	0.000	645.000	0.	0.	0.	0.	0.	0.	0.	0.
33114	0.000	0.000	663.100	0.	0.	0.	0.	0.	0.	0.	0.
33115	0.000	0.000	667.333	0.	0.	0.	0.	0.	0.	0.	0.
33116	0.000	0.000	651.186	0.	0.	0.	0.	0.	0.	0.	0.
33117	0.000	2.583	589.543	0.	0.	0.	0.	0.	0.	0.	0.
33118	0.000	7.232	351.071	0.	0.	0.	0.	0.	0.	0.	0.
33119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
33120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
33121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
33122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
33123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
33124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 31)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	667.333	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7902.718	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	329.280	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (MAR)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	667.333	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	2802.556	156499.547	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	210.349	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 91 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
4 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 1 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 1 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 1 7	0.000	0.000	463.017	0.	0.	0.	0.	0.	0.	0.	0.
4 1 8	0.000	0.000	469.064	0.	0.	0.	0.	0.	0.	0.	0.
4 1 9	0.000	0.000	476.130	0.	0.	0.	0.	0.	0.	0.	0.
4 110	0.000	0.000	475.004	0.	0.	0.	0.	0.	0.	0.	0.
4 111	0.000	0.000	450.364	0.	0.	0.	0.	0.	0.	0.	0.
4 112	0.000	0.000	449.575	0.	0.	0.	0.	0.	0.	0.	0.
4 113	0.000	0.000	470.303	0.	0.	0.	0.	0.	0.	0.	0.
4 114	0.000	0.000	492.794	0.	0.	0.	0.	0.	0.	0.	0.
4 115	0.000	0.000	485.509	0.	0.	0.	0.	0.	0.	0.	0.
4 116	0.000	0.000	479.019	0.	0.	0.	0.	0.	0.	0.	0.
4 117	0.000	2.583	440.945	0.	0.	0.	0.	0.	0.	0.	0.
4 118	0.000	7.232	328.846	0.	0.	0.	0.	0.	0.	0.	0.
4 119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	492.794	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6207.860	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	258.661	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 92 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
4 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 2 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 2 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 2 7	0.000	0.000	461.999	0.	0.	0.	0.	0.	0.	0.	0.
4 2 8	0.000	0.000	466.894	0.	0.	0.	0.	0.	0.	0.	0.
4 2 9	0.000	0.000	476.270	0.	0.	0.	0.	0.	0.	0.	0.
4 210	0.000	0.000	474.014	0.	0.	0.	0.	0.	0.	0.	0.
4 211	0.000	0.000	450.014	0.	0.	0.	0.	0.	0.	0.	0.
4 212	0.000	0.000	449.263	0.	0.	0.	0.	0.	0.	0.	0.
4 213	0.000	0.000	471.375	0.	0.	0.	0.	0.	0.	0.	0.
4 214	0.000	0.000	483.643	0.	0.	0.	0.	0.	0.	0.	0.
4 215	0.000	0.000	485.387	0.	0.	0.	0.	0.	0.	0.	0.
4 216	0.000	0.000	478.081	0.	0.	0.	0.	0.	0.	0.	0.
4 217	0.000	2.583	439.919	0.	0.	0.	0.	0.	0.	0.	0.
4 218	0.000	7.232	328.359	0.	0.	0.	0.	0.	0.	0.	0.
4 219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	485.387	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6192.508	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	258.021	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 93 - 2

		EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
		DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
		---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
4 3 1		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 3 2		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 3 3		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 3 4		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 3 5		0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 3 6		0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 3 7		0.000	0.000	462.184	0.	0.	0.	0.	0.	0.	0.	0.
4 3 8		0.000	0.000	467.036	0.	0.	0.	0.	0.	0.	0.	0.
4 3 9		0.000	0.000	476.748	0.	0.	0.	0.	0.	0.	0.	0.
4 310		0.000	0.000	473.550	0.	0.	0.	0.	0.	0.	0.	0.
4 311		0.000	0.000	448.575	0.	0.	0.	0.	0.	0.	0.	0.
4 312		0.000	0.000	447.686	0.	0.	0.	0.	0.	0.	0.	0.
4 313		0.000	0.000	469.712	0.	0.	0.	0.	0.	0.	0.	0.
4 314		0.000	0.000	481.322	0.	0.	0.	0.	0.	0.	0.	0.
4 315		0.000	0.000	483.505	0.	0.	0.	0.	0.	0.	0.	0.
4 316		0.000	0.000	477.520	0.	0.	0.	0.	0.	0.	0.	0.
4 317		0.000	2.583	439.093	0.	0.	0.	0.	0.	0.	0.	0.
4 318		0.000	7.232	328.389	0.	0.	0.	0.	0.	0.	0.	0.
4 319		0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 320		0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 321		0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 322		0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 323		0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 324		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 3)												
MN		0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX		0.000	9.299	483.505	0.	0.	0.	0.	0.	0.	0.	0.
SM		0.000	90.405	6182.609	0.	0.	0.	0.	0.	0.	0.	0.
AV		0.000	3.767	257.609	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 94 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
4 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 4 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
4 4 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
4 4 7	0.000	0.000	249.767	0.	0.	0.	0.	0.	0.	0.	0.
4 4 8	0.000	0.000	195.872	0.	0.	0.	0.	0.	0.	0.	0.
4 4 9	0.000	0.000	195.619	0.	0.	0.	0.	0.	0.	0.	0.
4 410	0.000	0.000	195.673	0.	0.	0.	0.	0.	0.	0.	0.
4 411	0.000	0.000	195.675	0.	0.	0.	0.	0.	0.	0.	0.
4 412	0.000	0.000	195.611	0.	0.	0.	0.	0.	0.	0.	0.
4 413	0.000	0.000	201.604	0.	0.	0.	0.	0.	0.	0.	0.
4 414	0.000	0.000	195.859	0.	0.	0.	0.	0.	0.	0.	0.
4 415	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
4 416	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
4 417	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
4 418	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
4 419	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
4 420	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
4 421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
4 422	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
4 423	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
4 424	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 4)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.767	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2286.521	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	95.272	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 95 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
4 5 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
4 5 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
4 5 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
4 5 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
4 5 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
4 5 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
4 5 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 5 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 5 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
4 517	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
4 518	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
4 519	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
4 520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
4 521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
4 522	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
4 523	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
4 524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 5)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 96 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
4 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 6 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 6 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 6 7	0.000	0.000	462.528	0.	0.	0.	0.	0.	0.	0.	0.
4 6 8	0.000	0.000	466.838	0.	0.	0.	0.	0.	0.	0.	0.
4 6 9	0.000	0.000	474.745	0.	0.	0.	0.	0.	0.	0.	0.
4 610	0.000	0.000	542.925	0.	0.	0.	0.	0.	0.	0.	0.
4 611	0.000	0.000	489.684	0.	0.	0.	0.	0.	0.	0.	0.
4 612	0.000	0.000	486.288	0.	0.	0.	0.	0.	0.	0.	0.
4 613	0.000	0.000	503.465	0.	0.	0.	0.	0.	0.	0.	0.
4 614	0.000	0.000	512.646	0.	0.	0.	0.	0.	0.	0.	0.
4 615	0.000	0.000	516.629	0.	0.	0.	0.	0.	0.	0.	0.
4 616	0.000	0.000	509.504	0.	0.	0.	0.	0.	0.	0.	0.
4 617	0.000	2.583	440.984	0.	0.	0.	0.	0.	0.	0.	0.
4 618	0.000	7.232	328.585	0.	0.	0.	0.	0.	0.	0.	0.
4 619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	542.925	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6462.111	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	269.255	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE 97 - 2

		EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
		DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
		---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
4 7 1		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 7 2		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 7 3		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 7 4		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 7 5		0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 7 6		0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 7 7		0.000	0.000	462.450	0.	0.	0.	0.	0.	0.	0.	0.
4 7 8		0.000	0.000	468.790	0.	0.	0.	0.	0.	0.	0.	0.
4 7 9		0.000	0.000	507.329	0.	0.	0.	0.	0.	0.	0.	0.
4 710		0.000	0.000	590.866	0.	0.	0.	0.	0.	0.	0.	0.
4 711		0.000	0.000	579.989	0.	0.	0.	0.	0.	0.	0.	0.
4 712		0.000	0.000	564.315	0.	0.	0.	0.	0.	0.	0.	0.
4 713		0.000	0.000	595.192	0.	0.	0.	0.	0.	0.	0.	0.
4 714		0.000	0.000	576.752	0.	0.	0.	0.	0.	0.	0.	0.
4 715		0.000	0.000	614.485	0.	0.	0.	0.	0.	0.	0.	0.
4 716		0.000	0.000	606.832	0.	0.	0.	0.	0.	0.	0.	0.
4 717		0.000	2.583	514.877	0.	0.	0.	0.	0.	0.	0.	0.
4 718		0.000	7.232	386.473	0.	0.	0.	0.	0.	0.	0.	0.
4 719		0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 720		0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 721		0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 722		0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 723		0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 724		0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 7)												
MN		0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX		0.000	9.299	614.485	0.	0.	0.	0.	0.	0.	0.	0.
SM		0.000	90.405	7195.642	0.	0.	0.	0.	0.	0.	0.	0.
AV		0.000	3.767	299.818	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 98 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
4 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 8 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 8 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 8 7	0.000	0.000	469.318	0.	0.	0.	0.	0.	0.	0.	0.
4 8 8	0.000	0.000	594.657	0.	0.	0.	0.	0.	0.	0.	0.
4 8 9	0.000	0.000	643.466	0.	0.	0.	0.	0.	0.	0.	0.
4 810	0.000	0.000	651.518	0.	0.	0.	0.	0.	0.	0.	0.
4 811	0.000	0.000	632.717	0.	0.	0.	0.	0.	0.	0.	0.
4 812	0.000	0.000	628.305	0.	0.	0.	0.	0.	0.	0.	0.
4 813	0.000	0.000	647.329	0.	0.	0.	0.	0.	0.	0.	0.
4 814	0.000	0.000	661.387	0.	0.	0.	0.	0.	0.	0.	0.
4 815	0.000	0.000	664.523	0.	0.	0.	0.	0.	0.	0.	0.
4 816	0.000	0.000	651.552	0.	0.	0.	0.	0.	0.	0.	0.
4 817	0.000	2.583	602.652	0.	0.	0.	0.	0.	0.	0.	0.
4 818	0.000	7.232	430.667	0.	0.	0.	0.	0.	0.	0.	0.
4 819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	664.523	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	8005.382	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	333.558	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 99 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
4 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
4 9 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
4 9 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
4 9 7	0.000	0.000	465.453	0.	0.	0.	0.	0.	0.	0.	0.
4 9 8	0.000	0.000	546.850	0.	0.	0.	0.	0.	0.	0.	0.
4 9 9	0.000	0.000	631.030	0.	0.	0.	0.	0.	0.	0.	0.
4 910	0.000	0.000	653.922	0.	0.	0.	0.	0.	0.	0.	0.
4 911	0.000	0.000	619.197	0.	0.	0.	0.	0.	0.	0.	0.
4 912	0.000	0.000	593.157	0.	0.	0.	0.	0.	0.	0.	0.
4 913	0.000	0.000	603.014	0.	0.	0.	0.	0.	0.	0.	0.
4 914	0.000	0.000	602.378	0.	0.	0.	0.	0.	0.	0.	0.
4 915	0.000	0.000	600.007	0.	0.	0.	0.	0.	0.	0.	0.
4 916	0.000	0.000	591.670	0.	0.	0.	0.	0.	0.	0.	0.
4 917	0.000	2.583	499.927	0.	0.	0.	0.	0.	0.	0.	0.
4 918	0.000	7.232	338.066	0.	0.	0.	0.	0.	0.	0.	0.
4 919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
4 920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
4 921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
4 922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
4 923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
4 924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	653.922	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7471.964	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	311.332	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE100 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
410 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
410 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
410 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
410 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
410 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
410 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
410 7	0.000	0.000	463.396	0.	0.	0.	0.	0.	0.	0.	0.
410 8	0.000	0.000	470.886	0.	0.	0.	0.	0.	0.	0.	0.
410 9	0.000	0.000	556.777	0.	0.	0.	0.	0.	0.	0.	0.
41010	0.000	0.000	635.563	0.	0.	0.	0.	0.	0.	0.	0.
41011	0.000	0.000	633.287	0.	0.	0.	0.	0.	0.	0.	0.
41012	0.000	0.000	564.120	0.	0.	0.	0.	0.	0.	0.	0.
41013	0.000	0.000	597.565	0.	0.	0.	0.	0.	0.	0.	0.
41014	0.000	0.000	634.403	0.	0.	0.	0.	0.	0.	0.	0.
41015	0.000	0.000	646.615	0.	0.	0.	0.	0.	0.	0.	0.
41016	0.000	0.000	601.174	0.	0.	0.	0.	0.	0.	0.	0.
41017	0.000	2.583	524.213	0.	0.	0.	0.	0.	0.	0.	0.
41018	0.000	7.232	334.549	0.	0.	0.	0.	0.	0.	0.	0.
41019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
41020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
41021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
41022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
41023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
41024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	646.615	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7389.839	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	307.910	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE101 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
411 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
411 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
411 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
411 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
411 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
411 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
411 7	0.000	0.000	250.306	0.	0.	0.	0.	0.	0.	0.	0.
411 8	0.000	0.000	196.158	0.	0.	0.	0.	0.	0.	0.	0.
411 9	0.000	0.000	195.866	0.	0.	0.	0.	0.	0.	0.	0.
41110	0.000	0.000	353.448	0.	0.	0.	0.	0.	0.	0.	0.
41111	0.000	0.000	297.362	0.	0.	0.	0.	0.	0.	0.	0.
41112	0.000	0.000	317.589	0.	0.	0.	0.	0.	0.	0.	0.
41113	0.000	0.000	355.477	0.	0.	0.	0.	0.	0.	0.	0.
41114	0.000	0.000	379.332	0.	0.	0.	0.	0.	0.	0.	0.
41115	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
41116	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
41117	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
41118	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
41119	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
41120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
41121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
41122	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
41123	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
41124	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 11)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	379.332	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	3006.379	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	125.266	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE102 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
412 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
412 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
412 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
412 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
412 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
412 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
412 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
412 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
412 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41216	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41217	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
41218	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
41219	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
41220	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
41221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
41222	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
41223	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
41224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 12)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE103 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
413 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
413 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
413 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
413 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
413 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
413 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
413 7	0.000	0.000	470.879	0.	0.	0.	0.	0.	0.	0.	0.
413 8	0.000	0.000	608.151	0.	0.	0.	0.	0.	0.	0.	0.
413 9	0.000	0.000	654.394	0.	0.	0.	0.	0.	0.	0.	0.
41310	0.000	0.000	664.206	0.	0.	0.	0.	0.	0.	0.	0.
41311	0.000	0.000	642.310	0.	0.	0.	0.	0.	0.	0.	0.
41312	0.000	0.000	641.454	0.	0.	0.	0.	0.	0.	0.	0.
41313	0.000	0.000	674.717	0.	0.	0.	0.	0.	0.	0.	0.
41314	0.000	0.000	670.866	0.	0.	0.	0.	0.	0.	0.	0.
41315	0.000	0.000	658.238	0.	0.	0.	0.	0.	0.	0.	0.
41316	0.000	0.000	641.014	0.	0.	0.	0.	0.	0.	0.	0.
41317	0.000	2.583	601.137	0.	0.	0.	0.	0.	0.	0.	0.
41318	0.000	7.232	392.032	0.	0.	0.	0.	0.	0.	0.	0.
41319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
41320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
41321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
41322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
41323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
41324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	674.717	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	8046.687	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	335.279	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE104 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
414 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
414 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
414 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
414 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
414 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
414 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
414 7	0.000	0.000	466.349	0.	0.	0.	0.	0.	0.	0.	0.
414 8	0.000	0.000	532.062	0.	0.	0.	0.	0.	0.	0.	0.
414 9	0.000	0.000	627.781	0.	0.	0.	0.	0.	0.	0.	0.
41410	0.000	0.000	639.808	0.	0.	0.	0.	0.	0.	0.	0.
41411	0.000	0.000	623.362	0.	0.	0.	0.	0.	0.	0.	0.
41412	0.000	0.000	578.279	0.	0.	0.	0.	0.	0.	0.	0.
41413	0.000	0.000	608.176	0.	0.	0.	0.	0.	0.	0.	0.
41414	0.000	0.000	644.867	0.	0.	0.	0.	0.	0.	0.	0.
41415	0.000	0.000	582.708	0.	0.	0.	0.	0.	0.	0.	0.
41416	0.000	0.000	549.364	0.	0.	0.	0.	0.	0.	0.	0.
41417	0.000	2.583	482.544	0.	0.	0.	0.	0.	0.	0.	0.
41418	0.000	7.232	339.432	0.	0.	0.	0.	0.	0.	0.	0.
41419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
41420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
41421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
41422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
41423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
41424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	644.867	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7402.022	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	308.418	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE105 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
415 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
415 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
415 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
415 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
415 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
415 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
415 7	0.000	0.000	463.836	0.	0.	0.	0.	0.	0.	0.	0.
415 8	0.000	0.000	488.247	0.	0.	0.	0.	0.	0.	0.	0.
415 9	0.000	0.000	619.131	0.	0.	0.	0.	0.	0.	0.	0.
41510	0.000	0.000	623.309	0.	0.	0.	0.	0.	0.	0.	0.
41511	0.000	0.000	594.502	0.	0.	0.	0.	0.	0.	0.	0.
41512	0.000	0.000	612.380	0.	0.	0.	0.	0.	0.	0.	0.
41513	0.000	0.000	645.766	0.	0.	0.	0.	0.	0.	0.	0.
41514	0.000	0.000	664.230	0.	0.	0.	0.	0.	0.	0.	0.
41515	0.000	0.000	655.500	0.	0.	0.	0.	0.	0.	0.	0.
41516	0.000	0.000	636.288	0.	0.	0.	0.	0.	0.	0.	0.
41517	0.000	2.583	551.965	0.	0.	0.	0.	0.	0.	0.	0.
41518	0.000	7.232	336.362	0.	0.	0.	0.	0.	0.	0.	0.
41519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
41520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
41521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
41522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
41523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
41524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	664.230	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7618.807	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	317.450	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE106 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
416 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
416 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
416 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
416 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
416 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
416 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
416 7	0.000	0.000	464.531	0.	0.	0.	0.	0.	0.	0.	0.
416 8	0.000	0.000	602.366	0.	0.	0.	0.	0.	0.	0.	0.
416 9	0.000	0.000	645.140	0.	0.	0.	0.	0.	0.	0.	0.
41610	0.000	0.000	646.109	0.	0.	0.	0.	0.	0.	0.	0.
41611	0.000	0.000	618.929	0.	0.	0.	0.	0.	0.	0.	0.
41612	0.000	0.000	618.501	0.	0.	0.	0.	0.	0.	0.	0.
41613	0.000	0.000	648.411	0.	0.	0.	0.	0.	0.	0.	0.
41614	0.000	0.000	654.675	0.	0.	0.	0.	0.	0.	0.	0.
41615	0.000	0.000	650.766	0.	0.	0.	0.	0.	0.	0.	0.
41616	0.000	0.000	644.798	0.	0.	0.	0.	0.	0.	0.	0.
41617	0.000	2.583	606.111	0.	0.	0.	0.	0.	0.	0.	0.
41618	0.000	7.232	393.615	0.	0.	0.	0.	0.	0.	0.	0.
41619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
41620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
41621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
41622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
41623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
41624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	654.675	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	7921.242	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	330.052	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE107 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
417 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
417 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
417 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
417 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
417 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
417 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
417 7	0.000	0.000	464.129	0.	0.	0.	0.	0.	0.	0.	0.
417 8	0.000	0.000	473.008	0.	0.	0.	0.	0.	0.	0.	0.
417 9	0.000	0.000	547.012	0.	0.	0.	0.	0.	0.	0.	0.
41710	0.000	0.000	545.745	0.	0.	0.	0.	0.	0.	0.	0.
41711	0.000	0.000	470.163	0.	0.	0.	0.	0.	0.	0.	0.
41712	0.000	0.000	472.028	0.	0.	0.	0.	0.	0.	0.	0.
41713	0.000	0.000	476.770	0.	0.	0.	0.	0.	0.	0.	0.
41714	0.000	0.000	554.503	0.	0.	0.	0.	0.	0.	0.	0.
41715	0.000	0.000	507.369	0.	0.	0.	0.	0.	0.	0.	0.
41716	0.000	0.000	501.782	0.	0.	0.	0.	0.	0.	0.	0.
41717	0.000	2.583	443.763	0.	0.	0.	0.	0.	0.	0.	0.
41718	0.000	7.232	329.884	0.	0.	0.	0.	0.	0.	0.	0.
41719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
41720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
41721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
41722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
41723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
41724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	554.503	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6513.448	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	271.394	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE108 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
418 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
418 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
418 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
418 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
418 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
418 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
418 7	0.000	0.000	250.218	0.	0.	0.	0.	0.	0.	0.	0.
418 8	0.000	0.000	196.156	0.	0.	0.	0.	0.	0.	0.	0.
418 9	0.000	0.000	195.866	0.	0.	0.	0.	0.	0.	0.	0.
41810	0.000	0.000	247.301	0.	0.	0.	0.	0.	0.	0.	0.
41811	0.000	0.000	344.275	0.	0.	0.	0.	0.	0.	0.	0.
41812	0.000	0.000	262.949	0.	0.	0.	0.	0.	0.	0.	0.
41813	0.000	0.000	304.280	0.	0.	0.	0.	0.	0.	0.	0.
41814	0.000	0.000	289.194	0.	0.	0.	0.	0.	0.	0.	0.
41815	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
41816	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
41817	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
41818	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
41819	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
41820	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
41821	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
41822	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
41823	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
41824	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 18)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	344.275	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2751.080	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	114.628	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE109 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
419 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
419 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
419 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
419 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
419 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
419 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
419 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
419 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
419 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41910	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41911	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41912	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41913	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41914	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41915	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41916	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
41917	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
41918	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
41919	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
41920	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
41921	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
41922	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
41923	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
41924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 19)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE110 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
420 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
420 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
420 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
420 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
420 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
420 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
420 7	0.000	0.000	464.334	0.	0.	0.	0.	0.	0.	0.	0.
420 8	0.000	0.000	468.404	0.	0.	0.	0.	0.	0.	0.	0.
420 9	0.000	0.000	474.914	0.	0.	0.	0.	0.	0.	0.	0.
42010	0.000	0.000	485.746	0.	0.	0.	0.	0.	0.	0.	0.
42011	0.000	0.000	606.296	0.	0.	0.	0.	0.	0.	0.	0.
42012	0.000	0.000	545.784	0.	0.	0.	0.	0.	0.	0.	0.
42013	0.000	0.000	592.465	0.	0.	0.	0.	0.	0.	0.	0.
42014	0.000	0.000	568.311	0.	0.	0.	0.	0.	0.	0.	0.
42015	0.000	0.000	574.958	0.	0.	0.	0.	0.	0.	0.	0.
42016	0.000	0.000	543.043	0.	0.	0.	0.	0.	0.	0.	0.
42017	0.000	2.583	445.122	0.	0.	0.	0.	0.	0.	0.	0.
42018	0.000	7.232	330.109	0.	0.	0.	0.	0.	0.	0.	0.
42019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	606.296	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6826.776	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	284.449	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE111 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
421 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
421 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
421 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
421 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
421 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
421 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
421 7	0.000	0.000	462.510	0.	0.	0.	0.	0.	0.	0.	0.
421 8	0.000	0.000	467.191	0.	0.	0.	0.	0.	0.	0.	0.
421 9	0.000	0.000	474.372	0.	0.	0.	0.	0.	0.	0.	0.
42110	0.000	0.000	470.497	0.	0.	0.	0.	0.	0.	0.	0.
42111	0.000	0.000	447.130	0.	0.	0.	0.	0.	0.	0.	0.
42112	0.000	0.000	447.451	0.	0.	0.	0.	0.	0.	0.	0.
42113	0.000	0.000	469.846	0.	0.	0.	0.	0.	0.	0.	0.
42114	0.000	0.000	481.228	0.	0.	0.	0.	0.	0.	0.	0.
42115	0.000	0.000	484.793	0.	0.	0.	0.	0.	0.	0.	0.
42116	0.000	0.000	477.202	0.	0.	0.	0.	0.	0.	0.	0.
42117	0.000	2.583	439.784	0.	0.	0.	0.	0.	0.	0.	0.
42118	0.000	7.232	328.305	0.	0.	0.	0.	0.	0.	0.	0.
42119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	484.793	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6177.600	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.400	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE112 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
422 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
422 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
422 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
422 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
422 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
422 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
422 7	0.000	0.000	462.190	0.	0.	0.	0.	0.	0.	0.	0.
422 8	0.000	0.000	466.229	0.	0.	0.	0.	0.	0.	0.	0.
422 9	0.000	0.000	474.807	0.	0.	0.	0.	0.	0.	0.	0.
42210	0.000	0.000	470.203	0.	0.	0.	0.	0.	0.	0.	0.
42211	0.000	0.000	444.870	0.	0.	0.	0.	0.	0.	0.	0.
42212	0.000	0.000	445.889	0.	0.	0.	0.	0.	0.	0.	0.
42213	0.000	0.000	465.947	0.	0.	0.	0.	0.	0.	0.	0.
42214	0.000	0.000	479.812	0.	0.	0.	0.	0.	0.	0.	0.
42215	0.000	0.000	483.294	0.	0.	0.	0.	0.	0.	0.	0.
42216	0.000	0.000	476.075	0.	0.	0.	0.	0.	0.	0.	0.
42217	0.000	2.583	438.774	0.	0.	0.	0.	0.	0.	0.	0.
42218	0.000	7.232	328.147	0.	0.	0.	0.	0.	0.	0.	0.
42219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	483.294	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6163.527	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	256.814	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE113 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
423 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
423 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
423 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
423 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
423 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
423 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
423 7	0.000	0.000	462.129	0.	0.	0.	0.	0.	0.	0.	0.
423 8	0.000	0.000	465.496	0.	0.	0.	0.	0.	0.	0.	0.
423 9	0.000	0.000	471.284	0.	0.	0.	0.	0.	0.	0.	0.
42310	0.000	0.000	466.844	0.	0.	0.	0.	0.	0.	0.	0.
42311	0.000	0.000	443.774	0.	0.	0.	0.	0.	0.	0.	0.
42312	0.000	0.000	442.854	0.	0.	0.	0.	0.	0.	0.	0.
42313	0.000	0.000	462.654	0.	0.	0.	0.	0.	0.	0.	0.
42314	0.000	0.000	474.046	0.	0.	0.	0.	0.	0.	0.	0.
42315	0.000	0.000	472.167	0.	0.	0.	0.	0.	0.	0.	0.
42316	0.000	0.000	468.494	0.	0.	0.	0.	0.	0.	0.	0.
42317	0.000	2.583	433.043	0.	0.	0.	0.	0.	0.	0.	0.
42318	0.000	7.232	328.086	0.	0.	0.	0.	0.	0.	0.	0.
42319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	474.046	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6118.163	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	254.923	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE114 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
424 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
424 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
424 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
424 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
424 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
424 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
424 7	0.000	0.000	462.373	0.	0.	0.	0.	0.	0.	0.	0.
424 8	0.000	0.000	465.519	0.	0.	0.	0.	0.	0.	0.	0.
424 9	0.000	0.000	471.917	0.	0.	0.	0.	0.	0.	0.	0.
42410	0.000	0.000	469.053	0.	0.	0.	0.	0.	0.	0.	0.
42411	0.000	0.000	445.742	0.	0.	0.	0.	0.	0.	0.	0.
42412	0.000	0.000	453.379	0.	0.	0.	0.	0.	0.	0.	0.
42413	0.000	0.000	477.187	0.	0.	0.	0.	0.	0.	0.	0.
42414	0.000	0.000	478.425	0.	0.	0.	0.	0.	0.	0.	0.
42415	0.000	0.000	479.441	0.	0.	0.	0.	0.	0.	0.	0.
42416	0.000	0.000	474.457	0.	0.	0.	0.	0.	0.	0.	0.
42417	0.000	2.583	437.870	0.	0.	0.	0.	0.	0.	0.	0.
42418	0.000	7.232	328.497	0.	0.	0.	0.	0.	0.	0.	0.
42419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	479.441	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6171.149	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.131	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE115 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
425 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
425 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
425 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
425 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
425 5	0.000	4.649	41.933	0.	0.	0.	0.	0.	0.	0.	0.
425 6	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
425 7	0.000	0.000	249.994	0.	0.	0.	0.	0.	0.	0.	0.
425 8	0.000	0.000	196.045	0.	0.	0.	0.	0.	0.	0.	0.
425 9	0.000	0.000	215.740	0.	0.	0.	0.	0.	0.	0.	0.
42510	0.000	0.000	202.565	0.	0.	0.	0.	0.	0.	0.	0.
42511	0.000	0.000	202.853	0.	0.	0.	0.	0.	0.	0.	0.
42512	0.000	0.000	228.169	0.	0.	0.	0.	0.	0.	0.	0.
42513	0.000	0.000	219.599	0.	0.	0.	0.	0.	0.	0.	0.
42514	0.000	0.000	233.801	0.	0.	0.	0.	0.	0.	0.	0.
42515	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
42516	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
42517	0.000	2.583	39.866	0.	0.	0.	0.	0.	0.	0.	0.
42518	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
42519	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
42520	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
42521	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
42522	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
42523	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
42524	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 25)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	249.994	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	2409.606	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	100.400	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE116 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
426 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
426 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
426 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
426 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
426 5	0.000	4.649	15.834	0.	0.	0.	0.	0.	0.	0.	0.
426 6	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
426 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
426 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
426 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42616	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
42617	0.000	2.583	13.768	0.	0.	0.	0.	0.	0.	0.	0.
42618	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
42619	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
42620	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
42621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
42622	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
42623	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
42624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 26)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	384.944	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	16.039	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE117 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
427 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
427 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
427 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
427 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
427 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
427 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
427 7	0.000	0.000	463.454	0.	0.	0.	0.	0.	0.	0.	0.
427 8	0.000	0.000	465.780	0.	0.	0.	0.	0.	0.	0.	0.
427 9	0.000	0.000	505.798	0.	0.	0.	0.	0.	0.	0.	0.
42710	0.000	0.000	496.780	0.	0.	0.	0.	0.	0.	0.	0.
42711	0.000	0.000	475.296	0.	0.	0.	0.	0.	0.	0.	0.
42712	0.000	0.000	483.414	0.	0.	0.	0.	0.	0.	0.	0.
42713	0.000	0.000	532.758	0.	0.	0.	0.	0.	0.	0.	0.
42714	0.000	0.000	505.374	0.	0.	0.	0.	0.	0.	0.	0.
42715	0.000	0.000	482.775	0.	0.	0.	0.	0.	0.	0.	0.
42716	0.000	0.000	467.037	0.	0.	0.	0.	0.	0.	0.	0.
42717	0.000	2.583	432.596	0.	0.	0.	0.	0.	0.	0.	0.
42718	0.000	7.232	328.239	0.	0.	0.	0.	0.	0.	0.	0.
42719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	532.758	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6366.588	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	265.275	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE118 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
428 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
428 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
428 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
428 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
428 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
428 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
428 7	0.000	0.000	462.739	0.	0.	0.	0.	0.	0.	0.	0.
428 8	0.000	0.000	465.710	0.	0.	0.	0.	0.	0.	0.	0.
428 9	0.000	0.000	498.729	0.	0.	0.	0.	0.	0.	0.	0.
42810	0.000	0.000	495.787	0.	0.	0.	0.	0.	0.	0.	0.
42811	0.000	0.000	555.517	0.	0.	0.	0.	0.	0.	0.	0.
42812	0.000	0.000	516.095	0.	0.	0.	0.	0.	0.	0.	0.
42813	0.000	0.000	466.369	0.	0.	0.	0.	0.	0.	0.	0.
42814	0.000	0.000	472.121	0.	0.	0.	0.	0.	0.	0.	0.
42815	0.000	0.000	472.431	0.	0.	0.	0.	0.	0.	0.	0.
42816	0.000	0.000	465.208	0.	0.	0.	0.	0.	0.	0.	0.
42817	0.000	2.583	431.476	0.	0.	0.	0.	0.	0.	0.	0.
42818	0.000	7.232	328.237	0.	0.	0.	0.	0.	0.	0.	0.
42819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	555.517	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6357.708	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	264.905	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE119 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
429 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
429 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
429 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
429 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
429 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
429 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
429 7	0.000	0.000	462.710	0.	0.	0.	0.	0.	0.	0.	0.
429 8	0.000	0.000	467.467	0.	0.	0.	0.	0.	0.	0.	0.
429 9	0.000	0.000	473.181	0.	0.	0.	0.	0.	0.	0.	0.
42910	0.000	0.000	469.762	0.	0.	0.	0.	0.	0.	0.	0.
42911	0.000	0.000	445.076	0.	0.	0.	0.	0.	0.	0.	0.
42912	0.000	0.000	455.782	0.	0.	0.	0.	0.	0.	0.	0.
42913	0.000	0.000	479.533	0.	0.	0.	0.	0.	0.	0.	0.
42914	0.000	0.000	489.490	0.	0.	0.	0.	0.	0.	0.	0.
42915	0.000	0.000	481.363	0.	0.	0.	0.	0.	0.	0.	0.
42916	0.000	0.000	474.101	0.	0.	0.	0.	0.	0.	0.	0.
42917	0.000	2.583	437.806	0.	0.	0.	0.	0.	0.	0.	0.
42918	0.000	7.232	328.401	0.	0.	0.	0.	0.	0.	0.	0.
42919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
42920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
42921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
42922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
42923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
42924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	489.490	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6191.965	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	257.999	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE120 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
430 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
430 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
430 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
430 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
430 5	0.000	4.649	48.734	0.	0.	0.	0.	0.	0.	0.	0.
430 6	0.000	1.550	106.064	0.	0.	0.	0.	0.	0.	0.	0.
430 7	0.000	0.000	462.624	0.	0.	0.	0.	0.	0.	0.	0.
430 8	0.000	0.000	465.707	0.	0.	0.	0.	0.	0.	0.	0.
430 9	0.000	0.000	471.489	0.	0.	0.	0.	0.	0.	0.	0.
43010	0.000	0.000	467.103	0.	0.	0.	0.	0.	0.	0.	0.
43011	0.000	0.000	443.925	0.	0.	0.	0.	0.	0.	0.	0.
43012	0.000	0.000	443.283	0.	0.	0.	0.	0.	0.	0.	0.
43013	0.000	0.000	463.214	0.	0.	0.	0.	0.	0.	0.	0.
43014	0.000	0.000	471.424	0.	0.	0.	0.	0.	0.	0.	0.
43015	0.000	0.000	471.744	0.	0.	0.	0.	0.	0.	0.	0.
43016	0.000	0.000	464.650	0.	0.	0.	0.	0.	0.	0.	0.
43017	0.000	2.583	431.372	0.	0.	0.	0.	0.	0.	0.	0.
43018	0.000	7.232	328.237	0.	0.	0.	0.	0.	0.	0.	0.
43019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
43020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
43021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
43022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
43023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
43024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	471.744	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	90.405	6112.064	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	254.669	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (APR)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	674.717	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	2712.151	161089.016	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.767	223.735	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE121 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 1 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
5 1 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
5 1 7	0.000	0.000	463.036	0.	0.	0.	0.	0.	0.	0.	0.
5 1 8	0.000	0.000	480.973	0.	0.	0.	0.	0.	0.	0.	0.
5 1 9	0.000	0.000	586.897	0.	0.	0.	0.	0.	0.	0.	0.
5 110	0.000	0.000	632.350	0.	0.	0.	0.	0.	0.	0.	0.
5 111	0.000	0.000	622.430	0.	0.	0.	0.	0.	0.	0.	0.
5 112	0.000	0.000	622.708	0.	0.	0.	0.	0.	0.	0.	0.
5 113	0.000	0.000	647.558	0.	0.	0.	0.	0.	0.	0.	0.
5 114	0.000	0.000	662.213	0.	0.	0.	0.	0.	0.	0.	0.
5 115	0.000	0.000	662.377	0.	0.	0.	0.	0.	0.	0.	0.
5 116	0.000	0.000	649.058	0.	0.	0.	0.	0.	0.	0.	0.
5 117	0.000	0.000	592.498	0.	0.	0.	0.	0.	0.	0.	0.
5 118	0.000	0.000	362.841	0.	0.	0.	0.	0.	0.	0.	0.
5 119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
5 120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
5 121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
5 122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
5 123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
5 124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	662.377	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7704.480	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	321.020	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE122 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 2 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
5 2 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
5 2 7	0.000	0.000	250.981	0.	0.	0.	0.	0.	0.	0.	0.
5 2 8	0.000	0.000	196.233	0.	0.	0.	0.	0.	0.	0.	0.
5 2 9	0.000	0.000	254.320	0.	0.	0.	0.	0.	0.	0.	0.
5 210	0.000	0.000	265.027	0.	0.	0.	0.	0.	0.	0.	0.
5 211	0.000	0.000	290.854	0.	0.	0.	0.	0.	0.	0.	0.
5 212	0.000	0.000	303.271	0.	0.	0.	0.	0.	0.	0.	0.
5 213	0.000	0.000	302.693	0.	0.	0.	0.	0.	0.	0.	0.
5 214	0.000	0.000	331.932	0.	0.	0.	0.	0.	0.	0.	0.
5 215	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 216	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 217	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 218	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 219	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
5 220	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
5 221	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
5 222	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
5 223	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
5 224	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 2)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	331.932	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	2838.589	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	118.275	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE123 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 3 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
5 3 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
5 3 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
5 3 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
5 3 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
5 3 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
5 3 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 3 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 3 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 310	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 311	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 312	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 313	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 314	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 315	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 316	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 317	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 318	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
5 319	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
5 320	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
5 321	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
5 322	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
5 323	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
5 324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 3)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE124 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 4 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
5 4 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
5 4 7	0.000	0.000	464.786	0.	0.	0.	0.	0.	0.	0.	0.
5 4 8	0.000	0.000	466.072	0.	0.	0.	0.	0.	0.	0.	0.
5 4 9	0.000	0.000	472.875	0.	0.	0.	0.	0.	0.	0.	0.
5 410	0.000	0.000	480.593	0.	0.	0.	0.	0.	0.	0.	0.
5 411	0.000	0.000	499.681	0.	0.	0.	0.	0.	0.	0.	0.
5 412	0.000	0.000	502.530	0.	0.	0.	0.	0.	0.	0.	0.
5 413	0.000	0.000	529.609	0.	0.	0.	0.	0.	0.	0.	0.
5 414	0.000	0.000	596.817	0.	0.	0.	0.	0.	0.	0.	0.
5 415	0.000	0.000	584.170	0.	0.	0.	0.	0.	0.	0.	0.
5 416	0.000	0.000	510.365	0.	0.	0.	0.	0.	0.	0.	0.
5 417	0.000	0.000	442.369	0.	0.	0.	0.	0.	0.	0.	0.
5 418	0.000	0.000	321.372	0.	0.	0.	0.	0.	0.	0.	0.
5 419	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
5 420	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
5 421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
5 422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
5 423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
5 424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	596.817	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6590.781	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	274.616	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE125 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 5 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
5 5 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
5 5 7	0.000	0.000	462.699	0.	0.	0.	0.	0.	0.	0.	0.
5 5 8	0.000	0.000	493.632	0.	0.	0.	0.	0.	0.	0.	0.
5 5 9	0.000	0.000	521.795	0.	0.	0.	0.	0.	0.	0.	0.
5 510	0.000	0.000	527.905	0.	0.	0.	0.	0.	0.	0.	0.
5 511	0.000	0.000	553.763	0.	0.	0.	0.	0.	0.	0.	0.
5 512	0.000	0.000	524.043	0.	0.	0.	0.	0.	0.	0.	0.
5 513	0.000	0.000	507.733	0.	0.	0.	0.	0.	0.	0.	0.
5 514	0.000	0.000	539.256	0.	0.	0.	0.	0.	0.	0.	0.
5 515	0.000	0.000	540.339	0.	0.	0.	0.	0.	0.	0.	0.
5 516	0.000	0.000	501.707	0.	0.	0.	0.	0.	0.	0.	0.
5 517	0.000	0.000	432.189	0.	0.	0.	0.	0.	0.	0.	0.
5 518	0.000	0.000	321.011	0.	0.	0.	0.	0.	0.	0.	0.
5 519	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
5 520	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
5 521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
5 522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
5 523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
5 524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	553.763	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6645.614	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	276.901	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE126 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 6 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
5 6 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
5 6 7	0.000	0.000	462.624	0.	0.	0.	0.	0.	0.	0.	0.
5 6 8	0.000	0.000	466.243	0.	0.	0.	0.	0.	0.	0.	0.
5 6 9	0.000	0.000	501.147	0.	0.	0.	0.	0.	0.	0.	0.
5 610	0.000	0.000	514.866	0.	0.	0.	0.	0.	0.	0.	0.
5 611	0.000	0.000	517.455	0.	0.	0.	0.	0.	0.	0.	0.
5 612	0.000	0.000	575.651	0.	0.	0.	0.	0.	0.	0.	0.
5 613	0.000	0.000	562.799	0.	0.	0.	0.	0.	0.	0.	0.
5 614	0.000	0.000	613.783	0.	0.	0.	0.	0.	0.	0.	0.
5 615	0.000	0.000	518.091	0.	0.	0.	0.	0.	0.	0.	0.
5 616	0.000	0.000	483.353	0.	0.	0.	0.	0.	0.	0.	0.
5 617	0.000	0.000	445.067	0.	0.	0.	0.	0.	0.	0.	0.
5 618	0.000	0.000	321.621	0.	0.	0.	0.	0.	0.	0.	0.
5 619	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
5 620	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
5 621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
5 622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
5 623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
5 624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	613.783	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6702.241	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	279.260	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE127 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 7 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
5 7 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
5 7 7	0.000	0.000	462.538	0.	0.	0.	0.	0.	0.	0.	0.
5 7 8	0.000	0.000	467.433	0.	0.	0.	0.	0.	0.	0.	0.
5 7 9	0.000	0.000	483.028	0.	0.	0.	0.	0.	0.	0.	0.
5 710	0.000	0.000	480.658	0.	0.	0.	0.	0.	0.	0.	0.
5 711	0.000	0.000	480.068	0.	0.	0.	0.	0.	0.	0.	0.
5 712	0.000	0.000	572.203	0.	0.	0.	0.	0.	0.	0.	0.
5 713	0.000	0.000	612.390	0.	0.	0.	0.	0.	0.	0.	0.
5 714	0.000	0.000	618.222	0.	0.	0.	0.	0.	0.	0.	0.
5 715	0.000	0.000	607.769	0.	0.	0.	0.	0.	0.	0.	0.
5 716	0.000	0.000	544.177	0.	0.	0.	0.	0.	0.	0.	0.
5 717	0.000	0.000	469.304	0.	0.	0.	0.	0.	0.	0.	0.
5 718	0.000	0.000	323.437	0.	0.	0.	0.	0.	0.	0.	0.
5 719	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
5 720	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
5 721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
5 722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
5 723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
5 724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 7)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	618.222	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6840.767	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	285.032	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE128 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
5 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 8 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
5 8 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
5 8 7	0.000	0.000	462.724	0.	0.	0.	0.	0.	0.	0.	0.
5 8 8	0.000	0.000	476.201	0.	0.	0.	0.	0.	0.	0.	0.
5 8 9	0.000	0.000	525.559	0.	0.	0.	0.	0.	0.	0.	0.
5 810	0.000	0.000	553.232	0.	0.	0.	0.	0.	0.	0.	0.
5 811	0.000	0.000	540.603	0.	0.	0.	0.	0.	0.	0.	0.
5 812	0.000	0.000	573.237	0.	0.	0.	0.	0.	0.	0.	0.
5 813	0.000	0.000	619.293	0.	0.	0.	0.	0.	0.	0.	0.
5 814	0.000	0.000	622.904	0.	0.	0.	0.	0.	0.	0.	0.
5 815	0.000	0.000	591.304	0.	0.	0.	0.	0.	0.	0.	0.
5 816	0.000	0.000	586.641	0.	0.	0.	0.	0.	0.	0.	0.
5 817	0.000	0.000	504.629	0.	0.	0.	0.	0.	0.	0.	0.
5 818	0.000	0.000	350.202	0.	0.	0.	0.	0.	0.	0.	0.
5 819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
5 820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
5 821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
5 822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
5 823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
5 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	622.904	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7126.068	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	296.920	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE129 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
5 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
5 9 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
5 9 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
5 9 7	0.000	0.000	250.825	0.	0.	0.	0.	0.	0.	0.	0.
5 9 8	0.000	0.000	224.278	0.	0.	0.	0.	0.	0.	0.	0.
5 9 9	0.000	0.000	255.278	0.	0.	0.	0.	0.	0.	0.	0.
5 910	0.000	0.000	278.590	0.	0.	0.	0.	0.	0.	0.	0.
5 911	0.000	0.000	289.991	0.	0.	0.	0.	0.	0.	0.	0.
5 912	0.000	0.000	290.418	0.	0.	0.	0.	0.	0.	0.	0.
5 913	0.000	0.000	278.576	0.	0.	0.	0.	0.	0.	0.	0.
5 914	0.000	0.000	302.216	0.	0.	0.	0.	0.	0.	0.	0.
5 915	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 916	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 917	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 918	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
5 919	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
5 920	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
5 921	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
5 922	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
5 923	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
5 924	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 9)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	302.216	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	2813.450	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	117.227	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE130 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
510 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
510 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
510 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
510 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
510 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
510 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
510 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
510 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
510 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51010	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51011	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51012	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51013	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51014	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51015	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51016	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51017	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51018	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51019	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
51020	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
51021	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
51022	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
51023	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
51024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 10)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE131 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
511 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
511 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
511 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
511 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
511 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
511 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
511 7	0.000	0.000	466.369	0.	0.	0.	0.	0.	0.	0.	0.
511 8	0.000	0.000	620.039	0.	0.	0.	0.	0.	0.	0.	0.
511 9	0.000	0.000	644.739	0.	0.	0.	0.	0.	0.	0.	0.
51110	0.000	0.000	659.360	0.	0.	0.	0.	0.	0.	0.	0.
51111	0.000	0.000	636.832	0.	0.	0.	0.	0.	0.	0.	0.
51112	0.000	0.000	647.253	0.	0.	0.	0.	0.	0.	0.	0.
51113	0.000	0.000	660.662	0.	0.	0.	0.	0.	0.	0.	0.
51114	0.000	0.000	674.384	0.	0.	0.	0.	0.	0.	0.	0.
51115	0.000	0.000	678.632	0.	0.	0.	0.	0.	0.	0.	0.
51116	0.000	0.000	663.823	0.	0.	0.	0.	0.	0.	0.	0.
51117	0.000	0.000	608.773	0.	0.	0.	0.	0.	0.	0.	0.
51118	0.000	0.000	446.601	0.	0.	0.	0.	0.	0.	0.	0.
51119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	678.632	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8127.008	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	338.625	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE132 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
512 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
512 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
512 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
512 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
512 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
512 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
512 7	0.000	0.000	465.895	0.	0.	0.	0.	0.	0.	0.	0.
512 8	0.000	0.000	624.852	0.	0.	0.	0.	0.	0.	0.	0.
512 9	0.000	0.000	650.749	0.	0.	0.	0.	0.	0.	0.	0.
51210	0.000	0.000	649.863	0.	0.	0.	0.	0.	0.	0.	0.
51211	0.000	0.000	627.260	0.	0.	0.	0.	0.	0.	0.	0.
51212	0.000	0.000	626.224	0.	0.	0.	0.	0.	0.	0.	0.
51213	0.000	0.000	671.786	0.	0.	0.	0.	0.	0.	0.	0.
51214	0.000	0.000	689.064	0.	0.	0.	0.	0.	0.	0.	0.
51215	0.000	0.000	693.205	0.	0.	0.	0.	0.	0.	0.	0.
51216	0.000	0.000	674.487	0.	0.	0.	0.	0.	0.	0.	0.
51217	0.000	0.000	634.646	0.	0.	0.	0.	0.	0.	0.	0.
51218	0.000	0.000	490.537	0.	0.	0.	0.	0.	0.	0.	0.
51219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	693.205	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8218.107	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	342.421	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE133 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
513 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
513 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
513 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
513 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
513 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
513 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
513 7	0.000	0.000	467.830	0.	0.	0.	0.	0.	0.	0.	0.
513 8	0.000	0.000	469.574	0.	0.	0.	0.	0.	0.	0.	0.
513 9	0.000	0.000	536.561	0.	0.	0.	0.	0.	0.	0.	0.
51310	0.000	0.000	636.747	0.	0.	0.	0.	0.	0.	0.	0.
51311	0.000	0.000	538.340	0.	0.	0.	0.	0.	0.	0.	0.
51312	0.000	0.000	611.439	0.	0.	0.	0.	0.	0.	0.	0.
51313	0.000	0.000	652.167	0.	0.	0.	0.	0.	0.	0.	0.
51314	0.000	0.000	672.626	0.	0.	0.	0.	0.	0.	0.	0.
51315	0.000	0.000	672.940	0.	0.	0.	0.	0.	0.	0.	0.
51316	0.000	0.000	659.078	0.	0.	0.	0.	0.	0.	0.	0.
51317	0.000	0.000	607.290	0.	0.	0.	0.	0.	0.	0.	0.
51318	0.000	0.000	446.258	0.	0.	0.	0.	0.	0.	0.	0.
51319	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51320	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	672.940	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7690.391	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	320.433	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE134 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
514 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
514 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
514 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
514 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
514 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
514 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
514 7	0.000	0.000	465.577	0.	0.	0.	0.	0.	0.	0.	0.
514 8	0.000	0.000	471.149	0.	0.	0.	0.	0.	0.	0.	0.
514 9	0.000	0.000	649.090	0.	0.	0.	0.	0.	0.	0.	0.
51410	0.000	0.000	661.886	0.	0.	0.	0.	0.	0.	0.	0.
51411	0.000	0.000	620.344	0.	0.	0.	0.	0.	0.	0.	0.
51412	0.000	0.000	615.018	0.	0.	0.	0.	0.	0.	0.	0.
51413	0.000	0.000	655.386	0.	0.	0.	0.	0.	0.	0.	0.
51414	0.000	0.000	666.206	0.	0.	0.	0.	0.	0.	0.	0.
51415	0.000	0.000	671.118	0.	0.	0.	0.	0.	0.	0.	0.
51416	0.000	0.000	650.455	0.	0.	0.	0.	0.	0.	0.	0.
51417	0.000	0.000	615.885	0.	0.	0.	0.	0.	0.	0.	0.
51418	0.000	0.000	438.898	0.	0.	0.	0.	0.	0.	0.	0.
51419	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51420	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	671.118	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7900.553	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	329.190	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE135 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
515 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
515 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
515 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
515 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
515 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
515 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
515 7	0.000	0.000	465.017	0.	0.	0.	0.	0.	0.	0.	0.
515 8	0.000	0.000	486.224	0.	0.	0.	0.	0.	0.	0.	0.
515 9	0.000	0.000	630.384	0.	0.	0.	0.	0.	0.	0.	0.
51510	0.000	0.000	637.126	0.	0.	0.	0.	0.	0.	0.	0.
51511	0.000	0.000	618.797	0.	0.	0.	0.	0.	0.	0.	0.
51512	0.000	0.000	618.902	0.	0.	0.	0.	0.	0.	0.	0.
51513	0.000	0.000	643.435	0.	0.	0.	0.	0.	0.	0.	0.
51514	0.000	0.000	657.848	0.	0.	0.	0.	0.	0.	0.	0.
51515	0.000	0.000	649.842	0.	0.	0.	0.	0.	0.	0.	0.
51516	0.000	0.000	564.317	0.	0.	0.	0.	0.	0.	0.	0.
51517	0.000	0.000	437.368	0.	0.	0.	0.	0.	0.	0.	0.
51518	0.000	0.000	321.195	0.	0.	0.	0.	0.	0.	0.	0.
51519	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51520	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	657.848	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7449.997	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	310.417	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE136 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
516 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
516 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
516 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
516 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
516 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
516 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
516 7	0.000	0.000	251.147	0.	0.	0.	0.	0.	0.	0.	0.
516 8	0.000	0.000	234.318	0.	0.	0.	0.	0.	0.	0.	0.
516 9	0.000	0.000	302.252	0.	0.	0.	0.	0.	0.	0.	0.
51610	0.000	0.000	302.410	0.	0.	0.	0.	0.	0.	0.	0.
51611	0.000	0.000	316.372	0.	0.	0.	0.	0.	0.	0.	0.
51612	0.000	0.000	315.767	0.	0.	0.	0.	0.	0.	0.	0.
51613	0.000	0.000	315.810	0.	0.	0.	0.	0.	0.	0.	0.
51614	0.000	0.000	315.808	0.	0.	0.	0.	0.	0.	0.	0.
51615	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
51616	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
51617	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
51618	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
51619	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
51620	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
51621	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
51622	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
51623	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
51624	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 16)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	316.372	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	2997.160	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	124.882	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE137 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
517 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
517 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
517 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
517 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
517 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
517 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
517 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
517 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
517 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51710	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51711	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51712	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51713	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51714	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51715	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51716	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51717	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51718	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
51719	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
51720	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
51721	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
51722	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
51723	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
51724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 17)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE138 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
518 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
518 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
518 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
518 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
518 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
518 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
518 7	0.000	0.000	464.731	0.	0.	0.	0.	0.	0.	0.	0.
518 8	0.000	0.000	467.114	0.	0.	0.	0.	0.	0.	0.	0.
518 9	0.000	0.000	474.716	0.	0.	0.	0.	0.	0.	0.	0.
51810	0.000	0.000	556.225	0.	0.	0.	0.	0.	0.	0.	0.
51811	0.000	0.000	480.991	0.	0.	0.	0.	0.	0.	0.	0.
51812	0.000	0.000	484.639	0.	0.	0.	0.	0.	0.	0.	0.
51813	0.000	0.000	620.195	0.	0.	0.	0.	0.	0.	0.	0.
51814	0.000	0.000	637.963	0.	0.	0.	0.	0.	0.	0.	0.
51815	0.000	0.000	581.053	0.	0.	0.	0.	0.	0.	0.	0.
51816	0.000	0.000	602.194	0.	0.	0.	0.	0.	0.	0.	0.
51817	0.000	0.000	468.591	0.	0.	0.	0.	0.	0.	0.	0.
51818	0.000	0.000	322.921	0.	0.	0.	0.	0.	0.	0.	0.
51819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	637.963	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6880.875	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	286.703	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE139 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
519 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
519 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
519 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
519 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
519 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
519 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
519 7	0.000	0.000	462.556	0.	0.	0.	0.	0.	0.	0.	0.
519 8	0.000	0.000	467.150	0.	0.	0.	0.	0.	0.	0.	0.
519 9	0.000	0.000	473.985	0.	0.	0.	0.	0.	0.	0.	0.
51910	0.000	0.000	468.444	0.	0.	0.	0.	0.	0.	0.	0.
51911	0.000	0.000	445.847	0.	0.	0.	0.	0.	0.	0.	0.
51912	0.000	0.000	454.054	0.	0.	0.	0.	0.	0.	0.	0.
51913	0.000	0.000	495.411	0.	0.	0.	0.	0.	0.	0.	0.
51914	0.000	0.000	485.583	0.	0.	0.	0.	0.	0.	0.	0.
51915	0.000	0.000	485.452	0.	0.	0.	0.	0.	0.	0.	0.
51916	0.000	0.000	469.735	0.	0.	0.	0.	0.	0.	0.	0.
51917	0.000	0.000	432.367	0.	0.	0.	0.	0.	0.	0.	0.
51918	0.000	0.000	320.879	0.	0.	0.	0.	0.	0.	0.	0.
51919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
51920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
51921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
51922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
51923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
51924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	495.411	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6181.004	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	257.542	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE140 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
520 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
520 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
520 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
520 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
520 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
520 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
520 7	0.000	0.000	462.377	0.	0.	0.	0.	0.	0.	0.	0.
520 8	0.000	0.000	467.494	0.	0.	0.	0.	0.	0.	0.	0.
520 9	0.000	0.000	476.925	0.	0.	0.	0.	0.	0.	0.	0.
52010	0.000	0.000	482.537	0.	0.	0.	0.	0.	0.	0.	0.
52011	0.000	0.000	535.707	0.	0.	0.	0.	0.	0.	0.	0.
52012	0.000	0.000	534.863	0.	0.	0.	0.	0.	0.	0.	0.
52013	0.000	0.000	584.261	0.	0.	0.	0.	0.	0.	0.	0.
52014	0.000	0.000	578.316	0.	0.	0.	0.	0.	0.	0.	0.
52015	0.000	0.000	583.686	0.	0.	0.	0.	0.	0.	0.	0.
52016	0.000	0.000	555.470	0.	0.	0.	0.	0.	0.	0.	0.
52017	0.000	0.000	514.081	0.	0.	0.	0.	0.	0.	0.	0.
52018	0.000	0.000	346.767	0.	0.	0.	0.	0.	0.	0.	0.
52019	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52020	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	584.261	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6842.025	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	285.084	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE141 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
521 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
521 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
521 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
521 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
521 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
521 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
521 7	0.000	0.000	463.662	0.	0.	0.	0.	0.	0.	0.	0.
521 8	0.000	0.000	480.044	0.	0.	0.	0.	0.	0.	0.	0.
521 9	0.000	0.000	530.884	0.	0.	0.	0.	0.	0.	0.	0.
52110	0.000	0.000	548.870	0.	0.	0.	0.	0.	0.	0.	0.
52111	0.000	0.000	540.264	0.	0.	0.	0.	0.	0.	0.	0.
52112	0.000	0.000	556.810	0.	0.	0.	0.	0.	0.	0.	0.
52113	0.000	0.000	600.230	0.	0.	0.	0.	0.	0.	0.	0.
52114	0.000	0.000	622.700	0.	0.	0.	0.	0.	0.	0.	0.
52115	0.000	0.000	630.451	0.	0.	0.	0.	0.	0.	0.	0.
52116	0.000	0.000	606.251	0.	0.	0.	0.	0.	0.	0.	0.
52117	0.000	0.000	539.854	0.	0.	0.	0.	0.	0.	0.	0.
52118	0.000	0.000	356.193	0.	0.	0.	0.	0.	0.	0.	0.
52119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	630.451	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7195.754	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	299.823	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE142 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
522 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
522 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
522 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
522 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
522 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
522 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
522 7	0.000	0.000	464.782	0.	0.	0.	0.	0.	0.	0.	0.
522 8	0.000	0.000	505.624	0.	0.	0.	0.	0.	0.	0.	0.
522 9	0.000	0.000	625.000	0.	0.	0.	0.	0.	0.	0.	0.
52210	0.000	0.000	648.894	0.	0.	0.	0.	0.	0.	0.	0.
52211	0.000	0.000	623.040	0.	0.	0.	0.	0.	0.	0.	0.
52212	0.000	0.000	614.543	0.	0.	0.	0.	0.	0.	0.	0.
52213	0.000	0.000	640.030	0.	0.	0.	0.	0.	0.	0.	0.
52214	0.000	0.000	651.341	0.	0.	0.	0.	0.	0.	0.	0.
52215	0.000	0.000	662.892	0.	0.	0.	0.	0.	0.	0.	0.
52216	0.000	0.000	653.276	0.	0.	0.	0.	0.	0.	0.	0.
52217	0.000	0.000	601.383	0.	0.	0.	0.	0.	0.	0.	0.
52218	0.000	0.000	422.032	0.	0.	0.	0.	0.	0.	0.	0.
52219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	662.892	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7832.379	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	326.349	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE143 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
523 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
523 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
523 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
523 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
523 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
523 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
523 7	0.000	0.000	253.085	0.	0.	0.	0.	0.	0.	0.	0.
523 8	0.000	0.000	265.167	0.	0.	0.	0.	0.	0.	0.	0.
523 9	0.000	0.000	344.763	0.	0.	0.	0.	0.	0.	0.	0.
52310	0.000	0.000	358.556	0.	0.	0.	0.	0.	0.	0.	0.
52311	0.000	0.000	354.051	0.	0.	0.	0.	0.	0.	0.	0.
52312	0.000	0.000	356.230	0.	0.	0.	0.	0.	0.	0.	0.
52313	0.000	0.000	341.328	0.	0.	0.	0.	0.	0.	0.	0.
52314	0.000	0.000	342.320	0.	0.	0.	0.	0.	0.	0.	0.
52315	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
52316	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
52317	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
52318	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
52319	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
52320	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
52321	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
52322	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
52323	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
52324	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 23)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	358.556	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3258.776	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	135.782	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE144 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
524 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
524 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
524 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
524 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
524 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
524 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
524 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
524 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
524 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52410	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52411	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52412	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52413	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52414	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52415	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52416	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52417	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52418	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52419	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
52420	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
52421	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
52422	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
52423	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
52424	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 24)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	341.281	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	14.220	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE145 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
525 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
525 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
525 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
525 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
525 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
525 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
525 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
525 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
525 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52517	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52518	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
52519	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
52520	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
52521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
52522	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
52523	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
52524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 25)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE146 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
526 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
526 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
526 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
526 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
526 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
526 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
526 7	0.000	0.000	465.199	0.	0.	0.	0.	0.	0.	0.	0.
526 8	0.000	0.000	467.075	0.	0.	0.	0.	0.	0.	0.	0.
526 9	0.000	0.000	484.973	0.	0.	0.	0.	0.	0.	0.	0.
52610	0.000	0.000	544.282	0.	0.	0.	0.	0.	0.	0.	0.
52611	0.000	0.000	591.589	0.	0.	0.	0.	0.	0.	0.	0.
52612	0.000	0.000	588.745	0.	0.	0.	0.	0.	0.	0.	0.
52613	0.000	0.000	617.143	0.	0.	0.	0.	0.	0.	0.	0.
52614	0.000	0.000	632.484	0.	0.	0.	0.	0.	0.	0.	0.
52615	0.000	0.000	636.101	0.	0.	0.	0.	0.	0.	0.	0.
52616	0.000	0.000	629.206	0.	0.	0.	0.	0.	0.	0.	0.
52617	0.000	0.000	535.232	0.	0.	0.	0.	0.	0.	0.	0.
52618	0.000	0.000	359.878	0.	0.	0.	0.	0.	0.	0.	0.
52619	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52620	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	636.101	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7271.448	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	302.977	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE147 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
527 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
527 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
527 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
527 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
527 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
527 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
527 7	0.000	0.000	463.603	0.	0.	0.	0.	0.	0.	0.	0.
527 8	0.000	0.000	484.319	0.	0.	0.	0.	0.	0.	0.	0.
527 9	0.000	0.000	490.522	0.	0.	0.	0.	0.	0.	0.	0.
52710	0.000	0.000	571.371	0.	0.	0.	0.	0.	0.	0.	0.
52711	0.000	0.000	612.326	0.	0.	0.	0.	0.	0.	0.	0.
52712	0.000	0.000	636.514	0.	0.	0.	0.	0.	0.	0.	0.
52713	0.000	0.000	659.521	0.	0.	0.	0.	0.	0.	0.	0.
52714	0.000	0.000	664.664	0.	0.	0.	0.	0.	0.	0.	0.
52715	0.000	0.000	672.642	0.	0.	0.	0.	0.	0.	0.	0.
52716	0.000	0.000	657.573	0.	0.	0.	0.	0.	0.	0.	0.
52717	0.000	0.000	614.537	0.	0.	0.	0.	0.	0.	0.	0.
52718	0.000	0.000	483.982	0.	0.	0.	0.	0.	0.	0.	0.
52719	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52720	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	672.642	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7731.116	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	322.130	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE148 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
528 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
528 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
528 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
528 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
528 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
528 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
528 7	0.000	0.000	574.769	0.	0.	0.	0.	0.	0.	0.	0.
528 8	0.000	0.000	686.153	0.	0.	0.	0.	0.	0.	0.	0.
528 9	0.000	0.000	684.817	0.	0.	0.	0.	0.	0.	0.	0.
52810	0.000	0.000	692.130	0.	0.	0.	0.	0.	0.	0.	0.
52811	0.000	0.000	672.448	0.	0.	0.	0.	0.	0.	0.	0.
52812	0.000	0.000	676.308	0.	0.	0.	0.	0.	0.	0.	0.
52813	0.000	0.000	681.891	0.	0.	0.	0.	0.	0.	0.	0.
52814	0.000	0.000	695.506	0.	0.	0.	0.	0.	0.	0.	0.
52815	0.000	0.000	698.347	0.	0.	0.	0.	0.	0.	0.	0.
52816	0.000	0.000	692.167	0.	0.	0.	0.	0.	0.	0.	0.
52817	0.000	0.000	640.095	0.	0.	0.	0.	0.	0.	0.	0.
52818	0.000	0.000	504.406	0.	0.	0.	0.	0.	0.	0.	0.
52819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	698.347	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8618.583	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	359.108	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE149 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
529 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
529 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
529 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
529 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
529 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
529 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
529 7	0.000	0.000	555.899	0.	0.	0.	0.	0.	0.	0.	0.
529 8	0.000	0.000	670.946	0.	0.	0.	0.	0.	0.	0.	0.
529 9	0.000	0.000	709.112	0.	0.	0.	0.	0.	0.	0.	0.
52910	0.000	0.000	715.200	0.	0.	0.	0.	0.	0.	0.	0.
52911	0.000	0.000	664.486	0.	0.	0.	0.	0.	0.	0.	0.
52912	0.000	0.000	666.126	0.	0.	0.	0.	0.	0.	0.	0.
52913	0.000	0.000	696.938	0.	0.	0.	0.	0.	0.	0.	0.
52914	0.000	0.000	706.469	0.	0.	0.	0.	0.	0.	0.	0.
52915	0.000	0.000	731.467	0.	0.	0.	0.	0.	0.	0.	0.
52916	0.000	0.000	725.229	0.	0.	0.	0.	0.	0.	0.	0.
52917	0.000	0.000	668.296	0.	0.	0.	0.	0.	0.	0.	0.
52918	0.000	0.000	527.165	0.	0.	0.	0.	0.	0.	0.	0.
52919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
52920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
52921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
52922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
52923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
52924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	731.467	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8756.875	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	364.870	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE150 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
530 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
530 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
530 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
530 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
530 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
530 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
530 7	0.000	0.000	369.000	0.	0.	0.	0.	0.	0.	0.	0.
530 8	0.000	0.000	400.663	0.	0.	0.	0.	0.	0.	0.	0.
530 9	0.000	0.000	387.908	0.	0.	0.	0.	0.	0.	0.	0.
53010	0.000	0.000	381.526	0.	0.	0.	0.	0.	0.	0.	0.
53011	0.000	0.000	381.842	0.	0.	0.	0.	0.	0.	0.	0.
53012	0.000	0.000	404.201	0.	0.	0.	0.	0.	0.	0.	0.
53013	0.000	0.000	405.671	0.	0.	0.	0.	0.	0.	0.	0.
53014	0.000	0.000	394.667	0.	0.	0.	0.	0.	0.	0.	0.
53015	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
53016	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
53017	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
53018	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
53019	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
53020	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
53021	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
53022	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
53023	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
53024	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 30)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	405.671	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3768.754	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	157.031	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE151 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
531 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
531 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
531 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
531 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
531 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
531 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
531 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
531 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
531 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53116	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53117	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53118	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
53119	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
53120	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
53121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
53122	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
53123	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
53124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 31)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (MAY)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	731.467	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	2258.058	166160.969	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	223.335	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE152 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
6 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 1 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 1 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 1 7	0.000	0.000	474.946	0.	0.	0.	0.	0.	0.	0.	0.
6 1 8	0.000	0.000	490.591	0.	0.	0.	0.	0.	0.	0.	0.
6 1 9	0.000	0.000	494.663	0.	0.	0.	0.	0.	0.	0.	0.
6 110	0.000	0.000	610.697	0.	0.	0.	0.	0.	0.	0.	0.
6 111	0.000	0.000	542.224	0.	0.	0.	0.	0.	0.	0.	0.
6 112	0.000	0.000	555.640	0.	0.	0.	0.	0.	0.	0.	0.
6 113	0.000	0.000	619.249	0.	0.	0.	0.	0.	0.	0.	0.
6 114	0.000	0.000	616.505	0.	0.	0.	0.	0.	0.	0.	0.
6 115	0.000	0.000	603.811	0.	0.	0.	0.	0.	0.	0.	0.
6 116	0.000	0.000	577.084	0.	0.	0.	0.	0.	0.	0.	0.
6 117	0.000	0.000	501.960	0.	0.	0.	0.	0.	0.	0.	0.
6 118	0.000	0.000	331.959	0.	0.	0.	0.	0.	0.	0.	0.
6 119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	619.249	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7138.871	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	297.453	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE153 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 2 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 2 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 2 7	0.000	0.000	464.619	0.	0.	0.	0.	0.	0.	0.	0.
6 2 8	0.000	0.000	505.483	0.	0.	0.	0.	0.	0.	0.	0.
6 2 9	0.000	0.000	581.918	0.	0.	0.	0.	0.	0.	0.	0.
6 210	0.000	0.000	580.259	0.	0.	0.	0.	0.	0.	0.	0.
6 211	0.000	0.000	589.889	0.	0.	0.	0.	0.	0.	0.	0.
6 212	0.000	0.000	549.189	0.	0.	0.	0.	0.	0.	0.	0.
6 213	0.000	0.000	618.746	0.	0.	0.	0.	0.	0.	0.	0.
6 214	0.000	0.000	635.657	0.	0.	0.	0.	0.	0.	0.	0.
6 215	0.000	0.000	599.179	0.	0.	0.	0.	0.	0.	0.	0.
6 216	0.000	0.000	563.530	0.	0.	0.	0.	0.	0.	0.	0.
6 217	0.000	0.000	486.096	0.	0.	0.	0.	0.	0.	0.	0.
6 218	0.000	0.000	332.513	0.	0.	0.	0.	0.	0.	0.	0.
6 219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	635.657	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7226.620	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	301.109	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE154 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 3 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 3 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 3 7	0.000	0.000	463.478	0.	0.	0.	0.	0.	0.	0.	0.
6 3 8	0.000	0.000	557.720	0.	0.	0.	0.	0.	0.	0.	0.
6 3 9	0.000	0.000	616.820	0.	0.	0.	0.	0.	0.	0.	0.
6 310	0.000	0.000	614.629	0.	0.	0.	0.	0.	0.	0.	0.
6 311	0.000	0.000	607.218	0.	0.	0.	0.	0.	0.	0.	0.
6 312	0.000	0.000	609.710	0.	0.	0.	0.	0.	0.	0.	0.
6 313	0.000	0.000	628.852	0.	0.	0.	0.	0.	0.	0.	0.
6 314	0.000	0.000	623.041	0.	0.	0.	0.	0.	0.	0.	0.
6 315	0.000	0.000	644.423	0.	0.	0.	0.	0.	0.	0.	0.
6 316	0.000	0.000	634.840	0.	0.	0.	0.	0.	0.	0.	0.
6 317	0.000	0.000	531.907	0.	0.	0.	0.	0.	0.	0.	0.
6 318	0.000	0.000	333.542	0.	0.	0.	0.	0.	0.	0.	0.
6 319	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 320	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	644.423	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7585.720	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	316.072	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE155 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 4 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 4 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 4 7	0.000	0.000	463.577	0.	0.	0.	0.	0.	0.	0.	0.
6 4 8	0.000	0.000	470.035	0.	0.	0.	0.	0.	0.	0.	0.
6 4 9	0.000	0.000	475.474	0.	0.	0.	0.	0.	0.	0.	0.
6 410	0.000	0.000	472.391	0.	0.	0.	0.	0.	0.	0.	0.
6 411	0.000	0.000	462.540	0.	0.	0.	0.	0.	0.	0.	0.
6 412	0.000	0.000	530.270	0.	0.	0.	0.	0.	0.	0.	0.
6 413	0.000	0.000	628.798	0.	0.	0.	0.	0.	0.	0.	0.
6 414	0.000	0.000	641.566	0.	0.	0.	0.	0.	0.	0.	0.
6 415	0.000	0.000	636.751	0.	0.	0.	0.	0.	0.	0.	0.
6 416	0.000	0.000	592.717	0.	0.	0.	0.	0.	0.	0.	0.
6 417	0.000	0.000	440.876	0.	0.	0.	0.	0.	0.	0.	0.
6 418	0.000	0.000	321.331	0.	0.	0.	0.	0.	0.	0.	0.
6 419	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 420	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	641.566	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6855.869	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	285.661	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE156 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
6 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 5 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 5 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 5 7	0.000	0.000	462.971	0.	0.	0.	0.	0.	0.	0.	0.
6 5 8	0.000	0.000	467.706	0.	0.	0.	0.	0.	0.	0.	0.
6 5 9	0.000	0.000	473.822	0.	0.	0.	0.	0.	0.	0.	0.
6 510	0.000	0.000	470.622	0.	0.	0.	0.	0.	0.	0.	0.
6 511	0.000	0.000	446.468	0.	0.	0.	0.	0.	0.	0.	0.
6 512	0.000	0.000	445.924	0.	0.	0.	0.	0.	0.	0.	0.
6 513	0.000	0.000	481.085	0.	0.	0.	0.	0.	0.	0.	0.
6 514	0.000	0.000	568.099	0.	0.	0.	0.	0.	0.	0.	0.
6 515	0.000	0.000	626.382	0.	0.	0.	0.	0.	0.	0.	0.
6 516	0.000	0.000	625.096	0.	0.	0.	0.	0.	0.	0.	0.
6 517	0.000	0.000	441.732	0.	0.	0.	0.	0.	0.	0.	0.
6 518	0.000	0.000	333.024	0.	0.	0.	0.	0.	0.	0.	0.
6 519	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 520	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	626.382	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6562.472	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	273.436	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE157 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 6 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
6 6 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
6 6 7	0.000	0.000	250.588	0.	0.	0.	0.	0.	0.	0.	0.
6 6 8	0.000	0.000	196.165	0.	0.	0.	0.	0.	0.	0.	0.
6 6 9	0.000	0.000	204.071	0.	0.	0.	0.	0.	0.	0.	0.
6 610	0.000	0.000	223.783	0.	0.	0.	0.	0.	0.	0.	0.
6 611	0.000	0.000	254.371	0.	0.	0.	0.	0.	0.	0.	0.
6 612	0.000	0.000	254.329	0.	0.	0.	0.	0.	0.	0.	0.
6 613	0.000	0.000	329.418	0.	0.	0.	0.	0.	0.	0.	0.
6 614	0.000	0.000	329.090	0.	0.	0.	0.	0.	0.	0.	0.
6 615	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
6 616	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
6 617	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
6 618	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
6 619	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
6 620	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
6 621	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
6 622	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
6 623	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
6 624	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 6)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	329.418	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	2685.093	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	111.879	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE158 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 7 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
6 7 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
6 7 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
6 7 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
6 7 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
6 7 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
6 7 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 7 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 7 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 710	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 711	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 712	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 713	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 714	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 715	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 716	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 717	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 718	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
6 719	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
6 720	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
6 721	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
6 722	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
6 723	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
6 724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 7)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE159 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 8 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 8 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 8 7	0.000	0.000	465.064	0.	0.	0.	0.	0.	0.	0.	0.
6 8 8	0.000	0.000	467.024	0.	0.	0.	0.	0.	0.	0.	0.
6 8 9	0.000	0.000	488.043	0.	0.	0.	0.	0.	0.	0.	0.
6 810	0.000	0.000	521.079	0.	0.	0.	0.	0.	0.	0.	0.
6 811	0.000	0.000	496.109	0.	0.	0.	0.	0.	0.	0.	0.
6 812	0.000	0.000	566.045	0.	0.	0.	0.	0.	0.	0.	0.
6 813	0.000	0.000	519.664	0.	0.	0.	0.	0.	0.	0.	0.
6 814	0.000	0.000	594.863	0.	0.	0.	0.	0.	0.	0.	0.
6 815	0.000	0.000	565.651	0.	0.	0.	0.	0.	0.	0.	0.
6 816	0.000	0.000	554.580	0.	0.	0.	0.	0.	0.	0.	0.
6 817	0.000	0.000	512.280	0.	0.	0.	0.	0.	0.	0.	0.
6 818	0.000	0.000	329.857	0.	0.	0.	0.	0.	0.	0.	0.
6 819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	594.863	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	6799.801	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	283.325	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE160 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
6 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
6 9 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
6 9 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
6 9 7	0.000	0.000	463.840	0.	0.	0.	0.	0.	0.	0.	0.
6 9 8	0.000	0.000	504.523	0.	0.	0.	0.	0.	0.	0.	0.
6 9 9	0.000	0.000	561.039	0.	0.	0.	0.	0.	0.	0.	0.
6 910	0.000	0.000	580.297	0.	0.	0.	0.	0.	0.	0.	0.
6 911	0.000	0.000	591.770	0.	0.	0.	0.	0.	0.	0.	0.
6 912	0.000	0.000	601.796	0.	0.	0.	0.	0.	0.	0.	0.
6 913	0.000	0.000	637.777	0.	0.	0.	0.	0.	0.	0.	0.
6 914	0.000	0.000	644.935	0.	0.	0.	0.	0.	0.	0.	0.
6 915	0.000	0.000	638.210	0.	0.	0.	0.	0.	0.	0.	0.
6 916	0.000	0.000	624.963	0.	0.	0.	0.	0.	0.	0.	0.
6 917	0.000	0.000	541.784	0.	0.	0.	0.	0.	0.	0.	0.
6 918	0.000	0.000	356.530	0.	0.	0.	0.	0.	0.	0.	0.
6 919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
6 920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
6 921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
6 922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
6 923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
6 924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	644.935	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7467.008	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	311.125	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE161 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
610 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
610 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
610 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
610 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
610 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
610 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
610 7	0.000	0.000	463.571	0.	0.	0.	0.	0.	0.	0.	0.
610 8	0.000	0.000	467.947	0.	0.	0.	0.	0.	0.	0.	0.
610 9	0.000	0.000	518.607	0.	0.	0.	0.	0.	0.	0.	0.
61010	0.000	0.000	562.378	0.	0.	0.	0.	0.	0.	0.	0.
61011	0.000	0.000	584.919	0.	0.	0.	0.	0.	0.	0.	0.
61012	0.000	0.000	613.693	0.	0.	0.	0.	0.	0.	0.	0.
61013	0.000	0.000	645.048	0.	0.	0.	0.	0.	0.	0.	0.
61014	0.000	0.000	635.957	0.	0.	0.	0.	0.	0.	0.	0.
61015	0.000	0.000	643.860	0.	0.	0.	0.	0.	0.	0.	0.
61016	0.000	0.000	638.313	0.	0.	0.	0.	0.	0.	0.	0.
61017	0.000	0.000	593.105	0.	0.	0.	0.	0.	0.	0.	0.
61018	0.000	0.000	365.175	0.	0.	0.	0.	0.	0.	0.	0.
61019	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61020	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	645.048	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7452.116	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	310.505	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE162 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
611 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
611 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
611 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
611 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
611 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
611 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
611 7	0.000	0.000	463.983	0.	0.	0.	0.	0.	0.	0.	0.
611 8	0.000	0.000	481.121	0.	0.	0.	0.	0.	0.	0.	0.
611 9	0.000	0.000	555.521	0.	0.	0.	0.	0.	0.	0.	0.
61110	0.000	0.000	577.153	0.	0.	0.	0.	0.	0.	0.	0.
61111	0.000	0.000	603.261	0.	0.	0.	0.	0.	0.	0.	0.
61112	0.000	0.000	619.225	0.	0.	0.	0.	0.	0.	0.	0.
61113	0.000	0.000	639.370	0.	0.	0.	0.	0.	0.	0.	0.
61114	0.000	0.000	651.683	0.	0.	0.	0.	0.	0.	0.	0.
61115	0.000	0.000	644.100	0.	0.	0.	0.	0.	0.	0.	0.
61116	0.000	0.000	601.576	0.	0.	0.	0.	0.	0.	0.	0.
61117	0.000	0.000	522.389	0.	0.	0.	0.	0.	0.	0.	0.
61118	0.000	0.000	332.675	0.	0.	0.	0.	0.	0.	0.	0.
61119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	651.683	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7411.598	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	308.817	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE163 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
612 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
612 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
612 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
612 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
612 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
612 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
612 7	0.000	0.000	464.108	0.	0.	0.	0.	0.	0.	0.	0.
612 8	0.000	0.000	519.351	0.	0.	0.	0.	0.	0.	0.	0.
612 9	0.000	0.000	554.016	0.	0.	0.	0.	0.	0.	0.	0.
61210	0.000	0.000	551.351	0.	0.	0.	0.	0.	0.	0.	0.
61211	0.000	0.000	551.486	0.	0.	0.	0.	0.	0.	0.	0.
61212	0.000	0.000	616.250	0.	0.	0.	0.	0.	0.	0.	0.
61213	0.000	0.000	639.045	0.	0.	0.	0.	0.	0.	0.	0.
61214	0.000	0.000	651.596	0.	0.	0.	0.	0.	0.	0.	0.
61215	0.000	0.000	656.599	0.	0.	0.	0.	0.	0.	0.	0.
61216	0.000	0.000	645.311	0.	0.	0.	0.	0.	0.	0.	0.
61217	0.000	0.000	565.172	0.	0.	0.	0.	0.	0.	0.	0.
61218	0.000	0.000	329.900	0.	0.	0.	0.	0.	0.	0.	0.
61219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	656.599	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7463.728	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	310.989	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE164 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
613 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
613 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
613 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
613 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
613 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
613 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
613 7	0.000	0.000	251.845	0.	0.	0.	0.	0.	0.	0.	0.
613 8	0.000	0.000	255.805	0.	0.	0.	0.	0.	0.	0.	0.
613 9	0.000	0.000	283.738	0.	0.	0.	0.	0.	0.	0.	0.
61310	0.000	0.000	301.465	0.	0.	0.	0.	0.	0.	0.	0.
61311	0.000	0.000	317.525	0.	0.	0.	0.	0.	0.	0.	0.
61312	0.000	0.000	345.857	0.	0.	0.	0.	0.	0.	0.	0.
61313	0.000	0.000	345.501	0.	0.	0.	0.	0.	0.	0.	0.
61314	0.000	0.000	316.330	0.	0.	0.	0.	0.	0.	0.	0.
61315	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
61316	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
61317	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
61318	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
61319	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
61320	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
61321	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
61322	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
61323	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
61324	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 13)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	345.857	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3061.343	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	127.556	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE165 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
614 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
614 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
614 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
614 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
614 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
614 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
614 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
614 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
614 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61410	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61411	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61412	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61413	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61414	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61415	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61416	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61417	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61418	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
61419	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
61420	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
61421	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
61422	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
61423	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
61424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 14)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE166 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
615 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
615 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
615 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
615 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
615 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
615 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
615 7	0.000	0.000	466.499	0.	0.	0.	0.	0.	0.	0.	0.
615 8	0.000	0.000	622.987	0.	0.	0.	0.	0.	0.	0.	0.
615 9	0.000	0.000	642.332	0.	0.	0.	0.	0.	0.	0.	0.
61510	0.000	0.000	636.093	0.	0.	0.	0.	0.	0.	0.	0.
61511	0.000	0.000	626.671	0.	0.	0.	0.	0.	0.	0.	0.
61512	0.000	0.000	625.031	0.	0.	0.	0.	0.	0.	0.	0.
61513	0.000	0.000	648.752	0.	0.	0.	0.	0.	0.	0.	0.
61514	0.000	0.000	662.572	0.	0.	0.	0.	0.	0.	0.	0.
61515	0.000	0.000	667.492	0.	0.	0.	0.	0.	0.	0.	0.
61516	0.000	0.000	661.331	0.	0.	0.	0.	0.	0.	0.	0.
61517	0.000	0.000	620.697	0.	0.	0.	0.	0.	0.	0.	0.
61518	0.000	0.000	489.301	0.	0.	0.	0.	0.	0.	0.	0.
61519	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61520	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	667.492	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8089.299	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	337.054	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE167 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
616 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
616 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
616 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
616 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
616 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
616 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
616 7	0.000	0.000	468.372	0.	0.	0.	0.	0.	0.	0.	0.
616 8	0.000	0.000	530.819	0.	0.	0.	0.	0.	0.	0.	0.
616 9	0.000	0.000	616.663	0.	0.	0.	0.	0.	0.	0.	0.
61610	0.000	0.000	679.555	0.	0.	0.	0.	0.	0.	0.	0.
61611	0.000	0.000	650.846	0.	0.	0.	0.	0.	0.	0.	0.
61612	0.000	0.000	651.669	0.	0.	0.	0.	0.	0.	0.	0.
61613	0.000	0.000	678.111	0.	0.	0.	0.	0.	0.	0.	0.
61614	0.000	0.000	688.067	0.	0.	0.	0.	0.	0.	0.	0.
61615	0.000	0.000	681.247	0.	0.	0.	0.	0.	0.	0.	0.
61616	0.000	0.000	676.016	0.	0.	0.	0.	0.	0.	0.	0.
61617	0.000	0.000	624.859	0.	0.	0.	0.	0.	0.	0.	0.
61618	0.000	0.000	487.391	0.	0.	0.	0.	0.	0.	0.	0.
61619	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61620	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	688.067	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8153.157	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	339.715	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE168 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
617 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
617 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
617 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
617 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
617 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
617 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
617 7	0.000	0.000	508.417	0.	0.	0.	0.	0.	0.	0.	0.
617 8	0.000	0.000	624.886	0.	0.	0.	0.	0.	0.	0.	0.
617 9	0.000	0.000	669.877	0.	0.	0.	0.	0.	0.	0.	0.
61710	0.000	0.000	682.447	0.	0.	0.	0.	0.	0.	0.	0.
61711	0.000	0.000	655.558	0.	0.	0.	0.	0.	0.	0.	0.
61712	0.000	0.000	657.352	0.	0.	0.	0.	0.	0.	0.	0.
61713	0.000	0.000	677.946	0.	0.	0.	0.	0.	0.	0.	0.
61714	0.000	0.000	698.320	0.	0.	0.	0.	0.	0.	0.	0.
61715	0.000	0.000	699.404	0.	0.	0.	0.	0.	0.	0.	0.
61716	0.000	0.000	673.816	0.	0.	0.	0.	0.	0.	0.	0.
61717	0.000	0.000	607.123	0.	0.	0.	0.	0.	0.	0.	0.
61718	0.000	0.000	418.577	0.	0.	0.	0.	0.	0.	0.	0.
61719	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61720	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	699.404	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8293.265	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	345.553	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE169 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
618 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
618 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
618 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
618 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
618 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
618 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
618 7	0.000	0.000	468.993	0.	0.	0.	0.	0.	0.	0.	0.
618 8	0.000	0.000	574.642	0.	0.	0.	0.	0.	0.	0.	0.
618 9	0.000	0.000	642.854	0.	0.	0.	0.	0.	0.	0.	0.
61810	0.000	0.000	662.461	0.	0.	0.	0.	0.	0.	0.	0.
61811	0.000	0.000	639.944	0.	0.	0.	0.	0.	0.	0.	0.
61812	0.000	0.000	638.120	0.	0.	0.	0.	0.	0.	0.	0.
61813	0.000	0.000	652.032	0.	0.	0.	0.	0.	0.	0.	0.
61814	0.000	0.000	659.585	0.	0.	0.	0.	0.	0.	0.	0.
61815	0.000	0.000	647.686	0.	0.	0.	0.	0.	0.	0.	0.
61816	0.000	0.000	575.638	0.	0.	0.	0.	0.	0.	0.	0.
61817	0.000	0.000	493.420	0.	0.	0.	0.	0.	0.	0.	0.
61818	0.000	0.000	371.021	0.	0.	0.	0.	0.	0.	0.	0.
61819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	662.461	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7745.938	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	322.747	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE170 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
619 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
619 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
619 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
619 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
619 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
619 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
619 7	0.000	0.000	470.337	0.	0.	0.	0.	0.	0.	0.	0.
619 8	0.000	0.000	606.431	0.	0.	0.	0.	0.	0.	0.	0.
619 9	0.000	0.000	660.040	0.	0.	0.	0.	0.	0.	0.	0.
61910	0.000	0.000	674.851	0.	0.	0.	0.	0.	0.	0.	0.
61911	0.000	0.000	627.833	0.	0.	0.	0.	0.	0.	0.	0.
61912	0.000	0.000	636.142	0.	0.	0.	0.	0.	0.	0.	0.
61913	0.000	0.000	666.109	0.	0.	0.	0.	0.	0.	0.	0.
61914	0.000	0.000	663.613	0.	0.	0.	0.	0.	0.	0.	0.
61915	0.000	0.000	667.180	0.	0.	0.	0.	0.	0.	0.	0.
61916	0.000	0.000	649.571	0.	0.	0.	0.	0.	0.	0.	0.
61917	0.000	0.000	608.998	0.	0.	0.	0.	0.	0.	0.	0.
61918	0.000	0.000	453.460	0.	0.	0.	0.	0.	0.	0.	0.
61919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
61920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
61921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
61922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
61923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
61924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	674.851	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8104.109	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	337.671	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE171 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
620 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
620 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
620 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
620 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
620 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
620 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
620 7	0.000	0.000	253.397	0.	0.	0.	0.	0.	0.	0.	0.
620 8	0.000	0.000	209.033	0.	0.	0.	0.	0.	0.	0.	0.
620 9	0.000	0.000	283.222	0.	0.	0.	0.	0.	0.	0.	0.
62010	0.000	0.000	330.406	0.	0.	0.	0.	0.	0.	0.	0.
62011	0.000	0.000	369.699	0.	0.	0.	0.	0.	0.	0.	0.
62012	0.000	0.000	370.100	0.	0.	0.	0.	0.	0.	0.	0.
62013	0.000	0.000	369.983	0.	0.	0.	0.	0.	0.	0.	0.
62014	0.000	0.000	361.105	0.	0.	0.	0.	0.	0.	0.	0.
62015	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62016	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62017	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62018	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62019	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
62020	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
62021	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
62022	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
62023	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
62024	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 20)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	370.100	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3190.221	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	132.926	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE172 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
621 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
621 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
621 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
621 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
621 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
621 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
621 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
621 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
621 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62116	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62117	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62118	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62119	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
62120	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
62121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
62122	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
62123	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
62124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 21)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE173 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
622 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
622 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
622 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
622 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
622 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
622 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
622 7	0.000	0.000	539.621	0.	0.	0.	0.	0.	0.	0.	0.
622 8	0.000	0.000	642.567	0.	0.	0.	0.	0.	0.	0.	0.
622 9	0.000	0.000	644.320	0.	0.	0.	0.	0.	0.	0.	0.
62210	0.000	0.000	669.294	0.	0.	0.	0.	0.	0.	0.	0.
62211	0.000	0.000	644.977	0.	0.	0.	0.	0.	0.	0.	0.
62212	0.000	0.000	647.087	0.	0.	0.	0.	0.	0.	0.	0.
62213	0.000	0.000	672.915	0.	0.	0.	0.	0.	0.	0.	0.
62214	0.000	0.000	688.109	0.	0.	0.	0.	0.	0.	0.	0.
62215	0.000	0.000	689.142	0.	0.	0.	0.	0.	0.	0.	0.
62216	0.000	0.000	664.990	0.	0.	0.	0.	0.	0.	0.	0.
62217	0.000	0.000	622.570	0.	0.	0.	0.	0.	0.	0.	0.
62218	0.000	0.000	485.749	0.	0.	0.	0.	0.	0.	0.	0.
62219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
62220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
62221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
62222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
62223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
62224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	689.142	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8330.884	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	347.120	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE174 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
623 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
623 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
623 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
623 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
623 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
623 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
623 7	0.000	0.000	516.271	0.	0.	0.	0.	0.	0.	0.	0.
623 8	0.000	0.000	589.659	0.	0.	0.	0.	0.	0.	0.	0.
623 9	0.000	0.000	631.161	0.	0.	0.	0.	0.	0.	0.	0.
62310	0.000	0.000	695.675	0.	0.	0.	0.	0.	0.	0.	0.
62311	0.000	0.000	690.345	0.	0.	0.	0.	0.	0.	0.	0.
62312	0.000	0.000	653.928	0.	0.	0.	0.	0.	0.	0.	0.
62313	0.000	0.000	684.501	0.	0.	0.	0.	0.	0.	0.	0.
62314	0.000	0.000	700.572	0.	0.	0.	0.	0.	0.	0.	0.
62315	0.000	0.000	717.535	0.	0.	0.	0.	0.	0.	0.	0.
62316	0.000	0.000	712.643	0.	0.	0.	0.	0.	0.	0.	0.
62317	0.000	0.000	652.428	0.	0.	0.	0.	0.	0.	0.	0.
62318	0.000	0.000	498.015	0.	0.	0.	0.	0.	0.	0.	0.
62319	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
62320	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
62321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
62322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
62323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
62324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	717.535	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8462.274	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	352.595	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE175 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
624 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
624 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
624 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
624 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
624 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
624 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
624 7	0.000	0.000	477.139	0.	0.	0.	0.	0.	0.	0.	0.
624 8	0.000	0.000	593.930	0.	0.	0.	0.	0.	0.	0.	0.
624 9	0.000	0.000	662.474	0.	0.	0.	0.	0.	0.	0.	0.
62410	0.000	0.000	661.632	0.	0.	0.	0.	0.	0.	0.	0.
62411	0.000	0.000	648.746	0.	0.	0.	0.	0.	0.	0.	0.
62412	0.000	0.000	651.571	0.	0.	0.	0.	0.	0.	0.	0.
62413	0.000	0.000	676.364	0.	0.	0.	0.	0.	0.	0.	0.
62414	0.000	0.000	692.156	0.	0.	0.	0.	0.	0.	0.	0.
62415	0.000	0.000	697.540	0.	0.	0.	0.	0.	0.	0.	0.
62416	0.000	0.000	690.399	0.	0.	0.	0.	0.	0.	0.	0.
62417	0.000	0.000	630.849	0.	0.	0.	0.	0.	0.	0.	0.
62418	0.000	0.000	496.174	0.	0.	0.	0.	0.	0.	0.	0.
62419	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
62420	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
62421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
62422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
62423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
62424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	697.540	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8298.518	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	345.772	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE176 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
625 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
625 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
625 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
625 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
625 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
625 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
625 7	0.000	0.000	473.849	0.	0.	0.	0.	0.	0.	0.	0.
625 8	0.000	0.000	577.552	0.	0.	0.	0.	0.	0.	0.	0.
625 9	0.000	0.000	644.755	0.	0.	0.	0.	0.	0.	0.	0.
62510	0.000	0.000	661.440	0.	0.	0.	0.	0.	0.	0.	0.
62511	0.000	0.000	639.980	0.	0.	0.	0.	0.	0.	0.	0.
62512	0.000	0.000	649.150	0.	0.	0.	0.	0.	0.	0.	0.
62513	0.000	0.000	675.591	0.	0.	0.	0.	0.	0.	0.	0.
62514	0.000	0.000	694.637	0.	0.	0.	0.	0.	0.	0.	0.
62515	0.000	0.000	687.849	0.	0.	0.	0.	0.	0.	0.	0.
62516	0.000	0.000	674.288	0.	0.	0.	0.	0.	0.	0.	0.
62517	0.000	0.000	608.351	0.	0.	0.	0.	0.	0.	0.	0.
62518	0.000	0.000	412.227	0.	0.	0.	0.	0.	0.	0.	0.
62519	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
62520	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
62521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
62522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
62523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
62524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 25)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	694.637	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8119.210	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	338.300	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE177 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
626 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
626 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
626 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
626 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
626 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
626 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
626 7	0.000	0.000	466.837	0.	0.	0.	0.	0.	0.	0.	0.
626 8	0.000	0.000	564.915	0.	0.	0.	0.	0.	0.	0.	0.
626 9	0.000	0.000	637.527	0.	0.	0.	0.	0.	0.	0.	0.
62610	0.000	0.000	653.982	0.	0.	0.	0.	0.	0.	0.	0.
62611	0.000	0.000	639.645	0.	0.	0.	0.	0.	0.	0.	0.
62612	0.000	0.000	646.182	0.	0.	0.	0.	0.	0.	0.	0.
62613	0.000	0.000	676.345	0.	0.	0.	0.	0.	0.	0.	0.
62614	0.000	0.000	677.935	0.	0.	0.	0.	0.	0.	0.	0.
62615	0.000	0.000	666.448	0.	0.	0.	0.	0.	0.	0.	0.
62616	0.000	0.000	660.755	0.	0.	0.	0.	0.	0.	0.	0.
62617	0.000	0.000	613.780	0.	0.	0.	0.	0.	0.	0.	0.
62618	0.000	0.000	364.541	0.	0.	0.	0.	0.	0.	0.	0.
62619	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
62620	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
62621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
62622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
62623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
62624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	677.935	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7988.434	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	332.851	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE178 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
627 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
627 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
627 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
627 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
627 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
627 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
627 7	0.000	0.000	261.360	0.	0.	0.	0.	0.	0.	0.	0.
627 8	0.000	0.000	330.041	0.	0.	0.	0.	0.	0.	0.	0.
627 9	0.000	0.000	359.996	0.	0.	0.	0.	0.	0.	0.	0.
62710	0.000	0.000	344.668	0.	0.	0.	0.	0.	0.	0.	0.
62711	0.000	0.000	360.204	0.	0.	0.	0.	0.	0.	0.	0.
62712	0.000	0.000	360.459	0.	0.	0.	0.	0.	0.	0.	0.
62713	0.000	0.000	364.124	0.	0.	0.	0.	0.	0.	0.	0.
62714	0.000	0.000	360.300	0.	0.	0.	0.	0.	0.	0.	0.
62715	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62716	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62717	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62718	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
62719	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
62720	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
62721	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
62722	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
62723	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
62724	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 27)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	364.124	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3384.429	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	141.018	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE179 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
628 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
628 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
628 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
628 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
628 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
628 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
628 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
628 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
628 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62810	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62811	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62812	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62813	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62814	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62815	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62816	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62817	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62818	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
62819	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
62820	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
62821	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
62822	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
62823	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
62824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 28)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE180 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
629 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
629 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
629 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
629 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
629 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
629 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
629 7	0.000	0.000	582.887	0.	0.	0.	0.	0.	0.	0.	0.
629 8	0.000	0.000	705.952	0.	0.	0.	0.	0.	0.	0.	0.
629 9	0.000	0.000	716.475	0.	0.	0.	0.	0.	0.	0.	0.
62910	0.000	0.000	702.715	0.	0.	0.	0.	0.	0.	0.	0.
62911	0.000	0.000	669.590	0.	0.	0.	0.	0.	0.	0.	0.
62912	0.000	0.000	657.471	0.	0.	0.	0.	0.	0.	0.	0.
62913	0.000	0.000	692.732	0.	0.	0.	0.	0.	0.	0.	0.
62914	0.000	0.000	707.692	0.	0.	0.	0.	0.	0.	0.	0.
62915	0.000	0.000	713.230	0.	0.	0.	0.	0.	0.	0.	0.
62916	0.000	0.000	696.306	0.	0.	0.	0.	0.	0.	0.	0.
62917	0.000	0.000	649.520	0.	0.	0.	0.	0.	0.	0.	0.
62918	0.000	0.000	511.875	0.	0.	0.	0.	0.	0.	0.	0.
62919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
62920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
62921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
62922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
62923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
62924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	716.475	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8725.988	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	363.583	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE181 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
630 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
630 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
630 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
630 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
630 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
630 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
630 7	0.000	0.000	570.874	0.	0.	0.	0.	0.	0.	0.	0.
630 8	0.000	0.000	683.227	0.	0.	0.	0.	0.	0.	0.	0.
630 9	0.000	0.000	694.404	0.	0.	0.	0.	0.	0.	0.	0.
63010	0.000	0.000	681.400	0.	0.	0.	0.	0.	0.	0.	0.
63011	0.000	0.000	655.164	0.	0.	0.	0.	0.	0.	0.	0.
63012	0.000	0.000	655.080	0.	0.	0.	0.	0.	0.	0.	0.
63013	0.000	0.000	681.063	0.	0.	0.	0.	0.	0.	0.	0.
63014	0.000	0.000	718.495	0.	0.	0.	0.	0.	0.	0.	0.
63015	0.000	0.000	697.226	0.	0.	0.	0.	0.	0.	0.	0.
63016	0.000	0.000	707.669	0.	0.	0.	0.	0.	0.	0.	0.
63017	0.000	0.000	661.859	0.	0.	0.	0.	0.	0.	0.	0.
63018	0.000	0.000	525.126	0.	0.	0.	0.	0.	0.	0.	0.
63019	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
63020	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
63021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
63022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
63023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
63024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	718.495	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8651.132	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	360.464	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (JUN)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	718.495	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	2185.218	184716.594	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	256.551	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE182 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
7 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 1 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
7 1 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
7 1 7	0.000	0.000	474.845	0.	0.	0.	0.	0.	0.	0.	0.
7 1 8	0.000	0.000	497.493	0.	0.	0.	0.	0.	0.	0.	0.
7 1 9	0.000	0.000	585.031	0.	0.	0.	0.	0.	0.	0.	0.
7 110	0.000	0.000	639.547	0.	0.	0.	0.	0.	0.	0.	0.
7 111	0.000	0.000	616.332	0.	0.	0.	0.	0.	0.	0.	0.
7 112	0.000	0.000	614.911	0.	0.	0.	0.	0.	0.	0.	0.
7 113	0.000	0.000	636.263	0.	0.	0.	0.	0.	0.	0.	0.
7 114	0.000	0.000	656.020	0.	0.	0.	0.	0.	0.	0.	0.
7 115	0.000	0.000	659.129	0.	0.	0.	0.	0.	0.	0.	0.
7 116	0.000	0.000	652.238	0.	0.	0.	0.	0.	0.	0.	0.
7 117	0.000	0.000	580.008	0.	0.	0.	0.	0.	0.	0.	0.
7 118	0.000	0.000	367.424	0.	0.	0.	0.	0.	0.	0.	0.
7 119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
7 120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
7 121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
7 122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
7 123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
7 124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	659.129	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7698.782	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	320.783	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE183 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
7 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 2 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
7 2 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
7 2 7	0.000	0.000	464.923	0.	0.	0.	0.	0.	0.	0.	0.
7 2 8	0.000	0.000	486.328	0.	0.	0.	0.	0.	0.	0.	0.
7 2 9	0.000	0.000	562.375	0.	0.	0.	0.	0.	0.	0.	0.
7 210	0.000	0.000	618.150	0.	0.	0.	0.	0.	0.	0.	0.
7 211	0.000	0.000	608.981	0.	0.	0.	0.	0.	0.	0.	0.
7 212	0.000	0.000	609.210	0.	0.	0.	0.	0.	0.	0.	0.
7 213	0.000	0.000	638.133	0.	0.	0.	0.	0.	0.	0.	0.
7 214	0.000	0.000	651.961	0.	0.	0.	0.	0.	0.	0.	0.
7 215	0.000	0.000	660.988	0.	0.	0.	0.	0.	0.	0.	0.
7 216	0.000	0.000	655.162	0.	0.	0.	0.	0.	0.	0.	0.
7 217	0.000	0.000	608.496	0.	0.	0.	0.	0.	0.	0.	0.
7 218	0.000	0.000	484.212	0.	0.	0.	0.	0.	0.	0.	0.
7 219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
7 220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
7 221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
7 222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
7 223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
7 224	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 2)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	660.988	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7742.363	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	322.598	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE184 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
7 3 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 3 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 3 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 3 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 3 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
7 3 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
7 3 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 3 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 3 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 310	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 311	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 312	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 313	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 314	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 315	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 316	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 317	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 318	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 319	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
7 320	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
7 321	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
7 322	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
7 323	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
7 324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 3)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE185 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
7 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 4 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
7 4 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
7 4 7	0.000	0.000	254.427	0.	0.	0.	0.	0.	0.	0.	0.
7 4 8	0.000	0.000	211.158	0.	0.	0.	0.	0.	0.	0.	0.
7 4 9	0.000	0.000	289.091	0.	0.	0.	0.	0.	0.	0.	0.
7 410	0.000	0.000	287.580	0.	0.	0.	0.	0.	0.	0.	0.
7 411	0.000	0.000	289.653	0.	0.	0.	0.	0.	0.	0.	0.
7 412	0.000	0.000	319.122	0.	0.	0.	0.	0.	0.	0.	0.
7 413	0.000	0.000	316.973	0.	0.	0.	0.	0.	0.	0.	0.
7 414	0.000	0.000	336.081	0.	0.	0.	0.	0.	0.	0.	0.
7 415	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
7 416	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
7 417	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
7 418	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
7 419	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
7 420	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
7 421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
7 422	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
7 423	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
7 424	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 4)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	336.081	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	2947.361	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	122.807	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE186 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
7 5 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 5 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 5 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 5 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
7 5 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
7 5 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
7 5 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 5 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 5 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 517	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 518	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
7 519	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
7 520	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
7 521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
7 522	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
7 523	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
7 524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 5)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE187 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
7 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 6 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
7 6 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
7 6 7	0.000	0.000	472.541	0.	0.	0.	0.	0.	0.	0.	0.
7 6 8	0.000	0.000	537.739	0.	0.	0.	0.	0.	0.	0.	0.
7 6 9	0.000	0.000	540.015	0.	0.	0.	0.	0.	0.	0.	0.
7 610	0.000	0.000	586.946	0.	0.	0.	0.	0.	0.	0.	0.
7 611	0.000	0.000	612.439	0.	0.	0.	0.	0.	0.	0.	0.
7 612	0.000	0.000	614.601	0.	0.	0.	0.	0.	0.	0.	0.
7 613	0.000	0.000	657.364	0.	0.	0.	0.	0.	0.	0.	0.
7 614	0.000	0.000	670.820	0.	0.	0.	0.	0.	0.	0.	0.
7 615	0.000	0.000	663.400	0.	0.	0.	0.	0.	0.	0.	0.
7 616	0.000	0.000	657.911	0.	0.	0.	0.	0.	0.	0.	0.
7 617	0.000	0.000	610.938	0.	0.	0.	0.	0.	0.	0.	0.
7 618	0.000	0.000	482.604	0.	0.	0.	0.	0.	0.	0.	0.
7 619	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
7 620	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
7 621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
7 622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
7 623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
7 624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	670.820	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	7826.858	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	326.119	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE188 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
7 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 7 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
7 7 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
7 7 7	0.000	0.000	513.950	0.	0.	0.	0.	0.	0.	0.	0.
7 7 8	0.000	0.000	624.432	0.	0.	0.	0.	0.	0.	0.	0.
7 7 9	0.000	0.000	657.538	0.	0.	0.	0.	0.	0.	0.	0.
7 710	0.000	0.000	656.686	0.	0.	0.	0.	0.	0.	0.	0.
7 711	0.000	0.000	631.956	0.	0.	0.	0.	0.	0.	0.	0.
7 712	0.000	0.000	650.405	0.	0.	0.	0.	0.	0.	0.	0.
7 713	0.000	0.000	700.101	0.	0.	0.	0.	0.	0.	0.	0.
7 714	0.000	0.000	716.698	0.	0.	0.	0.	0.	0.	0.	0.
7 715	0.000	0.000	706.289	0.	0.	0.	0.	0.	0.	0.	0.
7 716	0.000	0.000	683.994	0.	0.	0.	0.	0.	0.	0.	0.
7 717	0.000	0.000	642.325	0.	0.	0.	0.	0.	0.	0.	0.
7 718	0.000	0.000	498.459	0.	0.	0.	0.	0.	0.	0.	0.
7 719	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
7 720	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
7 721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
7 722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
7 723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
7 724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 7)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	716.698	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8402.374	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	350.099	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE189 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
7 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 8 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
7 8 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
7 8 7	0.000	0.000	576.265	0.	0.	0.	0.	0.	0.	0.	0.
7 8 8	0.000	0.000	647.441	0.	0.	0.	0.	0.	0.	0.	0.
7 8 9	0.000	0.000	672.737	0.	0.	0.	0.	0.	0.	0.	0.
7 810	0.000	0.000	677.552	0.	0.	0.	0.	0.	0.	0.	0.
7 811	0.000	0.000	651.342	0.	0.	0.	0.	0.	0.	0.	0.
7 812	0.000	0.000	658.851	0.	0.	0.	0.	0.	0.	0.	0.
7 813	0.000	0.000	682.920	0.	0.	0.	0.	0.	0.	0.	0.
7 814	0.000	0.000	716.427	0.	0.	0.	0.	0.	0.	0.	0.
7 815	0.000	0.000	713.631	0.	0.	0.	0.	0.	0.	0.	0.
7 816	0.000	0.000	705.993	0.	0.	0.	0.	0.	0.	0.	0.
7 817	0.000	0.000	652.025	0.	0.	0.	0.	0.	0.	0.	0.
7 818	0.000	0.000	513.378	0.	0.	0.	0.	0.	0.	0.	0.
7 819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
7 820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
7 821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
7 822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
7 823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
7 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	716.427	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8588.105	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	357.838	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE190 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
7 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
7 9 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
7 9 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
7 9 7	0.000	0.000	591.091	0.	0.	0.	0.	0.	0.	0.	0.
7 9 8	0.000	0.000	713.953	0.	0.	0.	0.	0.	0.	0.	0.
7 9 9	0.000	0.000	705.156	0.	0.	0.	0.	0.	0.	0.	0.
7 910	0.000	0.000	719.031	0.	0.	0.	0.	0.	0.	0.	0.
7 911	0.000	0.000	689.709	0.	0.	0.	0.	0.	0.	0.	0.
7 912	0.000	0.000	684.383	0.	0.	0.	0.	0.	0.	0.	0.
7 913	0.000	0.000	709.788	0.	0.	0.	0.	0.	0.	0.	0.
7 914	0.000	0.000	697.436	0.	0.	0.	0.	0.	0.	0.	0.
7 915	0.000	0.000	701.179	0.	0.	0.	0.	0.	0.	0.	0.
7 916	0.000	0.000	710.054	0.	0.	0.	0.	0.	0.	0.	0.
7 917	0.000	0.000	658.194	0.	0.	0.	0.	0.	0.	0.	0.
7 918	0.000	0.000	520.783	0.	0.	0.	0.	0.	0.	0.	0.
7 919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
7 920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
7 921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
7 922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
7 923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
7 924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	719.031	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8820.300	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	367.512	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE191 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
710 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
710 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
710 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
710 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
710 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
710 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
710 7	0.000	0.000	584.018	0.	0.	0.	0.	0.	0.	0.	0.
710 8	0.000	0.000	678.188	0.	0.	0.	0.	0.	0.	0.	0.
710 9	0.000	0.000	704.787	0.	0.	0.	0.	0.	0.	0.	0.
71010	0.000	0.000	707.481	0.	0.	0.	0.	0.	0.	0.	0.
71011	0.000	0.000	667.930	0.	0.	0.	0.	0.	0.	0.	0.
71012	0.000	0.000	659.808	0.	0.	0.	0.	0.	0.	0.	0.
71013	0.000	0.000	684.951	0.	0.	0.	0.	0.	0.	0.	0.
71014	0.000	0.000	699.459	0.	0.	0.	0.	0.	0.	0.	0.
71015	0.000	0.000	700.127	0.	0.	0.	0.	0.	0.	0.	0.
71016	0.000	0.000	694.298	0.	0.	0.	0.	0.	0.	0.	0.
71017	0.000	0.000	656.532	0.	0.	0.	0.	0.	0.	0.	0.
71018	0.000	0.000	523.311	0.	0.	0.	0.	0.	0.	0.	0.
71019	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
71020	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
71021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
71022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
71023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
71024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	707.481	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8680.434	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	361.685	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE192 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
711 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
711 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
711 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
711 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
711 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
711 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
711 7	0.000	0.000	365.322	0.	0.	0.	0.	0.	0.	0.	0.
711 8	0.000	0.000	406.902	0.	0.	0.	0.	0.	0.	0.	0.
711 9	0.000	0.000	387.330	0.	0.	0.	0.	0.	0.	0.	0.
71110	0.000	0.000	381.419	0.	0.	0.	0.	0.	0.	0.	0.
71111	0.000	0.000	380.573	0.	0.	0.	0.	0.	0.	0.	0.
71112	0.000	0.000	377.872	0.	0.	0.	0.	0.	0.	0.	0.
71113	0.000	0.000	377.562	0.	0.	0.	0.	0.	0.	0.	0.
71114	0.000	0.000	391.771	0.	0.	0.	0.	0.	0.	0.	0.
71115	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71116	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71117	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71118	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71119	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
71120	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
71121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
71122	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
71123	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
71124	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 11)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	406.902	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3712.028	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	154.668	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE193 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
712 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
712 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
712 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
712 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
712 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
712 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
712 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
712 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
712 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71216	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71217	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71218	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71219	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
71220	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
71221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
71222	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
71223	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
71224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 12)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE194 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
713 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
713 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
713 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
713 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
713 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
713 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
713 7	0.000	0.000	564.987	0.	0.	0.	0.	0.	0.	0.	0.
713 8	0.000	0.000	664.364	0.	0.	0.	0.	0.	0.	0.	0.
713 9	0.000	0.000	693.699	0.	0.	0.	0.	0.	0.	0.	0.
71310	0.000	0.000	691.716	0.	0.	0.	0.	0.	0.	0.	0.
71311	0.000	0.000	676.864	0.	0.	0.	0.	0.	0.	0.	0.
71312	0.000	0.000	674.586	0.	0.	0.	0.	0.	0.	0.	0.
71313	0.000	0.000	696.175	0.	0.	0.	0.	0.	0.	0.	0.
71314	0.000	0.000	700.109	0.	0.	0.	0.	0.	0.	0.	0.
71315	0.000	0.000	690.576	0.	0.	0.	0.	0.	0.	0.	0.
71316	0.000	0.000	683.346	0.	0.	0.	0.	0.	0.	0.	0.
71317	0.000	0.000	625.784	0.	0.	0.	0.	0.	0.	0.	0.
71318	0.000	0.000	493.845	0.	0.	0.	0.	0.	0.	0.	0.
71319	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
71320	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
71321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
71322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
71323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
71324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	700.109	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8575.594	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	357.316	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE195 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
714 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
714 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
714 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
714 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
714 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
714 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
714 7	0.000	0.000	512.327	0.	0.	0.	0.	0.	0.	0.	0.
714 8	0.000	0.000	595.644	0.	0.	0.	0.	0.	0.	0.	0.
714 9	0.000	0.000	651.120	0.	0.	0.	0.	0.	0.	0.	0.
71410	0.000	0.000	660.631	0.	0.	0.	0.	0.	0.	0.	0.
71411	0.000	0.000	643.881	0.	0.	0.	0.	0.	0.	0.	0.
71412	0.000	0.000	649.018	0.	0.	0.	0.	0.	0.	0.	0.
71413	0.000	0.000	681.909	0.	0.	0.	0.	0.	0.	0.	0.
71414	0.000	0.000	697.404	0.	0.	0.	0.	0.	0.	0.	0.
71415	0.000	0.000	688.934	0.	0.	0.	0.	0.	0.	0.	0.
71416	0.000	0.000	679.467	0.	0.	0.	0.	0.	0.	0.	0.
71417	0.000	0.000	637.846	0.	0.	0.	0.	0.	0.	0.	0.
71418	0.000	0.000	494.796	0.	0.	0.	0.	0.	0.	0.	0.
71419	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
71420	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
71421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
71422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
71423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
71424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	697.404	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8312.518	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	346.355	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE196 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
715 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
715 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
715 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
715 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
715 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
715 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
715 7	0.000	0.000	528.848	0.	0.	0.	0.	0.	0.	0.	0.
715 8	0.000	0.000	589.560	0.	0.	0.	0.	0.	0.	0.	0.
715 9	0.000	0.000	592.006	0.	0.	0.	0.	0.	0.	0.	0.
71510	0.000	0.000	632.088	0.	0.	0.	0.	0.	0.	0.	0.
71511	0.000	0.000	623.225	0.	0.	0.	0.	0.	0.	0.	0.
71512	0.000	0.000	651.755	0.	0.	0.	0.	0.	0.	0.	0.
71513	0.000	0.000	679.538	0.	0.	0.	0.	0.	0.	0.	0.
71514	0.000	0.000	694.551	0.	0.	0.	0.	0.	0.	0.	0.
71515	0.000	0.000	700.050	0.	0.	0.	0.	0.	0.	0.	0.
71516	0.000	0.000	689.939	0.	0.	0.	0.	0.	0.	0.	0.
71517	0.000	0.000	644.892	0.	0.	0.	0.	0.	0.	0.	0.
71518	0.000	0.000	511.689	0.	0.	0.	0.	0.	0.	0.	0.
71519	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
71520	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
71521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
71522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
71523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
71524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	700.050	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8257.684	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	344.070	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE197 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
716 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
716 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
716 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
716 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
716 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
716 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
716 7	0.000	0.000	509.581	0.	0.	0.	0.	0.	0.	0.	0.
716 8	0.000	0.000	577.688	0.	0.	0.	0.	0.	0.	0.	0.
716 9	0.000	0.000	652.674	0.	0.	0.	0.	0.	0.	0.	0.
71610	0.000	0.000	662.041	0.	0.	0.	0.	0.	0.	0.	0.
71611	0.000	0.000	638.846	0.	0.	0.	0.	0.	0.	0.	0.
71612	0.000	0.000	648.318	0.	0.	0.	0.	0.	0.	0.	0.
71613	0.000	0.000	673.560	0.	0.	0.	0.	0.	0.	0.	0.
71614	0.000	0.000	687.972	0.	0.	0.	0.	0.	0.	0.	0.
71615	0.000	0.000	704.092	0.	0.	0.	0.	0.	0.	0.	0.
71616	0.000	0.000	669.036	0.	0.	0.	0.	0.	0.	0.	0.
71617	0.000	0.000	624.724	0.	0.	0.	0.	0.	0.	0.	0.
71618	0.000	0.000	500.174	0.	0.	0.	0.	0.	0.	0.	0.
71619	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
71620	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
71621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
71622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
71623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
71624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	704.092	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8268.248	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	344.510	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE198 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
717 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
717 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
717 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
717 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
717 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
717 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
717 7	0.000	0.000	518.109	0.	0.	0.	0.	0.	0.	0.	0.
717 8	0.000	0.000	639.374	0.	0.	0.	0.	0.	0.	0.	0.
717 9	0.000	0.000	692.408	0.	0.	0.	0.	0.	0.	0.	0.
71710	0.000	0.000	696.143	0.	0.	0.	0.	0.	0.	0.	0.
71711	0.000	0.000	665.414	0.	0.	0.	0.	0.	0.	0.	0.
71712	0.000	0.000	662.308	0.	0.	0.	0.	0.	0.	0.	0.
71713	0.000	0.000	687.068	0.	0.	0.	0.	0.	0.	0.	0.
71714	0.000	0.000	702.001	0.	0.	0.	0.	0.	0.	0.	0.
71715	0.000	0.000	707.616	0.	0.	0.	0.	0.	0.	0.	0.
71716	0.000	0.000	703.043	0.	0.	0.	0.	0.	0.	0.	0.
71717	0.000	0.000	656.538	0.	0.	0.	0.	0.	0.	0.	0.
71718	0.000	0.000	490.054	0.	0.	0.	0.	0.	0.	0.	0.
71719	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
71720	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
71721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
71722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
71723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
71724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	707.616	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8539.620	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	355.818	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE199 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
718 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
718 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
718 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
718 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
718 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
718 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
718 7	0.000	0.000	291.590	0.	0.	0.	0.	0.	0.	0.	0.
718 8	0.000	0.000	275.241	0.	0.	0.	0.	0.	0.	0.	0.
718 9	0.000	0.000	316.849	0.	0.	0.	0.	0.	0.	0.	0.
71810	0.000	0.000	350.688	0.	0.	0.	0.	0.	0.	0.	0.
71811	0.000	0.000	352.362	0.	0.	0.	0.	0.	0.	0.	0.
71812	0.000	0.000	358.475	0.	0.	0.	0.	0.	0.	0.	0.
71813	0.000	0.000	358.285	0.	0.	0.	0.	0.	0.	0.	0.
71814	0.000	0.000	350.138	0.	0.	0.	0.	0.	0.	0.	0.
71815	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71816	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71817	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71818	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
71819	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
71820	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
71821	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
71822	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
71823	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
71824	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 18)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	358.475	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3296.904	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	137.371	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE200 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
719 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
719 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
719 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
719 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
719 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
719 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
719 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
719 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
719 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71910	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71911	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71912	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71913	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71914	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71915	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71916	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71917	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71918	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
71919	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
71920	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
71921	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
71922	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
71923	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
71924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 19)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE201 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
720 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
720 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
720 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
720 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
720 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
720 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
720 7	0.000	0.000	575.058	0.	0.	0.	0.	0.	0.	0.	0.
720 8	0.000	0.000	669.669	0.	0.	0.	0.	0.	0.	0.	0.
720 9	0.000	0.000	692.645	0.	0.	0.	0.	0.	0.	0.	0.
72010	0.000	0.000	701.363	0.	0.	0.	0.	0.	0.	0.	0.
72011	0.000	0.000	671.700	0.	0.	0.	0.	0.	0.	0.	0.
72012	0.000	0.000	664.308	0.	0.	0.	0.	0.	0.	0.	0.
72013	0.000	0.000	689.810	0.	0.	0.	0.	0.	0.	0.	0.
72014	0.000	0.000	743.447	0.	0.	0.	0.	0.	0.	0.	0.
72015	0.000	0.000	762.952	0.	0.	0.	0.	0.	0.	0.	0.
72016	0.000	0.000	740.851	0.	0.	0.	0.	0.	0.	0.	0.
72017	0.000	0.000	680.834	0.	0.	0.	0.	0.	0.	0.	0.
72018	0.000	0.000	529.557	0.	0.	0.	0.	0.	0.	0.	0.
72019	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72020	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	762.952	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8841.737	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	368.406	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE202 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
721 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
721 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
721 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
721 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
721 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
721 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
721 7	0.000	0.000	568.969	0.	0.	0.	0.	0.	0.	0.	0.
721 8	0.000	0.000	652.850	0.	0.	0.	0.	0.	0.	0.	0.
721 9	0.000	0.000	704.419	0.	0.	0.	0.	0.	0.	0.	0.
72110	0.000	0.000	713.354	0.	0.	0.	0.	0.	0.	0.	0.
72111	0.000	0.000	698.132	0.	0.	0.	0.	0.	0.	0.	0.
72112	0.000	0.000	696.879	0.	0.	0.	0.	0.	0.	0.	0.
72113	0.000	0.000	707.876	0.	0.	0.	0.	0.	0.	0.	0.
72114	0.000	0.000	709.647	0.	0.	0.	0.	0.	0.	0.	0.
72115	0.000	0.000	728.656	0.	0.	0.	0.	0.	0.	0.	0.
72116	0.000	0.000	696.275	0.	0.	0.	0.	0.	0.	0.	0.
72117	0.000	0.000	639.864	0.	0.	0.	0.	0.	0.	0.	0.
72118	0.000	0.000	506.871	0.	0.	0.	0.	0.	0.	0.	0.
72119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	728.656	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8743.334	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	364.306	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE203 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
722 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
722 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
722 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
722 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
722 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
722 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
722 7	0.000	0.000	559.201	0.	0.	0.	0.	0.	0.	0.	0.
722 8	0.000	0.000	661.762	0.	0.	0.	0.	0.	0.	0.	0.
722 9	0.000	0.000	698.262	0.	0.	0.	0.	0.	0.	0.	0.
72210	0.000	0.000	711.398	0.	0.	0.	0.	0.	0.	0.	0.
72211	0.000	0.000	682.756	0.	0.	0.	0.	0.	0.	0.	0.
72212	0.000	0.000	680.090	0.	0.	0.	0.	0.	0.	0.	0.
72213	0.000	0.000	692.865	0.	0.	0.	0.	0.	0.	0.	0.
72214	0.000	0.000	707.175	0.	0.	0.	0.	0.	0.	0.	0.
72215	0.000	0.000	712.797	0.	0.	0.	0.	0.	0.	0.	0.
72216	0.000	0.000	706.984	0.	0.	0.	0.	0.	0.	0.	0.
72217	0.000	0.000	657.392	0.	0.	0.	0.	0.	0.	0.	0.
72218	0.000	0.000	514.522	0.	0.	0.	0.	0.	0.	0.	0.
72219	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72220	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	712.797	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8704.748	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	362.698	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE204 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
723 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
723 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
723 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
723 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
723 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
723 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
723 7	0.000	0.000	582.206	0.	0.	0.	0.	0.	0.	0.	0.
723 8	0.000	0.000	680.650	0.	0.	0.	0.	0.	0.	0.	0.
723 9	0.000	0.000	708.798	0.	0.	0.	0.	0.	0.	0.	0.
72310	0.000	0.000	728.361	0.	0.	0.	0.	0.	0.	0.	0.
72311	0.000	0.000	702.692	0.	0.	0.	0.	0.	0.	0.	0.
72312	0.000	0.000	703.273	0.	0.	0.	0.	0.	0.	0.	0.
72313	0.000	0.000	697.752	0.	0.	0.	0.	0.	0.	0.	0.
72314	0.000	0.000	745.429	0.	0.	0.	0.	0.	0.	0.	0.
72315	0.000	0.000	752.614	0.	0.	0.	0.	0.	0.	0.	0.
72316	0.000	0.000	741.621	0.	0.	0.	0.	0.	0.	0.	0.
72317	0.000	0.000	665.594	0.	0.	0.	0.	0.	0.	0.	0.
72318	0.000	0.000	525.251	0.	0.	0.	0.	0.	0.	0.	0.
72319	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72320	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	752.614	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8953.783	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	373.074	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE205 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
724 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
724 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
724 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
724 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
724 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
724 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
724 7	0.000	0.000	593.977	0.	0.	0.	0.	0.	0.	0.	0.
724 8	0.000	0.000	689.292	0.	0.	0.	0.	0.	0.	0.	0.
724 9	0.000	0.000	735.280	0.	0.	0.	0.	0.	0.	0.	0.
72410	0.000	0.000	704.363	0.	0.	0.	0.	0.	0.	0.	0.
72411	0.000	0.000	673.835	0.	0.	0.	0.	0.	0.	0.	0.
72412	0.000	0.000	666.158	0.	0.	0.	0.	0.	0.	0.	0.
72413	0.000	0.000	692.397	0.	0.	0.	0.	0.	0.	0.	0.
72414	0.000	0.000	747.586	0.	0.	0.	0.	0.	0.	0.	0.
72415	0.000	0.000	752.135	0.	0.	0.	0.	0.	0.	0.	0.
72416	0.000	0.000	728.910	0.	0.	0.	0.	0.	0.	0.	0.
72417	0.000	0.000	647.812	0.	0.	0.	0.	0.	0.	0.	0.
72418	0.000	0.000	510.272	0.	0.	0.	0.	0.	0.	0.	0.
72419	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72420	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	752.135	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8861.562	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	369.232	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE206 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
725 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
725 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
725 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
725 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
725 5	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
725 6	0.000	1.033	38.317	0.	0.	0.	0.	0.	0.	0.	0.
725 7	0.000	0.000	357.241	0.	0.	0.	0.	0.	0.	0.	0.
725 8	0.000	0.000	360.179	0.	0.	0.	0.	0.	0.	0.	0.
725 9	0.000	0.000	368.213	0.	0.	0.	0.	0.	0.	0.	0.
72510	0.000	0.000	373.108	0.	0.	0.	0.	0.	0.	0.	0.
72511	0.000	0.000	375.885	0.	0.	0.	0.	0.	0.	0.	0.
72512	0.000	0.000	374.914	0.	0.	0.	0.	0.	0.	0.	0.
72513	0.000	0.000	376.652	0.	0.	0.	0.	0.	0.	0.	0.
72514	0.000	0.000	378.268	0.	0.	0.	0.	0.	0.	0.	0.
72515	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
72516	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
72517	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
72518	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
72519	0.000	4.133	41.416	0.	0.	0.	0.	0.	0.	0.	0.
72520	0.000	7.749	45.032	0.	0.	0.	0.	0.	0.	0.	0.
72521	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
72522	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
72523	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
72524	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 25)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	378.268	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	3607.737	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	150.322	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE207 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
726 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
726 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
726 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
726 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
726 5	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
726 6	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
726 7	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
726 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
726 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72616	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72617	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72618	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
72619	0.000	4.133	15.318	0.	0.	0.	0.	0.	0.	0.	0.
72620	0.000	7.749	18.934	0.	0.	0.	0.	0.	0.	0.	0.
72621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
72622	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
72623	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
72624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 26)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	367.380	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	15.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE208 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
727 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
727 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
727 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
727 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
727 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
727 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
727 7	0.000	0.000	591.423	0.	0.	0.	0.	0.	0.	0.	0.
727 8	0.000	0.000	684.417	0.	0.	0.	0.	0.	0.	0.	0.
727 9	0.000	0.000	687.847	0.	0.	0.	0.	0.	0.	0.	0.
72710	0.000	0.000	704.153	0.	0.	0.	0.	0.	0.	0.	0.
72711	0.000	0.000	691.880	0.	0.	0.	0.	0.	0.	0.	0.
72712	0.000	0.000	690.380	0.	0.	0.	0.	0.	0.	0.	0.
72713	0.000	0.000	716.311	0.	0.	0.	0.	0.	0.	0.	0.
72714	0.000	0.000	719.022	0.	0.	0.	0.	0.	0.	0.	0.
72715	0.000	0.000	721.792	0.	0.	0.	0.	0.	0.	0.	0.
72716	0.000	0.000	706.266	0.	0.	0.	0.	0.	0.	0.	0.
72717	0.000	0.000	645.920	0.	0.	0.	0.	0.	0.	0.	0.
72718	0.000	0.000	504.811	0.	0.	0.	0.	0.	0.	0.	0.
72719	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72720	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	721.792	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8783.764	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	365.990	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE209 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
728 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
728 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
728 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
728 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
728 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
728 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
728 7	0.000	0.000	594.698	0.	0.	0.	0.	0.	0.	0.	0.
728 8	0.000	0.000	691.964	0.	0.	0.	0.	0.	0.	0.	0.
728 9	0.000	0.000	694.360	0.	0.	0.	0.	0.	0.	0.	0.
72810	0.000	0.000	700.540	0.	0.	0.	0.	0.	0.	0.	0.
72811	0.000	0.000	663.404	0.	0.	0.	0.	0.	0.	0.	0.
72812	0.000	0.000	671.941	0.	0.	0.	0.	0.	0.	0.	0.
72813	0.000	0.000	699.565	0.	0.	0.	0.	0.	0.	0.	0.
72814	0.000	0.000	717.880	0.	0.	0.	0.	0.	0.	0.	0.
72815	0.000	0.000	705.783	0.	0.	0.	0.	0.	0.	0.	0.
72816	0.000	0.000	696.795	0.	0.	0.	0.	0.	0.	0.	0.
72817	0.000	0.000	653.648	0.	0.	0.	0.	0.	0.	0.	0.
72818	0.000	0.000	520.399	0.	0.	0.	0.	0.	0.	0.	0.
72819	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72820	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	717.880	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8730.521	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	363.772	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE210 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
729 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
729 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
729 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
729 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
729 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
729 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
729 7	0.000	0.000	610.735	0.	0.	0.	0.	0.	0.	0.	0.
729 8	0.000	0.000	690.676	0.	0.	0.	0.	0.	0.	0.	0.
729 9	0.000	0.000	737.780	0.	0.	0.	0.	0.	0.	0.	0.
72910	0.000	0.000	716.090	0.	0.	0.	0.	0.	0.	0.	0.
72911	0.000	0.000	679.559	0.	0.	0.	0.	0.	0.	0.	0.
72912	0.000	0.000	670.667	0.	0.	0.	0.	0.	0.	0.	0.
72913	0.000	0.000	693.032	0.	0.	0.	0.	0.	0.	0.	0.
72914	0.000	0.000	710.033	0.	0.	0.	0.	0.	0.	0.	0.
72915	0.000	0.000	709.496	0.	0.	0.	0.	0.	0.	0.	0.
72916	0.000	0.000	702.073	0.	0.	0.	0.	0.	0.	0.	0.
72917	0.000	0.000	689.326	0.	0.	0.	0.	0.	0.	0.	0.
72918	0.000	0.000	539.927	0.	0.	0.	0.	0.	0.	0.	0.
72919	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
72920	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
72921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
72922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
72923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
72924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	737.780	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8868.938	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	369.539	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE211 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
730 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
730 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
730 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
730 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
730 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
730 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
730 7	0.000	0.000	597.374	0.	0.	0.	0.	0.	0.	0.	0.
730 8	0.000	0.000	685.754	0.	0.	0.	0.	0.	0.	0.	0.
730 9	0.000	0.000	709.052	0.	0.	0.	0.	0.	0.	0.	0.
73010	0.000	0.000	731.973	0.	0.	0.	0.	0.	0.	0.	0.
73011	0.000	0.000	703.028	0.	0.	0.	0.	0.	0.	0.	0.
73012	0.000	0.000	690.684	0.	0.	0.	0.	0.	0.	0.	0.
73013	0.000	0.000	716.522	0.	0.	0.	0.	0.	0.	0.	0.
73014	0.000	0.000	732.413	0.	0.	0.	0.	0.	0.	0.	0.
73015	0.000	0.000	738.396	0.	0.	0.	0.	0.	0.	0.	0.
73016	0.000	0.000	723.057	0.	0.	0.	0.	0.	0.	0.	0.
73017	0.000	0.000	662.648	0.	0.	0.	0.	0.	0.	0.	0.
73018	0.000	0.000	510.789	0.	0.	0.	0.	0.	0.	0.	0.
73019	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
73020	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
73021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
73022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
73023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
73024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	738.396	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8921.233	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	371.718	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE212 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
731 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
731 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
731 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
731 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
731 5	0.000	4.133	48.217	0.	0.	0.	0.	0.	0.	0.	0.
731 6	0.000	1.033	105.547	0.	0.	0.	0.	0.	0.	0.	0.
731 7	0.000	0.000	585.369	0.	0.	0.	0.	0.	0.	0.	0.
731 8	0.000	0.000	662.968	0.	0.	0.	0.	0.	0.	0.	0.
731 9	0.000	0.000	687.711	0.	0.	0.	0.	0.	0.	0.	0.
73110	0.000	0.000	695.877	0.	0.	0.	0.	0.	0.	0.	0.
73111	0.000	0.000	683.949	0.	0.	0.	0.	0.	0.	0.	0.
73112	0.000	0.000	683.297	0.	0.	0.	0.	0.	0.	0.	0.
73113	0.000	0.000	711.042	0.	0.	0.	0.	0.	0.	0.	0.
73114	0.000	0.000	728.293	0.	0.	0.	0.	0.	0.	0.	0.
73115	0.000	0.000	735.001	0.	0.	0.	0.	0.	0.	0.	0.
73116	0.000	0.000	726.116	0.	0.	0.	0.	0.	0.	0.	0.
73117	0.000	0.000	674.028	0.	0.	0.	0.	0.	0.	0.	0.
73118	0.000	0.000	518.322	0.	0.	0.	0.	0.	0.	0.	0.
73119	0.000	4.133	100.636	0.	0.	0.	0.	0.	0.	0.	0.
73120	0.000	7.749	84.999	0.	0.	0.	0.	0.	0.	0.	0.
73121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
73122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
73123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
73124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 31)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	735.001	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	72.841	8811.517	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	367.147	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (JUL)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	762.952	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	2258.058	203334.938	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.035	273.300	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE213 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
8 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 1 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 1 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
8 1 7	0.000	1.033	353.829	0.	0.	0.	0.	0.	0.	0.	0.
8 1 8	0.000	0.000	369.541	0.	0.	0.	0.	0.	0.	0.	0.
8 1 9	0.000	0.000	370.627	0.	0.	0.	0.	0.	0.	0.	0.
8 110	0.000	0.000	391.559	0.	0.	0.	0.	0.	0.	0.	0.
8 111	0.000	0.000	393.167	0.	0.	0.	0.	0.	0.	0.	0.
8 112	0.000	0.000	382.804	0.	0.	0.	0.	0.	0.	0.	0.
8 113	0.000	0.000	382.350	0.	0.	0.	0.	0.	0.	0.	0.
8 114	0.000	0.000	382.408	0.	0.	0.	0.	0.	0.	0.	0.
8 115	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
8 116	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
8 117	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 118	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 119	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 122	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
8 123	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
8 124	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 1)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	393.167	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3697.460	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	154.061	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE214 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
8 2 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 2 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 2 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 2 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 2 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 2 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
8 2 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
8 2 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 2 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 216	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
8 217	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 218	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 219	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 220	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 222	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
8 223	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
8 224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 2)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE215 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
8 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 3 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
8 3 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
8 3 7	0.000	1.033	561.470	0.	0.	0.	0.	0.	0.	0.	0.
8 3 8	0.000	0.000	665.961	0.	0.	0.	0.	0.	0.	0.	0.
8 3 9	0.000	0.000	717.497	0.	0.	0.	0.	0.	0.	0.	0.
8 310	0.000	0.000	719.660	0.	0.	0.	0.	0.	0.	0.	0.
8 311	0.000	0.000	690.956	0.	0.	0.	0.	0.	0.	0.	0.
8 312	0.000	0.000	687.575	0.	0.	0.	0.	0.	0.	0.	0.
8 313	0.000	0.000	713.743	0.	0.	0.	0.	0.	0.	0.	0.
8 314	0.000	0.000	730.828	0.	0.	0.	0.	0.	0.	0.	0.
8 315	0.000	0.000	717.184	0.	0.	0.	0.	0.	0.	0.	0.
8 316	0.000	1.550	677.097	0.	0.	0.	0.	0.	0.	0.	0.
8 317	0.000	6.199	610.977	0.	0.	0.	0.	0.	0.	0.	0.
8 318	0.000	9.299	454.006	0.	0.	0.	0.	0.	0.	0.	0.
8 319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
8 320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
8 321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
8 322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
8 323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
8 324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	730.828	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8677.343	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	361.556	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE216 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
8 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 4 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
8 4 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
8 4 7	0.000	1.033	535.793	0.	0.	0.	0.	0.	0.	0.	0.
8 4 8	0.000	0.000	638.593	0.	0.	0.	0.	0.	0.	0.	0.
8 4 9	0.000	0.000	680.832	0.	0.	0.	0.	0.	0.	0.	0.
8 410	0.000	0.000	683.845	0.	0.	0.	0.	0.	0.	0.	0.
8 411	0.000	0.000	670.147	0.	0.	0.	0.	0.	0.	0.	0.
8 412	0.000	0.000	671.254	0.	0.	0.	0.	0.	0.	0.	0.
8 413	0.000	0.000	697.243	0.	0.	0.	0.	0.	0.	0.	0.
8 414	0.000	0.000	697.066	0.	0.	0.	0.	0.	0.	0.	0.
8 415	0.000	0.000	707.407	0.	0.	0.	0.	0.	0.	0.	0.
8 416	0.000	1.550	701.227	0.	0.	0.	0.	0.	0.	0.	0.
8 417	0.000	6.199	632.786	0.	0.	0.	0.	0.	0.	0.	0.
8 418	0.000	9.299	470.700	0.	0.	0.	0.	0.	0.	0.	0.
8 419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
8 420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
8 421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
8 422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
8 423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
8 424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	707.407	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8517.284	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	354.887	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE217 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
8 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 5 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
8 5 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
8 5 7	0.000	1.033	471.203	0.	0.	0.	0.	0.	0.	0.	0.
8 5 8	0.000	0.000	533.895	0.	0.	0.	0.	0.	0.	0.	0.
8 5 9	0.000	0.000	540.417	0.	0.	0.	0.	0.	0.	0.	0.
8 510	0.000	0.000	629.694	0.	0.	0.	0.	0.	0.	0.	0.
8 511	0.000	0.000	622.290	0.	0.	0.	0.	0.	0.	0.	0.
8 512	0.000	0.000	624.271	0.	0.	0.	0.	0.	0.	0.	0.
8 513	0.000	0.000	649.692	0.	0.	0.	0.	0.	0.	0.	0.
8 514	0.000	0.000	677.659	0.	0.	0.	0.	0.	0.	0.	0.
8 515	0.000	0.000	650.759	0.	0.	0.	0.	0.	0.	0.	0.
8 516	0.000	1.550	621.730	0.	0.	0.	0.	0.	0.	0.	0.
8 517	0.000	6.199	575.769	0.	0.	0.	0.	0.	0.	0.	0.
8 518	0.000	9.299	376.650	0.	0.	0.	0.	0.	0.	0.	0.
8 519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
8 520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
8 521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
8 522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
8 523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
8 524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	677.659	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7704.420	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	321.018	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE218 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
8 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 6 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
8 6 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
8 6 7	0.000	1.033	465.606	0.	0.	0.	0.	0.	0.	0.	0.
8 6 8	0.000	0.000	468.297	0.	0.	0.	0.	0.	0.	0.	0.
8 6 9	0.000	0.000	532.863	0.	0.	0.	0.	0.	0.	0.	0.
8 610	0.000	0.000	608.662	0.	0.	0.	0.	0.	0.	0.	0.
8 611	0.000	0.000	610.948	0.	0.	0.	0.	0.	0.	0.	0.
8 612	0.000	0.000	634.392	0.	0.	0.	0.	0.	0.	0.	0.
8 613	0.000	0.000	662.722	0.	0.	0.	0.	0.	0.	0.	0.
8 614	0.000	0.000	670.994	0.	0.	0.	0.	0.	0.	0.	0.
8 615	0.000	0.000	672.029	0.	0.	0.	0.	0.	0.	0.	0.
8 616	0.000	1.550	642.927	0.	0.	0.	0.	0.	0.	0.	0.
8 617	0.000	6.199	592.256	0.	0.	0.	0.	0.	0.	0.	0.
8 618	0.000	9.299	378.471	0.	0.	0.	0.	0.	0.	0.	0.
8 619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
8 620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
8 621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
8 622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
8 623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
8 624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	672.029	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7670.558	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	319.607	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE219 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
8 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 7 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
8 7 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
8 7 7	0.000	1.033	583.208	0.	0.	0.	0.	0.	0.	0.	0.
8 7 8	0.000	0.000	687.187	0.	0.	0.	0.	0.	0.	0.	0.
8 7 9	0.000	0.000	721.103	0.	0.	0.	0.	0.	0.	0.	0.
8 710	0.000	0.000	692.956	0.	0.	0.	0.	0.	0.	0.	0.
8 711	0.000	0.000	670.023	0.	0.	0.	0.	0.	0.	0.	0.
8 712	0.000	0.000	664.485	0.	0.	0.	0.	0.	0.	0.	0.
8 713	0.000	0.000	697.048	0.	0.	0.	0.	0.	0.	0.	0.
8 714	0.000	0.000	712.090	0.	0.	0.	0.	0.	0.	0.	0.
8 715	0.000	0.000	746.115	0.	0.	0.	0.	0.	0.	0.	0.
8 716	0.000	1.550	742.260	0.	0.	0.	0.	0.	0.	0.	0.
8 717	0.000	6.199	690.427	0.	0.	0.	0.	0.	0.	0.	0.
8 718	0.000	9.299	544.637	0.	0.	0.	0.	0.	0.	0.	0.
8 719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
8 720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
8 721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
8 722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
8 723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
8 724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 7)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	746.115	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8881.930	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	370.080	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE220 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
8 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 8 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 8 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
8 8 7	0.000	1.033	394.057	0.	0.	0.	0.	0.	0.	0.	0.
8 8 8	0.000	0.000	394.569	0.	0.	0.	0.	0.	0.	0.	0.
8 8 9	0.000	0.000	402.159	0.	0.	0.	0.	0.	0.	0.	0.
8 810	0.000	0.000	408.028	0.	0.	0.	0.	0.	0.	0.	0.
8 811	0.000	0.000	408.051	0.	0.	0.	0.	0.	0.	0.	0.
8 812	0.000	0.000	408.039	0.	0.	0.	0.	0.	0.	0.	0.
8 813	0.000	0.000	402.637	0.	0.	0.	0.	0.	0.	0.	0.
8 814	0.000	0.000	402.658	0.	0.	0.	0.	0.	0.	0.	0.
8 815	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
8 816	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
8 817	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
8 818	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 819	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 820	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 821	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
8 822	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
8 823	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
8 824	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 8)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	408.051	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3891.372	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	162.140	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE221 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
8 9 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 9 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 9 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 9 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 9 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 9 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
8 9 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
8 9 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 9 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 910	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 911	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 912	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 913	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 914	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 915	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
8 916	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
8 917	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
8 918	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 919	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 920	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 921	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
8 922	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
8 923	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
8 924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 9)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE222 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
810 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
810 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
810 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
810 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
810 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
810 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
810 7	0.000	1.033	486.399	0.	0.	0.	0.	0.	0.	0.	0.
810 8	0.000	0.000	656.803	0.	0.	0.	0.	0.	0.	0.	0.
810 9	0.000	0.000	697.501	0.	0.	0.	0.	0.	0.	0.	0.
81010	0.000	0.000	712.866	0.	0.	0.	0.	0.	0.	0.	0.
81011	0.000	0.000	675.043	0.	0.	0.	0.	0.	0.	0.	0.
81012	0.000	0.000	671.479	0.	0.	0.	0.	0.	0.	0.	0.
81013	0.000	0.000	696.928	0.	0.	0.	0.	0.	0.	0.	0.
81014	0.000	0.000	710.947	0.	0.	0.	0.	0.	0.	0.	0.
81015	0.000	0.000	713.279	0.	0.	0.	0.	0.	0.	0.	0.
81016	0.000	1.550	684.342	0.	0.	0.	0.	0.	0.	0.	0.
81017	0.000	6.199	629.198	0.	0.	0.	0.	0.	0.	0.	0.
81018	0.000	9.299	377.975	0.	0.	0.	0.	0.	0.	0.	0.
81019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	713.279	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8443.153	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	351.798	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE223 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
811 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
811 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
811 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
811 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
811 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
811 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
811 7	0.000	1.033	573.843	0.	0.	0.	0.	0.	0.	0.	0.
811 8	0.000	0.000	678.765	0.	0.	0.	0.	0.	0.	0.	0.
811 9	0.000	0.000	726.717	0.	0.	0.	0.	0.	0.	0.	0.
81110	0.000	0.000	702.305	0.	0.	0.	0.	0.	0.	0.	0.
81111	0.000	0.000	717.367	0.	0.	0.	0.	0.	0.	0.	0.
81112	0.000	0.000	717.298	0.	0.	0.	0.	0.	0.	0.	0.
81113	0.000	0.000	740.748	0.	0.	0.	0.	0.	0.	0.	0.
81114	0.000	0.000	757.530	0.	0.	0.	0.	0.	0.	0.	0.
81115	0.000	0.000	764.442	0.	0.	0.	0.	0.	0.	0.	0.
81116	0.000	1.550	759.875	0.	0.	0.	0.	0.	0.	0.	0.
81117	0.000	6.199	688.833	0.	0.	0.	0.	0.	0.	0.	0.
81118	0.000	9.299	545.256	0.	0.	0.	0.	0.	0.	0.	0.
81119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	764.442	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9103.368	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	379.307	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE224 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
812 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
812 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
812 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
812 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
812 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
812 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
812 7	0.000	1.033	607.109	0.	0.	0.	0.	0.	0.	0.	0.
812 8	0.000	0.000	757.568	0.	0.	0.	0.	0.	0.	0.	0.
812 9	0.000	0.000	726.337	0.	0.	0.	0.	0.	0.	0.	0.
81210	0.000	0.000	721.816	0.	0.	0.	0.	0.	0.	0.	0.
81211	0.000	0.000	685.947	0.	0.	0.	0.	0.	0.	0.	0.
81212	0.000	0.000	731.673	0.	0.	0.	0.	0.	0.	0.	0.
81213	0.000	0.000	760.783	0.	0.	0.	0.	0.	0.	0.	0.
81214	0.000	0.000	779.019	0.	0.	0.	0.	0.	0.	0.	0.
81215	0.000	0.000	786.456	0.	0.	0.	0.	0.	0.	0.	0.
81216	0.000	1.550	781.344	0.	0.	0.	0.	0.	0.	0.	0.
81217	0.000	6.199	719.814	0.	0.	0.	0.	0.	0.	0.	0.
81218	0.000	9.299	563.851	0.	0.	0.	0.	0.	0.	0.	0.
81219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	786.456	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9352.105	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	389.671	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE225 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
813 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
813 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
813 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
813 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
813 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
813 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
813 7	0.000	1.033	624.660	0.	0.	0.	0.	0.	0.	0.	0.
813 8	0.000	0.000	765.703	0.	0.	0.	0.	0.	0.	0.	0.
813 9	0.000	0.000	792.573	0.	0.	0.	0.	0.	0.	0.	0.
81310	0.000	0.000	791.537	0.	0.	0.	0.	0.	0.	0.	0.
81311	0.000	0.000	692.270	0.	0.	0.	0.	0.	0.	0.	0.
81312	0.000	0.000	684.653	0.	0.	0.	0.	0.	0.	0.	0.
81313	0.000	0.000	710.979	0.	0.	0.	0.	0.	0.	0.	0.
81314	0.000	0.000	725.529	0.	0.	0.	0.	0.	0.	0.	0.
81315	0.000	0.000	789.146	0.	0.	0.	0.	0.	0.	0.	0.
81316	0.000	1.550	787.882	0.	0.	0.	0.	0.	0.	0.	0.
81317	0.000	6.199	736.760	0.	0.	0.	0.	0.	0.	0.	0.
81318	0.000	9.299	551.290	0.	0.	0.	0.	0.	0.	0.	0.
81319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	792.573	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9383.372	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	390.974	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE226 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
814 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
814 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
814 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
814 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
814 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
814 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
814 7	0.000	1.033	613.001	0.	0.	0.	0.	0.	0.	0.	0.
814 8	0.000	0.000	758.156	0.	0.	0.	0.	0.	0.	0.	0.
814 9	0.000	0.000	717.743	0.	0.	0.	0.	0.	0.	0.	0.
81410	0.000	0.000	771.614	0.	0.	0.	0.	0.	0.	0.	0.
81411	0.000	0.000	756.609	0.	0.	0.	0.	0.	0.	0.	0.
81412	0.000	0.000	752.799	0.	0.	0.	0.	0.	0.	0.	0.
81413	0.000	0.000	766.988	0.	0.	0.	0.	0.	0.	0.	0.
81414	0.000	0.000	785.098	0.	0.	0.	0.	0.	0.	0.	0.
81415	0.000	0.000	787.908	0.	0.	0.	0.	0.	0.	0.	0.
81416	0.000	1.550	746.111	0.	0.	0.	0.	0.	0.	0.	0.
81417	0.000	6.199	676.966	0.	0.	0.	0.	0.	0.	0.	0.
81418	0.000	9.299	497.317	0.	0.	0.	0.	0.	0.	0.	0.
81419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	787.908	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9360.699	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	390.029	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE227 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
815 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
815 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
815 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
815 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
815 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
815 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
815 7	0.000	1.033	370.090	0.	0.	0.	0.	0.	0.	0.	0.
815 8	0.000	0.000	395.341	0.	0.	0.	0.	0.	0.	0.	0.
815 9	0.000	0.000	389.011	0.	0.	0.	0.	0.	0.	0.	0.
81510	0.000	0.000	386.467	0.	0.	0.	0.	0.	0.	0.	0.
81511	0.000	0.000	387.317	0.	0.	0.	0.	0.	0.	0.	0.
81512	0.000	0.000	394.128	0.	0.	0.	0.	0.	0.	0.	0.
81513	0.000	0.000	392.860	0.	0.	0.	0.	0.	0.	0.	0.
81514	0.000	0.000	416.078	0.	0.	0.	0.	0.	0.	0.	0.
81515	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
81516	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
81517	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
81518	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
81519	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
81520	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
81521	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
81522	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
81523	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
81524	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 15)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	416.078	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3802.466	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	158.436	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE228 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
816 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
816 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
816 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
816 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
816 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
816 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
816 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
816 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
816 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
81616	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
81617	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
81618	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
81619	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
81620	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
81621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
81622	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
81623	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
81624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 16)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE229 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
817 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
817 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
817 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
817 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
817 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
817 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
817 7	0.000	1.033	622.169	0.	0.	0.	0.	0.	0.	0.	0.
817 8	0.000	0.000	756.023	0.	0.	0.	0.	0.	0.	0.	0.
817 9	0.000	0.000	795.884	0.	0.	0.	0.	0.	0.	0.	0.
81710	0.000	0.000	728.574	0.	0.	0.	0.	0.	0.	0.	0.
81711	0.000	0.000	698.893	0.	0.	0.	0.	0.	0.	0.	0.
81712	0.000	0.000	688.440	0.	0.	0.	0.	0.	0.	0.	0.
81713	0.000	0.000	713.815	0.	0.	0.	0.	0.	0.	0.	0.
81714	0.000	0.000	794.379	0.	0.	0.	0.	0.	0.	0.	0.
81715	0.000	0.000	772.946	0.	0.	0.	0.	0.	0.	0.	0.
81716	0.000	1.550	766.594	0.	0.	0.	0.	0.	0.	0.	0.
81717	0.000	6.199	730.166	0.	0.	0.	0.	0.	0.	0.	0.
81718	0.000	9.299	561.078	0.	0.	0.	0.	0.	0.	0.	0.
81719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	795.884	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9359.350	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	389.973	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE230 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
818 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
818 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
818 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
818 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
818 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
818 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
818 7	0.000	1.033	568.838	0.	0.	0.	0.	0.	0.	0.	0.
818 8	0.000	0.000	661.634	0.	0.	0.	0.	0.	0.	0.	0.
818 9	0.000	0.000	671.782	0.	0.	0.	0.	0.	0.	0.	0.
81810	0.000	0.000	680.917	0.	0.	0.	0.	0.	0.	0.	0.
81811	0.000	0.000	657.726	0.	0.	0.	0.	0.	0.	0.	0.
81812	0.000	0.000	666.060	0.	0.	0.	0.	0.	0.	0.	0.
81813	0.000	0.000	684.829	0.	0.	0.	0.	0.	0.	0.	0.
81814	0.000	0.000	704.898	0.	0.	0.	0.	0.	0.	0.	0.
81815	0.000	0.000	715.992	0.	0.	0.	0.	0.	0.	0.	0.
81816	0.000	1.550	680.514	0.	0.	0.	0.	0.	0.	0.	0.
81817	0.000	6.199	616.128	0.	0.	0.	0.	0.	0.	0.	0.
81818	0.000	9.299	460.459	0.	0.	0.	0.	0.	0.	0.	0.
81819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	715.992	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8500.166	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	354.174	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE231 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
819 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
819 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
819 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
819 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
819 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
819 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
819 7	0.000	1.033	472.877	0.	0.	0.	0.	0.	0.	0.	0.
819 8	0.000	0.000	553.414	0.	0.	0.	0.	0.	0.	0.	0.
819 9	0.000	0.000	651.759	0.	0.	0.	0.	0.	0.	0.	0.
81910	0.000	0.000	666.027	0.	0.	0.	0.	0.	0.	0.	0.
81911	0.000	0.000	663.324	0.	0.	0.	0.	0.	0.	0.	0.
81912	0.000	0.000	677.837	0.	0.	0.	0.	0.	0.	0.	0.
81913	0.000	0.000	712.898	0.	0.	0.	0.	0.	0.	0.	0.
81914	0.000	0.000	728.978	0.	0.	0.	0.	0.	0.	0.	0.
81915	0.000	0.000	726.816	0.	0.	0.	0.	0.	0.	0.	0.
81916	0.000	1.550	701.136	0.	0.	0.	0.	0.	0.	0.	0.
81917	0.000	6.199	626.809	0.	0.	0.	0.	0.	0.	0.	0.
81918	0.000	9.299	498.616	0.	0.	0.	0.	0.	0.	0.	0.
81919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
81920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
81921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
81922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
81923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
81924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	728.978	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8410.882	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	350.453	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE232 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
820 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
820 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
820 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
820 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
820 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
820 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
820 7	0.000	1.033	512.381	0.	0.	0.	0.	0.	0.	0.	0.
820 8	0.000	0.000	624.310	0.	0.	0.	0.	0.	0.	0.	0.
820 9	0.000	0.000	644.617	0.	0.	0.	0.	0.	0.	0.	0.
82010	0.000	0.000	649.413	0.	0.	0.	0.	0.	0.	0.	0.
82011	0.000	0.000	656.970	0.	0.	0.	0.	0.	0.	0.	0.
82012	0.000	0.000	679.586	0.	0.	0.	0.	0.	0.	0.	0.
82013	0.000	0.000	708.510	0.	0.	0.	0.	0.	0.	0.	0.
82014	0.000	0.000	701.450	0.	0.	0.	0.	0.	0.	0.	0.
82015	0.000	0.000	700.497	0.	0.	0.	0.	0.	0.	0.	0.
82016	0.000	1.550	676.132	0.	0.	0.	0.	0.	0.	0.	0.
82017	0.000	6.199	605.203	0.	0.	0.	0.	0.	0.	0.	0.
82018	0.000	9.299	412.835	0.	0.	0.	0.	0.	0.	0.	0.
82019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	708.510	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8302.295	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	345.929	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE233 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
821 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
821 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
821 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
821 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
821 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
821 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
821 7	0.000	1.033	542.415	0.	0.	0.	0.	0.	0.	0.	0.
821 8	0.000	0.000	642.197	0.	0.	0.	0.	0.	0.	0.	0.
821 9	0.000	0.000	675.859	0.	0.	0.	0.	0.	0.	0.	0.
82110	0.000	0.000	673.359	0.	0.	0.	0.	0.	0.	0.	0.
82111	0.000	0.000	653.373	0.	0.	0.	0.	0.	0.	0.	0.
82112	0.000	0.000	652.906	0.	0.	0.	0.	0.	0.	0.	0.
82113	0.000	0.000	683.242	0.	0.	0.	0.	0.	0.	0.	0.
82114	0.000	0.000	712.753	0.	0.	0.	0.	0.	0.	0.	0.
82115	0.000	0.000	732.460	0.	0.	0.	0.	0.	0.	0.	0.
82116	0.000	1.550	697.540	0.	0.	0.	0.	0.	0.	0.	0.
82117	0.000	6.199	634.960	0.	0.	0.	0.	0.	0.	0.	0.
82118	0.000	9.299	492.214	0.	0.	0.	0.	0.	0.	0.	0.
82119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	732.460	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8523.669	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	355.153	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE234 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
822 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
822 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
822 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
822 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
822 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
822 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
822 7	0.000	1.033	264.132	0.	0.	0.	0.	0.	0.	0.	0.
822 8	0.000	0.000	314.883	0.	0.	0.	0.	0.	0.	0.	0.
822 9	0.000	0.000	356.717	0.	0.	0.	0.	0.	0.	0.	0.
82210	0.000	0.000	370.329	0.	0.	0.	0.	0.	0.	0.	0.
82211	0.000	0.000	370.355	0.	0.	0.	0.	0.	0.	0.	0.
82212	0.000	0.000	373.753	0.	0.	0.	0.	0.	0.	0.	0.
82213	0.000	0.000	373.792	0.	0.	0.	0.	0.	0.	0.	0.
82214	0.000	0.000	383.128	0.	0.	0.	0.	0.	0.	0.	0.
82215	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
82216	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
82217	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
82218	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82219	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82220	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82221	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82222	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
82223	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
82224	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 22)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	383.128	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3478.263	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	144.928	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE235 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
823 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
823 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
823 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
823 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
823 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
823 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
823 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
823 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
823 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82310	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82311	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82312	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82313	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82314	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82315	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
82316	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
82317	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
82318	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
82319	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
82320	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
82321	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
82322	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
82323	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
82324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 23)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE236 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
824 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
824 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
824 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
824 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
824 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
824 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
824 7	0.000	1.033	588.359	0.	0.	0.	0.	0.	0.	0.	0.
824 8	0.000	0.000	714.272	0.	0.	0.	0.	0.	0.	0.	0.
824 9	0.000	0.000	746.248	0.	0.	0.	0.	0.	0.	0.	0.
82410	0.000	0.000	743.966	0.	0.	0.	0.	0.	0.	0.	0.
82411	0.000	0.000	678.355	0.	0.	0.	0.	0.	0.	0.	0.
82412	0.000	0.000	673.815	0.	0.	0.	0.	0.	0.	0.	0.
82413	0.000	0.000	763.494	0.	0.	0.	0.	0.	0.	0.	0.
82414	0.000	0.000	723.169	0.	0.	0.	0.	0.	0.	0.	0.
82415	0.000	0.000	743.880	0.	0.	0.	0.	0.	0.	0.	0.
82416	0.000	1.550	714.339	0.	0.	0.	0.	0.	0.	0.	0.
82417	0.000	6.199	649.962	0.	0.	0.	0.	0.	0.	0.	0.
82418	0.000	9.299	523.146	0.	0.	0.	0.	0.	0.	0.	0.
82419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	763.494	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8993.396	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	374.725	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE237 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
825 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
825 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
825 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
825 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
825 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
825 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
825 7	0.000	1.033	600.548	0.	0.	0.	0.	0.	0.	0.	0.
825 8	0.000	0.000	694.487	0.	0.	0.	0.	0.	0.	0.	0.
825 9	0.000	0.000	721.668	0.	0.	0.	0.	0.	0.	0.	0.
82510	0.000	0.000	742.046	0.	0.	0.	0.	0.	0.	0.	0.
82511	0.000	0.000	715.030	0.	0.	0.	0.	0.	0.	0.	0.
82512	0.000	0.000	700.327	0.	0.	0.	0.	0.	0.	0.	0.
82513	0.000	0.000	714.209	0.	0.	0.	0.	0.	0.	0.	0.
82514	0.000	0.000	726.682	0.	0.	0.	0.	0.	0.	0.	0.
82515	0.000	0.000	730.291	0.	0.	0.	0.	0.	0.	0.	0.
82516	0.000	1.550	723.323	0.	0.	0.	0.	0.	0.	0.	0.
82517	0.000	6.199	651.807	0.	0.	0.	0.	0.	0.	0.	0.
82518	0.000	9.299	515.973	0.	0.	0.	0.	0.	0.	0.	0.
82519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 25)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	742.046	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8966.780	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	373.616	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE238 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
826 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
826 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
826 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
826 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
826 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
826 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
826 7	0.000	1.033	588.657	0.	0.	0.	0.	0.	0.	0.	0.
826 8	0.000	0.000	678.447	0.	0.	0.	0.	0.	0.	0.	0.
826 9	0.000	0.000	702.477	0.	0.	0.	0.	0.	0.	0.	0.
82610	0.000	0.000	723.463	0.	0.	0.	0.	0.	0.	0.	0.
82611	0.000	0.000	684.800	0.	0.	0.	0.	0.	0.	0.	0.
82612	0.000	0.000	678.731	0.	0.	0.	0.	0.	0.	0.	0.
82613	0.000	0.000	694.314	0.	0.	0.	0.	0.	0.	0.	0.
82614	0.000	0.000	706.079	0.	0.	0.	0.	0.	0.	0.	0.
82615	0.000	0.000	706.829	0.	0.	0.	0.	0.	0.	0.	0.
82616	0.000	1.550	700.064	0.	0.	0.	0.	0.	0.	0.	0.
82617	0.000	6.199	648.447	0.	0.	0.	0.	0.	0.	0.	0.
82618	0.000	9.299	515.149	0.	0.	0.	0.	0.	0.	0.	0.
82619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	723.463	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8757.848	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	364.910	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE239 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
827 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
827 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
827 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
827 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
827 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
827 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
827 7	0.000	1.033	590.987	0.	0.	0.	0.	0.	0.	0.	0.
827 8	0.000	0.000	706.441	0.	0.	0.	0.	0.	0.	0.	0.
827 9	0.000	0.000	702.557	0.	0.	0.	0.	0.	0.	0.	0.
82710	0.000	0.000	704.924	0.	0.	0.	0.	0.	0.	0.	0.
82711	0.000	0.000	675.670	0.	0.	0.	0.	0.	0.	0.	0.
82712	0.000	0.000	672.776	0.	0.	0.	0.	0.	0.	0.	0.
82713	0.000	0.000	762.279	0.	0.	0.	0.	0.	0.	0.	0.
82714	0.000	0.000	741.058	0.	0.	0.	0.	0.	0.	0.	0.
82715	0.000	0.000	745.165	0.	0.	0.	0.	0.	0.	0.	0.
82716	0.000	1.550	718.983	0.	0.	0.	0.	0.	0.	0.	0.
82717	0.000	6.199	672.913	0.	0.	0.	0.	0.	0.	0.	0.
82718	0.000	9.299	515.424	0.	0.	0.	0.	0.	0.	0.	0.
82719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	762.279	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8939.567	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	372.482	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE240 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
828 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
828 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
828 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
828 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
828 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
828 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
828 7	0.000	1.033	573.825	0.	0.	0.	0.	0.	0.	0.	0.
828 8	0.000	0.000	679.353	0.	0.	0.	0.	0.	0.	0.	0.
828 9	0.000	0.000	712.098	0.	0.	0.	0.	0.	0.	0.	0.
82810	0.000	0.000	728.038	0.	0.	0.	0.	0.	0.	0.	0.
82811	0.000	0.000	687.284	0.	0.	0.	0.	0.	0.	0.	0.
82812	0.000	0.000	683.367	0.	0.	0.	0.	0.	0.	0.	0.
82813	0.000	0.000	711.598	0.	0.	0.	0.	0.	0.	0.	0.
82814	0.000	0.000	721.835	0.	0.	0.	0.	0.	0.	0.	0.
82815	0.000	0.000	715.637	0.	0.	0.	0.	0.	0.	0.	0.
82816	0.000	1.550	702.659	0.	0.	0.	0.	0.	0.	0.	0.
82817	0.000	6.199	660.226	0.	0.	0.	0.	0.	0.	0.	0.
82818	0.000	9.299	513.126	0.	0.	0.	0.	0.	0.	0.	0.
82819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
82820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
82821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
82822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
82823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
82824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	728.038	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8819.437	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	367.477	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE241 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
829 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
829 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
829 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
829 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
829 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
829 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
829 7	0.000	1.033	295.087	0.	0.	0.	0.	0.	0.	0.	0.
829 8	0.000	0.000	355.436	0.	0.	0.	0.	0.	0.	0.	0.
829 9	0.000	0.000	367.206	0.	0.	0.	0.	0.	0.	0.	0.
82910	0.000	0.000	372.228	0.	0.	0.	0.	0.	0.	0.	0.
82911	0.000	0.000	372.339	0.	0.	0.	0.	0.	0.	0.	0.
82912	0.000	0.000	371.477	0.	0.	0.	0.	0.	0.	0.	0.
82913	0.000	0.000	372.235	0.	0.	0.	0.	0.	0.	0.	0.
82914	0.000	0.000	369.937	0.	0.	0.	0.	0.	0.	0.	0.
82915	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
82916	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
82917	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
82918	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82919	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82920	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82921	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
82922	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
82923	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
82924	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 29)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	372.339	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3547.119	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	147.797	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE242 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
830 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
830 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
830 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
830 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
830 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
830 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
830 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
830 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
830 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83010	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83011	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83012	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83013	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83014	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83015	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
83016	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
83017	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
83018	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
83019	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
83020	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
83021	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
83022	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
83023	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
83024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 30)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE243 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
831 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
831 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
831 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
831 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
831 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
831 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
831 7	0.000	1.033	565.922	0.	0.	0.	0.	0.	0.	0.	0.
831 8	0.000	0.000	689.788	0.	0.	0.	0.	0.	0.	0.	0.
831 9	0.000	0.000	723.929	0.	0.	0.	0.	0.	0.	0.	0.
83110	0.000	0.000	737.618	0.	0.	0.	0.	0.	0.	0.	0.
83111	0.000	0.000	698.204	0.	0.	0.	0.	0.	0.	0.	0.
83112	0.000	0.000	694.037	0.	0.	0.	0.	0.	0.	0.	0.
83113	0.000	0.000	721.625	0.	0.	0.	0.	0.	0.	0.	0.
83114	0.000	0.000	723.849	0.	0.	0.	0.	0.	0.	0.	0.
83115	0.000	0.000	715.052	0.	0.	0.	0.	0.	0.	0.	0.
83116	0.000	1.550	703.580	0.	0.	0.	0.	0.	0.	0.	0.
83117	0.000	6.199	657.999	0.	0.	0.	0.	0.	0.	0.	0.
83118	0.000	9.299	508.690	0.	0.	0.	0.	0.	0.	0.	0.
83119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
83120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
83121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
83122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
83123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
83124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 31)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	737.618	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8870.685	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	369.612	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (AUG)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	795.884	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	3154.877	203936.547	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	274.108	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE244 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 1 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
9 1 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
9 1 7	0.000	1.033	479.234	0.	0.	0.	0.	0.	0.	0.	0.
9 1 8	0.000	0.000	545.799	0.	0.	0.	0.	0.	0.	0.	0.
9 1 9	0.000	0.000	597.136	0.	0.	0.	0.	0.	0.	0.	0.
9 110	0.000	0.000	658.347	0.	0.	0.	0.	0.	0.	0.	0.
9 111	0.000	0.000	670.667	0.	0.	0.	0.	0.	0.	0.	0.
9 112	0.000	0.000	672.946	0.	0.	0.	0.	0.	0.	0.	0.
9 113	0.000	0.000	704.663	0.	0.	0.	0.	0.	0.	0.	0.
9 114	0.000	0.000	737.875	0.	0.	0.	0.	0.	0.	0.	0.
9 115	0.000	0.000	729.017	0.	0.	0.	0.	0.	0.	0.	0.
9 116	0.000	1.550	718.282	0.	0.	0.	0.	0.	0.	0.	0.
9 117	0.000	6.199	648.602	0.	0.	0.	0.	0.	0.	0.	0.
9 118	0.000	9.299	495.785	0.	0.	0.	0.	0.	0.	0.	0.
9 119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
9 120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
9 121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
9 122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
9 123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
9 124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	737.875	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8388.745	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	349.531	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE245 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 2 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
9 2 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
9 2 7	0.000	1.033	568.264	0.	0.	0.	0.	0.	0.	0.	0.
9 2 8	0.000	0.000	645.755	0.	0.	0.	0.	0.	0.	0.	0.
9 2 9	0.000	0.000	658.174	0.	0.	0.	0.	0.	0.	0.	0.
9 210	0.000	0.000	675.036	0.	0.	0.	0.	0.	0.	0.	0.
9 211	0.000	0.000	670.829	0.	0.	0.	0.	0.	0.	0.	0.
9 212	0.000	0.000	681.951	0.	0.	0.	0.	0.	0.	0.	0.
9 213	0.000	0.000	710.701	0.	0.	0.	0.	0.	0.	0.	0.
9 214	0.000	0.000	726.234	0.	0.	0.	0.	0.	0.	0.	0.
9 215	0.000	0.000	731.507	0.	0.	0.	0.	0.	0.	0.	0.
9 216	0.000	1.550	711.359	0.	0.	0.	0.	0.	0.	0.	0.
9 217	0.000	6.199	663.509	0.	0.	0.	0.	0.	0.	0.	0.
9 218	0.000	9.299	521.595	0.	0.	0.	0.	0.	0.	0.	0.
9 219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
9 220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
9 221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
9 222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
9 223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
9 224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	731.507	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8695.303	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	362.304	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE246 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 3 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
9 3 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
9 3 7	0.000	1.033	578.262	0.	0.	0.	0.	0.	0.	0.	0.
9 3 8	0.000	0.000	656.462	0.	0.	0.	0.	0.	0.	0.	0.
9 3 9	0.000	0.000	662.819	0.	0.	0.	0.	0.	0.	0.	0.
9 310	0.000	0.000	679.023	0.	0.	0.	0.	0.	0.	0.	0.
9 311	0.000	0.000	653.024	0.	0.	0.	0.	0.	0.	0.	0.
9 312	0.000	0.000	656.125	0.	0.	0.	0.	0.	0.	0.	0.
9 313	0.000	0.000	682.216	0.	0.	0.	0.	0.	0.	0.	0.
9 314	0.000	0.000	700.053	0.	0.	0.	0.	0.	0.	0.	0.
9 315	0.000	0.000	701.550	0.	0.	0.	0.	0.	0.	0.	0.
9 316	0.000	1.550	686.953	0.	0.	0.	0.	0.	0.	0.	0.
9 317	0.000	6.199	626.081	0.	0.	0.	0.	0.	0.	0.	0.
9 318	0.000	9.299	505.486	0.	0.	0.	0.	0.	0.	0.	0.
9 319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
9 320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
9 321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
9 322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
9 323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
9 324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	701.550	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8518.443	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	354.935	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE247 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 4 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
9 4 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
9 4 7	0.000	1.033	568.378	0.	0.	0.	0.	0.	0.	0.	0.
9 4 8	0.000	0.000	632.428	0.	0.	0.	0.	0.	0.	0.	0.
9 4 9	0.000	0.000	638.893	0.	0.	0.	0.	0.	0.	0.	0.
9 410	0.000	0.000	653.225	0.	0.	0.	0.	0.	0.	0.	0.
9 411	0.000	0.000	635.092	0.	0.	0.	0.	0.	0.	0.	0.
9 412	0.000	0.000	647.453	0.	0.	0.	0.	0.	0.	0.	0.
9 413	0.000	0.000	696.030	0.	0.	0.	0.	0.	0.	0.	0.
9 414	0.000	0.000	701.985	0.	0.	0.	0.	0.	0.	0.	0.
9 415	0.000	0.000	692.252	0.	0.	0.	0.	0.	0.	0.	0.
9 416	0.000	1.550	680.088	0.	0.	0.	0.	0.	0.	0.	0.
9 417	0.000	6.199	626.657	0.	0.	0.	0.	0.	0.	0.	0.
9 418	0.000	9.299	487.793	0.	0.	0.	0.	0.	0.	0.	0.
9 419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
9 420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
9 421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
9 422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
9 423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
9 424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	701.985	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8390.664	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	349.611	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE248 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 5 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 5 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
9 5 7	0.000	1.033	259.890	0.	0.	0.	0.	0.	0.	0.	0.
9 5 8	0.000	0.000	294.160	0.	0.	0.	0.	0.	0.	0.	0.
9 5 9	0.000	0.000	346.208	0.	0.	0.	0.	0.	0.	0.	0.
9 510	0.000	0.000	373.397	0.	0.	0.	0.	0.	0.	0.	0.
9 511	0.000	0.000	373.803	0.	0.	0.	0.	0.	0.	0.	0.
9 512	0.000	0.000	373.820	0.	0.	0.	0.	0.	0.	0.	0.
9 513	0.000	0.000	383.129	0.	0.	0.	0.	0.	0.	0.	0.
9 514	0.000	0.000	385.282	0.	0.	0.	0.	0.	0.	0.	0.
9 515	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
9 516	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
9 517	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 518	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
9 519	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
9 520	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
9 521	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
9 522	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
9 523	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
9 524	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 5)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	385.282	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3460.862	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	144.203	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE249 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 6 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 6 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 6 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 6 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 6 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 6 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
9 6 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
9 6 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 6 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 616	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
9 617	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 618	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 619	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 620	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 622	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
9 623	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
9 624	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 6)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE250 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 7 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 7 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 7 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 7 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 7 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 7 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
9 7 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
9 7 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 10	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 11	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 12	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 13	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 14	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 15	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
9 7 16	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
9 7 17	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
9 7 18	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 7 19	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 7 20	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 7 21	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
9 7 22	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
9 7 23	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
9 7 24	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 7)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE251 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
9 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 8 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
9 8 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
9 8 7	0.000	1.033	601.449	0.	0.	0.	0.	0.	0.	0.	0.
9 8 8	0.000	0.000	754.327	0.	0.	0.	0.	0.	0.	0.	0.
9 8 9	0.000	0.000	729.913	0.	0.	0.	0.	0.	0.	0.	0.
9 810	0.000	0.000	729.514	0.	0.	0.	0.	0.	0.	0.	0.
9 811	0.000	0.000	696.916	0.	0.	0.	0.	0.	0.	0.	0.
9 812	0.000	0.000	692.262	0.	0.	0.	0.	0.	0.	0.	0.
9 813	0.000	0.000	709.433	0.	0.	0.	0.	0.	0.	0.	0.
9 814	0.000	0.000	719.152	0.	0.	0.	0.	0.	0.	0.	0.
9 815	0.000	0.000	762.307	0.	0.	0.	0.	0.	0.	0.	0.
9 816	0.000	1.550	741.959	0.	0.	0.	0.	0.	0.	0.	0.
9 817	0.000	6.199	696.596	0.	0.	0.	0.	0.	0.	0.	0.
9 818	0.000	9.299	543.090	0.	0.	0.	0.	0.	0.	0.	0.
9 819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
9 820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
9 821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
9 822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
9 823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
9 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	762.307	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9107.310	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	379.471	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE252 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
9 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
9 9 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
9 9 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
9 9 7	0.000	1.033	593.845	0.	0.	0.	0.	0.	0.	0.	0.
9 9 8	0.000	0.000	728.328	0.	0.	0.	0.	0.	0.	0.	0.
9 9 9	0.000	0.000	756.416	0.	0.	0.	0.	0.	0.	0.	0.
9 910	0.000	0.000	722.259	0.	0.	0.	0.	0.	0.	0.	0.
9 911	0.000	0.000	696.982	0.	0.	0.	0.	0.	0.	0.	0.
9 912	0.000	0.000	687.649	0.	0.	0.	0.	0.	0.	0.	0.
9 913	0.000	0.000	704.902	0.	0.	0.	0.	0.	0.	0.	0.
9 914	0.000	0.000	719.445	0.	0.	0.	0.	0.	0.	0.	0.
9 915	0.000	0.000	718.568	0.	0.	0.	0.	0.	0.	0.	0.
9 916	0.000	1.550	750.411	0.	0.	0.	0.	0.	0.	0.	0.
9 917	0.000	6.199	691.259	0.	0.	0.	0.	0.	0.	0.	0.
9 918	0.000	9.299	531.222	0.	0.	0.	0.	0.	0.	0.	0.
9 919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
9 920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
9 921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
9 922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
9 923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
9 924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	756.416	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	9031.677	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	376.320	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE253 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
910 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
910 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
910 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
910 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
910 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
910 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
910 7	0.000	1.033	591.032	0.	0.	0.	0.	0.	0.	0.	0.
910 8	0.000	0.000	702.194	0.	0.	0.	0.	0.	0.	0.	0.
910 9	0.000	0.000	728.294	0.	0.	0.	0.	0.	0.	0.	0.
91010	0.000	0.000	707.791	0.	0.	0.	0.	0.	0.	0.	0.
91011	0.000	0.000	672.484	0.	0.	0.	0.	0.	0.	0.	0.
91012	0.000	0.000	692.011	0.	0.	0.	0.	0.	0.	0.	0.
91013	0.000	0.000	717.519	0.	0.	0.	0.	0.	0.	0.	0.
91014	0.000	0.000	734.049	0.	0.	0.	0.	0.	0.	0.	0.
91015	0.000	0.000	735.768	0.	0.	0.	0.	0.	0.	0.	0.
91016	0.000	1.550	728.216	0.	0.	0.	0.	0.	0.	0.	0.
91017	0.000	6.199	665.065	0.	0.	0.	0.	0.	0.	0.	0.
91018	0.000	9.299	509.716	0.	0.	0.	0.	0.	0.	0.	0.
91019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	735.768	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8914.529	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	371.439	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE254 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
911 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
911 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
911 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
911 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
911 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
911 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
911 7	0.000	1.033	567.064	0.	0.	0.	0.	0.	0.	0.	0.
911 8	0.000	0.000	664.229	0.	0.	0.	0.	0.	0.	0.	0.
911 9	0.000	0.000	710.408	0.	0.	0.	0.	0.	0.	0.	0.
91110	0.000	0.000	717.095	0.	0.	0.	0.	0.	0.	0.	0.
91111	0.000	0.000	692.702	0.	0.	0.	0.	0.	0.	0.	0.
91112	0.000	0.000	692.649	0.	0.	0.	0.	0.	0.	0.	0.
91113	0.000	0.000	710.371	0.	0.	0.	0.	0.	0.	0.	0.
91114	0.000	0.000	722.658	0.	0.	0.	0.	0.	0.	0.	0.
91115	0.000	0.000	722.816	0.	0.	0.	0.	0.	0.	0.	0.
91116	0.000	1.550	715.897	0.	0.	0.	0.	0.	0.	0.	0.
91117	0.000	6.199	669.367	0.	0.	0.	0.	0.	0.	0.	0.
91118	0.000	9.299	507.193	0.	0.	0.	0.	0.	0.	0.	0.
91119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	722.816	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8822.840	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	367.618	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE255 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
912 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
912 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
912 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
912 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
912 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
912 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
912 7	0.000	1.033	294.399	0.	0.	0.	0.	0.	0.	0.	0.
912 8	0.000	0.000	294.276	0.	0.	0.	0.	0.	0.	0.	0.
912 9	0.000	0.000	370.560	0.	0.	0.	0.	0.	0.	0.	0.
91210	0.000	0.000	376.444	0.	0.	0.	0.	0.	0.	0.	0.
91211	0.000	0.000	376.438	0.	0.	0.	0.	0.	0.	0.	0.
91212	0.000	0.000	377.171	0.	0.	0.	0.	0.	0.	0.	0.
91213	0.000	0.000	386.621	0.	0.	0.	0.	0.	0.	0.	0.
91214	0.000	0.000	388.365	0.	0.	0.	0.	0.	0.	0.	0.
91215	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
91216	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
91217	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
91218	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91219	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91220	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91221	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91222	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
91223	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
91224	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 12)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	388.365	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3535.447	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	147.310	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE256 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
913 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
913 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
913 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
913 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
913 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
913 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
913 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
913 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
913 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91310	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91311	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91312	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91313	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91314	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91315	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
91316	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
91317	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
91318	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
91319	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
91320	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
91321	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
91322	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
91323	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
91324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 13)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE257 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
914 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
914 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
914 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
914 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
914 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
914 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
914 7	0.000	1.033	540.117	0.	0.	0.	0.	0.	0.	0.	0.
914 8	0.000	0.000	625.717	0.	0.	0.	0.	0.	0.	0.	0.
914 9	0.000	0.000	650.461	0.	0.	0.	0.	0.	0.	0.	0.
91410	0.000	0.000	661.073	0.	0.	0.	0.	0.	0.	0.	0.
91411	0.000	0.000	636.852	0.	0.	0.	0.	0.	0.	0.	0.
91412	0.000	0.000	640.667	0.	0.	0.	0.	0.	0.	0.	0.
91413	0.000	0.000	665.615	0.	0.	0.	0.	0.	0.	0.	0.
91414	0.000	0.000	688.147	0.	0.	0.	0.	0.	0.	0.	0.
91415	0.000	0.000	691.914	0.	0.	0.	0.	0.	0.	0.	0.
91416	0.000	1.550	675.147	0.	0.	0.	0.	0.	0.	0.	0.
91417	0.000	6.199	628.861	0.	0.	0.	0.	0.	0.	0.	0.
91418	0.000	9.299	498.593	0.	0.	0.	0.	0.	0.	0.	0.
91419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	691.914	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8333.555	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	347.231	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE258 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
915 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
915 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
915 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
915 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
915 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
915 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
915 7	0.000	1.033	569.214	0.	0.	0.	0.	0.	0.	0.	0.
915 8	0.000	0.000	634.358	0.	0.	0.	0.	0.	0.	0.	0.
915 9	0.000	0.000	651.784	0.	0.	0.	0.	0.	0.	0.	0.
91510	0.000	0.000	668.642	0.	0.	0.	0.	0.	0.	0.	0.
91511	0.000	0.000	643.325	0.	0.	0.	0.	0.	0.	0.	0.
91512	0.000	0.000	643.807	0.	0.	0.	0.	0.	0.	0.	0.
91513	0.000	0.000	668.873	0.	0.	0.	0.	0.	0.	0.	0.
91514	0.000	0.000	681.473	0.	0.	0.	0.	0.	0.	0.	0.
91515	0.000	0.000	680.016	0.	0.	0.	0.	0.	0.	0.	0.
91516	0.000	1.550	672.533	0.	0.	0.	0.	0.	0.	0.	0.
91517	0.000	6.199	625.237	0.	0.	0.	0.	0.	0.	0.	0.
91518	0.000	9.299	499.461	0.	0.	0.	0.	0.	0.	0.	0.
91519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	681.473	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8369.113	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	348.713	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE259 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
916 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
916 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
916 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
916 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
916 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
916 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
916 7	0.000	1.033	516.802	0.	0.	0.	0.	0.	0.	0.	0.
916 8	0.000	0.000	629.354	0.	0.	0.	0.	0.	0.	0.	0.
916 9	0.000	0.000	668.081	0.	0.	0.	0.	0.	0.	0.	0.
91610	0.000	0.000	690.255	0.	0.	0.	0.	0.	0.	0.	0.
91611	0.000	0.000	682.417	0.	0.	0.	0.	0.	0.	0.	0.
91612	0.000	0.000	682.835	0.	0.	0.	0.	0.	0.	0.	0.
91613	0.000	0.000	714.608	0.	0.	0.	0.	0.	0.	0.	0.
91614	0.000	0.000	724.734	0.	0.	0.	0.	0.	0.	0.	0.
91615	0.000	0.000	729.432	0.	0.	0.	0.	0.	0.	0.	0.
91616	0.000	1.550	707.885	0.	0.	0.	0.	0.	0.	0.	0.
91617	0.000	6.199	658.245	0.	0.	0.	0.	0.	0.	0.	0.
91618	0.000	9.299	502.596	0.	0.	0.	0.	0.	0.	0.	0.
91619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	729.432	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8637.634	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	359.901	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE260 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
917 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
917 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
917 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
917 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
917 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
917 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
917 7	0.000	1.033	516.586	0.	0.	0.	0.	0.	0.	0.	0.
917 8	0.000	0.000	662.355	0.	0.	0.	0.	0.	0.	0.	0.
917 9	0.000	0.000	683.913	0.	0.	0.	0.	0.	0.	0.	0.
91710	0.000	0.000	682.830	0.	0.	0.	0.	0.	0.	0.	0.
91711	0.000	0.000	651.713	0.	0.	0.	0.	0.	0.	0.	0.
91712	0.000	0.000	649.746	0.	0.	0.	0.	0.	0.	0.	0.
91713	0.000	0.000	671.399	0.	0.	0.	0.	0.	0.	0.	0.
91714	0.000	0.000	681.957	0.	0.	0.	0.	0.	0.	0.	0.
91715	0.000	0.000	668.250	0.	0.	0.	0.	0.	0.	0.	0.
91716	0.000	1.550	659.143	0.	0.	0.	0.	0.	0.	0.	0.
91717	0.000	6.199	602.711	0.	0.	0.	0.	0.	0.	0.	0.
91718	0.000	9.299	446.989	0.	0.	0.	0.	0.	0.	0.	0.
91719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	683.913	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8307.980	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	346.166	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE261 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
918 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
918 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
918 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
918 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
918 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
918 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
918 7	0.000	1.033	508.222	0.	0.	0.	0.	0.	0.	0.	0.
918 8	0.000	0.000	604.569	0.	0.	0.	0.	0.	0.	0.	0.
918 9	0.000	0.000	612.510	0.	0.	0.	0.	0.	0.	0.	0.
91810	0.000	0.000	610.260	0.	0.	0.	0.	0.	0.	0.	0.
91811	0.000	0.000	616.290	0.	0.	0.	0.	0.	0.	0.	0.
91812	0.000	0.000	626.232	0.	0.	0.	0.	0.	0.	0.	0.
91813	0.000	0.000	665.819	0.	0.	0.	0.	0.	0.	0.	0.
91814	0.000	0.000	668.646	0.	0.	0.	0.	0.	0.	0.	0.
91815	0.000	0.000	671.784	0.	0.	0.	0.	0.	0.	0.	0.
91816	0.000	1.550	655.424	0.	0.	0.	0.	0.	0.	0.	0.
91817	0.000	6.199	602.358	0.	0.	0.	0.	0.	0.	0.	0.
91818	0.000	9.299	441.047	0.	0.	0.	0.	0.	0.	0.	0.
91819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
91820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
91821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
91822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
91823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
91824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	671.784	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8013.551	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	333.898	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE262 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
919 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
919 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
919 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
919 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
919 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
919 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
919 7	0.000	1.033	284.825	0.	0.	0.	0.	0.	0.	0.	0.
919 8	0.000	0.000	256.268	0.	0.	0.	0.	0.	0.	0.	0.
919 9	0.000	0.000	290.533	0.	0.	0.	0.	0.	0.	0.	0.
91910	0.000	0.000	289.849	0.	0.	0.	0.	0.	0.	0.	0.
91911	0.000	0.000	300.642	0.	0.	0.	0.	0.	0.	0.	0.
91912	0.000	0.000	300.929	0.	0.	0.	0.	0.	0.	0.	0.
91913	0.000	0.000	290.127	0.	0.	0.	0.	0.	0.	0.	0.
91914	0.000	0.000	301.363	0.	0.	0.	0.	0.	0.	0.	0.
91915	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
91916	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
91917	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
91918	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91919	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91920	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91921	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
91922	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
91923	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
91924	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 19)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	301.363	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2985.708	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	124.404	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE263 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
920 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
920 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
920 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
920 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
920 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
920 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
920 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
920 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
920 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92010	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92011	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92012	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92013	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92014	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92015	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92016	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
92017	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
92018	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92019	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92020	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92021	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92022	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
92023	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
92024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 20)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE264 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
921 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
921 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
921 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
921 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
921 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
921 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
921 7	0.000	1.033	466.739	0.	0.	0.	0.	0.	0.	0.	0.
921 8	0.000	0.000	504.007	0.	0.	0.	0.	0.	0.	0.	0.
921 9	0.000	0.000	606.868	0.	0.	0.	0.	0.	0.	0.	0.
92110	0.000	0.000	611.552	0.	0.	0.	0.	0.	0.	0.	0.
92111	0.000	0.000	630.930	0.	0.	0.	0.	0.	0.	0.	0.
92112	0.000	0.000	632.703	0.	0.	0.	0.	0.	0.	0.	0.
92113	0.000	0.000	658.865	0.	0.	0.	0.	0.	0.	0.	0.
92114	0.000	0.000	671.188	0.	0.	0.	0.	0.	0.	0.	0.
92115	0.000	0.000	684.017	0.	0.	0.	0.	0.	0.	0.	0.
92116	0.000	1.550	673.588	0.	0.	0.	0.	0.	0.	0.	0.
92117	0.000	6.199	626.268	0.	0.	0.	0.	0.	0.	0.	0.
92118	0.000	9.299	456.189	0.	0.	0.	0.	0.	0.	0.	0.
92119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	684.017	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7953.304	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	331.388	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE265 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	---- (11)	---- (12)	---- (20)	---- (1)	---- (2)	---- (3)	---- (4)	---- (5)	---- (6)	---- (7)	---- (8)
922 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
922 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
922 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
922 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
922 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
922 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
922 7	0.000	1.033	467.507	0.	0.	0.	0.	0.	0.	0.	0.
922 8	0.000	0.000	609.807	0.	0.	0.	0.	0.	0.	0.	0.
922 9	0.000	0.000	654.700	0.	0.	0.	0.	0.	0.	0.	0.
92210	0.000	0.000	678.232	0.	0.	0.	0.	0.	0.	0.	0.
92211	0.000	0.000	655.152	0.	0.	0.	0.	0.	0.	0.	0.
92212	0.000	0.000	656.122	0.	0.	0.	0.	0.	0.	0.	0.
92213	0.000	0.000	694.728	0.	0.	0.	0.	0.	0.	0.	0.
92214	0.000	0.000	683.486	0.	0.	0.	0.	0.	0.	0.	0.
92215	0.000	0.000	682.355	0.	0.	0.	0.	0.	0.	0.	0.
92216	0.000	1.550	694.461	0.	0.	0.	0.	0.	0.	0.	0.
92217	0.000	6.199	665.602	0.	0.	0.	0.	0.	0.	0.	0.
92218	0.000	9.299	516.001	0.	0.	0.	0.	0.	0.	0.	0.
92219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	694.728	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8388.544	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	349.523	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE266 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
923 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
923 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
923 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
923 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
923 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
923 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
923 7	0.000	1.033	488.493	0.	0.	0.	0.	0.	0.	0.	0.
923 8	0.000	0.000	636.869	0.	0.	0.	0.	0.	0.	0.	0.
923 9	0.000	0.000	661.414	0.	0.	0.	0.	0.	0.	0.	0.
92310	0.000	0.000	670.993	0.	0.	0.	0.	0.	0.	0.	0.
92311	0.000	0.000	648.764	0.	0.	0.	0.	0.	0.	0.	0.
92312	0.000	0.000	651.080	0.	0.	0.	0.	0.	0.	0.	0.
92313	0.000	0.000	674.859	0.	0.	0.	0.	0.	0.	0.	0.
92314	0.000	0.000	691.764	0.	0.	0.	0.	0.	0.	0.	0.
92315	0.000	0.000	693.361	0.	0.	0.	0.	0.	0.	0.	0.
92316	0.000	1.550	686.922	0.	0.	0.	0.	0.	0.	0.	0.
92317	0.000	6.199	643.036	0.	0.	0.	0.	0.	0.	0.	0.
92318	0.000	9.299	524.450	0.	0.	0.	0.	0.	0.	0.	0.
92319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	693.361	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8402.396	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	350.100	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE267 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
924 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
924 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
924 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
924 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
924 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
924 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
924 7	0.000	1.033	569.606	0.	0.	0.	0.	0.	0.	0.	0.
924 8	0.000	0.000	658.717	0.	0.	0.	0.	0.	0.	0.	0.
924 9	0.000	0.000	679.729	0.	0.	0.	0.	0.	0.	0.	0.
92410	0.000	0.000	686.263	0.	0.	0.	0.	0.	0.	0.	0.
92411	0.000	0.000	669.008	0.	0.	0.	0.	0.	0.	0.	0.
92412	0.000	0.000	667.236	0.	0.	0.	0.	0.	0.	0.	0.
92413	0.000	0.000	688.750	0.	0.	0.	0.	0.	0.	0.	0.
92414	0.000	0.000	701.248	0.	0.	0.	0.	0.	0.	0.	0.
92415	0.000	0.000	700.148	0.	0.	0.	0.	0.	0.	0.	0.
92416	0.000	1.550	692.018	0.	0.	0.	0.	0.	0.	0.	0.
92417	0.000	6.199	644.451	0.	0.	0.	0.	0.	0.	0.	0.
92418	0.000	9.299	527.332	0.	0.	0.	0.	0.	0.	0.	0.
92419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	701.248	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8614.896	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	358.954	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE268 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
925 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
925 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
925 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
925 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
925 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
925 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
925 7	0.000	1.033	576.287	0.	0.	0.	0.	0.	0.	0.	0.
925 8	0.000	0.000	661.927	0.	0.	0.	0.	0.	0.	0.	0.
925 9	0.000	0.000	682.790	0.	0.	0.	0.	0.	0.	0.	0.
92510	0.000	0.000	692.842	0.	0.	0.	0.	0.	0.	0.	0.
92511	0.000	0.000	662.022	0.	0.	0.	0.	0.	0.	0.	0.
92512	0.000	0.000	663.108	0.	0.	0.	0.	0.	0.	0.	0.
92513	0.000	0.000	689.666	0.	0.	0.	0.	0.	0.	0.	0.
92514	0.000	0.000	712.155	0.	0.	0.	0.	0.	0.	0.	0.
92515	0.000	0.000	728.839	0.	0.	0.	0.	0.	0.	0.	0.
92516	0.000	1.550	721.670	0.	0.	0.	0.	0.	0.	0.	0.
92517	0.000	6.199	668.276	0.	0.	0.	0.	0.	0.	0.	0.
92518	0.000	9.299	541.985	0.	0.	0.	0.	0.	0.	0.	0.
92519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 25)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	728.839	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8731.959	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	363.832	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE269 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
926 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
926 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
926 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
926 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
926 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
926 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
926 7	0.000	1.033	262.147	0.	0.	0.	0.	0.	0.	0.	0.
926 8	0.000	0.000	214.070	0.	0.	0.	0.	0.	0.	0.	0.
926 9	0.000	0.000	287.834	0.	0.	0.	0.	0.	0.	0.	0.
92610	0.000	0.000	369.892	0.	0.	0.	0.	0.	0.	0.	0.
92611	0.000	0.000	381.580	0.	0.	0.	0.	0.	0.	0.	0.
92612	0.000	0.000	371.577	0.	0.	0.	0.	0.	0.	0.	0.
92613	0.000	0.000	382.187	0.	0.	0.	0.	0.	0.	0.	0.
92614	0.000	0.000	375.446	0.	0.	0.	0.	0.	0.	0.	0.
92615	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
92616	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
92617	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
92618	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
92619	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
92620	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
92621	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
92622	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
92623	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
92624	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 26)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	382.187	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3315.907	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	138.163	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE270 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
927 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
927 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
927 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
927 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
927 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
927 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
927 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
927 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
927 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92710	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92711	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92712	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92713	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92714	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92715	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
92716	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
92717	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
92718	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92719	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92720	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92721	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
92722	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
92723	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
92724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 27)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE271 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
928 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
928 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
928 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
928 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
928 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
928 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
928 7	0.000	1.033	474.601	0.	0.	0.	0.	0.	0.	0.	0.
928 8	0.000	0.000	528.670	0.	0.	0.	0.	0.	0.	0.	0.
928 9	0.000	0.000	608.500	0.	0.	0.	0.	0.	0.	0.	0.
92810	0.000	0.000	642.403	0.	0.	0.	0.	0.	0.	0.	0.
92811	0.000	0.000	641.501	0.	0.	0.	0.	0.	0.	0.	0.
92812	0.000	0.000	655.252	0.	0.	0.	0.	0.	0.	0.	0.
92813	0.000	0.000	681.339	0.	0.	0.	0.	0.	0.	0.	0.
92814	0.000	0.000	687.407	0.	0.	0.	0.	0.	0.	0.	0.
92815	0.000	0.000	662.011	0.	0.	0.	0.	0.	0.	0.	0.
92816	0.000	1.550	650.948	0.	0.	0.	0.	0.	0.	0.	0.
92817	0.000	6.199	577.448	0.	0.	0.	0.	0.	0.	0.	0.
92818	0.000	9.299	441.556	0.	0.	0.	0.	0.	0.	0.	0.
92819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	687.407	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7982.026	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	332.584	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE272 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
929 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
929 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
929 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
929 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
929 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
929 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
929 7	0.000	1.033	522.560	0.	0.	0.	0.	0.	0.	0.	0.
929 8	0.000	0.000	578.556	0.	0.	0.	0.	0.	0.	0.	0.
929 9	0.000	0.000	623.430	0.	0.	0.	0.	0.	0.	0.	0.
92910	0.000	0.000	623.314	0.	0.	0.	0.	0.	0.	0.	0.
92911	0.000	0.000	605.428	0.	0.	0.	0.	0.	0.	0.	0.
92912	0.000	0.000	609.898	0.	0.	0.	0.	0.	0.	0.	0.
92913	0.000	0.000	649.562	0.	0.	0.	0.	0.	0.	0.	0.
92914	0.000	0.000	668.002	0.	0.	0.	0.	0.	0.	0.	0.
92915	0.000	0.000	665.476	0.	0.	0.	0.	0.	0.	0.	0.
92916	0.000	1.550	650.215	0.	0.	0.	0.	0.	0.	0.	0.
92917	0.000	6.199	607.725	0.	0.	0.	0.	0.	0.	0.	0.
92918	0.000	9.299	427.037	0.	0.	0.	0.	0.	0.	0.	0.
92919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
92920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
92921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
92922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
92923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
92924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	668.002	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7961.593	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	331.733	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE273 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
930 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
930 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
930 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
930 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
930 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
930 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
930 7	0.000	1.033	498.979	0.	0.	0.	0.	0.	0.	0.	0.
930 8	0.000	0.000	545.975	0.	0.	0.	0.	0.	0.	0.	0.
930 9	0.000	0.000	577.869	0.	0.	0.	0.	0.	0.	0.	0.
93010	0.000	0.000	596.069	0.	0.	0.	0.	0.	0.	0.	0.
93011	0.000	0.000	590.746	0.	0.	0.	0.	0.	0.	0.	0.
93012	0.000	0.000	613.294	0.	0.	0.	0.	0.	0.	0.	0.
93013	0.000	0.000	636.648	0.	0.	0.	0.	0.	0.	0.	0.
93014	0.000	0.000	645.376	0.	0.	0.	0.	0.	0.	0.	0.
93015	0.000	0.000	641.325	0.	0.	0.	0.	0.	0.	0.	0.
93016	0.000	1.550	621.188	0.	0.	0.	0.	0.	0.	0.	0.
93017	0.000	6.199	556.577	0.	0.	0.	0.	0.	0.	0.	0.
93018	0.000	9.299	382.049	0.	0.	0.	0.	0.	0.	0.	0.
93019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
93020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
93021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
93022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
93023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
93024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	645.376	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7636.484	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	318.187	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (SEP)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	762.307	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	3053.107	192455.906	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	267.300	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE274 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 1 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 1 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 1 7	0.000	1.033	467.090	0.	0.	0.	0.	0.	0.	0.	0.
10 1 8	0.000	0.000	523.909	0.	0.	0.	0.	0.	0.	0.	0.
10 1 9	0.000	0.000	636.564	0.	0.	0.	0.	0.	0.	0.	0.
10 110	0.000	0.000	661.182	0.	0.	0.	0.	0.	0.	0.	0.
10 111	0.000	0.000	655.783	0.	0.	0.	0.	0.	0.	0.	0.
10 112	0.000	0.000	659.173	0.	0.	0.	0.	0.	0.	0.	0.
10 113	0.000	0.000	690.260	0.	0.	0.	0.	0.	0.	0.	0.
10 114	0.000	0.000	702.100	0.	0.	0.	0.	0.	0.	0.	0.
10 115	0.000	0.000	688.611	0.	0.	0.	0.	0.	0.	0.	0.
10 116	0.000	1.550	667.815	0.	0.	0.	0.	0.	0.	0.	0.
10 117	0.000	6.199	614.960	0.	0.	0.	0.	0.	0.	0.	0.
10 118	0.000	9.299	447.889	0.	0.	0.	0.	0.	0.	0.	0.
10 119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	702.100	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8145.726	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	339.405	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE275 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 2 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 2 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 2 7	0.000	1.033	546.489	0.	0.	0.	0.	0.	0.	0.	0.
10 2 8	0.000	0.000	632.997	0.	0.	0.	0.	0.	0.	0.	0.
10 2 9	0.000	0.000	641.141	0.	0.	0.	0.	0.	0.	0.	0.
10 210	0.000	0.000	603.301	0.	0.	0.	0.	0.	0.	0.	0.
10 211	0.000	0.000	620.292	0.	0.	0.	0.	0.	0.	0.	0.
10 212	0.000	0.000	636.567	0.	0.	0.	0.	0.	0.	0.	0.
10 213	0.000	0.000	650.332	0.	0.	0.	0.	0.	0.	0.	0.
10 214	0.000	0.000	653.357	0.	0.	0.	0.	0.	0.	0.	0.
10 215	0.000	0.000	649.768	0.	0.	0.	0.	0.	0.	0.	0.
10 216	0.000	1.550	643.666	0.	0.	0.	0.	0.	0.	0.	0.
10 217	0.000	6.199	565.199	0.	0.	0.	0.	0.	0.	0.	0.
10 218	0.000	9.299	370.845	0.	0.	0.	0.	0.	0.	0.	0.
10 219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	653.357	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7944.344	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	331.014	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE276 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 3 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 3 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
10 3 7	0.000	1.033	254.363	0.	0.	0.	0.	0.	0.	0.	0.
10 3 8	0.000	0.000	257.487	0.	0.	0.	0.	0.	0.	0.	0.
10 3 9	0.000	0.000	302.633	0.	0.	0.	0.	0.	0.	0.	0.
10 310	0.000	0.000	308.887	0.	0.	0.	0.	0.	0.	0.	0.
10 311	0.000	0.000	337.245	0.	0.	0.	0.	0.	0.	0.	0.
10 312	0.000	0.000	338.116	0.	0.	0.	0.	0.	0.	0.	0.
10 313	0.000	0.000	326.910	0.	0.	0.	0.	0.	0.	0.	0.
10 314	0.000	0.000	308.772	0.	0.	0.	0.	0.	0.	0.	0.
10 315	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
10 316	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
10 317	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 318	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
10 319	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
10 320	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
10 321	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
10 322	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
10 323	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
10 324	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 3)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	338.116	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3105.586	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	129.399	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE277 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 4 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
10 4 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
10 4 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
10 4 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
10 4 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
10 4 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
10 4 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
10 4 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 4 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 410	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 411	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 412	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 413	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 414	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 415	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
10 416	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
10 417	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
10 418	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
10 419	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
10 420	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
10 421	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
10 422	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
10 423	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
10 424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 4)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE278 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 5 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 5 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 5 7	0.000	1.033	468.275	0.	0.	0.	0.	0.	0.	0.	0.
10 5 8	0.000	0.000	588.787	0.	0.	0.	0.	0.	0.	0.	0.
10 5 9	0.000	0.000	680.017	0.	0.	0.	0.	0.	0.	0.	0.
10 510	0.000	0.000	725.001	0.	0.	0.	0.	0.	0.	0.	0.
10 511	0.000	0.000	668.451	0.	0.	0.	0.	0.	0.	0.	0.
10 512	0.000	0.000	656.849	0.	0.	0.	0.	0.	0.	0.	0.
10 513	0.000	0.000	681.628	0.	0.	0.	0.	0.	0.	0.	0.
10 514	0.000	0.000	705.023	0.	0.	0.	0.	0.	0.	0.	0.
10 515	0.000	0.000	700.668	0.	0.	0.	0.	0.	0.	0.	0.
10 516	0.000	1.550	725.459	0.	0.	0.	0.	0.	0.	0.	0.
10 517	0.000	6.199	674.255	0.	0.	0.	0.	0.	0.	0.	0.
10 518	0.000	9.299	516.193	0.	0.	0.	0.	0.	0.	0.	0.
10 519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	725.459	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8520.996	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	355.042	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE279 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 6 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 6 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 6 7	0.000	1.033	544.380	0.	0.	0.	0.	0.	0.	0.	0.
10 6 8	0.000	0.000	640.348	0.	0.	0.	0.	0.	0.	0.	0.
10 6 9	0.000	0.000	653.374	0.	0.	0.	0.	0.	0.	0.	0.
10 610	0.000	0.000	663.344	0.	0.	0.	0.	0.	0.	0.	0.
10 611	0.000	0.000	650.625	0.	0.	0.	0.	0.	0.	0.	0.
10 612	0.000	0.000	665.656	0.	0.	0.	0.	0.	0.	0.	0.
10 613	0.000	0.000	690.792	0.	0.	0.	0.	0.	0.	0.	0.
10 614	0.000	0.000	708.525	0.	0.	0.	0.	0.	0.	0.	0.
10 615	0.000	0.000	709.721	0.	0.	0.	0.	0.	0.	0.	0.
10 616	0.000	1.550	685.610	0.	0.	0.	0.	0.	0.	0.	0.
10 617	0.000	6.199	627.654	0.	0.	0.	0.	0.	0.	0.	0.
10 618	0.000	9.299	493.778	0.	0.	0.	0.	0.	0.	0.	0.
10 619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	709.721	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8464.199	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	352.675	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE280 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 7 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 7 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 7 7	0.000	1.033	519.071	0.	0.	0.	0.	0.	0.	0.	0.
10 7 8	0.000	0.000	656.399	0.	0.	0.	0.	0.	0.	0.	0.
10 7 9	0.000	0.000	689.432	0.	0.	0.	0.	0.	0.	0.	0.
10 710	0.000	0.000	692.038	0.	0.	0.	0.	0.	0.	0.	0.
10 711	0.000	0.000	679.667	0.	0.	0.	0.	0.	0.	0.	0.
10 712	0.000	0.000	690.490	0.	0.	0.	0.	0.	0.	0.	0.
10 713	0.000	0.000	725.042	0.	0.	0.	0.	0.	0.	0.	0.
10 714	0.000	0.000	737.841	0.	0.	0.	0.	0.	0.	0.	0.
10 715	0.000	0.000	741.029	0.	0.	0.	0.	0.	0.	0.	0.
10 716	0.000	1.550	699.264	0.	0.	0.	0.	0.	0.	0.	0.
10 717	0.000	6.199	640.141	0.	0.	0.	0.	0.	0.	0.	0.
10 718	0.000	9.299	434.713	0.	0.	0.	0.	0.	0.	0.	0.
10 719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 7)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	741.029	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8635.519	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	359.813	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE281 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 8 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 8 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 8 7	0.000	1.033	469.432	0.	0.	0.	0.	0.	0.	0.	0.
10 8 8	0.000	0.000	469.703	0.	0.	0.	0.	0.	0.	0.	0.
10 8 9	0.000	0.000	638.787	0.	0.	0.	0.	0.	0.	0.	0.
10 810	0.000	0.000	693.339	0.	0.	0.	0.	0.	0.	0.	0.
10 811	0.000	0.000	664.288	0.	0.	0.	0.	0.	0.	0.	0.
10 812	0.000	0.000	665.535	0.	0.	0.	0.	0.	0.	0.	0.
10 813	0.000	0.000	689.408	0.	0.	0.	0.	0.	0.	0.	0.
10 814	0.000	0.000	685.456	0.	0.	0.	0.	0.	0.	0.	0.
10 815	0.000	0.000	675.447	0.	0.	0.	0.	0.	0.	0.	0.
10 816	0.000	1.550	643.132	0.	0.	0.	0.	0.	0.	0.	0.
10 817	0.000	6.199	511.578	0.	0.	0.	0.	0.	0.	0.	0.
10 818	0.000	9.299	348.708	0.	0.	0.	0.	0.	0.	0.	0.
10 819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	693.339	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7885.202	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	328.550	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE282 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
10 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
10 9 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
10 9 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
10 9 7	0.000	1.033	470.624	0.	0.	0.	0.	0.	0.	0.	0.
10 9 8	0.000	0.000	598.096	0.	0.	0.	0.	0.	0.	0.	0.
10 9 9	0.000	0.000	642.339	0.	0.	0.	0.	0.	0.	0.	0.
10 9 10	0.000	0.000	690.021	0.	0.	0.	0.	0.	0.	0.	0.
10 9 11	0.000	0.000	652.232	0.	0.	0.	0.	0.	0.	0.	0.
10 9 12	0.000	0.000	645.647	0.	0.	0.	0.	0.	0.	0.	0.
10 9 13	0.000	0.000	671.392	0.	0.	0.	0.	0.	0.	0.	0.
10 9 14	0.000	0.000	673.260	0.	0.	0.	0.	0.	0.	0.	0.
10 9 15	0.000	0.000	680.745	0.	0.	0.	0.	0.	0.	0.	0.
10 9 16	0.000	1.550	648.303	0.	0.	0.	0.	0.	0.	0.	0.
10 9 17	0.000	6.199	556.223	0.	0.	0.	0.	0.	0.	0.	0.
10 9 18	0.000	9.299	424.596	0.	0.	0.	0.	0.	0.	0.	0.
10 9 19	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
10 9 20	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
10 9 21	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
10 9 22	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
10 9 23	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
10 9 24	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	690.021	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8083.867	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	336.828	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE283 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1010 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1010 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1010 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1010 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1010 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1010 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1010 7	0.000	1.033	262.505	0.	0.	0.	0.	0.	0.	0.	0.
1010 8	0.000	0.000	255.328	0.	0.	0.	0.	0.	0.	0.	0.
1010 9	0.000	0.000	282.984	0.	0.	0.	0.	0.	0.	0.	0.
101010	0.000	0.000	317.170	0.	0.	0.	0.	0.	0.	0.	0.
101011	0.000	0.000	385.598	0.	0.	0.	0.	0.	0.	0.	0.
101012	0.000	0.000	374.166	0.	0.	0.	0.	0.	0.	0.	0.
101013	0.000	0.000	373.449	0.	0.	0.	0.	0.	0.	0.	0.
101014	0.000	0.000	344.297	0.	0.	0.	0.	0.	0.	0.	0.
101015	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
101016	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
101017	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
101018	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101019	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101020	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101021	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101022	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
101023	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
101024	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 10)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	385.598	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3266.672	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	136.111	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE284 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1011 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1011 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1011 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1011 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1011 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1011 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1011 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1011 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1011 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101116	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
101117	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
101118	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101119	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101120	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101122	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
101123	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
101124	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 11)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE285 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1012 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1012 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1012 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1012 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1012 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1012 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1012 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1012 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1012 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101216	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
101217	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
101218	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101219	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101220	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101222	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
101223	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
101224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 12)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE286 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1013 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1013 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1013 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1013 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1013 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1013 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1013 7	0.000	1.033	468.503	0.	0.	0.	0.	0.	0.	0.	0.
1013 8	0.000	0.000	524.749	0.	0.	0.	0.	0.	0.	0.	0.
1013 9	0.000	0.000	575.379	0.	0.	0.	0.	0.	0.	0.	0.
101310	0.000	0.000	648.142	0.	0.	0.	0.	0.	0.	0.	0.
101311	0.000	0.000	618.889	0.	0.	0.	0.	0.	0.	0.	0.
101312	0.000	0.000	611.510	0.	0.	0.	0.	0.	0.	0.	0.
101313	0.000	0.000	657.676	0.	0.	0.	0.	0.	0.	0.	0.
101314	0.000	0.000	680.019	0.	0.	0.	0.	0.	0.	0.	0.
101315	0.000	0.000	666.353	0.	0.	0.	0.	0.	0.	0.	0.
101316	0.000	1.550	643.591	0.	0.	0.	0.	0.	0.	0.	0.
101317	0.000	6.199	492.200	0.	0.	0.	0.	0.	0.	0.	0.
101318	0.000	9.299	343.793	0.	0.	0.	0.	0.	0.	0.	0.
101319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
101320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
101321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
101322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
101323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
101324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	680.019	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7661.195	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	319.216	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE287 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1014 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1014 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1014 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1014 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1014 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1014 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1014 7	0.000	1.033	495.289	0.	0.	0.	0.	0.	0.	0.	0.
1014 8	0.000	0.000	556.493	0.	0.	0.	0.	0.	0.	0.	0.
1014 9	0.000	0.000	596.934	0.	0.	0.	0.	0.	0.	0.	0.
101410	0.000	0.000	610.253	0.	0.	0.	0.	0.	0.	0.	0.
101411	0.000	0.000	608.440	0.	0.	0.	0.	0.	0.	0.	0.
101412	0.000	0.000	602.046	0.	0.	0.	0.	0.	0.	0.	0.
101413	0.000	0.000	631.849	0.	0.	0.	0.	0.	0.	0.	0.
101414	0.000	0.000	630.366	0.	0.	0.	0.	0.	0.	0.	0.
101415	0.000	0.000	656.466	0.	0.	0.	0.	0.	0.	0.	0.
101416	0.000	1.550	633.109	0.	0.	0.	0.	0.	0.	0.	0.
101417	0.000	6.199	569.876	0.	0.	0.	0.	0.	0.	0.	0.
101418	0.000	9.299	374.337	0.	0.	0.	0.	0.	0.	0.	0.
101419	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
101420	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
101421	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
101422	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
101423	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
101424	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	656.466	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7695.847	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	320.660	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE288 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1015 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1015 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1015 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1015 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1015 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1015 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1015 7	0.000	1.033	466.897	0.	0.	0.	0.	0.	0.	0.	0.
1015 8	0.000	0.000	514.539	0.	0.	0.	0.	0.	0.	0.	0.
1015 9	0.000	0.000	576.263	0.	0.	0.	0.	0.	0.	0.	0.
101510	0.000	0.000	592.668	0.	0.	0.	0.	0.	0.	0.	0.
101511	0.000	0.000	611.025	0.	0.	0.	0.	0.	0.	0.	0.
101512	0.000	0.000	616.633	0.	0.	0.	0.	0.	0.	0.	0.
101513	0.000	0.000	643.509	0.	0.	0.	0.	0.	0.	0.	0.
101514	0.000	0.000	659.823	0.	0.	0.	0.	0.	0.	0.	0.
101515	0.000	0.000	657.980	0.	0.	0.	0.	0.	0.	0.	0.
101516	0.000	1.550	639.073	0.	0.	0.	0.	0.	0.	0.	0.
101517	0.000	6.199	541.977	0.	0.	0.	0.	0.	0.	0.	0.
101518	0.000	9.299	342.954	0.	0.	0.	0.	0.	0.	0.	0.
101519	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
101520	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
101521	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
101522	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
101523	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
101524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	659.823	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7593.731	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	316.405	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE289 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1016 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1016 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1016 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1016 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1016 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1016 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1016 7	0.000	1.033	464.416	0.	0.	0.	0.	0.	0.	0.	0.
1016 8	0.000	0.000	557.551	0.	0.	0.	0.	0.	0.	0.	0.
1016 9	0.000	0.000	634.543	0.	0.	0.	0.	0.	0.	0.	0.
101610	0.000	0.000	650.812	0.	0.	0.	0.	0.	0.	0.	0.
101611	0.000	0.000	637.458	0.	0.	0.	0.	0.	0.	0.	0.
101612	0.000	0.000	628.233	0.	0.	0.	0.	0.	0.	0.	0.
101613	0.000	0.000	661.544	0.	0.	0.	0.	0.	0.	0.	0.
101614	0.000	0.000	678.983	0.	0.	0.	0.	0.	0.	0.	0.
101615	0.000	0.000	677.612	0.	0.	0.	0.	0.	0.	0.	0.
101616	0.000	1.550	664.954	0.	0.	0.	0.	0.	0.	0.	0.
101617	0.000	6.199	558.131	0.	0.	0.	0.	0.	0.	0.	0.
101618	0.000	9.299	388.141	0.	0.	0.	0.	0.	0.	0.	0.
101619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
101620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
101621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
101622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
101623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
101624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	678.983	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7932.769	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	330.532	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE290 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1017 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1017 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1017 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1017 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1017 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1017 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1017 7	0.000	1.033	252.790	0.	0.	0.	0.	0.	0.	0.	0.
1017 8	0.000	0.000	262.703	0.	0.	0.	0.	0.	0.	0.	0.
1017 9	0.000	0.000	355.553	0.	0.	0.	0.	0.	0.	0.	0.
101710	0.000	0.000	369.972	0.	0.	0.	0.	0.	0.	0.	0.
101711	0.000	0.000	357.022	0.	0.	0.	0.	0.	0.	0.	0.
101712	0.000	0.000	344.187	0.	0.	0.	0.	0.	0.	0.	0.
101713	0.000	0.000	370.508	0.	0.	0.	0.	0.	0.	0.	0.
101714	0.000	0.000	373.017	0.	0.	0.	0.	0.	0.	0.	0.
101715	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
101716	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
101717	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
101718	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101719	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101720	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101721	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
101722	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
101723	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
101724	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 17)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	373.017	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3356.926	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	139.872	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE291 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1018 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1018 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1018 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1018 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1018 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1018 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1018 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1018 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1018 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101810	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101811	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101812	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101813	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101814	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101815	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
101816	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
101817	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
101818	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101819	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101820	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101821	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
101822	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
101823	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
101824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 18)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE292 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1019 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1019 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1019 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1019 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1019 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1019 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1019 7	0.000	1.033	545.928	0.	0.	0.	0.	0.	0.	0.	0.
1019 8	0.000	0.000	634.497	0.	0.	0.	0.	0.	0.	0.	0.
1019 9	0.000	0.000	654.660	0.	0.	0.	0.	0.	0.	0.	0.
101910	0.000	0.000	662.685	0.	0.	0.	0.	0.	0.	0.	0.
101911	0.000	0.000	643.842	0.	0.	0.	0.	0.	0.	0.	0.
101912	0.000	0.000	664.525	0.	0.	0.	0.	0.	0.	0.	0.
101913	0.000	0.000	683.998	0.	0.	0.	0.	0.	0.	0.	0.
101914	0.000	0.000	697.926	0.	0.	0.	0.	0.	0.	0.	0.
101915	0.000	0.000	693.266	0.	0.	0.	0.	0.	0.	0.	0.
101916	0.000	1.550	691.215	0.	0.	0.	0.	0.	0.	0.	0.
101917	0.000	6.199	566.986	0.	0.	0.	0.	0.	0.	0.	0.
101918	0.000	9.299	392.627	0.	0.	0.	0.	0.	0.	0.	0.
101919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
101920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
101921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
101922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
101923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
101924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	697.926	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	8262.544	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	344.273	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE293 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1020 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1020 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1020 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1020 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1020 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1020 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1020 7	0.000	1.033	564.042	0.	0.	0.	0.	0.	0.	0.	0.
1020 8	0.000	0.000	624.780	0.	0.	0.	0.	0.	0.	0.	0.
1020 9	0.000	0.000	629.241	0.	0.	0.	0.	0.	0.	0.	0.
102010	0.000	0.000	601.476	0.	0.	0.	0.	0.	0.	0.	0.
102011	0.000	0.000	572.194	0.	0.	0.	0.	0.	0.	0.	0.
102012	0.000	0.000	553.228	0.	0.	0.	0.	0.	0.	0.	0.
102013	0.000	0.000	653.397	0.	0.	0.	0.	0.	0.	0.	0.
102014	0.000	0.000	677.156	0.	0.	0.	0.	0.	0.	0.	0.
102015	0.000	0.000	661.546	0.	0.	0.	0.	0.	0.	0.	0.
102016	0.000	1.550	634.576	0.	0.	0.	0.	0.	0.	0.	0.
102017	0.000	6.199	570.706	0.	0.	0.	0.	0.	0.	0.	0.
102018	0.000	9.299	421.291	0.	0.	0.	0.	0.	0.	0.	0.
102019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	677.156	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7894.023	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	328.918	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE294 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1021 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1021 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1021 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1021 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1021 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1021 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1021 7	0.000	1.033	469.290	0.	0.	0.	0.	0.	0.	0.	0.
1021 8	0.000	0.000	485.632	0.	0.	0.	0.	0.	0.	0.	0.
1021 9	0.000	0.000	609.003	0.	0.	0.	0.	0.	0.	0.	0.
102110	0.000	0.000	632.161	0.	0.	0.	0.	0.	0.	0.	0.
102111	0.000	0.000	611.218	0.	0.	0.	0.	0.	0.	0.	0.
102112	0.000	0.000	620.833	0.	0.	0.	0.	0.	0.	0.	0.
102113	0.000	0.000	651.568	0.	0.	0.	0.	0.	0.	0.	0.
102114	0.000	0.000	657.151	0.	0.	0.	0.	0.	0.	0.	0.
102115	0.000	0.000	654.833	0.	0.	0.	0.	0.	0.	0.	0.
102116	0.000	1.550	645.790	0.	0.	0.	0.	0.	0.	0.	0.
102117	0.000	6.199	603.190	0.	0.	0.	0.	0.	0.	0.	0.
102118	0.000	9.299	478.663	0.	0.	0.	0.	0.	0.	0.	0.
102119	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102120	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102121	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102122	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102123	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102124	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	657.151	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7849.723	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	327.072	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE295 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1022 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1022 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1022 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1022 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1022 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1022 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1022 7	0.000	1.033	473.949	0.	0.	0.	0.	0.	0.	0.	0.
1022 8	0.000	0.000	536.424	0.	0.	0.	0.	0.	0.	0.	0.
1022 9	0.000	0.000	541.263	0.	0.	0.	0.	0.	0.	0.	0.
102210	0.000	0.000	586.315	0.	0.	0.	0.	0.	0.	0.	0.
102211	0.000	0.000	556.787	0.	0.	0.	0.	0.	0.	0.	0.
102212	0.000	0.000	616.707	0.	0.	0.	0.	0.	0.	0.	0.
102213	0.000	0.000	694.284	0.	0.	0.	0.	0.	0.	0.	0.
102214	0.000	0.000	737.479	0.	0.	0.	0.	0.	0.	0.	0.
102215	0.000	0.000	691.916	0.	0.	0.	0.	0.	0.	0.	0.
102216	0.000	1.550	685.616	0.	0.	0.	0.	0.	0.	0.	0.
102217	0.000	6.199	615.315	0.	0.	0.	0.	0.	0.	0.	0.
102218	0.000	9.299	494.360	0.	0.	0.	0.	0.	0.	0.	0.
102219	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102220	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102221	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102222	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102223	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102224	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	737.479	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7960.806	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	331.700	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE296 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1023 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1023 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1023 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1023 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1023 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1023 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1023 7	0.000	1.033	475.692	0.	0.	0.	0.	0.	0.	0.	0.
1023 8	0.000	0.000	585.048	0.	0.	0.	0.	0.	0.	0.	0.
1023 9	0.000	0.000	629.809	0.	0.	0.	0.	0.	0.	0.	0.
102310	0.000	0.000	655.372	0.	0.	0.	0.	0.	0.	0.	0.
102311	0.000	0.000	617.905	0.	0.	0.	0.	0.	0.	0.	0.
102312	0.000	0.000	633.013	0.	0.	0.	0.	0.	0.	0.	0.
102313	0.000	0.000	661.224	0.	0.	0.	0.	0.	0.	0.	0.
102314	0.000	0.000	681.366	0.	0.	0.	0.	0.	0.	0.	0.
102315	0.000	0.000	672.013	0.	0.	0.	0.	0.	0.	0.	0.
102316	0.000	1.550	648.431	0.	0.	0.	0.	0.	0.	0.	0.
102317	0.000	6.199	543.498	0.	0.	0.	0.	0.	0.	0.	0.
102318	0.000	9.299	376.869	0.	0.	0.	0.	0.	0.	0.	0.
102319	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102320	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102321	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102322	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102323	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102324	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	681.366	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7910.630	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	329.610	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE297 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1024 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1024 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1024 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1024 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1024 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1024 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1024 7	0.000	1.033	252.642	0.	0.	0.	0.	0.	0.	0.	0.
1024 8	0.000	0.000	229.274	0.	0.	0.	0.	0.	0.	0.	0.
1024 9	0.000	0.000	283.196	0.	0.	0.	0.	0.	0.	0.	0.
102410	0.000	0.000	355.024	0.	0.	0.	0.	0.	0.	0.	0.
102411	0.000	0.000	360.731	0.	0.	0.	0.	0.	0.	0.	0.
102412	0.000	0.000	369.996	0.	0.	0.	0.	0.	0.	0.	0.
102413	0.000	0.000	366.231	0.	0.	0.	0.	0.	0.	0.	0.
102414	0.000	0.000	342.499	0.	0.	0.	0.	0.	0.	0.	0.
102415	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
102416	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
102417	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
102418	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
102419	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
102420	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
102421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
102422	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
102423	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
102424	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 24)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	369.996	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3230.767	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	134.615	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE298 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1025 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1025 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1025 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1025 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1025 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1025 6	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1025 7	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1025 8	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
1025 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
102516	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
102517	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
102518	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
102519	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
102520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
102521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
102522	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
102523	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
102524	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 25)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	43.483	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	396.309	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	16.513	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE299 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1026 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1026 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1026 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1026 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1026 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1026 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1026 7	0.000	1.033	465.353	0.	0.	0.	0.	0.	0.	0.	0.
1026 8	0.000	0.000	467.066	0.	0.	0.	0.	0.	0.	0.	0.
1026 9	0.000	0.000	525.465	0.	0.	0.	0.	0.	0.	0.	0.
102610	0.000	0.000	588.769	0.	0.	0.	0.	0.	0.	0.	0.
102611	0.000	0.000	602.760	0.	0.	0.	0.	0.	0.	0.	0.
102612	0.000	0.000	600.751	0.	0.	0.	0.	0.	0.	0.	0.
102613	0.000	0.000	597.362	0.	0.	0.	0.	0.	0.	0.	0.
102614	0.000	0.000	592.663	0.	0.	0.	0.	0.	0.	0.	0.
102615	0.000	0.000	596.721	0.	0.	0.	0.	0.	0.	0.	0.
102616	0.000	1.550	562.174	0.	0.	0.	0.	0.	0.	0.	0.
102617	0.000	6.199	444.749	0.	0.	0.	0.	0.	0.	0.	0.
102618	0.000	9.299	330.421	0.	0.	0.	0.	0.	0.	0.	0.
102619	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102620	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102621	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102622	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102623	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102624	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 26)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	602.760	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7104.646	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	296.027	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE300 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1027 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1027 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1027 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1027 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1027 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1027 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1027 7	0.000	1.033	463.229	0.	0.	0.	0.	0.	0.	0.	0.
1027 8	0.000	0.000	466.768	0.	0.	0.	0.	0.	0.	0.	0.
1027 9	0.000	0.000	484.056	0.	0.	0.	0.	0.	0.	0.	0.
102710	0.000	0.000	586.192	0.	0.	0.	0.	0.	0.	0.	0.
102711	0.000	0.000	564.328	0.	0.	0.	0.	0.	0.	0.	0.
102712	0.000	0.000	583.363	0.	0.	0.	0.	0.	0.	0.	0.
102713	0.000	0.000	626.882	0.	0.	0.	0.	0.	0.	0.	0.
102714	0.000	0.000	634.638	0.	0.	0.	0.	0.	0.	0.	0.
102715	0.000	0.000	618.014	0.	0.	0.	0.	0.	0.	0.	0.
102716	0.000	1.550	569.479	0.	0.	0.	0.	0.	0.	0.	0.
102717	0.000	6.199	444.784	0.	0.	0.	0.	0.	0.	0.	0.
102718	0.000	9.299	330.524	0.	0.	0.	0.	0.	0.	0.	0.
102719	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102720	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102721	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102722	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102723	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102724	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	634.638	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7102.646	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	295.944	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE301 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1028 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1028 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1028 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1028 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1028 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1028 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1028 7	0.000	1.033	463.281	0.	0.	0.	0.	0.	0.	0.	0.
1028 8	0.000	0.000	467.632	0.	0.	0.	0.	0.	0.	0.	0.
1028 9	0.000	0.000	506.551	0.	0.	0.	0.	0.	0.	0.	0.
102810	0.000	0.000	591.091	0.	0.	0.	0.	0.	0.	0.	0.
102811	0.000	0.000	606.790	0.	0.	0.	0.	0.	0.	0.	0.
102812	0.000	0.000	616.328	0.	0.	0.	0.	0.	0.	0.	0.
102813	0.000	0.000	641.093	0.	0.	0.	0.	0.	0.	0.	0.
102814	0.000	0.000	650.541	0.	0.	0.	0.	0.	0.	0.	0.
102815	0.000	0.000	605.296	0.	0.	0.	0.	0.	0.	0.	0.
102816	0.000	1.550	579.558	0.	0.	0.	0.	0.	0.	0.	0.
102817	0.000	6.199	475.176	0.	0.	0.	0.	0.	0.	0.	0.
102818	0.000	9.299	341.950	0.	0.	0.	0.	0.	0.	0.	0.
102819	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102820	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102821	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102822	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102823	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102824	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	650.541	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7275.677	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	303.153	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE302 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1029 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1029 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1029 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1029 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1029 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1029 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1029 7	0.000	1.033	463.460	0.	0.	0.	0.	0.	0.	0.	0.
1029 8	0.000	0.000	467.729	0.	0.	0.	0.	0.	0.	0.	0.
1029 9	0.000	0.000	566.554	0.	0.	0.	0.	0.	0.	0.	0.
102910	0.000	0.000	629.900	0.	0.	0.	0.	0.	0.	0.	0.
102911	0.000	0.000	619.881	0.	0.	0.	0.	0.	0.	0.	0.
102912	0.000	0.000	624.566	0.	0.	0.	0.	0.	0.	0.	0.
102913	0.000	0.000	651.262	0.	0.	0.	0.	0.	0.	0.	0.
102914	0.000	0.000	665.813	0.	0.	0.	0.	0.	0.	0.	0.
102915	0.000	0.000	670.166	0.	0.	0.	0.	0.	0.	0.	0.
102916	0.000	1.550	657.148	0.	0.	0.	0.	0.	0.	0.	0.
102917	0.000	6.199	600.598	0.	0.	0.	0.	0.	0.	0.	0.
102918	0.000	9.299	417.259	0.	0.	0.	0.	0.	0.	0.	0.
102919	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
102920	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
102921	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
102922	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
102923	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
102924	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	670.166	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7764.726	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	323.530	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE303 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1030 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1030 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1030 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1030 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1030 5	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1030 6	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1030 7	0.000	1.033	464.325	0.	0.	0.	0.	0.	0.	0.	0.
1030 8	0.000	0.000	513.658	0.	0.	0.	0.	0.	0.	0.	0.
1030 9	0.000	0.000	622.982	0.	0.	0.	0.	0.	0.	0.	0.
103010	0.000	0.000	638.270	0.	0.	0.	0.	0.	0.	0.	0.
103011	0.000	0.000	622.949	0.	0.	0.	0.	0.	0.	0.	0.
103012	0.000	0.000	626.746	0.	0.	0.	0.	0.	0.	0.	0.
103013	0.000	0.000	653.686	0.	0.	0.	0.	0.	0.	0.	0.
103014	0.000	0.000	658.049	0.	0.	0.	0.	0.	0.	0.	0.
103015	0.000	0.000	650.896	0.	0.	0.	0.	0.	0.	0.	0.
103016	0.000	1.550	627.815	0.	0.	0.	0.	0.	0.	0.	0.
103017	0.000	6.199	547.073	0.	0.	0.	0.	0.	0.	0.	0.
103018	0.000	9.299	398.711	0.	0.	0.	0.	0.	0.	0.	0.
103019	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
103020	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
103021	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
103022	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
103023	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
103024	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	658.049	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7755.551	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	323.148	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE304 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1031 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1031 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1031 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1031 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1031 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1031 6	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1031 7	0.000	1.033	251.577	0.	0.	0.	0.	0.	0.	0.	0.
1031 8	0.000	0.000	239.132	0.	0.	0.	0.	0.	0.	0.	0.
1031 9	0.000	0.000	317.414	0.	0.	0.	0.	0.	0.	0.	0.
103110	0.000	0.000	350.665	0.	0.	0.	0.	0.	0.	0.	0.
103111	0.000	0.000	350.431	0.	0.	0.	0.	0.	0.	0.	0.
103112	0.000	0.000	318.098	0.	0.	0.	0.	0.	0.	0.	0.
103113	0.000	0.000	317.996	0.	0.	0.	0.	0.	0.	0.	0.
103114	0.000	0.000	318.163	0.	0.	0.	0.	0.	0.	0.	0.
103115	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
103116	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
103117	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
103118	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
103119	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
103120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
103121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
103122	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
103123	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
103124	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 31)											
MN	0.000	0.000	17.384	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	350.665	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3134.650	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	130.610	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (OCT)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	741.029	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	3154.877	183494.391	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	246.632	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE305 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 1 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 1 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 1 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 1 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 1 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 1 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 1 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
11 1 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
11 1 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 116	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 117	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
11 118	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 119	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 120	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 122	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 123	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
11 124	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 1)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE306 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 2 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 2 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
11 2 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
11 2 8	0.000	1.033	465.503	0.	0.	0.	0.	0.	0.	0.	0.
11 2 9	0.000	0.000	469.048	0.	0.	0.	0.	0.	0.	0.	0.
11 210	0.000	0.000	578.010	0.	0.	0.	0.	0.	0.	0.	0.
11 211	0.000	0.000	609.777	0.	0.	0.	0.	0.	0.	0.	0.
11 212	0.000	0.000	592.671	0.	0.	0.	0.	0.	0.	0.	0.
11 213	0.000	0.000	599.293	0.	0.	0.	0.	0.	0.	0.	0.
11 214	0.000	0.000	632.242	0.	0.	0.	0.	0.	0.	0.	0.
11 215	0.000	0.000	632.635	0.	0.	0.	0.	0.	0.	0.	0.
11 216	0.000	0.000	572.574	0.	0.	0.	0.	0.	0.	0.	0.
11 217	0.000	1.550	522.893	0.	0.	0.	0.	0.	0.	0.	0.
11 218	0.000	6.199	478.971	0.	0.	0.	0.	0.	0.	0.	0.
11 219	0.000	9.299	339.554	0.	0.	0.	0.	0.	0.	0.	0.
11 220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11 221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11 222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11 223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11 224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	632.635	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7223.561	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	300.982	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE307 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 3 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 3 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
11 3 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
11 3 8	0.000	1.033	464.104	0.	0.	0.	0.	0.	0.	0.	0.
11 3 9	0.000	0.000	521.389	0.	0.	0.	0.	0.	0.	0.	0.
11 310	0.000	0.000	554.636	0.	0.	0.	0.	0.	0.	0.	0.
11 311	0.000	0.000	600.254	0.	0.	0.	0.	0.	0.	0.	0.
11 312	0.000	0.000	574.600	0.	0.	0.	0.	0.	0.	0.	0.
11 313	0.000	0.000	576.136	0.	0.	0.	0.	0.	0.	0.	0.
11 314	0.000	0.000	604.918	0.	0.	0.	0.	0.	0.	0.	0.
11 315	0.000	0.000	590.906	0.	0.	0.	0.	0.	0.	0.	0.
11 316	0.000	0.000	485.458	0.	0.	0.	0.	0.	0.	0.	0.
11 317	0.000	1.550	482.992	0.	0.	0.	0.	0.	0.	0.	0.
11 318	0.000	6.199	451.879	0.	0.	0.	0.	0.	0.	0.	0.
11 319	0.000	9.299	343.537	0.	0.	0.	0.	0.	0.	0.	0.
11 320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11 321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11 322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11 323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11 324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	604.918	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6981.200	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	290.883	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE308 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 4 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 4 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
11 4 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
11 4 8	0.000	1.033	464.775	0.	0.	0.	0.	0.	0.	0.	0.
11 4 9	0.000	0.000	488.023	0.	0.	0.	0.	0.	0.	0.	0.
11 410	0.000	0.000	579.800	0.	0.	0.	0.	0.	0.	0.	0.
11 411	0.000	0.000	617.084	0.	0.	0.	0.	0.	0.	0.	0.
11 412	0.000	0.000	610.459	0.	0.	0.	0.	0.	0.	0.	0.
11 413	0.000	0.000	601.468	0.	0.	0.	0.	0.	0.	0.	0.
11 414	0.000	0.000	633.088	0.	0.	0.	0.	0.	0.	0.	0.
11 415	0.000	0.000	640.905	0.	0.	0.	0.	0.	0.	0.	0.
11 416	0.000	0.000	576.373	0.	0.	0.	0.	0.	0.	0.	0.
11 417	0.000	1.550	476.393	0.	0.	0.	0.	0.	0.	0.	0.
11 418	0.000	6.199	437.331	0.	0.	0.	0.	0.	0.	0.	0.
11 419	0.000	9.299	330.312	0.	0.	0.	0.	0.	0.	0.	0.
11 420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11 421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11 422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11 423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11 424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	640.905	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7186.401	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	299.433	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE309 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 5 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 5 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
11 5 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
11 5 8	0.000	1.033	463.667	0.	0.	0.	0.	0.	0.	0.	0.
11 5 9	0.000	0.000	469.984	0.	0.	0.	0.	0.	0.	0.	0.
11 510	0.000	0.000	526.571	0.	0.	0.	0.	0.	0.	0.	0.
11 511	0.000	0.000	610.025	0.	0.	0.	0.	0.	0.	0.	0.
11 512	0.000	0.000	581.688	0.	0.	0.	0.	0.	0.	0.	0.
11 513	0.000	0.000	608.814	0.	0.	0.	0.	0.	0.	0.	0.
11 514	0.000	0.000	629.958	0.	0.	0.	0.	0.	0.	0.	0.
11 515	0.000	0.000	638.573	0.	0.	0.	0.	0.	0.	0.	0.
11 516	0.000	0.000	570.804	0.	0.	0.	0.	0.	0.	0.	0.
11 517	0.000	1.550	478.282	0.	0.	0.	0.	0.	0.	0.	0.
11 518	0.000	6.199	438.176	0.	0.	0.	0.	0.	0.	0.	0.
11 519	0.000	9.299	330.346	0.	0.	0.	0.	0.	0.	0.	0.
11 520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11 521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11 522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11 523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11 524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 5)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	638.573	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7077.278	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	294.887	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE310 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 6 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 6 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 6 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 6 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 6 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 6 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
11 6 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
11 6 8	0.000	1.033	463.414	0.	0.	0.	0.	0.	0.	0.	0.
11 6 9	0.000	0.000	467.867	0.	0.	0.	0.	0.	0.	0.	0.
11 610	0.000	0.000	524.176	0.	0.	0.	0.	0.	0.	0.	0.
11 611	0.000	0.000	598.327	0.	0.	0.	0.	0.	0.	0.	0.
11 612	0.000	0.000	614.979	0.	0.	0.	0.	0.	0.	0.	0.
11 613	0.000	0.000	628.139	0.	0.	0.	0.	0.	0.	0.	0.
11 614	0.000	0.000	644.375	0.	0.	0.	0.	0.	0.	0.	0.
11 615	0.000	0.000	645.287	0.	0.	0.	0.	0.	0.	0.	0.
11 616	0.000	0.000	574.467	0.	0.	0.	0.	0.	0.	0.	0.
11 617	0.000	1.550	480.940	0.	0.	0.	0.	0.	0.	0.	0.
11 618	0.000	6.199	450.908	0.	0.	0.	0.	0.	0.	0.	0.
11 619	0.000	9.299	331.007	0.	0.	0.	0.	0.	0.	0.	0.
11 620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11 621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11 622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11 623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11 624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 6)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	645.287	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7154.276	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	298.095	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE311 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 7 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 7 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 7 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
11 7 8	0.000	1.033	251.204	0.	0.	0.	0.	0.	0.	0.	0.
11 7 9	0.000	0.000	207.608	0.	0.	0.	0.	0.	0.	0.	0.
11 710	0.000	0.000	317.294	0.	0.	0.	0.	0.	0.	0.	0.
11 711	0.000	0.000	353.343	0.	0.	0.	0.	0.	0.	0.	0.
11 712	0.000	0.000	358.109	0.	0.	0.	0.	0.	0.	0.	0.
11 713	0.000	0.000	363.607	0.	0.	0.	0.	0.	0.	0.	0.
11 714	0.000	0.000	344.364	0.	0.	0.	0.	0.	0.	0.	0.
11 715	0.000	0.000	331.450	0.	0.	0.	0.	0.	0.	0.	0.
11 716	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
11 717	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
11 718	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 719	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11 720	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11 721	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11 722	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
11 723	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
11 724	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 7)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	363.607	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3224.250	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	134.344	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE312 - 2

EM1		EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
DHW END USE KWH		EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
----(11)		----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 8 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 8 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 8 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 8 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 8 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 8 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 8 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
11 8 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
11 8 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 810	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 811	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 812	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 813	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 814	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 815	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 816	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
11 817	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
11 818	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
11 819	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 820	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 821	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 822	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
11 823	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
11 824	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 8)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE313 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
11 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 9 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
11 9 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
11 9 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
11 9 8	0.000	1.033	472.967	0.	0.	0.	0.	0.	0.	0.	0.
11 9 9	0.000	0.000	598.805	0.	0.	0.	0.	0.	0.	0.	0.
11 910	0.000	0.000	637.758	0.	0.	0.	0.	0.	0.	0.	0.
11 911	0.000	0.000	652.470	0.	0.	0.	0.	0.	0.	0.	0.
11 912	0.000	0.000	635.099	0.	0.	0.	0.	0.	0.	0.	0.
11 913	0.000	0.000	643.930	0.	0.	0.	0.	0.	0.	0.	0.
11 914	0.000	0.000	659.418	0.	0.	0.	0.	0.	0.	0.	0.
11 915	0.000	0.000	662.537	0.	0.	0.	0.	0.	0.	0.	0.
11 916	0.000	0.000	681.948	0.	0.	0.	0.	0.	0.	0.	0.
11 917	0.000	1.550	633.382	0.	0.	0.	0.	0.	0.	0.	0.
11 918	0.000	6.199	528.108	0.	0.	0.	0.	0.	0.	0.	0.
11 919	0.000	9.299	377.309	0.	0.	0.	0.	0.	0.	0.	0.
11 920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
11 921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
11 922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
11 923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
11 924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	681.948	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7914.124	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	329.755	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE314 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1110 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1110 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1110 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1110 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1110 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1110 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1110 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1110 8	0.000	1.033	465.699	0.	0.	0.	0.	0.	0.	0.	0.
1110 9	0.000	0.000	585.000	0.	0.	0.	0.	0.	0.	0.	0.
111010	0.000	0.000	644.524	0.	0.	0.	0.	0.	0.	0.	0.
111011	0.000	0.000	659.621	0.	0.	0.	0.	0.	0.	0.	0.
111012	0.000	0.000	637.969	0.	0.	0.	0.	0.	0.	0.	0.
111013	0.000	0.000	650.840	0.	0.	0.	0.	0.	0.	0.	0.
111014	0.000	0.000	665.282	0.	0.	0.	0.	0.	0.	0.	0.
111015	0.000	0.000	673.124	0.	0.	0.	0.	0.	0.	0.	0.
111016	0.000	0.000	656.965	0.	0.	0.	0.	0.	0.	0.	0.
111017	0.000	1.550	629.393	0.	0.	0.	0.	0.	0.	0.	0.
111018	0.000	6.199	528.753	0.	0.	0.	0.	0.	0.	0.	0.
111019	0.000	9.299	377.646	0.	0.	0.	0.	0.	0.	0.	0.
111020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	673.124	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7905.206	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	329.384	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE315 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1111 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1111 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1111 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1111 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1111 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1111 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1111 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1111 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1111 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111110	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111111	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111112	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111113	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111114	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111115	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111116	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111117	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
111118	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111119	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111120	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111121	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111122	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111123	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
111124	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 11)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE316 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1112 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1112 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1112 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1112 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1112 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1112 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1112 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1112 8	0.000	1.033	465.122	0.	0.	0.	0.	0.	0.	0.	0.
1112 9	0.000	0.000	559.047	0.	0.	0.	0.	0.	0.	0.	0.
111210	0.000	0.000	570.124	0.	0.	0.	0.	0.	0.	0.	0.
111211	0.000	0.000	567.977	0.	0.	0.	0.	0.	0.	0.	0.
111212	0.000	0.000	556.630	0.	0.	0.	0.	0.	0.	0.	0.
111213	0.000	0.000	579.066	0.	0.	0.	0.	0.	0.	0.	0.
111214	0.000	0.000	624.620	0.	0.	0.	0.	0.	0.	0.	0.
111215	0.000	0.000	613.119	0.	0.	0.	0.	0.	0.	0.	0.
111216	0.000	0.000	529.436	0.	0.	0.	0.	0.	0.	0.	0.
111217	0.000	1.550	471.020	0.	0.	0.	0.	0.	0.	0.	0.
111218	0.000	6.199	436.440	0.	0.	0.	0.	0.	0.	0.	0.
111219	0.000	9.299	330.386	0.	0.	0.	0.	0.	0.	0.	0.
111220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 12)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	624.620	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7033.377	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	293.057	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE317 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1113 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1113 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1113 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1113 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1113 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1113 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1113 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1113 8	0.000	1.033	463.306	0.	0.	0.	0.	0.	0.	0.	0.
1113 9	0.000	0.000	476.434	0.	0.	0.	0.	0.	0.	0.	0.
111310	0.000	0.000	565.555	0.	0.	0.	0.	0.	0.	0.	0.
111311	0.000	0.000	604.302	0.	0.	0.	0.	0.	0.	0.	0.
111312	0.000	0.000	601.534	0.	0.	0.	0.	0.	0.	0.	0.
111313	0.000	0.000	611.203	0.	0.	0.	0.	0.	0.	0.	0.
111314	0.000	0.000	631.441	0.	0.	0.	0.	0.	0.	0.	0.
111315	0.000	0.000	616.393	0.	0.	0.	0.	0.	0.	0.	0.
111316	0.000	0.000	567.597	0.	0.	0.	0.	0.	0.	0.	0.
111317	0.000	1.550	480.827	0.	0.	0.	0.	0.	0.	0.	0.
111318	0.000	6.199	464.767	0.	0.	0.	0.	0.	0.	0.	0.
111319	0.000	9.299	351.131	0.	0.	0.	0.	0.	0.	0.	0.
111320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 13)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	631.441	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7164.881	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	298.537	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE318 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1114 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1114 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1114 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1114 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1114 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1114 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1114 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1114 8	0.000	1.033	250.928	0.	0.	0.	0.	0.	0.	0.	0.
1114 9	0.000	0.000	195.774	0.	0.	0.	0.	0.	0.	0.	0.
111410	0.000	0.000	214.204	0.	0.	0.	0.	0.	0.	0.	0.
111411	0.000	0.000	257.567	0.	0.	0.	0.	0.	0.	0.	0.
111412	0.000	0.000	257.689	0.	0.	0.	0.	0.	0.	0.	0.
111413	0.000	0.000	277.444	0.	0.	0.	0.	0.	0.	0.	0.
111414	0.000	0.000	267.412	0.	0.	0.	0.	0.	0.	0.	0.
111415	0.000	0.000	253.347	0.	0.	0.	0.	0.	0.	0.	0.
111416	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
111417	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
111418	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
111419	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
111420	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
111421	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
111422	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
111423	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
111424	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 14)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	277.444	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2671.637	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	111.318	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE319 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1115 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1115 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1115 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1115 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1115 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1115 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1115 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1115 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1115 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
111517	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
111518	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
111519	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111522	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
111523	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
111524	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 15)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE320 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1116 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1116 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1116 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1116 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1116 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1116 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1116 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1116 8	0.000	1.033	464.886	0.	0.	0.	0.	0.	0.	0.	0.
1116 9	0.000	0.000	498.614	0.	0.	0.	0.	0.	0.	0.	0.
111610	0.000	0.000	553.019	0.	0.	0.	0.	0.	0.	0.	0.
111611	0.000	0.000	604.458	0.	0.	0.	0.	0.	0.	0.	0.
111612	0.000	0.000	566.912	0.	0.	0.	0.	0.	0.	0.	0.
111613	0.000	0.000	575.433	0.	0.	0.	0.	0.	0.	0.	0.
111614	0.000	0.000	593.136	0.	0.	0.	0.	0.	0.	0.	0.
111615	0.000	0.000	587.709	0.	0.	0.	0.	0.	0.	0.	0.
111616	0.000	0.000	525.918	0.	0.	0.	0.	0.	0.	0.	0.
111617	0.000	1.550	469.037	0.	0.	0.	0.	0.	0.	0.	0.
111618	0.000	6.199	435.369	0.	0.	0.	0.	0.	0.	0.	0.
111619	0.000	9.299	330.431	0.	0.	0.	0.	0.	0.	0.	0.
111620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	604.458	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6935.313	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	288.971	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE321 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1117 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1117 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1117 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1117 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1117 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1117 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1117 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1117 8	0.000	1.033	463.605	0.	0.	0.	0.	0.	0.	0.	0.
1117 9	0.000	0.000	466.581	0.	0.	0.	0.	0.	0.	0.	0.
111710	0.000	0.000	517.318	0.	0.	0.	0.	0.	0.	0.	0.
111711	0.000	0.000	594.053	0.	0.	0.	0.	0.	0.	0.	0.
111712	0.000	0.000	586.909	0.	0.	0.	0.	0.	0.	0.	0.
111713	0.000	0.000	591.982	0.	0.	0.	0.	0.	0.	0.	0.
111714	0.000	0.000	569.206	0.	0.	0.	0.	0.	0.	0.	0.
111715	0.000	0.000	586.249	0.	0.	0.	0.	0.	0.	0.	0.
111716	0.000	0.000	536.169	0.	0.	0.	0.	0.	0.	0.	0.
111717	0.000	1.550	471.250	0.	0.	0.	0.	0.	0.	0.	0.
111718	0.000	6.199	436.170	0.	0.	0.	0.	0.	0.	0.	0.
111719	0.000	9.299	330.389	0.	0.	0.	0.	0.	0.	0.	0.
111720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	594.053	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6880.271	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	286.678	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE322 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1118 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1118 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1118 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1118 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1118 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1118 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1118 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1118 8	0.000	1.033	463.568	0.	0.	0.	0.	0.	0.	0.	0.
1118 9	0.000	0.000	466.251	0.	0.	0.	0.	0.	0.	0.	0.
111810	0.000	0.000	475.082	0.	0.	0.	0.	0.	0.	0.	0.
111811	0.000	0.000	472.189	0.	0.	0.	0.	0.	0.	0.	0.
111812	0.000	0.000	460.966	0.	0.	0.	0.	0.	0.	0.	0.
111813	0.000	0.000	500.959	0.	0.	0.	0.	0.	0.	0.	0.
111814	0.000	0.000	529.932	0.	0.	0.	0.	0.	0.	0.	0.
111815	0.000	0.000	499.010	0.	0.	0.	0.	0.	0.	0.	0.
111816	0.000	0.000	477.396	0.	0.	0.	0.	0.	0.	0.	0.
111817	0.000	1.550	469.016	0.	0.	0.	0.	0.	0.	0.	0.
111818	0.000	6.199	435.738	0.	0.	0.	0.	0.	0.	0.	0.
111819	0.000	9.299	330.383	0.	0.	0.	0.	0.	0.	0.	0.
111820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	529.932	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6310.881	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	262.953	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE323 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1119 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1119 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1119 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1119 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1119 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1119 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1119 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1119 8	0.000	1.033	463.655	0.	0.	0.	0.	0.	0.	0.	0.
1119 9	0.000	0.000	465.609	0.	0.	0.	0.	0.	0.	0.	0.
111910	0.000	0.000	474.204	0.	0.	0.	0.	0.	0.	0.	0.
111911	0.000	0.000	574.181	0.	0.	0.	0.	0.	0.	0.	0.
111912	0.000	0.000	585.579	0.	0.	0.	0.	0.	0.	0.	0.
111913	0.000	0.000	569.434	0.	0.	0.	0.	0.	0.	0.	0.
111914	0.000	0.000	624.607	0.	0.	0.	0.	0.	0.	0.	0.
111915	0.000	0.000	637.447	0.	0.	0.	0.	0.	0.	0.	0.
111916	0.000	0.000	529.593	0.	0.	0.	0.	0.	0.	0.	0.
111917	0.000	1.550	471.433	0.	0.	0.	0.	0.	0.	0.	0.
111918	0.000	6.199	436.320	0.	0.	0.	0.	0.	0.	0.	0.
111919	0.000	9.299	330.432	0.	0.	0.	0.	0.	0.	0.	0.
111920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
111921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
111922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
111923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
111924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 19)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	637.447	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6892.885	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	287.204	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE324 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1120 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1120 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1120 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1120 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1120 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1120 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1120 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1120 8	0.000	1.033	463.647	0.	0.	0.	0.	0.	0.	0.	0.
1120 9	0.000	0.000	587.350	0.	0.	0.	0.	0.	0.	0.	0.
112010	0.000	0.000	647.315	0.	0.	0.	0.	0.	0.	0.	0.
112011	0.000	0.000	655.391	0.	0.	0.	0.	0.	0.	0.	0.
112012	0.000	0.000	633.625	0.	0.	0.	0.	0.	0.	0.	0.
112013	0.000	0.000	636.542	0.	0.	0.	0.	0.	0.	0.	0.
112014	0.000	0.000	660.500	0.	0.	0.	0.	0.	0.	0.	0.
112015	0.000	0.000	669.850	0.	0.	0.	0.	0.	0.	0.	0.
112016	0.000	0.000	659.778	0.	0.	0.	0.	0.	0.	0.	0.
112017	0.000	1.550	613.956	0.	0.	0.	0.	0.	0.	0.	0.
112018	0.000	6.199	559.190	0.	0.	0.	0.	0.	0.	0.	0.
112019	0.000	9.299	383.005	0.	0.	0.	0.	0.	0.	0.	0.
112020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
112021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
112022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
112023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
112024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 20)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	669.850	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7900.541	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	329.189	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE325 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1121 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1121 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1121 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1121 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1121 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1121 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1121 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1121 8	0.000	1.033	263.570	0.	0.	0.	0.	0.	0.	0.	0.
1121 9	0.000	0.000	294.328	0.	0.	0.	0.	0.	0.	0.	0.
112110	0.000	0.000	321.268	0.	0.	0.	0.	0.	0.	0.	0.
112111	0.000	0.000	327.806	0.	0.	0.	0.	0.	0.	0.	0.
112112	0.000	0.000	336.181	0.	0.	0.	0.	0.	0.	0.	0.
112113	0.000	0.000	355.592	0.	0.	0.	0.	0.	0.	0.	0.
112114	0.000	0.000	356.286	0.	0.	0.	0.	0.	0.	0.	0.
112115	0.000	0.000	354.842	0.	0.	0.	0.	0.	0.	0.	0.
112116	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
112117	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
112118	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112119	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112120	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112121	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112122	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112123	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
112124	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 21)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	356.286	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3307.144	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	137.798	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE326 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1122 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1122 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1122 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1122 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1122 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1122 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1122 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1122 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1122 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112210	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112211	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112212	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112213	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112214	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112215	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112216	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112217	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
112218	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
112219	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112220	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112221	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112222	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112223	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
112224	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 22)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE327 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1123 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1123 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1123 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1123 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1123 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1123 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1123 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1123 8	0.000	1.033	466.664	0.	0.	0.	0.	0.	0.	0.	0.
1123 9	0.000	0.000	465.669	0.	0.	0.	0.	0.	0.	0.	0.
112310	0.000	0.000	472.632	0.	0.	0.	0.	0.	0.	0.	0.
112311	0.000	0.000	517.973	0.	0.	0.	0.	0.	0.	0.	0.
112312	0.000	0.000	600.947	0.	0.	0.	0.	0.	0.	0.	0.
112313	0.000	0.000	607.240	0.	0.	0.	0.	0.	0.	0.	0.
112314	0.000	0.000	556.462	0.	0.	0.	0.	0.	0.	0.	0.
112315	0.000	0.000	489.272	0.	0.	0.	0.	0.	0.	0.	0.
112316	0.000	0.000	475.354	0.	0.	0.	0.	0.	0.	0.	0.
112317	0.000	1.550	467.306	0.	0.	0.	0.	0.	0.	0.	0.
112318	0.000	6.199	435.422	0.	0.	0.	0.	0.	0.	0.	0.
112319	0.000	9.299	330.383	0.	0.	0.	0.	0.	0.	0.	0.
112320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
112321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
112322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
112323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
112324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	607.240	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6615.714	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	275.655	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE328 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1124 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1124 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1124 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1124 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1124 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1124 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1124 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1124 8	0.000	1.033	464.068	0.	0.	0.	0.	0.	0.	0.	0.
1124 9	0.000	0.000	465.773	0.	0.	0.	0.	0.	0.	0.	0.
112410	0.000	0.000	471.889	0.	0.	0.	0.	0.	0.	0.	0.
112411	0.000	0.000	505.334	0.	0.	0.	0.	0.	0.	0.	0.
112412	0.000	0.000	518.890	0.	0.	0.	0.	0.	0.	0.	0.
112413	0.000	0.000	564.224	0.	0.	0.	0.	0.	0.	0.	0.
112414	0.000	0.000	592.357	0.	0.	0.	0.	0.	0.	0.	0.
112415	0.000	0.000	524.956	0.	0.	0.	0.	0.	0.	0.	0.
112416	0.000	0.000	490.201	0.	0.	0.	0.	0.	0.	0.	0.
112417	0.000	1.550	495.711	0.	0.	0.	0.	0.	0.	0.	0.
112418	0.000	6.199	459.409	0.	0.	0.	0.	0.	0.	0.	0.
112419	0.000	9.299	330.880	0.	0.	0.	0.	0.	0.	0.	0.
112420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
112421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
112422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
112423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
112424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	592.357	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6614.082	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	275.587	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE329 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1125 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1125 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1125 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1125 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1125 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1125 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1125 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1125 8	0.000	1.033	463.072	0.	0.	0.	0.	0.	0.	0.	0.
1125 9	0.000	0.000	466.831	0.	0.	0.	0.	0.	0.	0.	0.
112510	0.000	0.000	475.353	0.	0.	0.	0.	0.	0.	0.	0.
112511	0.000	0.000	471.176	0.	0.	0.	0.	0.	0.	0.	0.
112512	0.000	0.000	494.922	0.	0.	0.	0.	0.	0.	0.	0.
112513	0.000	0.000	555.598	0.	0.	0.	0.	0.	0.	0.	0.
112514	0.000	0.000	587.751	0.	0.	0.	0.	0.	0.	0.	0.
112515	0.000	0.000	603.637	0.	0.	0.	0.	0.	0.	0.	0.
112516	0.000	0.000	533.092	0.	0.	0.	0.	0.	0.	0.	0.
112517	0.000	1.550	473.306	0.	0.	0.	0.	0.	0.	0.	0.
112518	0.000	6.199	436.090	0.	0.	0.	0.	0.	0.	0.	0.
112519	0.000	9.299	330.066	0.	0.	0.	0.	0.	0.	0.	0.
112520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
112521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
112522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
112523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
112524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 25)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	603.637	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6621.285	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	275.887	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE330 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1126 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1126 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1126 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1126 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1126 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1126 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1126 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1126 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1126 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112616	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112617	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
112618	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
112619	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112620	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112622	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112623	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
112624	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 26)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE331 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1127 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1127 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1127 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1127 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1127 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1127 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1127 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1127 8	0.000	1.033	462.934	0.	0.	0.	0.	0.	0.	0.	0.
1127 9	0.000	0.000	466.402	0.	0.	0.	0.	0.	0.	0.	0.
112710	0.000	0.000	501.660	0.	0.	0.	0.	0.	0.	0.	0.
112711	0.000	0.000	572.938	0.	0.	0.	0.	0.	0.	0.	0.
112712	0.000	0.000	571.096	0.	0.	0.	0.	0.	0.	0.	0.
112713	0.000	0.000	559.560	0.	0.	0.	0.	0.	0.	0.	0.
112714	0.000	0.000	570.520	0.	0.	0.	0.	0.	0.	0.	0.
112715	0.000	0.000	549.448	0.	0.	0.	0.	0.	0.	0.	0.
112716	0.000	0.000	506.765	0.	0.	0.	0.	0.	0.	0.	0.
112717	0.000	1.550	470.824	0.	0.	0.	0.	0.	0.	0.	0.
112718	0.000	6.199	436.050	0.	0.	0.	0.	0.	0.	0.	0.
112719	0.000	9.299	330.343	0.	0.	0.	0.	0.	0.	0.	0.
112720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
112721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
112722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
112723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
112724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 27)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	572.938	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6728.931	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	280.372	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE332 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1128 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1128 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1128 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1128 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1128 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1128 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1128 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1128 8	0.000	1.033	250.475	0.	0.	0.	0.	0.	0.	0.	0.
1128 9	0.000	0.000	195.738	0.	0.	0.	0.	0.	0.	0.	0.
112810	0.000	0.000	201.459	0.	0.	0.	0.	0.	0.	0.	0.
112811	0.000	0.000	252.293	0.	0.	0.	0.	0.	0.	0.	0.
112812	0.000	0.000	291.581	0.	0.	0.	0.	0.	0.	0.	0.
112813	0.000	0.000	305.182	0.	0.	0.	0.	0.	0.	0.	0.
112814	0.000	0.000	265.779	0.	0.	0.	0.	0.	0.	0.	0.
112815	0.000	0.000	265.909	0.	0.	0.	0.	0.	0.	0.	0.
112816	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
112817	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
112818	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
112819	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112820	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112821	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112822	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
112823	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
112824	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 28)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	305.182	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2725.688	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	113.570	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE333 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1129 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1129 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1129 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1129 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1129 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1129 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1129 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1129 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1129 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112910	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112911	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112912	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112913	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112914	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112915	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112916	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
112917	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
112918	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
112919	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112920	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112921	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112922	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
112923	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
112924	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 29)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE334 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1130 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1130 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1130 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1130 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1130 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1130 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1130 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1130 8	0.000	1.033	464.315	0.	0.	0.	0.	0.	0.	0.	0.
1130 9	0.000	0.000	465.428	0.	0.	0.	0.	0.	0.	0.	0.
113010	0.000	0.000	471.300	0.	0.	0.	0.	0.	0.	0.	0.
113011	0.000	0.000	474.056	0.	0.	0.	0.	0.	0.	0.	0.
113012	0.000	0.000	466.155	0.	0.	0.	0.	0.	0.	0.	0.
113013	0.000	0.000	465.279	0.	0.	0.	0.	0.	0.	0.	0.
113014	0.000	0.000	470.310	0.	0.	0.	0.	0.	0.	0.	0.
113015	0.000	0.000	471.759	0.	0.	0.	0.	0.	0.	0.	0.
113016	0.000	0.000	471.864	0.	0.	0.	0.	0.	0.	0.	0.
113017	0.000	1.550	465.869	0.	0.	0.	0.	0.	0.	0.	0.
113018	0.000	6.199	434.881	0.	0.	0.	0.	0.	0.	0.	0.
113019	0.000	9.299	330.206	0.	0.	0.	0.	0.	0.	0.	0.
113020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
113021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
113022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
113023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
113024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	474.056	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6181.812	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	257.575	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (NOV)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	681.948	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	3053.107	147842.203	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	205.336	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE335 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 1 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 1 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 1 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 1 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 1 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 1 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 1 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 1 8	0.000	1.033	463.449	0.	0.	0.	0.	0.	0.	0.	0.
12 1 9	0.000	0.000	465.483	0.	0.	0.	0.	0.	0.	0.	0.
12 110	0.000	0.000	471.329	0.	0.	0.	0.	0.	0.	0.	0.
12 111	0.000	0.000	467.373	0.	0.	0.	0.	0.	0.	0.	0.
12 112	0.000	0.000	444.170	0.	0.	0.	0.	0.	0.	0.	0.
12 113	0.000	0.000	443.354	0.	0.	0.	0.	0.	0.	0.	0.
12 114	0.000	0.000	464.005	0.	0.	0.	0.	0.	0.	0.	0.
12 115	0.000	0.000	472.090	0.	0.	0.	0.	0.	0.	0.	0.
12 116	0.000	0.000	471.509	0.	0.	0.	0.	0.	0.	0.	0.
12 117	0.000	1.550	465.552	0.	0.	0.	0.	0.	0.	0.	0.
12 118	0.000	6.199	434.853	0.	0.	0.	0.	0.	0.	0.	0.
12 119	0.000	9.299	330.178	0.	0.	0.	0.	0.	0.	0.	0.
12 120	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 121	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 122	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 123	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 124	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 1)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	472.090	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6123.737	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.156	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE336 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 2 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 2 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 2 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 2 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 2 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 2 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 2 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 2 8	0.000	1.033	463.489	0.	0.	0.	0.	0.	0.	0.	0.
12 2 9	0.000	0.000	465.522	0.	0.	0.	0.	0.	0.	0.	0.
12 210	0.000	0.000	471.360	0.	0.	0.	0.	0.	0.	0.	0.
12 211	0.000	0.000	466.737	0.	0.	0.	0.	0.	0.	0.	0.
12 212	0.000	0.000	443.801	0.	0.	0.	0.	0.	0.	0.	0.
12 213	0.000	0.000	442.880	0.	0.	0.	0.	0.	0.	0.	0.
12 214	0.000	0.000	462.153	0.	0.	0.	0.	0.	0.	0.	0.
12 215	0.000	0.000	470.396	0.	0.	0.	0.	0.	0.	0.	0.
12 216	0.000	0.000	470.565	0.	0.	0.	0.	0.	0.	0.	0.
12 217	0.000	1.550	465.277	0.	0.	0.	0.	0.	0.	0.	0.
12 218	0.000	6.199	434.908	0.	0.	0.	0.	0.	0.	0.	0.
12 219	0.000	9.299	330.236	0.	0.	0.	0.	0.	0.	0.	0.
12 220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 2)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	471.360	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6117.713	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	254.905	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE337 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 3 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 3 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 3 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 3 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 3 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 3 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 3 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 3 8	0.000	1.033	463.747	0.	0.	0.	0.	0.	0.	0.	0.
12 3 9	0.000	0.000	465.709	0.	0.	0.	0.	0.	0.	0.	0.
12 310	0.000	0.000	504.083	0.	0.	0.	0.	0.	0.	0.	0.
12 311	0.000	0.000	537.824	0.	0.	0.	0.	0.	0.	0.	0.
12 312	0.000	0.000	503.215	0.	0.	0.	0.	0.	0.	0.	0.
12 313	0.000	0.000	506.887	0.	0.	0.	0.	0.	0.	0.	0.
12 314	0.000	0.000	538.676	0.	0.	0.	0.	0.	0.	0.	0.
12 315	0.000	0.000	487.163	0.	0.	0.	0.	0.	0.	0.	0.
12 316	0.000	0.000	473.418	0.	0.	0.	0.	0.	0.	0.	0.
12 317	0.000	1.550	466.192	0.	0.	0.	0.	0.	0.	0.	0.
12 318	0.000	6.199	435.016	0.	0.	0.	0.	0.	0.	0.	0.
12 319	0.000	9.299	330.341	0.	0.	0.	0.	0.	0.	0.	0.
12 320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 3)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	538.676	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6442.662	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	268.444	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE338 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 4 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 4 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 4 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 4 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 4 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 4 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 4 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 4 8	0.000	1.033	463.490	0.	0.	0.	0.	0.	0.	0.	0.
12 4 9	0.000	0.000	484.234	0.	0.	0.	0.	0.	0.	0.	0.
12 410	0.000	0.000	565.618	0.	0.	0.	0.	0.	0.	0.	0.
12 411	0.000	0.000	628.251	0.	0.	0.	0.	0.	0.	0.	0.
12 412	0.000	0.000	611.854	0.	0.	0.	0.	0.	0.	0.	0.
12 413	0.000	0.000	607.480	0.	0.	0.	0.	0.	0.	0.	0.
12 414	0.000	0.000	563.190	0.	0.	0.	0.	0.	0.	0.	0.
12 415	0.000	0.000	564.990	0.	0.	0.	0.	0.	0.	0.	0.
12 416	0.000	0.000	486.826	0.	0.	0.	0.	0.	0.	0.	0.
12 417	0.000	1.550	467.992	0.	0.	0.	0.	0.	0.	0.	0.
12 418	0.000	6.199	435.361	0.	0.	0.	0.	0.	0.	0.	0.
12 419	0.000	9.299	330.384	0.	0.	0.	0.	0.	0.	0.	0.
12 420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 4)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	628.251	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6940.060	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	289.169	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE339 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 5 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 5 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 5 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 5 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 5 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 5 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 5 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
12 5 8	0.000	1.033	251.308	0.	0.	0.	0.	0.	0.	0.	0.
12 5 9	0.000	0.000	196.217	0.	0.	0.	0.	0.	0.	0.	0.
12 510	0.000	0.000	247.194	0.	0.	0.	0.	0.	0.	0.	0.
12 511	0.000	0.000	268.339	0.	0.	0.	0.	0.	0.	0.	0.
12 512	0.000	0.000	301.295	0.	0.	0.	0.	0.	0.	0.	0.
12 513	0.000	0.000	254.650	0.	0.	0.	0.	0.	0.	0.	0.
12 514	0.000	0.000	248.643	0.	0.	0.	0.	0.	0.	0.	0.
12 515	0.000	0.000	228.526	0.	0.	0.	0.	0.	0.	0.	0.
12 516	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
12 517	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
12 518	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 519	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12 520	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12 521	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12 522	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
12 523	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
12 524	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 5)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	301.295	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2693.444	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	112.227	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE340 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 6 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 6 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 6 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 6 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 6 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 6 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 6 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
12 6 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
12 6 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 610	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 611	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 612	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 613	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 614	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 615	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 616	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
12 617	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
12 618	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
12 619	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12 620	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12 621	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12 622	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
12 623	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
12 624	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 6)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE341 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 7 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 7 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 7 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 7 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 7 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 7 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 7 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 7 8	0.000	1.033	463.743	0.	0.	0.	0.	0.	0.	0.	0.
12 7 9	0.000	0.000	465.452	0.	0.	0.	0.	0.	0.	0.	0.
12 710	0.000	0.000	495.352	0.	0.	0.	0.	0.	0.	0.	0.
12 711	0.000	0.000	585.491	0.	0.	0.	0.	0.	0.	0.	0.
12 712	0.000	0.000	560.637	0.	0.	0.	0.	0.	0.	0.	0.
12 713	0.000	0.000	531.821	0.	0.	0.	0.	0.	0.	0.	0.
12 714	0.000	0.000	559.629	0.	0.	0.	0.	0.	0.	0.	0.
12 715	0.000	0.000	544.628	0.	0.	0.	0.	0.	0.	0.	0.
12 716	0.000	0.000	527.183	0.	0.	0.	0.	0.	0.	0.	0.
12 717	0.000	1.550	471.374	0.	0.	0.	0.	0.	0.	0.	0.
12 718	0.000	6.199	435.701	0.	0.	0.	0.	0.	0.	0.	0.
12 719	0.000	9.299	330.346	0.	0.	0.	0.	0.	0.	0.	0.
12 720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 7)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	585.491	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6701.749	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	279.240	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE342 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 8 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 8 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 8 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 8 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 8 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 8 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 8 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 8 8	0.000	1.033	463.364	0.	0.	0.	0.	0.	0.	0.	0.
12 8 9	0.000	0.000	465.602	0.	0.	0.	0.	0.	0.	0.	0.
12 810	0.000	0.000	472.826	0.	0.	0.	0.	0.	0.	0.	0.
12 811	0.000	0.000	469.240	0.	0.	0.	0.	0.	0.	0.	0.
12 812	0.000	0.000	445.612	0.	0.	0.	0.	0.	0.	0.	0.
12 813	0.000	0.000	445.644	0.	0.	0.	0.	0.	0.	0.	0.
12 814	0.000	0.000	468.277	0.	0.	0.	0.	0.	0.	0.	0.
12 815	0.000	0.000	475.868	0.	0.	0.	0.	0.	0.	0.	0.
12 816	0.000	0.000	475.084	0.	0.	0.	0.	0.	0.	0.	0.
12 817	0.000	1.550	466.506	0.	0.	0.	0.	0.	0.	0.	0.
12 818	0.000	6.199	434.956	0.	0.	0.	0.	0.	0.	0.	0.
12 819	0.000	9.299	330.047	0.	0.	0.	0.	0.	0.	0.	0.
12 820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 8)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	475.868	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6143.417	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.976	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE343 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
12 9 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 9 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 9 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 9 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 9 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
12 9 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
12 9 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
12 9 8	0.000	1.033	462.865	0.	0.	0.	0.	0.	0.	0.	0.
12 9 9	0.000	0.000	465.270	0.	0.	0.	0.	0.	0.	0.	0.
12 910	0.000	0.000	474.130	0.	0.	0.	0.	0.	0.	0.	0.
12 911	0.000	0.000	470.847	0.	0.	0.	0.	0.	0.	0.	0.
12 912	0.000	0.000	446.531	0.	0.	0.	0.	0.	0.	0.	0.
12 913	0.000	0.000	447.141	0.	0.	0.	0.	0.	0.	0.	0.
12 914	0.000	0.000	469.774	0.	0.	0.	0.	0.	0.	0.	0.
12 915	0.000	0.000	490.926	0.	0.	0.	0.	0.	0.	0.	0.
12 916	0.000	0.000	480.429	0.	0.	0.	0.	0.	0.	0.	0.
12 917	0.000	1.550	470.309	0.	0.	0.	0.	0.	0.	0.	0.
12 918	0.000	6.199	435.684	0.	0.	0.	0.	0.	0.	0.	0.
12 919	0.000	9.299	330.029	0.	0.	0.	0.	0.	0.	0.	0.
12 920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
12 921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
12 922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
12 923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
12 924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 9)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	490.926	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6174.326	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	257.264	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE344 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1210 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1210 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1210 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1210 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1210 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1210 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1210 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1210 8	0.000	1.033	462.860	0.	0.	0.	0.	0.	0.	0.	0.
1210 9	0.000	0.000	465.228	0.	0.	0.	0.	0.	0.	0.	0.
121010	0.000	0.000	471.165	0.	0.	0.	0.	0.	0.	0.	0.
121011	0.000	0.000	467.586	0.	0.	0.	0.	0.	0.	0.	0.
121012	0.000	0.000	444.480	0.	0.	0.	0.	0.	0.	0.	0.
121013	0.000	0.000	443.133	0.	0.	0.	0.	0.	0.	0.	0.
121014	0.000	0.000	462.505	0.	0.	0.	0.	0.	0.	0.	0.
121015	0.000	0.000	471.745	0.	0.	0.	0.	0.	0.	0.	0.
121016	0.000	0.000	472.549	0.	0.	0.	0.	0.	0.	0.	0.
121017	0.000	1.550	465.641	0.	0.	0.	0.	0.	0.	0.	0.
121018	0.000	6.199	434.688	0.	0.	0.	0.	0.	0.	0.	0.
121019	0.000	9.299	330.029	0.	0.	0.	0.	0.	0.	0.	0.
121020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 10)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	472.549	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6121.999	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.083	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE345 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1211 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1211 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1211 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1211 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1211 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1211 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1211 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1211 8	0.000	1.033	462.860	0.	0.	0.	0.	0.	0.	0.	0.
1211 9	0.000	0.000	465.208	0.	0.	0.	0.	0.	0.	0.	0.
121110	0.000	0.000	471.103	0.	0.	0.	0.	0.	0.	0.	0.
121111	0.000	0.000	467.493	0.	0.	0.	0.	0.	0.	0.	0.
121112	0.000	0.000	444.449	0.	0.	0.	0.	0.	0.	0.	0.
121113	0.000	0.000	444.941	0.	0.	0.	0.	0.	0.	0.	0.
121114	0.000	0.000	466.529	0.	0.	0.	0.	0.	0.	0.	0.
121115	0.000	0.000	477.339	0.	0.	0.	0.	0.	0.	0.	0.
121116	0.000	0.000	475.048	0.	0.	0.	0.	0.	0.	0.	0.
121117	0.000	1.550	466.487	0.	0.	0.	0.	0.	0.	0.	0.
121118	0.000	6.199	434.633	0.	0.	0.	0.	0.	0.	0.	0.
121119	0.000	9.299	329.959	0.	0.	0.	0.	0.	0.	0.	0.
121120	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121121	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121122	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121123	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121124	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 11)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	477.339	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6136.441	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.685	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE346 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1212 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1212 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1212 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1212 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1212 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1212 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1212 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1212 8	0.000	1.033	250.200	0.	0.	0.	0.	0.	0.	0.	0.
1212 9	0.000	0.000	195.547	0.	0.	0.	0.	0.	0.	0.	0.
121210	0.000	0.000	195.350	0.	0.	0.	0.	0.	0.	0.	0.
121211	0.000	0.000	195.370	0.	0.	0.	0.	0.	0.	0.	0.
121212	0.000	0.000	195.371	0.	0.	0.	0.	0.	0.	0.	0.
121213	0.000	0.000	195.385	0.	0.	0.	0.	0.	0.	0.	0.
121214	0.000	0.000	195.435	0.	0.	0.	0.	0.	0.	0.	0.
121215	0.000	0.000	195.420	0.	0.	0.	0.	0.	0.	0.	0.
121216	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
121217	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
121218	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121219	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121220	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121221	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121222	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121223	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
121224	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 12)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	250.200	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2315.350	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	96.473	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE347 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1213 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1213 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1213 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1213 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1213 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1213 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1213 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1213 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1213 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121310	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121311	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121312	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121313	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121314	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121315	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121316	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
121317	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
121318	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
121319	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
121320	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
121321	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
121322	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
121323	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
121324	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 13)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE348 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1214 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1214 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1214 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1214 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1214 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1214 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1214 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1214 8	0.000	1.033	462.857	0.	0.	0.	0.	0.	0.	0.	0.
1214 9	0.000	0.000	465.228	0.	0.	0.	0.	0.	0.	0.	0.
121410	0.000	0.000	471.165	0.	0.	0.	0.	0.	0.	0.	0.
121411	0.000	0.000	489.191	0.	0.	0.	0.	0.	0.	0.	0.
121412	0.000	0.000	524.600	0.	0.	0.	0.	0.	0.	0.	0.
121413	0.000	0.000	497.090	0.	0.	0.	0.	0.	0.	0.	0.
121414	0.000	0.000	470.614	0.	0.	0.	0.	0.	0.	0.	0.
121415	0.000	0.000	482.899	0.	0.	0.	0.	0.	0.	0.	0.
121416	0.000	0.000	474.363	0.	0.	0.	0.	0.	0.	0.	0.
121417	0.000	1.550	466.255	0.	0.	0.	0.	0.	0.	0.	0.
121418	0.000	6.199	434.704	0.	0.	0.	0.	0.	0.	0.	0.
121419	0.000	9.299	330.014	0.	0.	0.	0.	0.	0.	0.	0.
121420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 14)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	524.600	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6299.370	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	262.474	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE349 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1215 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1215 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1215 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1215 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1215 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1215 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1215 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1215 8	0.000	1.033	463.012	0.	0.	0.	0.	0.	0.	0.	0.
1215 9	0.000	0.000	465.296	0.	0.	0.	0.	0.	0.	0.	0.
121510	0.000	0.000	477.950	0.	0.	0.	0.	0.	0.	0.	0.
121511	0.000	0.000	536.649	0.	0.	0.	0.	0.	0.	0.	0.
121512	0.000	0.000	565.386	0.	0.	0.	0.	0.	0.	0.	0.
121513	0.000	0.000	555.907	0.	0.	0.	0.	0.	0.	0.	0.
121514	0.000	0.000	512.224	0.	0.	0.	0.	0.	0.	0.	0.
121515	0.000	0.000	481.950	0.	0.	0.	0.	0.	0.	0.	0.
121516	0.000	0.000	500.302	0.	0.	0.	0.	0.	0.	0.	0.
121517	0.000	1.550	473.162	0.	0.	0.	0.	0.	0.	0.	0.
121518	0.000	6.199	435.159	0.	0.	0.	0.	0.	0.	0.	0.
121519	0.000	9.299	330.244	0.	0.	0.	0.	0.	0.	0.	0.
121520	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121521	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121522	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121523	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121524	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 15)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	565.386	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6527.631	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	271.985	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE350 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1216 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1216 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1216 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1216 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1216 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1216 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1216 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1216 8	0.000	1.033	463.108	0.	0.	0.	0.	0.	0.	0.	0.
1216 9	0.000	0.000	547.256	0.	0.	0.	0.	0.	0.	0.	0.
121610	0.000	0.000	622.354	0.	0.	0.	0.	0.	0.	0.	0.
121611	0.000	0.000	630.903	0.	0.	0.	0.	0.	0.	0.	0.
121612	0.000	0.000	615.039	0.	0.	0.	0.	0.	0.	0.	0.
121613	0.000	0.000	612.848	0.	0.	0.	0.	0.	0.	0.	0.
121614	0.000	0.000	626.809	0.	0.	0.	0.	0.	0.	0.	0.
121615	0.000	0.000	647.719	0.	0.	0.	0.	0.	0.	0.	0.
121616	0.000	0.000	643.753	0.	0.	0.	0.	0.	0.	0.	0.
121617	0.000	1.550	577.000	0.	0.	0.	0.	0.	0.	0.	0.
121618	0.000	6.199	529.215	0.	0.	0.	0.	0.	0.	0.	0.
121619	0.000	9.299	414.885	0.	0.	0.	0.	0.	0.	0.	0.
121620	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121621	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121622	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121623	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121624	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 16)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	647.719	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7661.279	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	319.220	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE351 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1217 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1217 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1217 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1217 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1217 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1217 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1217 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1217 8	0.000	1.033	464.416	0.	0.	0.	0.	0.	0.	0.	0.
1217 9	0.000	0.000	519.826	0.	0.	0.	0.	0.	0.	0.	0.
121710	0.000	0.000	608.902	0.	0.	0.	0.	0.	0.	0.	0.
121711	0.000	0.000	640.068	0.	0.	0.	0.	0.	0.	0.	0.
121712	0.000	0.000	618.264	0.	0.	0.	0.	0.	0.	0.	0.
121713	0.000	0.000	623.090	0.	0.	0.	0.	0.	0.	0.	0.
121714	0.000	0.000	646.707	0.	0.	0.	0.	0.	0.	0.	0.
121715	0.000	0.000	639.716	0.	0.	0.	0.	0.	0.	0.	0.
121716	0.000	0.000	636.846	0.	0.	0.	0.	0.	0.	0.	0.
121717	0.000	1.550	539.547	0.	0.	0.	0.	0.	0.	0.	0.
121718	0.000	6.199	480.623	0.	0.	0.	0.	0.	0.	0.	0.
121719	0.000	9.299	364.293	0.	0.	0.	0.	0.	0.	0.	0.
121720	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121721	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121722	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121723	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121724	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 17)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	646.707	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7512.688	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	313.029	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE352 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1218 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1218 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1218 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1218 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1218 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1218 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1218 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1218 8	0.000	1.033	463.672	0.	0.	0.	0.	0.	0.	0.	0.
1218 9	0.000	0.000	592.553	0.	0.	0.	0.	0.	0.	0.	0.
121810	0.000	0.000	630.843	0.	0.	0.	0.	0.	0.	0.	0.
121811	0.000	0.000	646.704	0.	0.	0.	0.	0.	0.	0.	0.
121812	0.000	0.000	627.654	0.	0.	0.	0.	0.	0.	0.	0.
121813	0.000	0.000	627.304	0.	0.	0.	0.	0.	0.	0.	0.
121814	0.000	0.000	652.275	0.	0.	0.	0.	0.	0.	0.	0.
121815	0.000	0.000	653.293	0.	0.	0.	0.	0.	0.	0.	0.
121816	0.000	0.000	647.627	0.	0.	0.	0.	0.	0.	0.	0.
121817	0.000	1.550	611.627	0.	0.	0.	0.	0.	0.	0.	0.
121818	0.000	6.199	539.971	0.	0.	0.	0.	0.	0.	0.	0.
121819	0.000	9.299	436.884	0.	0.	0.	0.	0.	0.	0.	0.
121820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
121821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
121822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
121823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
121824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 18)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	653.293	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7860.796	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	327.533	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE353 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1219 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1219 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1219 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1219 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1219 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1219 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1219 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1219 8	0.000	1.033	252.388	0.	0.	0.	0.	0.	0.	0.	0.
1219 9	0.000	0.000	279.515	0.	0.	0.	0.	0.	0.	0.	0.
121910	0.000	0.000	331.938	0.	0.	0.	0.	0.	0.	0.	0.
121911	0.000	0.000	350.797	0.	0.	0.	0.	0.	0.	0.	0.
121912	0.000	0.000	356.103	0.	0.	0.	0.	0.	0.	0.	0.
121913	0.000	0.000	359.436	0.	0.	0.	0.	0.	0.	0.	0.
121914	0.000	0.000	355.071	0.	0.	0.	0.	0.	0.	0.	0.
121915	0.000	0.000	354.551	0.	0.	0.	0.	0.	0.	0.	0.
121916	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
121917	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
121918	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
121919	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121920	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121921	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121922	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
121923	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
121924	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 19)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	359.436	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	3337.071	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	139.045	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE354 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1220 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1220 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1220 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1220 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1220 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1220 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1220 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1220 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1220 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122010	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122011	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122012	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122013	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122014	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122015	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122016	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122017	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
122018	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
122019	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122020	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122021	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122022	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122023	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
122024	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 20)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE355 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1221 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1221 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1221 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1221 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1221 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1221 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1221 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1221 8	0.000	1.033	465.945	0.	0.	0.	0.	0.	0.	0.	0.
1221 9	0.000	0.000	529.272	0.	0.	0.	0.	0.	0.	0.	0.
122110	0.000	0.000	629.782	0.	0.	0.	0.	0.	0.	0.	0.
122111	0.000	0.000	639.400	0.	0.	0.	0.	0.	0.	0.	0.
122112	0.000	0.000	609.199	0.	0.	0.	0.	0.	0.	0.	0.
122113	0.000	0.000	605.058	0.	0.	0.	0.	0.	0.	0.	0.
122114	0.000	0.000	629.599	0.	0.	0.	0.	0.	0.	0.	0.
122115	0.000	0.000	632.895	0.	0.	0.	0.	0.	0.	0.	0.
122116	0.000	0.000	631.142	0.	0.	0.	0.	0.	0.	0.	0.
122117	0.000	1.550	478.451	0.	0.	0.	0.	0.	0.	0.	0.
122118	0.000	6.199	437.191	0.	0.	0.	0.	0.	0.	0.	0.
122119	0.000	9.299	330.243	0.	0.	0.	0.	0.	0.	0.	0.
122120	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
122121	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
122122	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
122123	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
122124	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 21)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	639.400	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7348.569	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	306.190	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE356 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1222 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1222 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1222 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1222 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1222 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1222 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1222 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1222 8	0.000	1.033	463.301	0.	0.	0.	0.	0.	0.	0.	0.
1222 9	0.000	0.000	466.410	0.	0.	0.	0.	0.	0.	0.	0.
122210	0.000	0.000	585.420	0.	0.	0.	0.	0.	0.	0.	0.
122211	0.000	0.000	621.795	0.	0.	0.	0.	0.	0.	0.	0.
122212	0.000	0.000	559.160	0.	0.	0.	0.	0.	0.	0.	0.
122213	0.000	0.000	590.999	0.	0.	0.	0.	0.	0.	0.	0.
122214	0.000	0.000	515.250	0.	0.	0.	0.	0.	0.	0.	0.
122215	0.000	0.000	522.424	0.	0.	0.	0.	0.	0.	0.	0.
122216	0.000	0.000	487.216	0.	0.	0.	0.	0.	0.	0.	0.
122217	0.000	1.550	470.445	0.	0.	0.	0.	0.	0.	0.	0.
122218	0.000	6.199	436.175	0.	0.	0.	0.	0.	0.	0.	0.
122219	0.000	9.299	330.238	0.	0.	0.	0.	0.	0.	0.	0.
122220	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
122221	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
122222	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
122223	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
122224	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 22)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	621.795	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6779.225	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	282.468	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE357 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1223 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1223 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1223 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1223 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1223 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1223 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1223 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1223 8	0.000	1.033	463.067	0.	0.	0.	0.	0.	0.	0.	0.
1223 9	0.000	0.000	465.749	0.	0.	0.	0.	0.	0.	0.	0.
122310	0.000	0.000	499.811	0.	0.	0.	0.	0.	0.	0.	0.
122311	0.000	0.000	626.524	0.	0.	0.	0.	0.	0.	0.	0.
122312	0.000	0.000	611.144	0.	0.	0.	0.	0.	0.	0.	0.
122313	0.000	0.000	550.440	0.	0.	0.	0.	0.	0.	0.	0.
122314	0.000	0.000	533.449	0.	0.	0.	0.	0.	0.	0.	0.
122315	0.000	0.000	480.622	0.	0.	0.	0.	0.	0.	0.	0.
122316	0.000	0.000	481.415	0.	0.	0.	0.	0.	0.	0.	0.
122317	0.000	1.550	467.089	0.	0.	0.	0.	0.	0.	0.	0.
122318	0.000	6.199	435.203	0.	0.	0.	0.	0.	0.	0.	0.
122319	0.000	9.299	330.152	0.	0.	0.	0.	0.	0.	0.	0.
122320	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
122321	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
122322	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
122323	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
122324	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 23)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	626.524	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6675.056	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	278.127	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE358 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1224 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1224 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1224 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1224 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1224 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1224 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1224 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1224 8	0.000	1.033	463.062	0.	0.	0.	0.	0.	0.	0.	0.
1224 9	0.000	0.000	465.348	0.	0.	0.	0.	0.	0.	0.	0.
122410	0.000	0.000	498.011	0.	0.	0.	0.	0.	0.	0.	0.
122411	0.000	0.000	626.616	0.	0.	0.	0.	0.	0.	0.	0.
122412	0.000	0.000	614.839	0.	0.	0.	0.	0.	0.	0.	0.
122413	0.000	0.000	624.720	0.	0.	0.	0.	0.	0.	0.	0.
122414	0.000	0.000	619.184	0.	0.	0.	0.	0.	0.	0.	0.
122415	0.000	0.000	618.821	0.	0.	0.	0.	0.	0.	0.	0.
122416	0.000	0.000	528.394	0.	0.	0.	0.	0.	0.	0.	0.
122417	0.000	1.550	470.787	0.	0.	0.	0.	0.	0.	0.	0.
122418	0.000	6.199	443.850	0.	0.	0.	0.	0.	0.	0.	0.
122419	0.000	9.299	336.600	0.	0.	0.	0.	0.	0.	0.	0.
122420	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
122421	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
122422	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
122423	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
122424	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 24)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	626.616	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7040.625	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	293.359	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE359 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1225 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1225 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1225 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1225 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1225 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1225 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1225 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1225 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1225 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122510	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122511	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122512	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122513	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122514	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122515	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122516	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122517	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
122518	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
122519	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122520	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122521	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122522	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122523	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
122524	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 25)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

WEATHER FILE- Los Angeles CA TMY2PAGE360 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW	EXT	TOTAL	LIGHT	TASK	EQUIP	HEAT	COOL	HTREJ	AUX	VENT
	END USE	END USE	USAGE	END USE	END USE	END USE	END USE	END USE	END USE	END USE	END USE
	KWH	KWH	KWH	BTU	BTU	BTU	BTU	BTU	BTU	BTU	BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1226 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1226 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1226 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1226 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1226 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1226 6	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1226 7	0.000	3.100	40.383	0.	0.	0.	0.	0.	0.	0.	0.
1226 8	0.000	1.033	250.983	0.	0.	0.	0.	0.	0.	0.	0.
1226 9	0.000	0.000	195.875	0.	0.	0.	0.	0.	0.	0.	0.
122610	0.000	0.000	195.619	0.	0.	0.	0.	0.	0.	0.	0.
122611	0.000	0.000	214.155	0.	0.	0.	0.	0.	0.	0.	0.
122612	0.000	0.000	196.418	0.	0.	0.	0.	0.	0.	0.	0.
122613	0.000	0.000	195.738	0.	0.	0.	0.	0.	0.	0.	0.
122614	0.000	0.000	195.714	0.	0.	0.	0.	0.	0.	0.	0.
122615	0.000	0.000	195.677	0.	0.	0.	0.	0.	0.	0.	0.
122616	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
122617	0.000	1.550	38.833	0.	0.	0.	0.	0.	0.	0.	0.
122618	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
122619	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
122620	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
122621	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
122622	0.000	9.299	46.582	0.	0.	0.	0.	0.	0.	0.	0.
122623	0.000	8.266	45.549	0.	0.	0.	0.	0.	0.	0.	0.
122624	0.000	7.232	44.516	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 26)											
MN	0.000	0.000	37.283	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	250.983	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	2337.452	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	97.394	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE361 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1227 1	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1227 2	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1227 3	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1227 4	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1227 5	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1227 6	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
1227 7	0.000	3.100	14.285	0.	0.	0.	0.	0.	0.	0.	0.
1227 8	0.000	1.033	12.218	0.	0.	0.	0.	0.	0.	0.	0.
1227 9	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122710	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122711	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122712	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122713	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122714	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122715	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122716	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
122717	0.000	1.550	12.735	0.	0.	0.	0.	0.	0.	0.	0.
122718	0.000	6.199	17.384	0.	0.	0.	0.	0.	0.	0.	0.
122719	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122720	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122721	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122722	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
122723	0.000	8.266	19.451	0.	0.	0.	0.	0.	0.	0.	0.
122724	0.000	7.232	18.417	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 27)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	20.484	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	370.211	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	15.425	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE362 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1228 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1228 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1228 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1228 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1228 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1228 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1228 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1228 8	0.000	1.033	463.230	0.	0.	0.	0.	0.	0.	0.	0.
1228 9	0.000	0.000	465.380	0.	0.	0.	0.	0.	0.	0.	0.
122810	0.000	0.000	471.273	0.	0.	0.	0.	0.	0.	0.	0.
122811	0.000	0.000	474.933	0.	0.	0.	0.	0.	0.	0.	0.
122812	0.000	0.000	468.964	0.	0.	0.	0.	0.	0.	0.	0.
122813	0.000	0.000	444.691	0.	0.	0.	0.	0.	0.	0.	0.
122814	0.000	0.000	463.734	0.	0.	0.	0.	0.	0.	0.	0.
122815	0.000	0.000	471.819	0.	0.	0.	0.	0.	0.	0.	0.
122816	0.000	0.000	471.486	0.	0.	0.	0.	0.	0.	0.	0.
122817	0.000	1.550	465.590	0.	0.	0.	0.	0.	0.	0.	0.
122818	0.000	6.199	435.013	0.	0.	0.	0.	0.	0.	0.	0.
122819	0.000	9.299	330.341	0.	0.	0.	0.	0.	0.	0.	0.
122820	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
122821	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
122822	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
122823	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
122824	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 28)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	474.933	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6156.846	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	256.535	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE363 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1229 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1229 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1229 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1229 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1229 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1229 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1229 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1229 8	0.000	1.033	463.484	0.	0.	0.	0.	0.	0.	0.	0.
1229 9	0.000	0.000	465.756	0.	0.	0.	0.	0.	0.	0.	0.
122910	0.000	0.000	493.083	0.	0.	0.	0.	0.	0.	0.	0.
122911	0.000	0.000	532.376	0.	0.	0.	0.	0.	0.	0.	0.
122912	0.000	0.000	550.997	0.	0.	0.	0.	0.	0.	0.	0.
122913	0.000	0.000	578.717	0.	0.	0.	0.	0.	0.	0.	0.
122914	0.000	0.000	614.803	0.	0.	0.	0.	0.	0.	0.	0.
122915	0.000	0.000	625.374	0.	0.	0.	0.	0.	0.	0.	0.
122916	0.000	0.000	604.286	0.	0.	0.	0.	0.	0.	0.	0.
122917	0.000	1.550	584.078	0.	0.	0.	0.	0.	0.	0.	0.
122918	0.000	6.199	516.941	0.	0.	0.	0.	0.	0.	0.	0.
122919	0.000	9.299	375.190	0.	0.	0.	0.	0.	0.	0.	0.
122920	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
122921	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
122922	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
122923	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
122924	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 29)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	625.374	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	7135.475	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	297.311	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE364 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1230 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1230 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1230 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1230 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1230 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1230 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1230 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1230 8	0.000	1.033	464.466	0.	0.	0.	0.	0.	0.	0.	0.
1230 9	0.000	0.000	471.673	0.	0.	0.	0.	0.	0.	0.	0.
123010	0.000	0.000	517.659	0.	0.	0.	0.	0.	0.	0.	0.
123011	0.000	0.000	557.731	0.	0.	0.	0.	0.	0.	0.	0.
123012	0.000	0.000	545.026	0.	0.	0.	0.	0.	0.	0.	0.
123013	0.000	0.000	550.658	0.	0.	0.	0.	0.	0.	0.	0.
123014	0.000	0.000	567.998	0.	0.	0.	0.	0.	0.	0.	0.
123015	0.000	0.000	523.235	0.	0.	0.	0.	0.	0.	0.	0.
123016	0.000	0.000	479.882	0.	0.	0.	0.	0.	0.	0.	0.
123017	0.000	1.550	468.365	0.	0.	0.	0.	0.	0.	0.	0.
123018	0.000	6.199	435.654	0.	0.	0.	0.	0.	0.	0.	0.
123019	0.000	9.299	330.385	0.	0.	0.	0.	0.	0.	0.	0.
123020	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
123021	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
123022	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
123023	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
123024	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 30)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	567.998	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6643.123	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	276.797	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE365 - 2

	EM1	EM1	EM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1	FM1
	DHW END USE KWH	EXT END USE KWH	TOTAL USAGE KWH	LIGHT END USE BTU	TASK END USE BTU	EQUIP END USE BTU	HEAT END USE BTU	COOL END USE BTU	HTREJ END USE BTU	AUX END USE BTU	VENT END USE BTU
	----(11)	----(12)	----(20)	----(1)	----(2)	----(3)	----(4)	----(5)	----(6)	----(7)	----(8)
1231 1	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1231 2	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1231 3	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1231 4	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1231 5	0.000	6.199	43.483	0.	0.	0.	0.	0.	0.	0.	0.
1231 6	0.000	6.199	50.284	0.	0.	0.	0.	0.	0.	0.	0.
1231 7	0.000	3.100	107.614	0.	0.	0.	0.	0.	0.	0.	0.
1231 8	0.000	1.033	463.778	0.	0.	0.	0.	0.	0.	0.	0.
1231 9	0.000	0.000	465.659	0.	0.	0.	0.	0.	0.	0.	0.
123110	0.000	0.000	471.645	0.	0.	0.	0.	0.	0.	0.	0.
123111	0.000	0.000	467.232	0.	0.	0.	0.	0.	0.	0.	0.
123112	0.000	0.000	444.012	0.	0.	0.	0.	0.	0.	0.	0.
123113	0.000	0.000	443.463	0.	0.	0.	0.	0.	0.	0.	0.
123114	0.000	0.000	476.652	0.	0.	0.	0.	0.	0.	0.	0.
123115	0.000	0.000	472.716	0.	0.	0.	0.	0.	0.	0.	0.
123116	0.000	0.000	472.039	0.	0.	0.	0.	0.	0.	0.	0.
123117	0.000	1.550	466.011	0.	0.	0.	0.	0.	0.	0.	0.
123118	0.000	6.199	435.017	0.	0.	0.	0.	0.	0.	0.	0.
123119	0.000	9.299	330.341	0.	0.	0.	0.	0.	0.	0.	0.
123120	0.000	9.299	105.802	0.	0.	0.	0.	0.	0.	0.	0.
123121	0.000	9.299	86.549	0.	0.	0.	0.	0.	0.	0.	0.
123122	0.000	9.299	63.437	0.	0.	0.	0.	0.	0.	0.	0.
123123	0.000	8.266	53.550	0.	0.	0.	0.	0.	0.	0.	0.
123124	0.000	7.232	45.741	0.	0.	0.	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 31)											
MN	0.000	0.000	43.483	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	476.652	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	101.770	6138.956	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	255.790	0.	0.	0.	0.	0.	0.	0.	0.
MONTHLY SUMMARY (DEC)											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	653.293	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	3154.877	159216.109	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	4.240	214.000	0.	0.	0.	0.	0.	0.	0.	0.
YEARLY SUMMARY											
MN	0.000	0.000	11.185	0.	0.	0.	0.	0.	0.	0.	0.
MX	0.000	9.299	795.884	0.	0.	0.	0.	0.	0.	0.	0.
SM	0.000	33473.105	2037319.125	0.	0.	0.	0.	0.	0.	0.	0.
AV	0.000	3.821	232.571	0.	0.	0.	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 1 - 3

MMDDHH	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 1 1	0.	0.	0.	0.	0.
1 1 2	0.	0.	0.	0.	0.
1 1 3	0.	0.	0.	0.	0.
1 1 4	0.	0.	0.	0.	0.
1 1 5	0.	0.	0.	0.	0.
1 1 6	0.	0.	0.	0.	0.
1 1 7	0.	0.	0.	0.	0.
1 1 8	0.	0.	0.	0.	0.
1 1 9	0.	0.	0.	0.	0.
1 110	0.	0.	0.	0.	0.
1 111	0.	0.	0.	0.	0.
1 112	0.	0.	0.	0.	0.
1 113	0.	0.	0.	0.	0.
1 114	0.	0.	0.	0.	0.
1 115	0.	0.	0.	0.	0.
1 116	0.	0.	0.	0.	0.
1 117	0.	0.	0.	0.	0.
1 118	0.	0.	0.	0.	0.
1 119	0.	0.	0.	0.	0.
1 120	0.	0.	0.	0.	0.
1 121	0.	0.	0.	0.	0.
1 122	0.	0.	0.	0.	0.
1 123	0.	0.	0.	0.	0.
1 124	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 2 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 2 1	0.	0.	0.	0.	0.
1 2 2	0.	0.	0.	0.	0.
1 2 3	0.	0.	0.	0.	0.
1 2 4	0.	0.	0.	0.	0.
1 2 5	0.	0.	0.	0.	0.
1 2 6	0.	0.	0.	0.	0.
1 2 7	0.	0.	0.	0.	0.
1 2 8	0.	0.	0.	0.	0.
1 2 9	0.	0.	0.	0.	0.
1 210	0.	0.	0.	0.	0.
1 211	0.	0.	0.	0.	0.
1 212	0.	0.	0.	0.	0.
1 213	0.	0.	0.	0.	0.
1 214	0.	0.	0.	0.	0.
1 215	0.	0.	0.	0.	0.
1 216	0.	0.	0.	0.	0.
1 217	0.	0.	0.	0.	0.
1 218	0.	0.	0.	0.	0.
1 219	0.	0.	0.	0.	0.
1 220	0.	0.	0.	0.	0.
1 221	0.	0.	0.	0.	0.
1 222	0.	0.	0.	0.	0.
1 223	0.	0.	0.	0.	0.
1 224	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 3 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 3 1	0.	0.	0.	0.	0.
1 3 2	0.	0.	0.	0.	0.
1 3 3	0.	0.	0.	0.	0.
1 3 4	0.	0.	0.	0.	0.
1 3 5	0.	0.	0.	0.	0.
1 3 6	0.	0.	0.	0.	0.
1 3 7	0.	0.	0.	0.	0.
1 3 8	0.	0.	0.	0.	0.
1 3 9	0.	0.	0.	0.	0.
1 310	0.	0.	0.	0.	0.
1 311	0.	0.	0.	0.	0.
1 312	0.	0.	0.	0.	0.
1 313	0.	0.	0.	0.	0.
1 314	0.	0.	0.	0.	0.
1 315	0.	0.	0.	0.	0.
1 316	0.	0.	0.	0.	0.
1 317	0.	0.	0.	0.	0.
1 318	0.	0.	0.	0.	0.
1 319	0.	0.	0.	0.	0.
1 320	0.	0.	0.	0.	0.
1 321	0.	0.	0.	0.	0.
1 322	0.	0.	0.	0.	0.
1 323	0.	0.	0.	0.	0.
1 324	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 4 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 4 1	0.	0.	0.	0.	0.
1 4 2	0.	0.	0.	0.	0.
1 4 3	0.	0.	0.	0.	0.
1 4 4	0.	0.	0.	0.	0.
1 4 5	0.	0.	0.	0.	0.
1 4 6	0.	0.	0.	0.	0.
1 4 7	0.	0.	0.	0.	0.
1 4 8	0.	0.	0.	0.	0.
1 4 9	0.	0.	0.	0.	0.
1 410	0.	0.	0.	0.	0.
1 411	0.	0.	0.	0.	0.
1 412	0.	0.	0.	0.	0.
1 413	0.	0.	0.	0.	0.
1 414	0.	0.	0.	0.	0.
1 415	0.	0.	0.	0.	0.
1 416	0.	0.	0.	0.	0.
1 417	0.	0.	0.	0.	0.
1 418	0.	0.	0.	0.	0.
1 419	0.	0.	0.	0.	0.
1 420	0.	0.	0.	0.	0.
1 421	0.	0.	0.	0.	0.
1 422	0.	0.	0.	0.	0.
1 423	0.	0.	0.	0.	0.
1 424	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 5 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 5 1	0.	0.	0.	0.	0.
1 5 2	0.	0.	0.	0.	0.
1 5 3	0.	0.	0.	0.	0.
1 5 4	0.	0.	0.	0.	0.
1 5 5	0.	0.	0.	0.	0.
1 5 6	0.	0.	0.	0.	0.
1 5 7	0.	0.	0.	0.	0.
1 5 8	0.	0.	0.	0.	0.
1 5 9	0.	0.	0.	0.	0.
1 510	0.	0.	0.	0.	0.
1 511	0.	0.	0.	0.	0.
1 512	0.	0.	0.	0.	0.
1 513	0.	0.	0.	0.	0.
1 514	0.	0.	0.	0.	0.
1 515	0.	0.	0.	0.	0.
1 516	0.	0.	0.	0.	0.
1 517	0.	0.	0.	0.	0.
1 518	0.	0.	0.	0.	0.
1 519	0.	0.	0.	0.	0.
1 520	0.	0.	0.	0.	0.
1 521	0.	0.	0.	0.	0.
1 522	0.	0.	0.	0.	0.
1 523	0.	0.	0.	0.	0.
1 524	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 6 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 6 1	0.	0.	0.	0.	0.
1 6 2	0.	0.	0.	0.	0.
1 6 3	0.	0.	0.	0.	0.
1 6 4	0.	0.	0.	0.	0.
1 6 5	0.	0.	0.	0.	0.
1 6 6	0.	0.	0.	0.	0.
1 6 7	0.	0.	0.	0.	0.
1 6 8	0.	0.	0.	0.	0.
1 6 9	0.	0.	0.	0.	0.
1 610	0.	0.	0.	0.	0.
1 611	0.	0.	0.	0.	0.
1 612	0.	0.	0.	0.	0.
1 613	0.	0.	0.	0.	0.
1 614	0.	0.	0.	0.	0.
1 615	0.	0.	0.	0.	0.
1 616	0.	0.	0.	0.	0.
1 617	0.	0.	0.	0.	0.
1 618	0.	0.	0.	0.	0.
1 619	0.	0.	0.	0.	0.
1 620	0.	0.	0.	0.	0.
1 621	0.	0.	0.	0.	0.
1 622	0.	0.	0.	0.	0.
1 623	0.	0.	0.	0.	0.
1 624	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 7 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 7 1	0.	0.	0.	0.	0.
1 7 2	0.	0.	0.	0.	0.
1 7 3	0.	0.	0.	0.	0.
1 7 4	0.	0.	0.	0.	0.
1 7 5	0.	0.	0.	0.	0.
1 7 6	0.	0.	0.	0.	0.
1 7 7	0.	0.	0.	0.	0.
1 7 8	0.	0.	0.	0.	0.
1 7 9	0.	0.	0.	0.	0.
1 710	0.	0.	0.	0.	0.
1 711	0.	0.	0.	0.	0.
1 712	0.	0.	0.	0.	0.
1 713	0.	0.	0.	0.	0.
1 714	0.	0.	0.	0.	0.
1 715	0.	0.	0.	0.	0.
1 716	0.	0.	0.	0.	0.
1 717	0.	0.	0.	0.	0.
1 718	0.	0.	0.	0.	0.
1 719	0.	0.	0.	0.	0.
1 720	0.	0.	0.	0.	0.
1 721	0.	0.	0.	0.	0.
1 722	0.	0.	0.	0.	0.
1 723	0.	0.	0.	0.	0.
1 724	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 8 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 8 1	0.	0.	0.	0.	0.
1 8 2	0.	0.	0.	0.	0.
1 8 3	0.	0.	0.	0.	0.
1 8 4	0.	0.	0.	0.	0.
1 8 5	0.	0.	0.	0.	0.
1 8 6	0.	0.	0.	0.	0.
1 8 7	0.	0.	0.	0.	0.
1 8 8	0.	0.	0.	0.	0.
1 8 9	0.	0.	0.	0.	0.
1 810	0.	0.	0.	0.	0.
1 811	0.	0.	0.	0.	0.
1 812	0.	0.	0.	0.	0.
1 813	0.	0.	0.	0.	0.
1 814	0.	0.	0.	0.	0.
1 815	0.	0.	0.	0.	0.
1 816	0.	0.	0.	0.	0.
1 817	0.	0.	0.	0.	0.
1 818	0.	0.	0.	0.	0.
1 819	0.	0.	0.	0.	0.
1 820	0.	0.	0.	0.	0.
1 821	0.	0.	0.	0.	0.
1 822	0.	0.	0.	0.	0.
1 823	0.	0.	0.	0.	0.
1 824	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 9 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1 9 1	0.	0.	0.	0.	0.
1 9 2	0.	0.	0.	0.	0.
1 9 3	0.	0.	0.	0.	0.
1 9 4	0.	0.	0.	0.	0.
1 9 5	0.	0.	0.	0.	0.
1 9 6	0.	0.	0.	0.	0.
1 9 7	0.	0.	0.	0.	0.
1 9 8	0.	0.	0.	0.	0.
1 9 9	0.	0.	0.	0.	0.
1 910	0.	0.	0.	0.	0.
1 911	0.	0.	0.	0.	0.
1 912	0.	0.	0.	0.	0.
1 913	0.	0.	0.	0.	0.
1 914	0.	0.	0.	0.	0.
1 915	0.	0.	0.	0.	0.
1 916	0.	0.	0.	0.	0.
1 917	0.	0.	0.	0.	0.
1 918	0.	0.	0.	0.	0.
1 919	0.	0.	0.	0.	0.
1 920	0.	0.	0.	0.	0.
1 921	0.	0.	0.	0.	0.
1 922	0.	0.	0.	0.	0.
1 923	0.	0.	0.	0.	0.
1 924	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 10 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
110 1	0.	0.	0.	0.	0.
110 2	0.	0.	0.	0.	0.
110 3	0.	0.	0.	0.	0.
110 4	0.	0.	0.	0.	0.
110 5	0.	0.	0.	0.	0.
110 6	0.	0.	0.	0.	0.
110 7	0.	0.	0.	0.	0.
110 8	0.	0.	0.	0.	0.
110 9	0.	0.	0.	0.	0.
11010	0.	0.	0.	0.	0.
11011	0.	0.	0.	0.	0.
11012	0.	0.	0.	0.	0.
11013	0.	0.	0.	0.	0.
11014	0.	0.	0.	0.	0.
11015	0.	0.	0.	0.	0.
11016	0.	0.	0.	0.	0.
11017	0.	0.	0.	0.	0.
11018	0.	0.	0.	0.	0.
11019	0.	0.	0.	0.	0.
11020	0.	0.	0.	0.	0.
11021	0.	0.	0.	0.	0.
11022	0.	0.	0.	0.	0.
11023	0.	0.	0.	0.	0.
11024	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 11 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
111 1	0.	0.	0.	0.	0.
111 2	0.	0.	0.	0.	0.
111 3	0.	0.	0.	0.	0.
111 4	0.	0.	0.	0.	0.
111 5	0.	0.	0.	0.	0.
111 6	0.	0.	0.	0.	0.
111 7	0.	0.	0.	0.	0.
111 8	0.	0.	0.	0.	0.
111 9	0.	0.	0.	0.	0.
11110	0.	0.	0.	0.	0.
11111	0.	0.	0.	0.	0.
11112	0.	0.	0.	0.	0.
11113	0.	0.	0.	0.	0.
11114	0.	0.	0.	0.	0.
11115	0.	0.	0.	0.	0.
11116	0.	0.	0.	0.	0.
11117	0.	0.	0.	0.	0.
11118	0.	0.	0.	0.	0.
11119	0.	0.	0.	0.	0.
11120	0.	0.	0.	0.	0.
11121	0.	0.	0.	0.	0.
11122	0.	0.	0.	0.	0.
11123	0.	0.	0.	0.	0.
11124	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 12 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
112 1	0.	0.	0.	0.	0.
112 2	0.	0.	0.	0.	0.
112 3	0.	0.	0.	0.	0.
112 4	0.	0.	0.	0.	0.
112 5	0.	0.	0.	0.	0.
112 6	0.	0.	0.	0.	0.
112 7	0.	0.	0.	0.	0.
112 8	0.	0.	0.	0.	0.
112 9	0.	0.	0.	0.	0.
11210	0.	0.	0.	0.	0.
11211	0.	0.	0.	0.	0.
11212	0.	0.	0.	0.	0.
11213	0.	0.	0.	0.	0.
11214	0.	0.	0.	0.	0.
11215	0.	0.	0.	0.	0.
11216	0.	0.	0.	0.	0.
11217	0.	0.	0.	0.	0.
11218	0.	0.	0.	0.	0.
11219	0.	0.	0.	0.	0.
11220	0.	0.	0.	0.	0.
11221	0.	0.	0.	0.	0.
11222	0.	0.	0.	0.	0.
11223	0.	0.	0.	0.	0.
11224	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 13 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
113 1	0.	0.	0.	0.	0.
113 2	0.	0.	0.	0.	0.
113 3	0.	0.	0.	0.	0.
113 4	0.	0.	0.	0.	0.
113 5	0.	0.	0.	0.	0.
113 6	0.	0.	0.	0.	0.
113 7	0.	0.	0.	0.	0.
113 8	0.	0.	0.	0.	0.
113 9	0.	0.	0.	0.	0.
11310	0.	0.	0.	0.	0.
11311	0.	0.	0.	0.	0.
11312	0.	0.	0.	0.	0.
11313	0.	0.	0.	0.	0.
11314	0.	0.	0.	0.	0.
11315	0.	0.	0.	0.	0.
11316	0.	0.	0.	0.	0.
11317	0.	0.	0.	0.	0.
11318	0.	0.	0.	0.	0.
11319	0.	0.	0.	0.	0.
11320	0.	0.	0.	0.	0.
11321	0.	0.	0.	0.	0.
11322	0.	0.	0.	0.	0.
11323	0.	0.	0.	0.	0.
11324	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 14 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
114 1	0.	0.	0.	0.	0.
114 2	0.	0.	0.	0.	0.
114 3	0.	0.	0.	0.	0.
114 4	0.	0.	0.	0.	0.
114 5	0.	0.	0.	0.	0.
114 6	0.	0.	0.	0.	0.
114 7	0.	0.	0.	0.	0.
114 8	0.	0.	0.	0.	0.
114 9	0.	0.	0.	0.	0.
11410	0.	0.	0.	0.	0.
11411	0.	0.	0.	0.	0.
11412	0.	0.	0.	0.	0.
11413	0.	0.	0.	0.	0.
11414	0.	0.	0.	0.	0.
11415	0.	0.	0.	0.	0.
11416	0.	0.	0.	0.	0.
11417	0.	0.	0.	0.	0.
11418	0.	0.	0.	0.	0.
11419	0.	0.	0.	0.	0.
11420	0.	0.	0.	0.	0.
11421	0.	0.	0.	0.	0.
11422	0.	0.	0.	0.	0.
11423	0.	0.	0.	0.	0.
11424	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 15 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
115 1	0.	0.	0.	0.	0.
115 2	0.	0.	0.	0.	0.
115 3	0.	0.	0.	0.	0.
115 4	0.	0.	0.	0.	0.
115 5	0.	0.	0.	0.	0.
115 6	0.	0.	0.	0.	0.
115 7	0.	0.	0.	0.	0.
115 8	0.	0.	0.	0.	0.
115 9	0.	0.	0.	0.	0.
11510	0.	0.	0.	0.	0.
11511	0.	0.	0.	0.	0.
11512	0.	0.	0.	0.	0.
11513	0.	0.	0.	0.	0.
11514	0.	0.	0.	0.	0.
11515	0.	0.	0.	0.	0.
11516	0.	0.	0.	0.	0.
11517	0.	0.	0.	0.	0.
11518	0.	0.	0.	0.	0.
11519	0.	0.	0.	0.	0.
11520	0.	0.	0.	0.	0.
11521	0.	0.	0.	0.	0.
11522	0.	0.	0.	0.	0.
11523	0.	0.	0.	0.	0.
11524	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 16 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
116 1	0.	0.	0.	0.	0.
116 2	0.	0.	0.	0.	0.
116 3	0.	0.	0.	0.	0.
116 4	0.	0.	0.	0.	0.
116 5	0.	0.	0.	0.	0.
116 6	0.	0.	0.	0.	0.
116 7	0.	0.	0.	0.	0.
116 8	0.	0.	0.	0.	0.
116 9	0.	0.	0.	0.	0.
11610	0.	0.	0.	0.	0.
11611	0.	0.	0.	0.	0.
11612	0.	0.	0.	0.	0.
11613	0.	0.	0.	0.	0.
11614	0.	0.	0.	0.	0.
11615	0.	0.	0.	0.	0.
11616	0.	0.	0.	0.	0.
11617	0.	0.	0.	0.	0.
11618	0.	0.	0.	0.	0.
11619	0.	0.	0.	0.	0.
11620	0.	0.	0.	0.	0.
11621	0.	0.	0.	0.	0.
11622	0.	0.	0.	0.	0.
11623	0.	0.	0.	0.	0.
11624	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 17 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
117 1	0.	0.	0.	0.	0.
117 2	0.	0.	0.	0.	0.
117 3	0.	0.	0.	0.	0.
117 4	0.	0.	0.	0.	0.
117 5	0.	0.	0.	0.	0.
117 6	0.	0.	0.	0.	0.
117 7	0.	0.	0.	0.	0.
117 8	0.	0.	0.	0.	0.
117 9	0.	0.	0.	0.	0.
11710	0.	0.	0.	0.	0.
11711	0.	0.	0.	0.	0.
11712	0.	0.	0.	0.	0.
11713	0.	0.	0.	0.	0.
11714	0.	0.	0.	0.	0.
11715	0.	0.	0.	0.	0.
11716	0.	0.	0.	0.	0.
11717	0.	0.	0.	0.	0.
11718	0.	0.	0.	0.	0.
11719	0.	0.	0.	0.	0.
11720	0.	0.	0.	0.	0.
11721	0.	0.	0.	0.	0.
11722	0.	0.	0.	0.	0.
11723	0.	0.	0.	0.	0.
11724	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 18 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
118 1	0.	0.	0.	0.	0.
118 2	0.	0.	0.	0.	0.
118 3	0.	0.	0.	0.	0.
118 4	0.	0.	0.	0.	0.
118 5	0.	0.	0.	0.	0.
118 6	0.	0.	0.	0.	0.
118 7	0.	0.	0.	0.	0.
118 8	0.	0.	0.	0.	0.
118 9	0.	0.	0.	0.	0.
11810	0.	0.	0.	0.	0.
11811	0.	0.	0.	0.	0.
11812	0.	0.	0.	0.	0.
11813	0.	0.	0.	0.	0.
11814	0.	0.	0.	0.	0.
11815	0.	0.	0.	0.	0.
11816	0.	0.	0.	0.	0.
11817	0.	0.	0.	0.	0.
11818	0.	0.	0.	0.	0.
11819	0.	0.	0.	0.	0.
11820	0.	0.	0.	0.	0.
11821	0.	0.	0.	0.	0.
11822	0.	0.	0.	0.	0.
11823	0.	0.	0.	0.	0.
11824	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 19 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
119 1	0.	0.	0.	0.	0.
119 2	0.	0.	0.	0.	0.
119 3	0.	0.	0.	0.	0.
119 4	0.	0.	0.	0.	0.
119 5	0.	0.	0.	0.	0.
119 6	0.	0.	0.	0.	0.
119 7	0.	0.	0.	0.	0.
119 8	0.	0.	0.	0.	0.
119 9	0.	0.	0.	0.	0.
11910	0.	0.	0.	0.	0.
11911	0.	0.	0.	0.	0.
11912	0.	0.	0.	0.	0.
11913	0.	0.	0.	0.	0.
11914	0.	0.	0.	0.	0.
11915	0.	0.	0.	0.	0.
11916	0.	0.	0.	0.	0.
11917	0.	0.	0.	0.	0.
11918	0.	0.	0.	0.	0.
11919	0.	0.	0.	0.	0.
11920	0.	0.	0.	0.	0.
11921	0.	0.	0.	0.	0.
11922	0.	0.	0.	0.	0.
11923	0.	0.	0.	0.	0.
11924	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 20 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
120 1	0.	0.	0.	0.	0.
120 2	0.	0.	0.	0.	0.
120 3	0.	0.	0.	0.	0.
120 4	0.	0.	0.	0.	0.
120 5	0.	0.	0.	0.	0.
120 6	0.	0.	0.	0.	0.
120 7	0.	0.	0.	0.	0.
120 8	0.	0.	0.	0.	0.
120 9	0.	0.	0.	0.	0.
12010	0.	0.	0.	0.	0.
12011	0.	0.	0.	0.	0.
12012	0.	0.	0.	0.	0.
12013	0.	0.	0.	0.	0.
12014	0.	0.	0.	0.	0.
12015	0.	0.	0.	0.	0.
12016	0.	0.	0.	0.	0.
12017	0.	0.	0.	0.	0.
12018	0.	0.	0.	0.	0.
12019	0.	0.	0.	0.	0.
12020	0.	0.	0.	0.	0.
12021	0.	0.	0.	0.	0.
12022	0.	0.	0.	0.	0.
12023	0.	0.	0.	0.	0.
12024	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 21 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
121 1	0.	0.	0.	0.	0.
121 2	0.	0.	0.	0.	0.
121 3	0.	0.	0.	0.	0.
121 4	0.	0.	0.	0.	0.
121 5	0.	0.	0.	0.	0.
121 6	0.	0.	0.	0.	0.
121 7	0.	0.	0.	0.	0.
121 8	0.	0.	0.	0.	0.
121 9	0.	0.	0.	0.	0.
12110	0.	0.	0.	0.	0.
12111	0.	0.	0.	0.	0.
12112	0.	0.	0.	0.	0.
12113	0.	0.	0.	0.	0.
12114	0.	0.	0.	0.	0.
12115	0.	0.	0.	0.	0.
12116	0.	0.	0.	0.	0.
12117	0.	0.	0.	0.	0.
12118	0.	0.	0.	0.	0.
12119	0.	0.	0.	0.	0.
12120	0.	0.	0.	0.	0.
12121	0.	0.	0.	0.	0.
12122	0.	0.	0.	0.	0.
12123	0.	0.	0.	0.	0.
12124	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 22 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
122 1	0.	0.	0.	0.	0.
122 2	0.	0.	0.	0.	0.
122 3	0.	0.	0.	0.	0.
122 4	0.	0.	0.	0.	0.
122 5	0.	0.	0.	0.	0.
122 6	0.	0.	0.	0.	0.
122 7	0.	0.	0.	0.	0.
122 8	0.	0.	0.	0.	0.
122 9	0.	0.	0.	0.	0.
12210	0.	0.	0.	0.	0.
12211	0.	0.	0.	0.	0.
12212	0.	0.	0.	0.	0.
12213	0.	0.	0.	0.	0.
12214	0.	0.	0.	0.	0.
12215	0.	0.	0.	0.	0.
12216	0.	0.	0.	0.	0.
12217	0.	0.	0.	0.	0.
12218	0.	0.	0.	0.	0.
12219	0.	0.	0.	0.	0.
12220	0.	0.	0.	0.	0.
12221	0.	0.	0.	0.	0.
12222	0.	0.	0.	0.	0.
12223	0.	0.	0.	0.	0.
12224	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 23 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
123 1	0.	0.	0.	0.	0.
123 2	0.	0.	0.	0.	0.
123 3	0.	0.	0.	0.	0.
123 4	0.	0.	0.	0.	0.
123 5	0.	0.	0.	0.	0.
123 6	0.	0.	0.	0.	0.
123 7	0.	0.	0.	0.	0.
123 8	0.	0.	0.	0.	0.
123 9	0.	0.	0.	0.	0.
12310	0.	0.	0.	0.	0.
12311	0.	0.	0.	0.	0.
12312	0.	0.	0.	0.	0.
12313	0.	0.	0.	0.	0.
12314	0.	0.	0.	0.	0.
12315	0.	0.	0.	0.	0.
12316	0.	0.	0.	0.	0.
12317	0.	0.	0.	0.	0.
12318	0.	0.	0.	0.	0.
12319	0.	0.	0.	0.	0.
12320	0.	0.	0.	0.	0.
12321	0.	0.	0.	0.	0.
12322	0.	0.	0.	0.	0.
12323	0.	0.	0.	0.	0.
12324	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 24 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
124 1	0.	0.	0.	0.	0.
124 2	0.	0.	0.	0.	0.
124 3	0.	0.	0.	0.	0.
124 4	0.	0.	0.	0.	0.
124 5	0.	0.	0.	0.	0.
124 6	0.	0.	0.	0.	0.
124 7	0.	0.	0.	0.	0.
124 8	0.	0.	0.	0.	0.
124 9	0.	0.	0.	0.	0.
12410	0.	0.	0.	0.	0.
12411	0.	0.	0.	0.	0.
12412	0.	0.	0.	0.	0.
12413	0.	0.	0.	0.	0.
12414	0.	0.	0.	0.	0.
12415	0.	0.	0.	0.	0.
12416	0.	0.	0.	0.	0.
12417	0.	0.	0.	0.	0.
12418	0.	0.	0.	0.	0.
12419	0.	0.	0.	0.	0.
12420	0.	0.	0.	0.	0.
12421	0.	0.	0.	0.	0.
12422	0.	0.	0.	0.	0.
12423	0.	0.	0.	0.	0.
12424	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 25 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
125 1	0.	0.	0.	0.	0.
125 2	0.	0.	0.	0.	0.
125 3	0.	0.	0.	0.	0.
125 4	0.	0.	0.	0.	0.
125 5	0.	0.	0.	0.	0.
125 6	0.	0.	0.	0.	0.
125 7	0.	0.	0.	0.	0.
125 8	0.	0.	0.	0.	0.
125 9	0.	0.	0.	0.	0.
12510	0.	0.	0.	0.	0.
12511	0.	0.	0.	0.	0.
12512	0.	0.	0.	0.	0.
12513	0.	0.	0.	0.	0.
12514	0.	0.	0.	0.	0.
12515	0.	0.	0.	0.	0.
12516	0.	0.	0.	0.	0.
12517	0.	0.	0.	0.	0.
12518	0.	0.	0.	0.	0.
12519	0.	0.	0.	0.	0.
12520	0.	0.	0.	0.	0.
12521	0.	0.	0.	0.	0.
12522	0.	0.	0.	0.	0.
12523	0.	0.	0.	0.	0.
12524	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 26 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
126 1	0.	0.	0.	0.	0.
126 2	0.	0.	0.	0.	0.
126 3	0.	0.	0.	0.	0.
126 4	0.	0.	0.	0.	0.
126 5	0.	0.	0.	0.	0.
126 6	0.	0.	0.	0.	0.
126 7	0.	0.	0.	0.	0.
126 8	0.	0.	0.	0.	0.
126 9	0.	0.	0.	0.	0.
12610	0.	0.	0.	0.	0.
12611	0.	0.	0.	0.	0.
12612	0.	0.	0.	0.	0.
12613	0.	0.	0.	0.	0.
12614	0.	0.	0.	0.	0.
12615	0.	0.	0.	0.	0.
12616	0.	0.	0.	0.	0.
12617	0.	0.	0.	0.	0.
12618	0.	0.	0.	0.	0.
12619	0.	0.	0.	0.	0.
12620	0.	0.	0.	0.	0.
12621	0.	0.	0.	0.	0.
12622	0.	0.	0.	0.	0.
12623	0.	0.	0.	0.	0.
12624	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 27 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
127 1	0.	0.	0.	0.	0.
127 2	0.	0.	0.	0.	0.
127 3	0.	0.	0.	0.	0.
127 4	0.	0.	0.	0.	0.
127 5	0.	0.	0.	0.	0.
127 6	0.	0.	0.	0.	0.
127 7	0.	0.	0.	0.	0.
127 8	0.	0.	0.	0.	0.
127 9	0.	0.	0.	0.	0.
12710	0.	0.	0.	0.	0.
12711	0.	0.	0.	0.	0.
12712	0.	0.	0.	0.	0.
12713	0.	0.	0.	0.	0.
12714	0.	0.	0.	0.	0.
12715	0.	0.	0.	0.	0.
12716	0.	0.	0.	0.	0.
12717	0.	0.	0.	0.	0.
12718	0.	0.	0.	0.	0.
12719	0.	0.	0.	0.	0.
12720	0.	0.	0.	0.	0.
12721	0.	0.	0.	0.	0.
12722	0.	0.	0.	0.	0.
12723	0.	0.	0.	0.	0.
12724	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 28 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
128 1	0.	0.	0.	0.	0.
128 2	0.	0.	0.	0.	0.
128 3	0.	0.	0.	0.	0.
128 4	0.	0.	0.	0.	0.
128 5	0.	0.	0.	0.	0.
128 6	0.	0.	0.	0.	0.
128 7	0.	0.	0.	0.	0.
128 8	0.	0.	0.	0.	0.
128 9	0.	0.	0.	0.	0.
12810	0.	0.	0.	0.	0.
12811	0.	0.	0.	0.	0.
12812	0.	0.	0.	0.	0.
12813	0.	0.	0.	0.	0.
12814	0.	0.	0.	0.	0.
12815	0.	0.	0.	0.	0.
12816	0.	0.	0.	0.	0.
12817	0.	0.	0.	0.	0.
12818	0.	0.	0.	0.	0.
12819	0.	0.	0.	0.	0.
12820	0.	0.	0.	0.	0.
12821	0.	0.	0.	0.	0.
12822	0.	0.	0.	0.	0.
12823	0.	0.	0.	0.	0.
12824	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 29 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
129 1	0.	0.	0.	0.	0.
129 2	0.	0.	0.	0.	0.
129 3	0.	0.	0.	0.	0.
129 4	0.	0.	0.	0.	0.
129 5	0.	0.	0.	0.	0.
129 6	0.	0.	0.	0.	0.
129 7	0.	0.	0.	0.	0.
129 8	0.	0.	0.	0.	0.
129 9	0.	0.	0.	0.	0.
12910	0.	0.	0.	0.	0.
12911	0.	0.	0.	0.	0.
12912	0.	0.	0.	0.	0.
12913	0.	0.	0.	0.	0.
12914	0.	0.	0.	0.	0.
12915	0.	0.	0.	0.	0.
12916	0.	0.	0.	0.	0.
12917	0.	0.	0.	0.	0.
12918	0.	0.	0.	0.	0.
12919	0.	0.	0.	0.	0.
12920	0.	0.	0.	0.	0.
12921	0.	0.	0.	0.	0.
12922	0.	0.	0.	0.	0.
12923	0.	0.	0.	0.	0.
12924	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 30 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
130 1	0.	0.	0.	0.	0.
130 2	0.	0.	0.	0.	0.
130 3	0.	0.	0.	0.	0.
130 4	0.	0.	0.	0.	0.
130 5	0.	0.	0.	0.	0.
130 6	0.	0.	0.	0.	0.
130 7	0.	0.	0.	0.	0.
130 8	0.	0.	0.	0.	0.
130 9	0.	0.	0.	0.	0.
13010	0.	0.	0.	0.	0.
13011	0.	0.	0.	0.	0.
13012	0.	0.	0.	0.	0.
13013	0.	0.	0.	0.	0.
13014	0.	0.	0.	0.	0.
13015	0.	0.	0.	0.	0.
13016	0.	0.	0.	0.	0.
13017	0.	0.	0.	0.	0.
13018	0.	0.	0.	0.	0.
13019	0.	0.	0.	0.	0.
13020	0.	0.	0.	0.	0.
13021	0.	0.	0.	0.	0.
13022	0.	0.	0.	0.	0.
13023	0.	0.	0.	0.	0.
13024	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 31 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
131 1	0.	0.	0.	0.	0.
131 2	0.	0.	0.	0.	0.
131 3	0.	0.	0.	0.	0.
131 4	0.	0.	0.	0.	0.
131 5	0.	0.	0.	0.	0.
131 6	0.	0.	0.	0.	0.
131 7	0.	0.	0.	0.	0.
131 8	0.	0.	0.	0.	0.
131 9	0.	0.	0.	0.	0.
13110	0.	0.	0.	0.	0.
13111	0.	0.	0.	0.	0.
13112	0.	0.	0.	0.	0.
13113	0.	0.	0.	0.	0.
13114	0.	0.	0.	0.	0.
13115	0.	0.	0.	0.	0.
13116	0.	0.	0.	0.	0.
13117	0.	0.	0.	0.	0.
13118	0.	0.	0.	0.	0.
13119	0.	0.	0.	0.	0.
13120	0.	0.	0.	0.	0.
13121	0.	0.	0.	0.	0.
13122	0.	0.	0.	0.	0.
13123	0.	0.	0.	0.	0.
13124	0.	0.	0.	0.	0.
DAILY SUMMARY (JAN 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (JAN)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 32 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 1 1	0.	0.	0.	0.	0.
2 1 2	0.	0.	0.	0.	0.
2 1 3	0.	0.	0.	0.	0.
2 1 4	0.	0.	0.	0.	0.
2 1 5	0.	0.	0.	0.	0.
2 1 6	0.	0.	0.	0.	0.
2 1 7	0.	0.	0.	0.	0.
2 1 8	0.	0.	0.	0.	0.
2 1 9	0.	0.	0.	0.	0.
2 110	0.	0.	0.	0.	0.
2 111	0.	0.	0.	0.	0.
2 112	0.	0.	0.	0.	0.
2 113	0.	0.	0.	0.	0.
2 114	0.	0.	0.	0.	0.
2 115	0.	0.	0.	0.	0.
2 116	0.	0.	0.	0.	0.
2 117	0.	0.	0.	0.	0.
2 118	0.	0.	0.	0.	0.
2 119	0.	0.	0.	0.	0.
2 120	0.	0.	0.	0.	0.
2 121	0.	0.	0.	0.	0.
2 122	0.	0.	0.	0.	0.
2 123	0.	0.	0.	0.	0.
2 124	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 33 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 2 1	0.	0.	0.	0.	0.
2 2 2	0.	0.	0.	0.	0.
2 2 3	0.	0.	0.	0.	0.
2 2 4	0.	0.	0.	0.	0.
2 2 5	0.	0.	0.	0.	0.
2 2 6	0.	0.	0.	0.	0.
2 2 7	0.	0.	0.	0.	0.
2 2 8	0.	0.	0.	0.	0.
2 2 9	0.	0.	0.	0.	0.
2 210	0.	0.	0.	0.	0.
2 211	0.	0.	0.	0.	0.
2 212	0.	0.	0.	0.	0.
2 213	0.	0.	0.	0.	0.
2 214	0.	0.	0.	0.	0.
2 215	0.	0.	0.	0.	0.
2 216	0.	0.	0.	0.	0.
2 217	0.	0.	0.	0.	0.
2 218	0.	0.	0.	0.	0.
2 219	0.	0.	0.	0.	0.
2 220	0.	0.	0.	0.	0.
2 221	0.	0.	0.	0.	0.
2 222	0.	0.	0.	0.	0.
2 223	0.	0.	0.	0.	0.
2 224	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 34 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 3 1	0.	0.	0.	0.	0.
2 3 2	0.	0.	0.	0.	0.
2 3 3	0.	0.	0.	0.	0.
2 3 4	0.	0.	0.	0.	0.
2 3 5	0.	0.	0.	0.	0.
2 3 6	0.	0.	0.	0.	0.
2 3 7	0.	0.	0.	0.	0.
2 3 8	0.	0.	0.	0.	0.
2 3 9	0.	0.	0.	0.	0.
2 310	0.	0.	0.	0.	0.
2 311	0.	0.	0.	0.	0.
2 312	0.	0.	0.	0.	0.
2 313	0.	0.	0.	0.	0.
2 314	0.	0.	0.	0.	0.
2 315	0.	0.	0.	0.	0.
2 316	0.	0.	0.	0.	0.
2 317	0.	0.	0.	0.	0.
2 318	0.	0.	0.	0.	0.
2 319	0.	0.	0.	0.	0.
2 320	0.	0.	0.	0.	0.
2 321	0.	0.	0.	0.	0.
2 322	0.	0.	0.	0.	0.
2 323	0.	0.	0.	0.	0.
2 324	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 35 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 4 1	0.	0.	0.	0.	0.
2 4 2	0.	0.	0.	0.	0.
2 4 3	0.	0.	0.	0.	0.
2 4 4	0.	0.	0.	0.	0.
2 4 5	0.	0.	0.	0.	0.
2 4 6	0.	0.	0.	0.	0.
2 4 7	0.	0.	0.	0.	0.
2 4 8	0.	0.	0.	0.	0.
2 4 9	0.	0.	0.	0.	0.
2 410	0.	0.	0.	0.	0.
2 411	0.	0.	0.	0.	0.
2 412	0.	0.	0.	0.	0.
2 413	0.	0.	0.	0.	0.
2 414	0.	0.	0.	0.	0.
2 415	0.	0.	0.	0.	0.
2 416	0.	0.	0.	0.	0.
2 417	0.	0.	0.	0.	0.
2 418	0.	0.	0.	0.	0.
2 419	0.	0.	0.	0.	0.
2 420	0.	0.	0.	0.	0.
2 421	0.	0.	0.	0.	0.
2 422	0.	0.	0.	0.	0.
2 423	0.	0.	0.	0.	0.
2 424	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 36 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 5 1	0.	0.	0.	0.	0.
2 5 2	0.	0.	0.	0.	0.
2 5 3	0.	0.	0.	0.	0.
2 5 4	0.	0.	0.	0.	0.
2 5 5	0.	0.	0.	0.	0.
2 5 6	0.	0.	0.	0.	0.
2 5 7	0.	0.	0.	0.	0.
2 5 8	0.	0.	0.	0.	0.
2 5 9	0.	0.	0.	0.	0.
2 510	0.	0.	0.	0.	0.
2 511	0.	0.	0.	0.	0.
2 512	0.	0.	0.	0.	0.
2 513	0.	0.	0.	0.	0.
2 514	0.	0.	0.	0.	0.
2 515	0.	0.	0.	0.	0.
2 516	0.	0.	0.	0.	0.
2 517	0.	0.	0.	0.	0.
2 518	0.	0.	0.	0.	0.
2 519	0.	0.	0.	0.	0.
2 520	0.	0.	0.	0.	0.
2 521	0.	0.	0.	0.	0.
2 522	0.	0.	0.	0.	0.
2 523	0.	0.	0.	0.	0.
2 524	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 37 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 6 1	0.	0.	0.	0.	0.
2 6 2	0.	0.	0.	0.	0.
2 6 3	0.	0.	0.	0.	0.
2 6 4	0.	0.	0.	0.	0.
2 6 5	0.	0.	0.	0.	0.
2 6 6	0.	0.	0.	0.	0.
2 6 7	0.	0.	0.	0.	0.
2 6 8	0.	0.	0.	0.	0.
2 6 9	0.	0.	0.	0.	0.
2 610	0.	0.	0.	0.	0.
2 611	0.	0.	0.	0.	0.
2 612	0.	0.	0.	0.	0.
2 613	0.	0.	0.	0.	0.
2 614	0.	0.	0.	0.	0.
2 615	0.	0.	0.	0.	0.
2 616	0.	0.	0.	0.	0.
2 617	0.	0.	0.	0.	0.
2 618	0.	0.	0.	0.	0.
2 619	0.	0.	0.	0.	0.
2 620	0.	0.	0.	0.	0.
2 621	0.	0.	0.	0.	0.
2 622	0.	0.	0.	0.	0.
2 623	0.	0.	0.	0.	0.
2 624	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 38 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 7 1	0.	0.	0.	0.	0.
2 7 2	0.	0.	0.	0.	0.
2 7 3	0.	0.	0.	0.	0.
2 7 4	0.	0.	0.	0.	0.
2 7 5	0.	0.	0.	0.	0.
2 7 6	0.	0.	0.	0.	0.
2 7 7	0.	0.	0.	0.	0.
2 7 8	0.	0.	0.	0.	0.
2 7 9	0.	0.	0.	0.	0.
2 710	0.	0.	0.	0.	0.
2 711	0.	0.	0.	0.	0.
2 712	0.	0.	0.	0.	0.
2 713	0.	0.	0.	0.	0.
2 714	0.	0.	0.	0.	0.
2 715	0.	0.	0.	0.	0.
2 716	0.	0.	0.	0.	0.
2 717	0.	0.	0.	0.	0.
2 718	0.	0.	0.	0.	0.
2 719	0.	0.	0.	0.	0.
2 720	0.	0.	0.	0.	0.
2 721	0.	0.	0.	0.	0.
2 722	0.	0.	0.	0.	0.
2 723	0.	0.	0.	0.	0.
2 724	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 39 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 8 1	0.	0.	0.	0.	0.
2 8 2	0.	0.	0.	0.	0.
2 8 3	0.	0.	0.	0.	0.
2 8 4	0.	0.	0.	0.	0.
2 8 5	0.	0.	0.	0.	0.
2 8 6	0.	0.	0.	0.	0.
2 8 7	0.	0.	0.	0.	0.
2 8 8	0.	0.	0.	0.	0.
2 8 9	0.	0.	0.	0.	0.
2 810	0.	0.	0.	0.	0.
2 811	0.	0.	0.	0.	0.
2 812	0.	0.	0.	0.	0.
2 813	0.	0.	0.	0.	0.
2 814	0.	0.	0.	0.	0.
2 815	0.	0.	0.	0.	0.
2 816	0.	0.	0.	0.	0.
2 817	0.	0.	0.	0.	0.
2 818	0.	0.	0.	0.	0.
2 819	0.	0.	0.	0.	0.
2 820	0.	0.	0.	0.	0.
2 821	0.	0.	0.	0.	0.
2 822	0.	0.	0.	0.	0.
2 823	0.	0.	0.	0.	0.
2 824	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 40 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
2 9 1	0.	0.	0.	0.	0.
2 9 2	0.	0.	0.	0.	0.
2 9 3	0.	0.	0.	0.	0.
2 9 4	0.	0.	0.	0.	0.
2 9 5	0.	0.	0.	0.	0.
2 9 6	0.	0.	0.	0.	0.
2 9 7	0.	0.	0.	0.	0.
2 9 8	0.	0.	0.	0.	0.
2 9 9	0.	0.	0.	0.	0.
2 910	0.	0.	0.	0.	0.
2 911	0.	0.	0.	0.	0.
2 912	0.	0.	0.	0.	0.
2 913	0.	0.	0.	0.	0.
2 914	0.	0.	0.	0.	0.
2 915	0.	0.	0.	0.	0.
2 916	0.	0.	0.	0.	0.
2 917	0.	0.	0.	0.	0.
2 918	0.	0.	0.	0.	0.
2 919	0.	0.	0.	0.	0.
2 920	0.	0.	0.	0.	0.
2 921	0.	0.	0.	0.	0.
2 922	0.	0.	0.	0.	0.
2 923	0.	0.	0.	0.	0.
2 924	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 41 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
210 1	0.	0.	0.	0.	0.
210 2	0.	0.	0.	0.	0.
210 3	0.	0.	0.	0.	0.
210 4	0.	0.	0.	0.	0.
210 5	0.	0.	0.	0.	0.
210 6	0.	0.	0.	0.	0.
210 7	0.	0.	0.	0.	0.
210 8	0.	0.	0.	0.	0.
210 9	0.	0.	0.	0.	0.
21010	0.	0.	0.	0.	0.
21011	0.	0.	0.	0.	0.
21012	0.	0.	0.	0.	0.
21013	0.	0.	0.	0.	0.
21014	0.	0.	0.	0.	0.
21015	0.	0.	0.	0.	0.
21016	0.	0.	0.	0.	0.
21017	0.	0.	0.	0.	0.
21018	0.	0.	0.	0.	0.
21019	0.	0.	0.	0.	0.
21020	0.	0.	0.	0.	0.
21021	0.	0.	0.	0.	0.
21022	0.	0.	0.	0.	0.
21023	0.	0.	0.	0.	0.
21024	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 42 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
211 1	0.	0.	0.	0.	0.
211 2	0.	0.	0.	0.	0.
211 3	0.	0.	0.	0.	0.
211 4	0.	0.	0.	0.	0.
211 5	0.	0.	0.	0.	0.
211 6	0.	0.	0.	0.	0.
211 7	0.	0.	0.	0.	0.
211 8	0.	0.	0.	0.	0.
211 9	0.	0.	0.	0.	0.
21110	0.	0.	0.	0.	0.
21111	0.	0.	0.	0.	0.
21112	0.	0.	0.	0.	0.
21113	0.	0.	0.	0.	0.
21114	0.	0.	0.	0.	0.
21115	0.	0.	0.	0.	0.
21116	0.	0.	0.	0.	0.
21117	0.	0.	0.	0.	0.
21118	0.	0.	0.	0.	0.
21119	0.	0.	0.	0.	0.
21120	0.	0.	0.	0.	0.
21121	0.	0.	0.	0.	0.
21122	0.	0.	0.	0.	0.
21123	0.	0.	0.	0.	0.
21124	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 43 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
212 1	0.	0.	0.	0.	0.
212 2	0.	0.	0.	0.	0.
212 3	0.	0.	0.	0.	0.
212 4	0.	0.	0.	0.	0.
212 5	0.	0.	0.	0.	0.
212 6	0.	0.	0.	0.	0.
212 7	0.	0.	0.	0.	0.
212 8	0.	0.	0.	0.	0.
212 9	0.	0.	0.	0.	0.
21210	0.	0.	0.	0.	0.
21211	0.	0.	0.	0.	0.
21212	0.	0.	0.	0.	0.
21213	0.	0.	0.	0.	0.
21214	0.	0.	0.	0.	0.
21215	0.	0.	0.	0.	0.
21216	0.	0.	0.	0.	0.
21217	0.	0.	0.	0.	0.
21218	0.	0.	0.	0.	0.
21219	0.	0.	0.	0.	0.
21220	0.	0.	0.	0.	0.
21221	0.	0.	0.	0.	0.
21222	0.	0.	0.	0.	0.
21223	0.	0.	0.	0.	0.
21224	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 44 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
213 1	0.	0.	0.	0.	0.
213 2	0.	0.	0.	0.	0.
213 3	0.	0.	0.	0.	0.
213 4	0.	0.	0.	0.	0.
213 5	0.	0.	0.	0.	0.
213 6	0.	0.	0.	0.	0.
213 7	0.	0.	0.	0.	0.
213 8	0.	0.	0.	0.	0.
213 9	0.	0.	0.	0.	0.
21310	0.	0.	0.	0.	0.
21311	0.	0.	0.	0.	0.
21312	0.	0.	0.	0.	0.
21313	0.	0.	0.	0.	0.
21314	0.	0.	0.	0.	0.
21315	0.	0.	0.	0.	0.
21316	0.	0.	0.	0.	0.
21317	0.	0.	0.	0.	0.
21318	0.	0.	0.	0.	0.
21319	0.	0.	0.	0.	0.
21320	0.	0.	0.	0.	0.
21321	0.	0.	0.	0.	0.
21322	0.	0.	0.	0.	0.
21323	0.	0.	0.	0.	0.
21324	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 45 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
214 1	0.	0.	0.	0.	0.
214 2	0.	0.	0.	0.	0.
214 3	0.	0.	0.	0.	0.
214 4	0.	0.	0.	0.	0.
214 5	0.	0.	0.	0.	0.
214 6	0.	0.	0.	0.	0.
214 7	0.	0.	0.	0.	0.
214 8	0.	0.	0.	0.	0.
214 9	0.	0.	0.	0.	0.
21410	0.	0.	0.	0.	0.
21411	0.	0.	0.	0.	0.
21412	0.	0.	0.	0.	0.
21413	0.	0.	0.	0.	0.
21414	0.	0.	0.	0.	0.
21415	0.	0.	0.	0.	0.
21416	0.	0.	0.	0.	0.
21417	0.	0.	0.	0.	0.
21418	0.	0.	0.	0.	0.
21419	0.	0.	0.	0.	0.
21420	0.	0.	0.	0.	0.
21421	0.	0.	0.	0.	0.
21422	0.	0.	0.	0.	0.
21423	0.	0.	0.	0.	0.
21424	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 46 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
215 1	0.	0.	0.	0.	0.
215 2	0.	0.	0.	0.	0.
215 3	0.	0.	0.	0.	0.
215 4	0.	0.	0.	0.	0.
215 5	0.	0.	0.	0.	0.
215 6	0.	0.	0.	0.	0.
215 7	0.	0.	0.	0.	0.
215 8	0.	0.	0.	0.	0.
215 9	0.	0.	0.	0.	0.
21510	0.	0.	0.	0.	0.
21511	0.	0.	0.	0.	0.
21512	0.	0.	0.	0.	0.
21513	0.	0.	0.	0.	0.
21514	0.	0.	0.	0.	0.
21515	0.	0.	0.	0.	0.
21516	0.	0.	0.	0.	0.
21517	0.	0.	0.	0.	0.
21518	0.	0.	0.	0.	0.
21519	0.	0.	0.	0.	0.
21520	0.	0.	0.	0.	0.
21521	0.	0.	0.	0.	0.
21522	0.	0.	0.	0.	0.
21523	0.	0.	0.	0.	0.
21524	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 47 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
216 1	0.	0.	0.	0.	0.
216 2	0.	0.	0.	0.	0.
216 3	0.	0.	0.	0.	0.
216 4	0.	0.	0.	0.	0.
216 5	0.	0.	0.	0.	0.
216 6	0.	0.	0.	0.	0.
216 7	0.	0.	0.	0.	0.
216 8	0.	0.	0.	0.	0.
216 9	0.	0.	0.	0.	0.
21610	0.	0.	0.	0.	0.
21611	0.	0.	0.	0.	0.
21612	0.	0.	0.	0.	0.
21613	0.	0.	0.	0.	0.
21614	0.	0.	0.	0.	0.
21615	0.	0.	0.	0.	0.
21616	0.	0.	0.	0.	0.
21617	0.	0.	0.	0.	0.
21618	0.	0.	0.	0.	0.
21619	0.	0.	0.	0.	0.
21620	0.	0.	0.	0.	0.
21621	0.	0.	0.	0.	0.
21622	0.	0.	0.	0.	0.
21623	0.	0.	0.	0.	0.
21624	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 48 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
217 1	0.	0.	0.	0.	0.
217 2	0.	0.	0.	0.	0.
217 3	0.	0.	0.	0.	0.
217 4	0.	0.	0.	0.	0.
217 5	0.	0.	0.	0.	0.
217 6	0.	0.	0.	0.	0.
217 7	0.	0.	0.	0.	0.
217 8	0.	0.	0.	0.	0.
217 9	0.	0.	0.	0.	0.
21710	0.	0.	0.	0.	0.
21711	0.	0.	0.	0.	0.
21712	0.	0.	0.	0.	0.
21713	0.	0.	0.	0.	0.
21714	0.	0.	0.	0.	0.
21715	0.	0.	0.	0.	0.
21716	0.	0.	0.	0.	0.
21717	0.	0.	0.	0.	0.
21718	0.	0.	0.	0.	0.
21719	0.	0.	0.	0.	0.
21720	0.	0.	0.	0.	0.
21721	0.	0.	0.	0.	0.
21722	0.	0.	0.	0.	0.
21723	0.	0.	0.	0.	0.
21724	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 49 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
218 1	0.	0.	0.	0.	0.
218 2	0.	0.	0.	0.	0.
218 3	0.	0.	0.	0.	0.
218 4	0.	0.	0.	0.	0.
218 5	0.	0.	0.	0.	0.
218 6	0.	0.	0.	0.	0.
218 7	0.	0.	0.	0.	0.
218 8	0.	0.	0.	0.	0.
218 9	0.	0.	0.	0.	0.
21810	0.	0.	0.	0.	0.
21811	0.	0.	0.	0.	0.
21812	0.	0.	0.	0.	0.
21813	0.	0.	0.	0.	0.
21814	0.	0.	0.	0.	0.
21815	0.	0.	0.	0.	0.
21816	0.	0.	0.	0.	0.
21817	0.	0.	0.	0.	0.
21818	0.	0.	0.	0.	0.
21819	0.	0.	0.	0.	0.
21820	0.	0.	0.	0.	0.
21821	0.	0.	0.	0.	0.
21822	0.	0.	0.	0.	0.
21823	0.	0.	0.	0.	0.
21824	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 50 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
219 1	0.	0.	0.	0.	0.
219 2	0.	0.	0.	0.	0.
219 3	0.	0.	0.	0.	0.
219 4	0.	0.	0.	0.	0.
219 5	0.	0.	0.	0.	0.
219 6	0.	0.	0.	0.	0.
219 7	0.	0.	0.	0.	0.
219 8	0.	0.	0.	0.	0.
219 9	0.	0.	0.	0.	0.
21910	0.	0.	0.	0.	0.
21911	0.	0.	0.	0.	0.
21912	0.	0.	0.	0.	0.
21913	0.	0.	0.	0.	0.
21914	0.	0.	0.	0.	0.
21915	0.	0.	0.	0.	0.
21916	0.	0.	0.	0.	0.
21917	0.	0.	0.	0.	0.
21918	0.	0.	0.	0.	0.
21919	0.	0.	0.	0.	0.
21920	0.	0.	0.	0.	0.
21921	0.	0.	0.	0.	0.
21922	0.	0.	0.	0.	0.
21923	0.	0.	0.	0.	0.
21924	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 51 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
220 1	0.	0.	0.	0.	0.
220 2	0.	0.	0.	0.	0.
220 3	0.	0.	0.	0.	0.
220 4	0.	0.	0.	0.	0.
220 5	0.	0.	0.	0.	0.
220 6	0.	0.	0.	0.	0.
220 7	0.	0.	0.	0.	0.
220 8	0.	0.	0.	0.	0.
220 9	0.	0.	0.	0.	0.
22010	0.	0.	0.	0.	0.
22011	0.	0.	0.	0.	0.
22012	0.	0.	0.	0.	0.
22013	0.	0.	0.	0.	0.
22014	0.	0.	0.	0.	0.
22015	0.	0.	0.	0.	0.
22016	0.	0.	0.	0.	0.
22017	0.	0.	0.	0.	0.
22018	0.	0.	0.	0.	0.
22019	0.	0.	0.	0.	0.
22020	0.	0.	0.	0.	0.
22021	0.	0.	0.	0.	0.
22022	0.	0.	0.	0.	0.
22023	0.	0.	0.	0.	0.
22024	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 52 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
221 1	0.	0.	0.	0.	0.
221 2	0.	0.	0.	0.	0.
221 3	0.	0.	0.	0.	0.
221 4	0.	0.	0.	0.	0.
221 5	0.	0.	0.	0.	0.
221 6	0.	0.	0.	0.	0.
221 7	0.	0.	0.	0.	0.
221 8	0.	0.	0.	0.	0.
221 9	0.	0.	0.	0.	0.
22110	0.	0.	0.	0.	0.
22111	0.	0.	0.	0.	0.
22112	0.	0.	0.	0.	0.
22113	0.	0.	0.	0.	0.
22114	0.	0.	0.	0.	0.
22115	0.	0.	0.	0.	0.
22116	0.	0.	0.	0.	0.
22117	0.	0.	0.	0.	0.
22118	0.	0.	0.	0.	0.
22119	0.	0.	0.	0.	0.
22120	0.	0.	0.	0.	0.
22121	0.	0.	0.	0.	0.
22122	0.	0.	0.	0.	0.
22123	0.	0.	0.	0.	0.
22124	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 53 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
222 1	0.	0.	0.	0.	0.
222 2	0.	0.	0.	0.	0.
222 3	0.	0.	0.	0.	0.
222 4	0.	0.	0.	0.	0.
222 5	0.	0.	0.	0.	0.
222 6	0.	0.	0.	0.	0.
222 7	0.	0.	0.	0.	0.
222 8	0.	0.	0.	0.	0.
222 9	0.	0.	0.	0.	0.
22210	0.	0.	0.	0.	0.
22211	0.	0.	0.	0.	0.
22212	0.	0.	0.	0.	0.
22213	0.	0.	0.	0.	0.
22214	0.	0.	0.	0.	0.
22215	0.	0.	0.	0.	0.
22216	0.	0.	0.	0.	0.
22217	0.	0.	0.	0.	0.
22218	0.	0.	0.	0.	0.
22219	0.	0.	0.	0.	0.
22220	0.	0.	0.	0.	0.
22221	0.	0.	0.	0.	0.
22222	0.	0.	0.	0.	0.
22223	0.	0.	0.	0.	0.
22224	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 54 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
223 1	0.	0.	0.	0.	0.
223 2	0.	0.	0.	0.	0.
223 3	0.	0.	0.	0.	0.
223 4	0.	0.	0.	0.	0.
223 5	0.	0.	0.	0.	0.
223 6	0.	0.	0.	0.	0.
223 7	0.	0.	0.	0.	0.
223 8	0.	0.	0.	0.	0.
223 9	0.	0.	0.	0.	0.
22310	0.	0.	0.	0.	0.
22311	0.	0.	0.	0.	0.
22312	0.	0.	0.	0.	0.
22313	0.	0.	0.	0.	0.
22314	0.	0.	0.	0.	0.
22315	0.	0.	0.	0.	0.
22316	0.	0.	0.	0.	0.
22317	0.	0.	0.	0.	0.
22318	0.	0.	0.	0.	0.
22319	0.	0.	0.	0.	0.
22320	0.	0.	0.	0.	0.
22321	0.	0.	0.	0.	0.
22322	0.	0.	0.	0.	0.
22323	0.	0.	0.	0.	0.
22324	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 55 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
224 1	0.	0.	0.	0.	0.
224 2	0.	0.	0.	0.	0.
224 3	0.	0.	0.	0.	0.
224 4	0.	0.	0.	0.	0.
224 5	0.	0.	0.	0.	0.
224 6	0.	0.	0.	0.	0.
224 7	0.	0.	0.	0.	0.
224 8	0.	0.	0.	0.	0.
224 9	0.	0.	0.	0.	0.
22410	0.	0.	0.	0.	0.
22411	0.	0.	0.	0.	0.
22412	0.	0.	0.	0.	0.
22413	0.	0.	0.	0.	0.
22414	0.	0.	0.	0.	0.
22415	0.	0.	0.	0.	0.
22416	0.	0.	0.	0.	0.
22417	0.	0.	0.	0.	0.
22418	0.	0.	0.	0.	0.
22419	0.	0.	0.	0.	0.
22420	0.	0.	0.	0.	0.
22421	0.	0.	0.	0.	0.
22422	0.	0.	0.	0.	0.
22423	0.	0.	0.	0.	0.
22424	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 56 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
225 1	0.	0.	0.	0.	0.
225 2	0.	0.	0.	0.	0.
225 3	0.	0.	0.	0.	0.
225 4	0.	0.	0.	0.	0.
225 5	0.	0.	0.	0.	0.
225 6	0.	0.	0.	0.	0.
225 7	0.	0.	0.	0.	0.
225 8	0.	0.	0.	0.	0.
225 9	0.	0.	0.	0.	0.
22510	0.	0.	0.	0.	0.
22511	0.	0.	0.	0.	0.
22512	0.	0.	0.	0.	0.
22513	0.	0.	0.	0.	0.
22514	0.	0.	0.	0.	0.
22515	0.	0.	0.	0.	0.
22516	0.	0.	0.	0.	0.
22517	0.	0.	0.	0.	0.
22518	0.	0.	0.	0.	0.
22519	0.	0.	0.	0.	0.
22520	0.	0.	0.	0.	0.
22521	0.	0.	0.	0.	0.
22522	0.	0.	0.	0.	0.
22523	0.	0.	0.	0.	0.
22524	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 57 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
226 1	0.	0.	0.	0.	0.
226 2	0.	0.	0.	0.	0.
226 3	0.	0.	0.	0.	0.
226 4	0.	0.	0.	0.	0.
226 5	0.	0.	0.	0.	0.
226 6	0.	0.	0.	0.	0.
226 7	0.	0.	0.	0.	0.
226 8	0.	0.	0.	0.	0.
226 9	0.	0.	0.	0.	0.
22610	0.	0.	0.	0.	0.
22611	0.	0.	0.	0.	0.
22612	0.	0.	0.	0.	0.
22613	0.	0.	0.	0.	0.
22614	0.	0.	0.	0.	0.
22615	0.	0.	0.	0.	0.
22616	0.	0.	0.	0.	0.
22617	0.	0.	0.	0.	0.
22618	0.	0.	0.	0.	0.
22619	0.	0.	0.	0.	0.
22620	0.	0.	0.	0.	0.
22621	0.	0.	0.	0.	0.
22622	0.	0.	0.	0.	0.
22623	0.	0.	0.	0.	0.
22624	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 58 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
227 1	0.	0.	0.	0.	0.
227 2	0.	0.	0.	0.	0.
227 3	0.	0.	0.	0.	0.
227 4	0.	0.	0.	0.	0.
227 5	0.	0.	0.	0.	0.
227 6	0.	0.	0.	0.	0.
227 7	0.	0.	0.	0.	0.
227 8	0.	0.	0.	0.	0.
227 9	0.	0.	0.	0.	0.
22710	0.	0.	0.	0.	0.
22711	0.	0.	0.	0.	0.
22712	0.	0.	0.	0.	0.
22713	0.	0.	0.	0.	0.
22714	0.	0.	0.	0.	0.
22715	0.	0.	0.	0.	0.
22716	0.	0.	0.	0.	0.
22717	0.	0.	0.	0.	0.
22718	0.	0.	0.	0.	0.
22719	0.	0.	0.	0.	0.
22720	0.	0.	0.	0.	0.
22721	0.	0.	0.	0.	0.
22722	0.	0.	0.	0.	0.
22723	0.	0.	0.	0.	0.
22724	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 59 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
228 1	0.	0.	0.	0.	0.
228 2	0.	0.	0.	0.	0.
228 3	0.	0.	0.	0.	0.
228 4	0.	0.	0.	0.	0.
228 5	0.	0.	0.	0.	0.
228 6	0.	0.	0.	0.	0.
228 7	0.	0.	0.	0.	0.
228 8	0.	0.	0.	0.	0.
228 9	0.	0.	0.	0.	0.
22810	0.	0.	0.	0.	0.
22811	0.	0.	0.	0.	0.
22812	0.	0.	0.	0.	0.
22813	0.	0.	0.	0.	0.
22814	0.	0.	0.	0.	0.
22815	0.	0.	0.	0.	0.
22816	0.	0.	0.	0.	0.
22817	0.	0.	0.	0.	0.
22818	0.	0.	0.	0.	0.
22819	0.	0.	0.	0.	0.
22820	0.	0.	0.	0.	0.
22821	0.	0.	0.	0.	0.
22822	0.	0.	0.	0.	0.
22823	0.	0.	0.	0.	0.
22824	0.	0.	0.	0.	0.
DAILY SUMMARY (FEB 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (FEB)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 60 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 1 1	0.	0.	0.	0.	0.
3 1 2	0.	0.	0.	0.	0.
3 1 3	0.	0.	0.	0.	0.
3 1 4	0.	0.	0.	0.	0.
3 1 5	0.	0.	0.	0.	0.
3 1 6	0.	0.	0.	0.	0.
3 1 7	0.	0.	0.	0.	0.
3 1 8	0.	0.	0.	0.	0.
3 1 9	0.	0.	0.	0.	0.
3 110	0.	0.	0.	0.	0.
3 111	0.	0.	0.	0.	0.
3 112	0.	0.	0.	0.	0.
3 113	0.	0.	0.	0.	0.
3 114	0.	0.	0.	0.	0.
3 115	0.	0.	0.	0.	0.
3 116	0.	0.	0.	0.	0.
3 117	0.	0.	0.	0.	0.
3 118	0.	0.	0.	0.	0.
3 119	0.	0.	0.	0.	0.
3 120	0.	0.	0.	0.	0.
3 121	0.	0.	0.	0.	0.
3 122	0.	0.	0.	0.	0.
3 123	0.	0.	0.	0.	0.
3 124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 61 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 2 1	0.	0.	0.	0.	0.
3 2 2	0.	0.	0.	0.	0.
3 2 3	0.	0.	0.	0.	0.
3 2 4	0.	0.	0.	0.	0.
3 2 5	0.	0.	0.	0.	0.
3 2 6	0.	0.	0.	0.	0.
3 2 7	0.	0.	0.	0.	0.
3 2 8	0.	0.	0.	0.	0.
3 2 9	0.	0.	0.	0.	0.
3 210	0.	0.	0.	0.	0.
3 211	0.	0.	0.	0.	0.
3 212	0.	0.	0.	0.	0.
3 213	0.	0.	0.	0.	0.
3 214	0.	0.	0.	0.	0.
3 215	0.	0.	0.	0.	0.
3 216	0.	0.	0.	0.	0.
3 217	0.	0.	0.	0.	0.
3 218	0.	0.	0.	0.	0.
3 219	0.	0.	0.	0.	0.
3 220	0.	0.	0.	0.	0.
3 221	0.	0.	0.	0.	0.
3 222	0.	0.	0.	0.	0.
3 223	0.	0.	0.	0.	0.
3 224	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 62 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 3 1	0.	0.	0.	0.	0.
3 3 2	0.	0.	0.	0.	0.
3 3 3	0.	0.	0.	0.	0.
3 3 4	0.	0.	0.	0.	0.
3 3 5	0.	0.	0.	0.	0.
3 3 6	0.	0.	0.	0.	0.
3 3 7	0.	0.	0.	0.	0.
3 3 8	0.	0.	0.	0.	0.
3 3 9	0.	0.	0.	0.	0.
3 310	0.	0.	0.	0.	0.
3 311	0.	0.	0.	0.	0.
3 312	0.	0.	0.	0.	0.
3 313	0.	0.	0.	0.	0.
3 314	0.	0.	0.	0.	0.
3 315	0.	0.	0.	0.	0.
3 316	0.	0.	0.	0.	0.
3 317	0.	0.	0.	0.	0.
3 318	0.	0.	0.	0.	0.
3 319	0.	0.	0.	0.	0.
3 320	0.	0.	0.	0.	0.
3 321	0.	0.	0.	0.	0.
3 322	0.	0.	0.	0.	0.
3 323	0.	0.	0.	0.	0.
3 324	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 63 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 4 1	0.	0.	0.	0.	0.
3 4 2	0.	0.	0.	0.	0.
3 4 3	0.	0.	0.	0.	0.
3 4 4	0.	0.	0.	0.	0.
3 4 5	0.	0.	0.	0.	0.
3 4 6	0.	0.	0.	0.	0.
3 4 7	0.	0.	0.	0.	0.
3 4 8	0.	0.	0.	0.	0.
3 4 9	0.	0.	0.	0.	0.
3 410	0.	0.	0.	0.	0.
3 411	0.	0.	0.	0.	0.
3 412	0.	0.	0.	0.	0.
3 413	0.	0.	0.	0.	0.
3 414	0.	0.	0.	0.	0.
3 415	0.	0.	0.	0.	0.
3 416	0.	0.	0.	0.	0.
3 417	0.	0.	0.	0.	0.
3 418	0.	0.	0.	0.	0.
3 419	0.	0.	0.	0.	0.
3 420	0.	0.	0.	0.	0.
3 421	0.	0.	0.	0.	0.
3 422	0.	0.	0.	0.	0.
3 423	0.	0.	0.	0.	0.
3 424	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 64 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 5 1	0.	0.	0.	0.	0.
3 5 2	0.	0.	0.	0.	0.
3 5 3	0.	0.	0.	0.	0.
3 5 4	0.	0.	0.	0.	0.
3 5 5	0.	0.	0.	0.	0.
3 5 6	0.	0.	0.	0.	0.
3 5 7	0.	0.	0.	0.	0.
3 5 8	0.	0.	0.	0.	0.
3 5 9	0.	0.	0.	0.	0.
3 510	0.	0.	0.	0.	0.
3 511	0.	0.	0.	0.	0.
3 512	0.	0.	0.	0.	0.
3 513	0.	0.	0.	0.	0.
3 514	0.	0.	0.	0.	0.
3 515	0.	0.	0.	0.	0.
3 516	0.	0.	0.	0.	0.
3 517	0.	0.	0.	0.	0.
3 518	0.	0.	0.	0.	0.
3 519	0.	0.	0.	0.	0.
3 520	0.	0.	0.	0.	0.
3 521	0.	0.	0.	0.	0.
3 522	0.	0.	0.	0.	0.
3 523	0.	0.	0.	0.	0.
3 524	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 65 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 6 1	0.	0.	0.	0.	0.
3 6 2	0.	0.	0.	0.	0.
3 6 3	0.	0.	0.	0.	0.
3 6 4	0.	0.	0.	0.	0.
3 6 5	0.	0.	0.	0.	0.
3 6 6	0.	0.	0.	0.	0.
3 6 7	0.	0.	0.	0.	0.
3 6 8	0.	0.	0.	0.	0.
3 6 9	0.	0.	0.	0.	0.
3 610	0.	0.	0.	0.	0.
3 611	0.	0.	0.	0.	0.
3 612	0.	0.	0.	0.	0.
3 613	0.	0.	0.	0.	0.
3 614	0.	0.	0.	0.	0.
3 615	0.	0.	0.	0.	0.
3 616	0.	0.	0.	0.	0.
3 617	0.	0.	0.	0.	0.
3 618	0.	0.	0.	0.	0.
3 619	0.	0.	0.	0.	0.
3 620	0.	0.	0.	0.	0.
3 621	0.	0.	0.	0.	0.
3 622	0.	0.	0.	0.	0.
3 623	0.	0.	0.	0.	0.
3 624	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 66 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 7 1	0.	0.	0.	0.	0.
3 7 2	0.	0.	0.	0.	0.
3 7 3	0.	0.	0.	0.	0.
3 7 4	0.	0.	0.	0.	0.
3 7 5	0.	0.	0.	0.	0.
3 7 6	0.	0.	0.	0.	0.
3 7 7	0.	0.	0.	0.	0.
3 7 8	0.	0.	0.	0.	0.
3 7 9	0.	0.	0.	0.	0.
3 710	0.	0.	0.	0.	0.
3 711	0.	0.	0.	0.	0.
3 712	0.	0.	0.	0.	0.
3 713	0.	0.	0.	0.	0.
3 714	0.	0.	0.	0.	0.
3 715	0.	0.	0.	0.	0.
3 716	0.	0.	0.	0.	0.
3 717	0.	0.	0.	0.	0.
3 718	0.	0.	0.	0.	0.
3 719	0.	0.	0.	0.	0.
3 720	0.	0.	0.	0.	0.
3 721	0.	0.	0.	0.	0.
3 722	0.	0.	0.	0.	0.
3 723	0.	0.	0.	0.	0.
3 724	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 67 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 8 1	0.	0.	0.	0.	0.
3 8 2	0.	0.	0.	0.	0.
3 8 3	0.	0.	0.	0.	0.
3 8 4	0.	0.	0.	0.	0.
3 8 5	0.	0.	0.	0.	0.
3 8 6	0.	0.	0.	0.	0.
3 8 7	0.	0.	0.	0.	0.
3 8 8	0.	0.	0.	0.	0.
3 8 9	0.	0.	0.	0.	0.
3 810	0.	0.	0.	0.	0.
3 811	0.	0.	0.	0.	0.
3 812	0.	0.	0.	0.	0.
3 813	0.	0.	0.	0.	0.
3 814	0.	0.	0.	0.	0.
3 815	0.	0.	0.	0.	0.
3 816	0.	0.	0.	0.	0.
3 817	0.	0.	0.	0.	0.
3 818	0.	0.	0.	0.	0.
3 819	0.	0.	0.	0.	0.
3 820	0.	0.	0.	0.	0.
3 821	0.	0.	0.	0.	0.
3 822	0.	0.	0.	0.	0.
3 823	0.	0.	0.	0.	0.
3 824	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 68 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
3 9 1	0.	0.	0.	0.	0.
3 9 2	0.	0.	0.	0.	0.
3 9 3	0.	0.	0.	0.	0.
3 9 4	0.	0.	0.	0.	0.
3 9 5	0.	0.	0.	0.	0.
3 9 6	0.	0.	0.	0.	0.
3 9 7	0.	0.	0.	0.	0.
3 9 8	0.	0.	0.	0.	0.
3 9 9	0.	0.	0.	0.	0.
3 910	0.	0.	0.	0.	0.
3 911	0.	0.	0.	0.	0.
3 912	0.	0.	0.	0.	0.
3 913	0.	0.	0.	0.	0.
3 914	0.	0.	0.	0.	0.
3 915	0.	0.	0.	0.	0.
3 916	0.	0.	0.	0.	0.
3 917	0.	0.	0.	0.	0.
3 918	0.	0.	0.	0.	0.
3 919	0.	0.	0.	0.	0.
3 920	0.	0.	0.	0.	0.
3 921	0.	0.	0.	0.	0.
3 922	0.	0.	0.	0.	0.
3 923	0.	0.	0.	0.	0.
3 924	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 69 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
310 1	0.	0.	0.	0.	0.
310 2	0.	0.	0.	0.	0.
310 3	0.	0.	0.	0.	0.
310 4	0.	0.	0.	0.	0.
310 5	0.	0.	0.	0.	0.
310 6	0.	0.	0.	0.	0.
310 7	0.	0.	0.	0.	0.
310 8	0.	0.	0.	0.	0.
310 9	0.	0.	0.	0.	0.
31010	0.	0.	0.	0.	0.
31011	0.	0.	0.	0.	0.
31012	0.	0.	0.	0.	0.
31013	0.	0.	0.	0.	0.
31014	0.	0.	0.	0.	0.
31015	0.	0.	0.	0.	0.
31016	0.	0.	0.	0.	0.
31017	0.	0.	0.	0.	0.
31018	0.	0.	0.	0.	0.
31019	0.	0.	0.	0.	0.
31020	0.	0.	0.	0.	0.
31021	0.	0.	0.	0.	0.
31022	0.	0.	0.	0.	0.
31023	0.	0.	0.	0.	0.
31024	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 70 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
311 1	0.	0.	0.	0.	0.
311 2	0.	0.	0.	0.	0.
311 3	0.	0.	0.	0.	0.
311 4	0.	0.	0.	0.	0.
311 5	0.	0.	0.	0.	0.
311 6	0.	0.	0.	0.	0.
311 7	0.	0.	0.	0.	0.
311 8	0.	0.	0.	0.	0.
311 9	0.	0.	0.	0.	0.
31110	0.	0.	0.	0.	0.
31111	0.	0.	0.	0.	0.
31112	0.	0.	0.	0.	0.
31113	0.	0.	0.	0.	0.
31114	0.	0.	0.	0.	0.
31115	0.	0.	0.	0.	0.
31116	0.	0.	0.	0.	0.
31117	0.	0.	0.	0.	0.
31118	0.	0.	0.	0.	0.
31119	0.	0.	0.	0.	0.
31120	0.	0.	0.	0.	0.
31121	0.	0.	0.	0.	0.
31122	0.	0.	0.	0.	0.
31123	0.	0.	0.	0.	0.
31124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 71 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
312 1	0.	0.	0.	0.	0.
312 2	0.	0.	0.	0.	0.
312 3	0.	0.	0.	0.	0.
312 4	0.	0.	0.	0.	0.
312 5	0.	0.	0.	0.	0.
312 6	0.	0.	0.	0.	0.
312 7	0.	0.	0.	0.	0.
312 8	0.	0.	0.	0.	0.
312 9	0.	0.	0.	0.	0.
31210	0.	0.	0.	0.	0.
31211	0.	0.	0.	0.	0.
31212	0.	0.	0.	0.	0.
31213	0.	0.	0.	0.	0.
31214	0.	0.	0.	0.	0.
31215	0.	0.	0.	0.	0.
31216	0.	0.	0.	0.	0.
31217	0.	0.	0.	0.	0.
31218	0.	0.	0.	0.	0.
31219	0.	0.	0.	0.	0.
31220	0.	0.	0.	0.	0.
31221	0.	0.	0.	0.	0.
31222	0.	0.	0.	0.	0.
31223	0.	0.	0.	0.	0.
31224	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 72 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
313 1	0.	0.	0.	0.	0.
313 2	0.	0.	0.	0.	0.
313 3	0.	0.	0.	0.	0.
313 4	0.	0.	0.	0.	0.
313 5	0.	0.	0.	0.	0.
313 6	0.	0.	0.	0.	0.
313 7	0.	0.	0.	0.	0.
313 8	0.	0.	0.	0.	0.
313 9	0.	0.	0.	0.	0.
31310	0.	0.	0.	0.	0.
31311	0.	0.	0.	0.	0.
31312	0.	0.	0.	0.	0.
31313	0.	0.	0.	0.	0.
31314	0.	0.	0.	0.	0.
31315	0.	0.	0.	0.	0.
31316	0.	0.	0.	0.	0.
31317	0.	0.	0.	0.	0.
31318	0.	0.	0.	0.	0.
31319	0.	0.	0.	0.	0.
31320	0.	0.	0.	0.	0.
31321	0.	0.	0.	0.	0.
31322	0.	0.	0.	0.	0.
31323	0.	0.	0.	0.	0.
31324	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 73 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
314 1	0.	0.	0.	0.	0.
314 2	0.	0.	0.	0.	0.
314 3	0.	0.	0.	0.	0.
314 4	0.	0.	0.	0.	0.
314 5	0.	0.	0.	0.	0.
314 6	0.	0.	0.	0.	0.
314 7	0.	0.	0.	0.	0.
314 8	0.	0.	0.	0.	0.
314 9	0.	0.	0.	0.	0.
31410	0.	0.	0.	0.	0.
31411	0.	0.	0.	0.	0.
31412	0.	0.	0.	0.	0.
31413	0.	0.	0.	0.	0.
31414	0.	0.	0.	0.	0.
31415	0.	0.	0.	0.	0.
31416	0.	0.	0.	0.	0.
31417	0.	0.	0.	0.	0.
31418	0.	0.	0.	0.	0.
31419	0.	0.	0.	0.	0.
31420	0.	0.	0.	0.	0.
31421	0.	0.	0.	0.	0.
31422	0.	0.	0.	0.	0.
31423	0.	0.	0.	0.	0.
31424	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 74 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
315 1	0.	0.	0.	0.	0.
315 2	0.	0.	0.	0.	0.
315 3	0.	0.	0.	0.	0.
315 4	0.	0.	0.	0.	0.
315 5	0.	0.	0.	0.	0.
315 6	0.	0.	0.	0.	0.
315 7	0.	0.	0.	0.	0.
315 8	0.	0.	0.	0.	0.
315 9	0.	0.	0.	0.	0.
31510	0.	0.	0.	0.	0.
31511	0.	0.	0.	0.	0.
31512	0.	0.	0.	0.	0.
31513	0.	0.	0.	0.	0.
31514	0.	0.	0.	0.	0.
31515	0.	0.	0.	0.	0.
31516	0.	0.	0.	0.	0.
31517	0.	0.	0.	0.	0.
31518	0.	0.	0.	0.	0.
31519	0.	0.	0.	0.	0.
31520	0.	0.	0.	0.	0.
31521	0.	0.	0.	0.	0.
31522	0.	0.	0.	0.	0.
31523	0.	0.	0.	0.	0.
31524	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 75 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
316 1	0.	0.	0.	0.	0.
316 2	0.	0.	0.	0.	0.
316 3	0.	0.	0.	0.	0.
316 4	0.	0.	0.	0.	0.
316 5	0.	0.	0.	0.	0.
316 6	0.	0.	0.	0.	0.
316 7	0.	0.	0.	0.	0.
316 8	0.	0.	0.	0.	0.
316 9	0.	0.	0.	0.	0.
31610	0.	0.	0.	0.	0.
31611	0.	0.	0.	0.	0.
31612	0.	0.	0.	0.	0.
31613	0.	0.	0.	0.	0.
31614	0.	0.	0.	0.	0.
31615	0.	0.	0.	0.	0.
31616	0.	0.	0.	0.	0.
31617	0.	0.	0.	0.	0.
31618	0.	0.	0.	0.	0.
31619	0.	0.	0.	0.	0.
31620	0.	0.	0.	0.	0.
31621	0.	0.	0.	0.	0.
31622	0.	0.	0.	0.	0.
31623	0.	0.	0.	0.	0.
31624	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 76 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
317 1	0.	0.	0.	0.	0.
317 2	0.	0.	0.	0.	0.
317 3	0.	0.	0.	0.	0.
317 4	0.	0.	0.	0.	0.
317 5	0.	0.	0.	0.	0.
317 6	0.	0.	0.	0.	0.
317 7	0.	0.	0.	0.	0.
317 8	0.	0.	0.	0.	0.
317 9	0.	0.	0.	0.	0.
31710	0.	0.	0.	0.	0.
31711	0.	0.	0.	0.	0.
31712	0.	0.	0.	0.	0.
31713	0.	0.	0.	0.	0.
31714	0.	0.	0.	0.	0.
31715	0.	0.	0.	0.	0.
31716	0.	0.	0.	0.	0.
31717	0.	0.	0.	0.	0.
31718	0.	0.	0.	0.	0.
31719	0.	0.	0.	0.	0.
31720	0.	0.	0.	0.	0.
31721	0.	0.	0.	0.	0.
31722	0.	0.	0.	0.	0.
31723	0.	0.	0.	0.	0.
31724	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 77 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
318 1	0.	0.	0.	0.	0.
318 2	0.	0.	0.	0.	0.
318 3	0.	0.	0.	0.	0.
318 4	0.	0.	0.	0.	0.
318 5	0.	0.	0.	0.	0.
318 6	0.	0.	0.	0.	0.
318 7	0.	0.	0.	0.	0.
318 8	0.	0.	0.	0.	0.
318 9	0.	0.	0.	0.	0.
31810	0.	0.	0.	0.	0.
31811	0.	0.	0.	0.	0.
31812	0.	0.	0.	0.	0.
31813	0.	0.	0.	0.	0.
31814	0.	0.	0.	0.	0.
31815	0.	0.	0.	0.	0.
31816	0.	0.	0.	0.	0.
31817	0.	0.	0.	0.	0.
31818	0.	0.	0.	0.	0.
31819	0.	0.	0.	0.	0.
31820	0.	0.	0.	0.	0.
31821	0.	0.	0.	0.	0.
31822	0.	0.	0.	0.	0.
31823	0.	0.	0.	0.	0.
31824	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 78 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
319 1	0.	0.	0.	0.	0.
319 2	0.	0.	0.	0.	0.
319 3	0.	0.	0.	0.	0.
319 4	0.	0.	0.	0.	0.
319 5	0.	0.	0.	0.	0.
319 6	0.	0.	0.	0.	0.
319 7	0.	0.	0.	0.	0.
319 8	0.	0.	0.	0.	0.
319 9	0.	0.	0.	0.	0.
31910	0.	0.	0.	0.	0.
31911	0.	0.	0.	0.	0.
31912	0.	0.	0.	0.	0.
31913	0.	0.	0.	0.	0.
31914	0.	0.	0.	0.	0.
31915	0.	0.	0.	0.	0.
31916	0.	0.	0.	0.	0.
31917	0.	0.	0.	0.	0.
31918	0.	0.	0.	0.	0.
31919	0.	0.	0.	0.	0.
31920	0.	0.	0.	0.	0.
31921	0.	0.	0.	0.	0.
31922	0.	0.	0.	0.	0.
31923	0.	0.	0.	0.	0.
31924	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 79 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
320 1	0.	0.	0.	0.	0.
320 2	0.	0.	0.	0.	0.
320 3	0.	0.	0.	0.	0.
320 4	0.	0.	0.	0.	0.
320 5	0.	0.	0.	0.	0.
320 6	0.	0.	0.	0.	0.
320 7	0.	0.	0.	0.	0.
320 8	0.	0.	0.	0.	0.
320 9	0.	0.	0.	0.	0.
32010	0.	0.	0.	0.	0.
32011	0.	0.	0.	0.	0.
32012	0.	0.	0.	0.	0.
32013	0.	0.	0.	0.	0.
32014	0.	0.	0.	0.	0.
32015	0.	0.	0.	0.	0.
32016	0.	0.	0.	0.	0.
32017	0.	0.	0.	0.	0.
32018	0.	0.	0.	0.	0.
32019	0.	0.	0.	0.	0.
32020	0.	0.	0.	0.	0.
32021	0.	0.	0.	0.	0.
32022	0.	0.	0.	0.	0.
32023	0.	0.	0.	0.	0.
32024	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 80 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
321 1	0.	0.	0.	0.	0.
321 2	0.	0.	0.	0.	0.
321 3	0.	0.	0.	0.	0.
321 4	0.	0.	0.	0.	0.
321 5	0.	0.	0.	0.	0.
321 6	0.	0.	0.	0.	0.
321 7	0.	0.	0.	0.	0.
321 8	0.	0.	0.	0.	0.
321 9	0.	0.	0.	0.	0.
32110	0.	0.	0.	0.	0.
32111	0.	0.	0.	0.	0.
32112	0.	0.	0.	0.	0.
32113	0.	0.	0.	0.	0.
32114	0.	0.	0.	0.	0.
32115	0.	0.	0.	0.	0.
32116	0.	0.	0.	0.	0.
32117	0.	0.	0.	0.	0.
32118	0.	0.	0.	0.	0.
32119	0.	0.	0.	0.	0.
32120	0.	0.	0.	0.	0.
32121	0.	0.	0.	0.	0.
32122	0.	0.	0.	0.	0.
32123	0.	0.	0.	0.	0.
32124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 81 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
322 1	0.	0.	0.	0.	0.
322 2	0.	0.	0.	0.	0.
322 3	0.	0.	0.	0.	0.
322 4	0.	0.	0.	0.	0.
322 5	0.	0.	0.	0.	0.
322 6	0.	0.	0.	0.	0.
322 7	0.	0.	0.	0.	0.
322 8	0.	0.	0.	0.	0.
322 9	0.	0.	0.	0.	0.
32210	0.	0.	0.	0.	0.
32211	0.	0.	0.	0.	0.
32212	0.	0.	0.	0.	0.
32213	0.	0.	0.	0.	0.
32214	0.	0.	0.	0.	0.
32215	0.	0.	0.	0.	0.
32216	0.	0.	0.	0.	0.
32217	0.	0.	0.	0.	0.
32218	0.	0.	0.	0.	0.
32219	0.	0.	0.	0.	0.
32220	0.	0.	0.	0.	0.
32221	0.	0.	0.	0.	0.
32222	0.	0.	0.	0.	0.
32223	0.	0.	0.	0.	0.
32224	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 82 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
323 1	0.	0.	0.	0.	0.
323 2	0.	0.	0.	0.	0.
323 3	0.	0.	0.	0.	0.
323 4	0.	0.	0.	0.	0.
323 5	0.	0.	0.	0.	0.
323 6	0.	0.	0.	0.	0.
323 7	0.	0.	0.	0.	0.
323 8	0.	0.	0.	0.	0.
323 9	0.	0.	0.	0.	0.
32310	0.	0.	0.	0.	0.
32311	0.	0.	0.	0.	0.
32312	0.	0.	0.	0.	0.
32313	0.	0.	0.	0.	0.
32314	0.	0.	0.	0.	0.
32315	0.	0.	0.	0.	0.
32316	0.	0.	0.	0.	0.
32317	0.	0.	0.	0.	0.
32318	0.	0.	0.	0.	0.
32319	0.	0.	0.	0.	0.
32320	0.	0.	0.	0.	0.
32321	0.	0.	0.	0.	0.
32322	0.	0.	0.	0.	0.
32323	0.	0.	0.	0.	0.
32324	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 83 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
324 1	0.	0.	0.	0.	0.
324 2	0.	0.	0.	0.	0.
324 3	0.	0.	0.	0.	0.
324 4	0.	0.	0.	0.	0.
324 5	0.	0.	0.	0.	0.
324 6	0.	0.	0.	0.	0.
324 7	0.	0.	0.	0.	0.
324 8	0.	0.	0.	0.	0.
324 9	0.	0.	0.	0.	0.
32410	0.	0.	0.	0.	0.
32411	0.	0.	0.	0.	0.
32412	0.	0.	0.	0.	0.
32413	0.	0.	0.	0.	0.
32414	0.	0.	0.	0.	0.
32415	0.	0.	0.	0.	0.
32416	0.	0.	0.	0.	0.
32417	0.	0.	0.	0.	0.
32418	0.	0.	0.	0.	0.
32419	0.	0.	0.	0.	0.
32420	0.	0.	0.	0.	0.
32421	0.	0.	0.	0.	0.
32422	0.	0.	0.	0.	0.
32423	0.	0.	0.	0.	0.
32424	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 84 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
325 1	0.	0.	0.	0.	0.
325 2	0.	0.	0.	0.	0.
325 3	0.	0.	0.	0.	0.
325 4	0.	0.	0.	0.	0.
325 5	0.	0.	0.	0.	0.
325 6	0.	0.	0.	0.	0.
325 7	0.	0.	0.	0.	0.
325 8	0.	0.	0.	0.	0.
325 9	0.	0.	0.	0.	0.
32510	0.	0.	0.	0.	0.
32511	0.	0.	0.	0.	0.
32512	0.	0.	0.	0.	0.
32513	0.	0.	0.	0.	0.
32514	0.	0.	0.	0.	0.
32515	0.	0.	0.	0.	0.
32516	0.	0.	0.	0.	0.
32517	0.	0.	0.	0.	0.
32518	0.	0.	0.	0.	0.
32519	0.	0.	0.	0.	0.
32520	0.	0.	0.	0.	0.
32521	0.	0.	0.	0.	0.
32522	0.	0.	0.	0.	0.
32523	0.	0.	0.	0.	0.
32524	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 85 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
326 1	0.	0.	0.	0.	0.
326 2	0.	0.	0.	0.	0.
326 3	0.	0.	0.	0.	0.
326 4	0.	0.	0.	0.	0.
326 5	0.	0.	0.	0.	0.
326 6	0.	0.	0.	0.	0.
326 7	0.	0.	0.	0.	0.
326 8	0.	0.	0.	0.	0.
326 9	0.	0.	0.	0.	0.
32610	0.	0.	0.	0.	0.
32611	0.	0.	0.	0.	0.
32612	0.	0.	0.	0.	0.
32613	0.	0.	0.	0.	0.
32614	0.	0.	0.	0.	0.
32615	0.	0.	0.	0.	0.
32616	0.	0.	0.	0.	0.
32617	0.	0.	0.	0.	0.
32618	0.	0.	0.	0.	0.
32619	0.	0.	0.	0.	0.
32620	0.	0.	0.	0.	0.
32621	0.	0.	0.	0.	0.
32622	0.	0.	0.	0.	0.
32623	0.	0.	0.	0.	0.
32624	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 86 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
327 1	0.	0.	0.	0.	0.
327 2	0.	0.	0.	0.	0.
327 3	0.	0.	0.	0.	0.
327 4	0.	0.	0.	0.	0.
327 5	0.	0.	0.	0.	0.
327 6	0.	0.	0.	0.	0.
327 7	0.	0.	0.	0.	0.
327 8	0.	0.	0.	0.	0.
327 9	0.	0.	0.	0.	0.
32710	0.	0.	0.	0.	0.
32711	0.	0.	0.	0.	0.
32712	0.	0.	0.	0.	0.
32713	0.	0.	0.	0.	0.
32714	0.	0.	0.	0.	0.
32715	0.	0.	0.	0.	0.
32716	0.	0.	0.	0.	0.
32717	0.	0.	0.	0.	0.
32718	0.	0.	0.	0.	0.
32719	0.	0.	0.	0.	0.
32720	0.	0.	0.	0.	0.
32721	0.	0.	0.	0.	0.
32722	0.	0.	0.	0.	0.
32723	0.	0.	0.	0.	0.
32724	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 87 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
328 1	0.	0.	0.	0.	0.
328 2	0.	0.	0.	0.	0.
328 3	0.	0.	0.	0.	0.
328 4	0.	0.	0.	0.	0.
328 5	0.	0.	0.	0.	0.
328 6	0.	0.	0.	0.	0.
328 7	0.	0.	0.	0.	0.
328 8	0.	0.	0.	0.	0.
328 9	0.	0.	0.	0.	0.
32810	0.	0.	0.	0.	0.
32811	0.	0.	0.	0.	0.
32812	0.	0.	0.	0.	0.
32813	0.	0.	0.	0.	0.
32814	0.	0.	0.	0.	0.
32815	0.	0.	0.	0.	0.
32816	0.	0.	0.	0.	0.
32817	0.	0.	0.	0.	0.
32818	0.	0.	0.	0.	0.
32819	0.	0.	0.	0.	0.
32820	0.	0.	0.	0.	0.
32821	0.	0.	0.	0.	0.
32822	0.	0.	0.	0.	0.
32823	0.	0.	0.	0.	0.
32824	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 88 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
329 1	0.	0.	0.	0.	0.
329 2	0.	0.	0.	0.	0.
329 3	0.	0.	0.	0.	0.
329 4	0.	0.	0.	0.	0.
329 5	0.	0.	0.	0.	0.
329 6	0.	0.	0.	0.	0.
329 7	0.	0.	0.	0.	0.
329 8	0.	0.	0.	0.	0.
329 9	0.	0.	0.	0.	0.
32910	0.	0.	0.	0.	0.
32911	0.	0.	0.	0.	0.
32912	0.	0.	0.	0.	0.
32913	0.	0.	0.	0.	0.
32914	0.	0.	0.	0.	0.
32915	0.	0.	0.	0.	0.
32916	0.	0.	0.	0.	0.
32917	0.	0.	0.	0.	0.
32918	0.	0.	0.	0.	0.
32919	0.	0.	0.	0.	0.
32920	0.	0.	0.	0.	0.
32921	0.	0.	0.	0.	0.
32922	0.	0.	0.	0.	0.
32923	0.	0.	0.	0.	0.
32924	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 89 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
330 1	0.	0.	0.	0.	0.
330 2	0.	0.	0.	0.	0.
330 3	0.	0.	0.	0.	0.
330 4	0.	0.	0.	0.	0.
330 5	0.	0.	0.	0.	0.
330 6	0.	0.	0.	0.	0.
330 7	0.	0.	0.	0.	0.
330 8	0.	0.	0.	0.	0.
330 9	0.	0.	0.	0.	0.
33010	0.	0.	0.	0.	0.
33011	0.	0.	0.	0.	0.
33012	0.	0.	0.	0.	0.
33013	0.	0.	0.	0.	0.
33014	0.	0.	0.	0.	0.
33015	0.	0.	0.	0.	0.
33016	0.	0.	0.	0.	0.
33017	0.	0.	0.	0.	0.
33018	0.	0.	0.	0.	0.
33019	0.	0.	0.	0.	0.
33020	0.	0.	0.	0.	0.
33021	0.	0.	0.	0.	0.
33022	0.	0.	0.	0.	0.
33023	0.	0.	0.	0.	0.
33024	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 90 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
331 1	0.	0.	0.	0.	0.
331 2	0.	0.	0.	0.	0.
331 3	0.	0.	0.	0.	0.
331 4	0.	0.	0.	0.	0.
331 5	0.	0.	0.	0.	0.
331 6	0.	0.	0.	0.	0.
331 7	0.	0.	0.	0.	0.
331 8	0.	0.	0.	0.	0.
331 9	0.	0.	0.	0.	0.
33110	0.	0.	0.	0.	0.
33111	0.	0.	0.	0.	0.
33112	0.	0.	0.	0.	0.
33113	0.	0.	0.	0.	0.
33114	0.	0.	0.	0.	0.
33115	0.	0.	0.	0.	0.
33116	0.	0.	0.	0.	0.
33117	0.	0.	0.	0.	0.
33118	0.	0.	0.	0.	0.
33119	0.	0.	0.	0.	0.
33120	0.	0.	0.	0.	0.
33121	0.	0.	0.	0.	0.
33122	0.	0.	0.	0.	0.
33123	0.	0.	0.	0.	0.
33124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAR 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (MAR)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 91 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 1 1	0.	0.	0.	0.	0.
4 1 2	0.	0.	0.	0.	0.
4 1 3	0.	0.	0.	0.	0.
4 1 4	0.	0.	0.	0.	0.
4 1 5	0.	0.	0.	0.	0.
4 1 6	0.	0.	0.	0.	0.
4 1 7	0.	0.	0.	0.	0.
4 1 8	0.	0.	0.	0.	0.
4 1 9	0.	0.	0.	0.	0.
4 110	0.	0.	0.	0.	0.
4 111	0.	0.	0.	0.	0.
4 112	0.	0.	0.	0.	0.
4 113	0.	0.	0.	0.	0.
4 114	0.	0.	0.	0.	0.
4 115	0.	0.	0.	0.	0.
4 116	0.	0.	0.	0.	0.
4 117	0.	0.	0.	0.	0.
4 118	0.	0.	0.	0.	0.
4 119	0.	0.	0.	0.	0.
4 120	0.	0.	0.	0.	0.
4 121	0.	0.	0.	0.	0.
4 122	0.	0.	0.	0.	0.
4 123	0.	0.	0.	0.	0.
4 124	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 92 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 2 1	0.	0.	0.	0.	0.
4 2 2	0.	0.	0.	0.	0.
4 2 3	0.	0.	0.	0.	0.
4 2 4	0.	0.	0.	0.	0.
4 2 5	0.	0.	0.	0.	0.
4 2 6	0.	0.	0.	0.	0.
4 2 7	0.	0.	0.	0.	0.
4 2 8	0.	0.	0.	0.	0.
4 2 9	0.	0.	0.	0.	0.
4 210	0.	0.	0.	0.	0.
4 211	0.	0.	0.	0.	0.
4 212	0.	0.	0.	0.	0.
4 213	0.	0.	0.	0.	0.
4 214	0.	0.	0.	0.	0.
4 215	0.	0.	0.	0.	0.
4 216	0.	0.	0.	0.	0.
4 217	0.	0.	0.	0.	0.
4 218	0.	0.	0.	0.	0.
4 219	0.	0.	0.	0.	0.
4 220	0.	0.	0.	0.	0.
4 221	0.	0.	0.	0.	0.
4 222	0.	0.	0.	0.	0.
4 223	0.	0.	0.	0.	0.
4 224	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 93 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 3 1	0.	0.	0.	0.	0.
4 3 2	0.	0.	0.	0.	0.
4 3 3	0.	0.	0.	0.	0.
4 3 4	0.	0.	0.	0.	0.
4 3 5	0.	0.	0.	0.	0.
4 3 6	0.	0.	0.	0.	0.
4 3 7	0.	0.	0.	0.	0.
4 3 8	0.	0.	0.	0.	0.
4 3 9	0.	0.	0.	0.	0.
4 310	0.	0.	0.	0.	0.
4 311	0.	0.	0.	0.	0.
4 312	0.	0.	0.	0.	0.
4 313	0.	0.	0.	0.	0.
4 314	0.	0.	0.	0.	0.
4 315	0.	0.	0.	0.	0.
4 316	0.	0.	0.	0.	0.
4 317	0.	0.	0.	0.	0.
4 318	0.	0.	0.	0.	0.
4 319	0.	0.	0.	0.	0.
4 320	0.	0.	0.	0.	0.
4 321	0.	0.	0.	0.	0.
4 322	0.	0.	0.	0.	0.
4 323	0.	0.	0.	0.	0.
4 324	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 94 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 4 1	0.	0.	0.	0.	0.
4 4 2	0.	0.	0.	0.	0.
4 4 3	0.	0.	0.	0.	0.
4 4 4	0.	0.	0.	0.	0.
4 4 5	0.	0.	0.	0.	0.
4 4 6	0.	0.	0.	0.	0.
4 4 7	0.	0.	0.	0.	0.
4 4 8	0.	0.	0.	0.	0.
4 4 9	0.	0.	0.	0.	0.
4 410	0.	0.	0.	0.	0.
4 411	0.	0.	0.	0.	0.
4 412	0.	0.	0.	0.	0.
4 413	0.	0.	0.	0.	0.
4 414	0.	0.	0.	0.	0.
4 415	0.	0.	0.	0.	0.
4 416	0.	0.	0.	0.	0.
4 417	0.	0.	0.	0.	0.
4 418	0.	0.	0.	0.	0.
4 419	0.	0.	0.	0.	0.
4 420	0.	0.	0.	0.	0.
4 421	0.	0.	0.	0.	0.
4 422	0.	0.	0.	0.	0.
4 423	0.	0.	0.	0.	0.
4 424	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 95 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 5 1	0.	0.	0.	0.	0.
4 5 2	0.	0.	0.	0.	0.
4 5 3	0.	0.	0.	0.	0.
4 5 4	0.	0.	0.	0.	0.
4 5 5	0.	0.	0.	0.	0.
4 5 6	0.	0.	0.	0.	0.
4 5 7	0.	0.	0.	0.	0.
4 5 8	0.	0.	0.	0.	0.
4 5 9	0.	0.	0.	0.	0.
4 510	0.	0.	0.	0.	0.
4 511	0.	0.	0.	0.	0.
4 512	0.	0.	0.	0.	0.
4 513	0.	0.	0.	0.	0.
4 514	0.	0.	0.	0.	0.
4 515	0.	0.	0.	0.	0.
4 516	0.	0.	0.	0.	0.
4 517	0.	0.	0.	0.	0.
4 518	0.	0.	0.	0.	0.
4 519	0.	0.	0.	0.	0.
4 520	0.	0.	0.	0.	0.
4 521	0.	0.	0.	0.	0.
4 522	0.	0.	0.	0.	0.
4 523	0.	0.	0.	0.	0.
4 524	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 96 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 6 1	0.	0.	0.	0.	0.
4 6 2	0.	0.	0.	0.	0.
4 6 3	0.	0.	0.	0.	0.
4 6 4	0.	0.	0.	0.	0.
4 6 5	0.	0.	0.	0.	0.
4 6 6	0.	0.	0.	0.	0.
4 6 7	0.	0.	0.	0.	0.
4 6 8	0.	0.	0.	0.	0.
4 6 9	0.	0.	0.	0.	0.
4 610	0.	0.	0.	0.	0.
4 611	0.	0.	0.	0.	0.
4 612	0.	0.	0.	0.	0.
4 613	0.	0.	0.	0.	0.
4 614	0.	0.	0.	0.	0.
4 615	0.	0.	0.	0.	0.
4 616	0.	0.	0.	0.	0.
4 617	0.	0.	0.	0.	0.
4 618	0.	0.	0.	0.	0.
4 619	0.	0.	0.	0.	0.
4 620	0.	0.	0.	0.	0.
4 621	0.	0.	0.	0.	0.
4 622	0.	0.	0.	0.	0.
4 623	0.	0.	0.	0.	0.
4 624	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 97 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 7 1	0.	0.	0.	0.	0.
4 7 2	0.	0.	0.	0.	0.
4 7 3	0.	0.	0.	0.	0.
4 7 4	0.	0.	0.	0.	0.
4 7 5	0.	0.	0.	0.	0.
4 7 6	0.	0.	0.	0.	0.
4 7 7	0.	0.	0.	0.	0.
4 7 8	0.	0.	0.	0.	0.
4 7 9	0.	0.	0.	0.	0.
4 710	0.	0.	0.	0.	0.
4 711	0.	0.	0.	0.	0.
4 712	0.	0.	0.	0.	0.
4 713	0.	0.	0.	0.	0.
4 714	0.	0.	0.	0.	0.
4 715	0.	0.	0.	0.	0.
4 716	0.	0.	0.	0.	0.
4 717	0.	0.	0.	0.	0.
4 718	0.	0.	0.	0.	0.
4 719	0.	0.	0.	0.	0.
4 720	0.	0.	0.	0.	0.
4 721	0.	0.	0.	0.	0.
4 722	0.	0.	0.	0.	0.
4 723	0.	0.	0.	0.	0.
4 724	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 98 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 8 1	0.	0.	0.	0.	0.
4 8 2	0.	0.	0.	0.	0.
4 8 3	0.	0.	0.	0.	0.
4 8 4	0.	0.	0.	0.	0.
4 8 5	0.	0.	0.	0.	0.
4 8 6	0.	0.	0.	0.	0.
4 8 7	0.	0.	0.	0.	0.
4 8 8	0.	0.	0.	0.	0.
4 8 9	0.	0.	0.	0.	0.
4 810	0.	0.	0.	0.	0.
4 811	0.	0.	0.	0.	0.
4 812	0.	0.	0.	0.	0.
4 813	0.	0.	0.	0.	0.
4 814	0.	0.	0.	0.	0.
4 815	0.	0.	0.	0.	0.
4 816	0.	0.	0.	0.	0.
4 817	0.	0.	0.	0.	0.
4 818	0.	0.	0.	0.	0.
4 819	0.	0.	0.	0.	0.
4 820	0.	0.	0.	0.	0.
4 821	0.	0.	0.	0.	0.
4 822	0.	0.	0.	0.	0.
4 823	0.	0.	0.	0.	0.
4 824	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE 99 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
4 9 1	0.	0.	0.	0.	0.
4 9 2	0.	0.	0.	0.	0.
4 9 3	0.	0.	0.	0.	0.
4 9 4	0.	0.	0.	0.	0.
4 9 5	0.	0.	0.	0.	0.
4 9 6	0.	0.	0.	0.	0.
4 9 7	0.	0.	0.	0.	0.
4 9 8	0.	0.	0.	0.	0.
4 9 9	0.	0.	0.	0.	0.
4 910	0.	0.	0.	0.	0.
4 911	0.	0.	0.	0.	0.
4 912	0.	0.	0.	0.	0.
4 913	0.	0.	0.	0.	0.
4 914	0.	0.	0.	0.	0.
4 915	0.	0.	0.	0.	0.
4 916	0.	0.	0.	0.	0.
4 917	0.	0.	0.	0.	0.
4 918	0.	0.	0.	0.	0.
4 919	0.	0.	0.	0.	0.
4 920	0.	0.	0.	0.	0.
4 921	0.	0.	0.	0.	0.
4 922	0.	0.	0.	0.	0.
4 923	0.	0.	0.	0.	0.
4 924	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE100 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
410 1	0.	0.	0.	0.	0.
410 2	0.	0.	0.	0.	0.
410 3	0.	0.	0.	0.	0.
410 4	0.	0.	0.	0.	0.
410 5	0.	0.	0.	0.	0.
410 6	0.	0.	0.	0.	0.
410 7	0.	0.	0.	0.	0.
410 8	0.	0.	0.	0.	0.
410 9	0.	0.	0.	0.	0.
41010	0.	0.	0.	0.	0.
41011	0.	0.	0.	0.	0.
41012	0.	0.	0.	0.	0.
41013	0.	0.	0.	0.	0.
41014	0.	0.	0.	0.	0.
41015	0.	0.	0.	0.	0.
41016	0.	0.	0.	0.	0.
41017	0.	0.	0.	0.	0.
41018	0.	0.	0.	0.	0.
41019	0.	0.	0.	0.	0.
41020	0.	0.	0.	0.	0.
41021	0.	0.	0.	0.	0.
41022	0.	0.	0.	0.	0.
41023	0.	0.	0.	0.	0.
41024	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE101 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
411 1	0.	0.	0.	0.	0.
411 2	0.	0.	0.	0.	0.
411 3	0.	0.	0.	0.	0.
411 4	0.	0.	0.	0.	0.
411 5	0.	0.	0.	0.	0.
411 6	0.	0.	0.	0.	0.
411 7	0.	0.	0.	0.	0.
411 8	0.	0.	0.	0.	0.
411 9	0.	0.	0.	0.	0.
41110	0.	0.	0.	0.	0.
41111	0.	0.	0.	0.	0.
41112	0.	0.	0.	0.	0.
41113	0.	0.	0.	0.	0.
41114	0.	0.	0.	0.	0.
41115	0.	0.	0.	0.	0.
41116	0.	0.	0.	0.	0.
41117	0.	0.	0.	0.	0.
41118	0.	0.	0.	0.	0.
41119	0.	0.	0.	0.	0.
41120	0.	0.	0.	0.	0.
41121	0.	0.	0.	0.	0.
41122	0.	0.	0.	0.	0.
41123	0.	0.	0.	0.	0.
41124	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE102 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
412 1	0.	0.	0.	0.	0.
412 2	0.	0.	0.	0.	0.
412 3	0.	0.	0.	0.	0.
412 4	0.	0.	0.	0.	0.
412 5	0.	0.	0.	0.	0.
412 6	0.	0.	0.	0.	0.
412 7	0.	0.	0.	0.	0.
412 8	0.	0.	0.	0.	0.
412 9	0.	0.	0.	0.	0.
41210	0.	0.	0.	0.	0.
41211	0.	0.	0.	0.	0.
41212	0.	0.	0.	0.	0.
41213	0.	0.	0.	0.	0.
41214	0.	0.	0.	0.	0.
41215	0.	0.	0.	0.	0.
41216	0.	0.	0.	0.	0.
41217	0.	0.	0.	0.	0.
41218	0.	0.	0.	0.	0.
41219	0.	0.	0.	0.	0.
41220	0.	0.	0.	0.	0.
41221	0.	0.	0.	0.	0.
41222	0.	0.	0.	0.	0.
41223	0.	0.	0.	0.	0.
41224	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE103 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
413 1	0.	0.	0.	0.	0.
413 2	0.	0.	0.	0.	0.
413 3	0.	0.	0.	0.	0.
413 4	0.	0.	0.	0.	0.
413 5	0.	0.	0.	0.	0.
413 6	0.	0.	0.	0.	0.
413 7	0.	0.	0.	0.	0.
413 8	0.	0.	0.	0.	0.
413 9	0.	0.	0.	0.	0.
41310	0.	0.	0.	0.	0.
41311	0.	0.	0.	0.	0.
41312	0.	0.	0.	0.	0.
41313	0.	0.	0.	0.	0.
41314	0.	0.	0.	0.	0.
41315	0.	0.	0.	0.	0.
41316	0.	0.	0.	0.	0.
41317	0.	0.	0.	0.	0.
41318	0.	0.	0.	0.	0.
41319	0.	0.	0.	0.	0.
41320	0.	0.	0.	0.	0.
41321	0.	0.	0.	0.	0.
41322	0.	0.	0.	0.	0.
41323	0.	0.	0.	0.	0.
41324	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE104 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
414 1	0.	0.	0.	0.	0.
414 2	0.	0.	0.	0.	0.
414 3	0.	0.	0.	0.	0.
414 4	0.	0.	0.	0.	0.
414 5	0.	0.	0.	0.	0.
414 6	0.	0.	0.	0.	0.
414 7	0.	0.	0.	0.	0.
414 8	0.	0.	0.	0.	0.
414 9	0.	0.	0.	0.	0.
41410	0.	0.	0.	0.	0.
41411	0.	0.	0.	0.	0.
41412	0.	0.	0.	0.	0.
41413	0.	0.	0.	0.	0.
41414	0.	0.	0.	0.	0.
41415	0.	0.	0.	0.	0.
41416	0.	0.	0.	0.	0.
41417	0.	0.	0.	0.	0.
41418	0.	0.	0.	0.	0.
41419	0.	0.	0.	0.	0.
41420	0.	0.	0.	0.	0.
41421	0.	0.	0.	0.	0.
41422	0.	0.	0.	0.	0.
41423	0.	0.	0.	0.	0.
41424	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE105 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
415 1	0.	0.	0.	0.	0.
415 2	0.	0.	0.	0.	0.
415 3	0.	0.	0.	0.	0.
415 4	0.	0.	0.	0.	0.
415 5	0.	0.	0.	0.	0.
415 6	0.	0.	0.	0.	0.
415 7	0.	0.	0.	0.	0.
415 8	0.	0.	0.	0.	0.
415 9	0.	0.	0.	0.	0.
41510	0.	0.	0.	0.	0.
41511	0.	0.	0.	0.	0.
41512	0.	0.	0.	0.	0.
41513	0.	0.	0.	0.	0.
41514	0.	0.	0.	0.	0.
41515	0.	0.	0.	0.	0.
41516	0.	0.	0.	0.	0.
41517	0.	0.	0.	0.	0.
41518	0.	0.	0.	0.	0.
41519	0.	0.	0.	0.	0.
41520	0.	0.	0.	0.	0.
41521	0.	0.	0.	0.	0.
41522	0.	0.	0.	0.	0.
41523	0.	0.	0.	0.	0.
41524	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE106 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
416 1	0.	0.	0.	0.	0.
416 2	0.	0.	0.	0.	0.
416 3	0.	0.	0.	0.	0.
416 4	0.	0.	0.	0.	0.
416 5	0.	0.	0.	0.	0.
416 6	0.	0.	0.	0.	0.
416 7	0.	0.	0.	0.	0.
416 8	0.	0.	0.	0.	0.
416 9	0.	0.	0.	0.	0.
41610	0.	0.	0.	0.	0.
41611	0.	0.	0.	0.	0.
41612	0.	0.	0.	0.	0.
41613	0.	0.	0.	0.	0.
41614	0.	0.	0.	0.	0.
41615	0.	0.	0.	0.	0.
41616	0.	0.	0.	0.	0.
41617	0.	0.	0.	0.	0.
41618	0.	0.	0.	0.	0.
41619	0.	0.	0.	0.	0.
41620	0.	0.	0.	0.	0.
41621	0.	0.	0.	0.	0.
41622	0.	0.	0.	0.	0.
41623	0.	0.	0.	0.	0.
41624	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE107 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
417 1	0.	0.	0.	0.	0.
417 2	0.	0.	0.	0.	0.
417 3	0.	0.	0.	0.	0.
417 4	0.	0.	0.	0.	0.
417 5	0.	0.	0.	0.	0.
417 6	0.	0.	0.	0.	0.
417 7	0.	0.	0.	0.	0.
417 8	0.	0.	0.	0.	0.
417 9	0.	0.	0.	0.	0.
41710	0.	0.	0.	0.	0.
41711	0.	0.	0.	0.	0.
41712	0.	0.	0.	0.	0.
41713	0.	0.	0.	0.	0.
41714	0.	0.	0.	0.	0.
41715	0.	0.	0.	0.	0.
41716	0.	0.	0.	0.	0.
41717	0.	0.	0.	0.	0.
41718	0.	0.	0.	0.	0.
41719	0.	0.	0.	0.	0.
41720	0.	0.	0.	0.	0.
41721	0.	0.	0.	0.	0.
41722	0.	0.	0.	0.	0.
41723	0.	0.	0.	0.	0.
41724	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE108 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
418 1	0.	0.	0.	0.	0.
418 2	0.	0.	0.	0.	0.
418 3	0.	0.	0.	0.	0.
418 4	0.	0.	0.	0.	0.
418 5	0.	0.	0.	0.	0.
418 6	0.	0.	0.	0.	0.
418 7	0.	0.	0.	0.	0.
418 8	0.	0.	0.	0.	0.
418 9	0.	0.	0.	0.	0.
41810	0.	0.	0.	0.	0.
41811	0.	0.	0.	0.	0.
41812	0.	0.	0.	0.	0.
41813	0.	0.	0.	0.	0.
41814	0.	0.	0.	0.	0.
41815	0.	0.	0.	0.	0.
41816	0.	0.	0.	0.	0.
41817	0.	0.	0.	0.	0.
41818	0.	0.	0.	0.	0.
41819	0.	0.	0.	0.	0.
41820	0.	0.	0.	0.	0.
41821	0.	0.	0.	0.	0.
41822	0.	0.	0.	0.	0.
41823	0.	0.	0.	0.	0.
41824	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE109 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
419 1	0.	0.	0.	0.	0.
419 2	0.	0.	0.	0.	0.
419 3	0.	0.	0.	0.	0.
419 4	0.	0.	0.	0.	0.
419 5	0.	0.	0.	0.	0.
419 6	0.	0.	0.	0.	0.
419 7	0.	0.	0.	0.	0.
419 8	0.	0.	0.	0.	0.
419 9	0.	0.	0.	0.	0.
41910	0.	0.	0.	0.	0.
41911	0.	0.	0.	0.	0.
41912	0.	0.	0.	0.	0.
41913	0.	0.	0.	0.	0.
41914	0.	0.	0.	0.	0.
41915	0.	0.	0.	0.	0.
41916	0.	0.	0.	0.	0.
41917	0.	0.	0.	0.	0.
41918	0.	0.	0.	0.	0.
41919	0.	0.	0.	0.	0.
41920	0.	0.	0.	0.	0.
41921	0.	0.	0.	0.	0.
41922	0.	0.	0.	0.	0.
41923	0.	0.	0.	0.	0.
41924	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE110 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
420 1	0.	0.	0.	0.	0.
420 2	0.	0.	0.	0.	0.
420 3	0.	0.	0.	0.	0.
420 4	0.	0.	0.	0.	0.
420 5	0.	0.	0.	0.	0.
420 6	0.	0.	0.	0.	0.
420 7	0.	0.	0.	0.	0.
420 8	0.	0.	0.	0.	0.
420 9	0.	0.	0.	0.	0.
42010	0.	0.	0.	0.	0.
42011	0.	0.	0.	0.	0.
42012	0.	0.	0.	0.	0.
42013	0.	0.	0.	0.	0.
42014	0.	0.	0.	0.	0.
42015	0.	0.	0.	0.	0.
42016	0.	0.	0.	0.	0.
42017	0.	0.	0.	0.	0.
42018	0.	0.	0.	0.	0.
42019	0.	0.	0.	0.	0.
42020	0.	0.	0.	0.	0.
42021	0.	0.	0.	0.	0.
42022	0.	0.	0.	0.	0.
42023	0.	0.	0.	0.	0.
42024	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE111 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
421 1	0.	0.	0.	0.	0.
421 2	0.	0.	0.	0.	0.
421 3	0.	0.	0.	0.	0.
421 4	0.	0.	0.	0.	0.
421 5	0.	0.	0.	0.	0.
421 6	0.	0.	0.	0.	0.
421 7	0.	0.	0.	0.	0.
421 8	0.	0.	0.	0.	0.
421 9	0.	0.	0.	0.	0.
42110	0.	0.	0.	0.	0.
42111	0.	0.	0.	0.	0.
42112	0.	0.	0.	0.	0.
42113	0.	0.	0.	0.	0.
42114	0.	0.	0.	0.	0.
42115	0.	0.	0.	0.	0.
42116	0.	0.	0.	0.	0.
42117	0.	0.	0.	0.	0.
42118	0.	0.	0.	0.	0.
42119	0.	0.	0.	0.	0.
42120	0.	0.	0.	0.	0.
42121	0.	0.	0.	0.	0.
42122	0.	0.	0.	0.	0.
42123	0.	0.	0.	0.	0.
42124	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE112 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
422 1	0.	0.	0.	0.	0.
422 2	0.	0.	0.	0.	0.
422 3	0.	0.	0.	0.	0.
422 4	0.	0.	0.	0.	0.
422 5	0.	0.	0.	0.	0.
422 6	0.	0.	0.	0.	0.
422 7	0.	0.	0.	0.	0.
422 8	0.	0.	0.	0.	0.
422 9	0.	0.	0.	0.	0.
42210	0.	0.	0.	0.	0.
42211	0.	0.	0.	0.	0.
42212	0.	0.	0.	0.	0.
42213	0.	0.	0.	0.	0.
42214	0.	0.	0.	0.	0.
42215	0.	0.	0.	0.	0.
42216	0.	0.	0.	0.	0.
42217	0.	0.	0.	0.	0.
42218	0.	0.	0.	0.	0.
42219	0.	0.	0.	0.	0.
42220	0.	0.	0.	0.	0.
42221	0.	0.	0.	0.	0.
42222	0.	0.	0.	0.	0.
42223	0.	0.	0.	0.	0.
42224	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE113 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
423 1	0.	0.	0.	0.	0.
423 2	0.	0.	0.	0.	0.
423 3	0.	0.	0.	0.	0.
423 4	0.	0.	0.	0.	0.
423 5	0.	0.	0.	0.	0.
423 6	0.	0.	0.	0.	0.
423 7	0.	0.	0.	0.	0.
423 8	0.	0.	0.	0.	0.
423 9	0.	0.	0.	0.	0.
42310	0.	0.	0.	0.	0.
42311	0.	0.	0.	0.	0.
42312	0.	0.	0.	0.	0.
42313	0.	0.	0.	0.	0.
42314	0.	0.	0.	0.	0.
42315	0.	0.	0.	0.	0.
42316	0.	0.	0.	0.	0.
42317	0.	0.	0.	0.	0.
42318	0.	0.	0.	0.	0.
42319	0.	0.	0.	0.	0.
42320	0.	0.	0.	0.	0.
42321	0.	0.	0.	0.	0.
42322	0.	0.	0.	0.	0.
42323	0.	0.	0.	0.	0.
42324	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE114 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
424 1	0.	0.	0.	0.	0.
424 2	0.	0.	0.	0.	0.
424 3	0.	0.	0.	0.	0.
424 4	0.	0.	0.	0.	0.
424 5	0.	0.	0.	0.	0.
424 6	0.	0.	0.	0.	0.
424 7	0.	0.	0.	0.	0.
424 8	0.	0.	0.	0.	0.
424 9	0.	0.	0.	0.	0.
42410	0.	0.	0.	0.	0.
42411	0.	0.	0.	0.	0.
42412	0.	0.	0.	0.	0.
42413	0.	0.	0.	0.	0.
42414	0.	0.	0.	0.	0.
42415	0.	0.	0.	0.	0.
42416	0.	0.	0.	0.	0.
42417	0.	0.	0.	0.	0.
42418	0.	0.	0.	0.	0.
42419	0.	0.	0.	0.	0.
42420	0.	0.	0.	0.	0.
42421	0.	0.	0.	0.	0.
42422	0.	0.	0.	0.	0.
42423	0.	0.	0.	0.	0.
42424	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE115 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
425 1	0.	0.	0.	0.	0.
425 2	0.	0.	0.	0.	0.
425 3	0.	0.	0.	0.	0.
425 4	0.	0.	0.	0.	0.
425 5	0.	0.	0.	0.	0.
425 6	0.	0.	0.	0.	0.
425 7	0.	0.	0.	0.	0.
425 8	0.	0.	0.	0.	0.
425 9	0.	0.	0.	0.	0.
42510	0.	0.	0.	0.	0.
42511	0.	0.	0.	0.	0.
42512	0.	0.	0.	0.	0.
42513	0.	0.	0.	0.	0.
42514	0.	0.	0.	0.	0.
42515	0.	0.	0.	0.	0.
42516	0.	0.	0.	0.	0.
42517	0.	0.	0.	0.	0.
42518	0.	0.	0.	0.	0.
42519	0.	0.	0.	0.	0.
42520	0.	0.	0.	0.	0.
42521	0.	0.	0.	0.	0.
42522	0.	0.	0.	0.	0.
42523	0.	0.	0.	0.	0.
42524	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE116 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
426 1	0.	0.	0.	0.	0.
426 2	0.	0.	0.	0.	0.
426 3	0.	0.	0.	0.	0.
426 4	0.	0.	0.	0.	0.
426 5	0.	0.	0.	0.	0.
426 6	0.	0.	0.	0.	0.
426 7	0.	0.	0.	0.	0.
426 8	0.	0.	0.	0.	0.
426 9	0.	0.	0.	0.	0.
42610	0.	0.	0.	0.	0.
42611	0.	0.	0.	0.	0.
42612	0.	0.	0.	0.	0.
42613	0.	0.	0.	0.	0.
42614	0.	0.	0.	0.	0.
42615	0.	0.	0.	0.	0.
42616	0.	0.	0.	0.	0.
42617	0.	0.	0.	0.	0.
42618	0.	0.	0.	0.	0.
42619	0.	0.	0.	0.	0.
42620	0.	0.	0.	0.	0.
42621	0.	0.	0.	0.	0.
42622	0.	0.	0.	0.	0.
42623	0.	0.	0.	0.	0.
42624	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE117 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
427 1	0.	0.	0.	0.	0.
427 2	0.	0.	0.	0.	0.
427 3	0.	0.	0.	0.	0.
427 4	0.	0.	0.	0.	0.
427 5	0.	0.	0.	0.	0.
427 6	0.	0.	0.	0.	0.
427 7	0.	0.	0.	0.	0.
427 8	0.	0.	0.	0.	0.
427 9	0.	0.	0.	0.	0.
42710	0.	0.	0.	0.	0.
42711	0.	0.	0.	0.	0.
42712	0.	0.	0.	0.	0.
42713	0.	0.	0.	0.	0.
42714	0.	0.	0.	0.	0.
42715	0.	0.	0.	0.	0.
42716	0.	0.	0.	0.	0.
42717	0.	0.	0.	0.	0.
42718	0.	0.	0.	0.	0.
42719	0.	0.	0.	0.	0.
42720	0.	0.	0.	0.	0.
42721	0.	0.	0.	0.	0.
42722	0.	0.	0.	0.	0.
42723	0.	0.	0.	0.	0.
42724	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE118 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
428 1	0.	0.	0.	0.	0.
428 2	0.	0.	0.	0.	0.
428 3	0.	0.	0.	0.	0.
428 4	0.	0.	0.	0.	0.
428 5	0.	0.	0.	0.	0.
428 6	0.	0.	0.	0.	0.
428 7	0.	0.	0.	0.	0.
428 8	0.	0.	0.	0.	0.
428 9	0.	0.	0.	0.	0.
42810	0.	0.	0.	0.	0.
42811	0.	0.	0.	0.	0.
42812	0.	0.	0.	0.	0.
42813	0.	0.	0.	0.	0.
42814	0.	0.	0.	0.	0.
42815	0.	0.	0.	0.	0.
42816	0.	0.	0.	0.	0.
42817	0.	0.	0.	0.	0.
42818	0.	0.	0.	0.	0.
42819	0.	0.	0.	0.	0.
42820	0.	0.	0.	0.	0.
42821	0.	0.	0.	0.	0.
42822	0.	0.	0.	0.	0.
42823	0.	0.	0.	0.	0.
42824	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE119 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
429 1	0.	0.	0.	0.	0.
429 2	0.	0.	0.	0.	0.
429 3	0.	0.	0.	0.	0.
429 4	0.	0.	0.	0.	0.
429 5	0.	0.	0.	0.	0.
429 6	0.	0.	0.	0.	0.
429 7	0.	0.	0.	0.	0.
429 8	0.	0.	0.	0.	0.
429 9	0.	0.	0.	0.	0.
42910	0.	0.	0.	0.	0.
42911	0.	0.	0.	0.	0.
42912	0.	0.	0.	0.	0.
42913	0.	0.	0.	0.	0.
42914	0.	0.	0.	0.	0.
42915	0.	0.	0.	0.	0.
42916	0.	0.	0.	0.	0.
42917	0.	0.	0.	0.	0.
42918	0.	0.	0.	0.	0.
42919	0.	0.	0.	0.	0.
42920	0.	0.	0.	0.	0.
42921	0.	0.	0.	0.	0.
42922	0.	0.	0.	0.	0.
42923	0.	0.	0.	0.	0.
42924	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE120 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
430 1	0.	0.	0.	0.	0.
430 2	0.	0.	0.	0.	0.
430 3	0.	0.	0.	0.	0.
430 4	0.	0.	0.	0.	0.
430 5	0.	0.	0.	0.	0.
430 6	0.	0.	0.	0.	0.
430 7	0.	0.	0.	0.	0.
430 8	0.	0.	0.	0.	0.
430 9	0.	0.	0.	0.	0.
43010	0.	0.	0.	0.	0.
43011	0.	0.	0.	0.	0.
43012	0.	0.	0.	0.	0.
43013	0.	0.	0.	0.	0.
43014	0.	0.	0.	0.	0.
43015	0.	0.	0.	0.	0.
43016	0.	0.	0.	0.	0.
43017	0.	0.	0.	0.	0.
43018	0.	0.	0.	0.	0.
43019	0.	0.	0.	0.	0.
43020	0.	0.	0.	0.	0.
43021	0.	0.	0.	0.	0.
43022	0.	0.	0.	0.	0.
43023	0.	0.	0.	0.	0.
43024	0.	0.	0.	0.	0.
DAILY SUMMARY (APR 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (APR)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE121 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 1 1	0.	0.	0.	0.	0.
5 1 2	0.	0.	0.	0.	0.
5 1 3	0.	0.	0.	0.	0.
5 1 4	0.	0.	0.	0.	0.
5 1 5	0.	0.	0.	0.	0.
5 1 6	0.	0.	0.	0.	0.
5 1 7	0.	0.	0.	0.	0.
5 1 8	0.	0.	0.	0.	0.
5 1 9	0.	0.	0.	0.	0.
5 110	0.	0.	0.	0.	0.
5 111	0.	0.	0.	0.	0.
5 112	0.	0.	0.	0.	0.
5 113	0.	0.	0.	0.	0.
5 114	0.	0.	0.	0.	0.
5 115	0.	0.	0.	0.	0.
5 116	0.	0.	0.	0.	0.
5 117	0.	0.	0.	0.	0.
5 118	0.	0.	0.	0.	0.
5 119	0.	0.	0.	0.	0.
5 120	0.	0.	0.	0.	0.
5 121	0.	0.	0.	0.	0.
5 122	0.	0.	0.	0.	0.
5 123	0.	0.	0.	0.	0.
5 124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE122 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 2 1	0.	0.	0.	0.	0.
5 2 2	0.	0.	0.	0.	0.
5 2 3	0.	0.	0.	0.	0.
5 2 4	0.	0.	0.	0.	0.
5 2 5	0.	0.	0.	0.	0.
5 2 6	0.	0.	0.	0.	0.
5 2 7	0.	0.	0.	0.	0.
5 2 8	0.	0.	0.	0.	0.
5 2 9	0.	0.	0.	0.	0.
5 210	0.	0.	0.	0.	0.
5 211	0.	0.	0.	0.	0.
5 212	0.	0.	0.	0.	0.
5 213	0.	0.	0.	0.	0.
5 214	0.	0.	0.	0.	0.
5 215	0.	0.	0.	0.	0.
5 216	0.	0.	0.	0.	0.
5 217	0.	0.	0.	0.	0.
5 218	0.	0.	0.	0.	0.
5 219	0.	0.	0.	0.	0.
5 220	0.	0.	0.	0.	0.
5 221	0.	0.	0.	0.	0.
5 222	0.	0.	0.	0.	0.
5 223	0.	0.	0.	0.	0.
5 224	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE123 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 3 1	0.	0.	0.	0.	0.
5 3 2	0.	0.	0.	0.	0.
5 3 3	0.	0.	0.	0.	0.
5 3 4	0.	0.	0.	0.	0.
5 3 5	0.	0.	0.	0.	0.
5 3 6	0.	0.	0.	0.	0.
5 3 7	0.	0.	0.	0.	0.
5 3 8	0.	0.	0.	0.	0.
5 3 9	0.	0.	0.	0.	0.
5 310	0.	0.	0.	0.	0.
5 311	0.	0.	0.	0.	0.
5 312	0.	0.	0.	0.	0.
5 313	0.	0.	0.	0.	0.
5 314	0.	0.	0.	0.	0.
5 315	0.	0.	0.	0.	0.
5 316	0.	0.	0.	0.	0.
5 317	0.	0.	0.	0.	0.
5 318	0.	0.	0.	0.	0.
5 319	0.	0.	0.	0.	0.
5 320	0.	0.	0.	0.	0.
5 321	0.	0.	0.	0.	0.
5 322	0.	0.	0.	0.	0.
5 323	0.	0.	0.	0.	0.
5 324	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE124 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 4 1	0.	0.	0.	0.	0.
5 4 2	0.	0.	0.	0.	0.
5 4 3	0.	0.	0.	0.	0.
5 4 4	0.	0.	0.	0.	0.
5 4 5	0.	0.	0.	0.	0.
5 4 6	0.	0.	0.	0.	0.
5 4 7	0.	0.	0.	0.	0.
5 4 8	0.	0.	0.	0.	0.
5 4 9	0.	0.	0.	0.	0.
5 410	0.	0.	0.	0.	0.
5 411	0.	0.	0.	0.	0.
5 412	0.	0.	0.	0.	0.
5 413	0.	0.	0.	0.	0.
5 414	0.	0.	0.	0.	0.
5 415	0.	0.	0.	0.	0.
5 416	0.	0.	0.	0.	0.
5 417	0.	0.	0.	0.	0.
5 418	0.	0.	0.	0.	0.
5 419	0.	0.	0.	0.	0.
5 420	0.	0.	0.	0.	0.
5 421	0.	0.	0.	0.	0.
5 422	0.	0.	0.	0.	0.
5 423	0.	0.	0.	0.	0.
5 424	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE125 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 5 1	0.	0.	0.	0.	0.
5 5 2	0.	0.	0.	0.	0.
5 5 3	0.	0.	0.	0.	0.
5 5 4	0.	0.	0.	0.	0.
5 5 5	0.	0.	0.	0.	0.
5 5 6	0.	0.	0.	0.	0.
5 5 7	0.	0.	0.	0.	0.
5 5 8	0.	0.	0.	0.	0.
5 5 9	0.	0.	0.	0.	0.
5 510	0.	0.	0.	0.	0.
5 511	0.	0.	0.	0.	0.
5 512	0.	0.	0.	0.	0.
5 513	0.	0.	0.	0.	0.
5 514	0.	0.	0.	0.	0.
5 515	0.	0.	0.	0.	0.
5 516	0.	0.	0.	0.	0.
5 517	0.	0.	0.	0.	0.
5 518	0.	0.	0.	0.	0.
5 519	0.	0.	0.	0.	0.
5 520	0.	0.	0.	0.	0.
5 521	0.	0.	0.	0.	0.
5 522	0.	0.	0.	0.	0.
5 523	0.	0.	0.	0.	0.
5 524	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE126 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 6 1	0.	0.	0.	0.	0.
5 6 2	0.	0.	0.	0.	0.
5 6 3	0.	0.	0.	0.	0.
5 6 4	0.	0.	0.	0.	0.
5 6 5	0.	0.	0.	0.	0.
5 6 6	0.	0.	0.	0.	0.
5 6 7	0.	0.	0.	0.	0.
5 6 8	0.	0.	0.	0.	0.
5 6 9	0.	0.	0.	0.	0.
5 610	0.	0.	0.	0.	0.
5 611	0.	0.	0.	0.	0.
5 612	0.	0.	0.	0.	0.
5 613	0.	0.	0.	0.	0.
5 614	0.	0.	0.	0.	0.
5 615	0.	0.	0.	0.	0.
5 616	0.	0.	0.	0.	0.
5 617	0.	0.	0.	0.	0.
5 618	0.	0.	0.	0.	0.
5 619	0.	0.	0.	0.	0.
5 620	0.	0.	0.	0.	0.
5 621	0.	0.	0.	0.	0.
5 622	0.	0.	0.	0.	0.
5 623	0.	0.	0.	0.	0.
5 624	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE127 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 7 1	0.	0.	0.	0.	0.
5 7 2	0.	0.	0.	0.	0.
5 7 3	0.	0.	0.	0.	0.
5 7 4	0.	0.	0.	0.	0.
5 7 5	0.	0.	0.	0.	0.
5 7 6	0.	0.	0.	0.	0.
5 7 7	0.	0.	0.	0.	0.
5 7 8	0.	0.	0.	0.	0.
5 7 9	0.	0.	0.	0.	0.
5 710	0.	0.	0.	0.	0.
5 711	0.	0.	0.	0.	0.
5 712	0.	0.	0.	0.	0.
5 713	0.	0.	0.	0.	0.
5 714	0.	0.	0.	0.	0.
5 715	0.	0.	0.	0.	0.
5 716	0.	0.	0.	0.	0.
5 717	0.	0.	0.	0.	0.
5 718	0.	0.	0.	0.	0.
5 719	0.	0.	0.	0.	0.
5 720	0.	0.	0.	0.	0.
5 721	0.	0.	0.	0.	0.
5 722	0.	0.	0.	0.	0.
5 723	0.	0.	0.	0.	0.
5 724	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE128 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 8 1	0.	0.	0.	0.	0.
5 8 2	0.	0.	0.	0.	0.
5 8 3	0.	0.	0.	0.	0.
5 8 4	0.	0.	0.	0.	0.
5 8 5	0.	0.	0.	0.	0.
5 8 6	0.	0.	0.	0.	0.
5 8 7	0.	0.	0.	0.	0.
5 8 8	0.	0.	0.	0.	0.
5 8 9	0.	0.	0.	0.	0.
5 810	0.	0.	0.	0.	0.
5 811	0.	0.	0.	0.	0.
5 812	0.	0.	0.	0.	0.
5 813	0.	0.	0.	0.	0.
5 814	0.	0.	0.	0.	0.
5 815	0.	0.	0.	0.	0.
5 816	0.	0.	0.	0.	0.
5 817	0.	0.	0.	0.	0.
5 818	0.	0.	0.	0.	0.
5 819	0.	0.	0.	0.	0.
5 820	0.	0.	0.	0.	0.
5 821	0.	0.	0.	0.	0.
5 822	0.	0.	0.	0.	0.
5 823	0.	0.	0.	0.	0.
5 824	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE129 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
5 9 1	0.	0.	0.	0.	0.
5 9 2	0.	0.	0.	0.	0.
5 9 3	0.	0.	0.	0.	0.
5 9 4	0.	0.	0.	0.	0.
5 9 5	0.	0.	0.	0.	0.
5 9 6	0.	0.	0.	0.	0.
5 9 7	0.	0.	0.	0.	0.
5 9 8	0.	0.	0.	0.	0.
5 9 9	0.	0.	0.	0.	0.
5 910	0.	0.	0.	0.	0.
5 911	0.	0.	0.	0.	0.
5 912	0.	0.	0.	0.	0.
5 913	0.	0.	0.	0.	0.
5 914	0.	0.	0.	0.	0.
5 915	0.	0.	0.	0.	0.
5 916	0.	0.	0.	0.	0.
5 917	0.	0.	0.	0.	0.
5 918	0.	0.	0.	0.	0.
5 919	0.	0.	0.	0.	0.
5 920	0.	0.	0.	0.	0.
5 921	0.	0.	0.	0.	0.
5 922	0.	0.	0.	0.	0.
5 923	0.	0.	0.	0.	0.
5 924	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE130 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
510 1	0.	0.	0.	0.	0.
510 2	0.	0.	0.	0.	0.
510 3	0.	0.	0.	0.	0.
510 4	0.	0.	0.	0.	0.
510 5	0.	0.	0.	0.	0.
510 6	0.	0.	0.	0.	0.
510 7	0.	0.	0.	0.	0.
510 8	0.	0.	0.	0.	0.
510 9	0.	0.	0.	0.	0.
51010	0.	0.	0.	0.	0.
51011	0.	0.	0.	0.	0.
51012	0.	0.	0.	0.	0.
51013	0.	0.	0.	0.	0.
51014	0.	0.	0.	0.	0.
51015	0.	0.	0.	0.	0.
51016	0.	0.	0.	0.	0.
51017	0.	0.	0.	0.	0.
51018	0.	0.	0.	0.	0.
51019	0.	0.	0.	0.	0.
51020	0.	0.	0.	0.	0.
51021	0.	0.	0.	0.	0.
51022	0.	0.	0.	0.	0.
51023	0.	0.	0.	0.	0.
51024	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE131 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
511 1	0.	0.	0.	0.	0.
511 2	0.	0.	0.	0.	0.
511 3	0.	0.	0.	0.	0.
511 4	0.	0.	0.	0.	0.
511 5	0.	0.	0.	0.	0.
511 6	0.	0.	0.	0.	0.
511 7	0.	0.	0.	0.	0.
511 8	0.	0.	0.	0.	0.
511 9	0.	0.	0.	0.	0.
51110	0.	0.	0.	0.	0.
51111	0.	0.	0.	0.	0.
51112	0.	0.	0.	0.	0.
51113	0.	0.	0.	0.	0.
51114	0.	0.	0.	0.	0.
51115	0.	0.	0.	0.	0.
51116	0.	0.	0.	0.	0.
51117	0.	0.	0.	0.	0.
51118	0.	0.	0.	0.	0.
51119	0.	0.	0.	0.	0.
51120	0.	0.	0.	0.	0.
51121	0.	0.	0.	0.	0.
51122	0.	0.	0.	0.	0.
51123	0.	0.	0.	0.	0.
51124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE132 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
512 1	0.	0.	0.	0.	0.
512 2	0.	0.	0.	0.	0.
512 3	0.	0.	0.	0.	0.
512 4	0.	0.	0.	0.	0.
512 5	0.	0.	0.	0.	0.
512 6	0.	0.	0.	0.	0.
512 7	0.	0.	0.	0.	0.
512 8	0.	0.	0.	0.	0.
512 9	0.	0.	0.	0.	0.
51210	0.	0.	0.	0.	0.
51211	0.	0.	0.	0.	0.
51212	0.	0.	0.	0.	0.
51213	0.	0.	0.	0.	0.
51214	0.	0.	0.	0.	0.
51215	0.	0.	0.	0.	0.
51216	0.	0.	0.	0.	0.
51217	0.	0.	0.	0.	0.
51218	0.	0.	0.	0.	0.
51219	0.	0.	0.	0.	0.
51220	0.	0.	0.	0.	0.
51221	0.	0.	0.	0.	0.
51222	0.	0.	0.	0.	0.
51223	0.	0.	0.	0.	0.
51224	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE133 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
513 1	0.	0.	0.	0.	0.
513 2	0.	0.	0.	0.	0.
513 3	0.	0.	0.	0.	0.
513 4	0.	0.	0.	0.	0.
513 5	0.	0.	0.	0.	0.
513 6	0.	0.	0.	0.	0.
513 7	0.	0.	0.	0.	0.
513 8	0.	0.	0.	0.	0.
513 9	0.	0.	0.	0.	0.
51310	0.	0.	0.	0.	0.
51311	0.	0.	0.	0.	0.
51312	0.	0.	0.	0.	0.
51313	0.	0.	0.	0.	0.
51314	0.	0.	0.	0.	0.
51315	0.	0.	0.	0.	0.
51316	0.	0.	0.	0.	0.
51317	0.	0.	0.	0.	0.
51318	0.	0.	0.	0.	0.
51319	0.	0.	0.	0.	0.
51320	0.	0.	0.	0.	0.
51321	0.	0.	0.	0.	0.
51322	0.	0.	0.	0.	0.
51323	0.	0.	0.	0.	0.
51324	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE134 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
514 1	0.	0.	0.	0.	0.
514 2	0.	0.	0.	0.	0.
514 3	0.	0.	0.	0.	0.
514 4	0.	0.	0.	0.	0.
514 5	0.	0.	0.	0.	0.
514 6	0.	0.	0.	0.	0.
514 7	0.	0.	0.	0.	0.
514 8	0.	0.	0.	0.	0.
514 9	0.	0.	0.	0.	0.
51410	0.	0.	0.	0.	0.
51411	0.	0.	0.	0.	0.
51412	0.	0.	0.	0.	0.
51413	0.	0.	0.	0.	0.
51414	0.	0.	0.	0.	0.
51415	0.	0.	0.	0.	0.
51416	0.	0.	0.	0.	0.
51417	0.	0.	0.	0.	0.
51418	0.	0.	0.	0.	0.
51419	0.	0.	0.	0.	0.
51420	0.	0.	0.	0.	0.
51421	0.	0.	0.	0.	0.
51422	0.	0.	0.	0.	0.
51423	0.	0.	0.	0.	0.
51424	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE135 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
515 1	0.	0.	0.	0.	0.
515 2	0.	0.	0.	0.	0.
515 3	0.	0.	0.	0.	0.
515 4	0.	0.	0.	0.	0.
515 5	0.	0.	0.	0.	0.
515 6	0.	0.	0.	0.	0.
515 7	0.	0.	0.	0.	0.
515 8	0.	0.	0.	0.	0.
515 9	0.	0.	0.	0.	0.
51510	0.	0.	0.	0.	0.
51511	0.	0.	0.	0.	0.
51512	0.	0.	0.	0.	0.
51513	0.	0.	0.	0.	0.
51514	0.	0.	0.	0.	0.
51515	0.	0.	0.	0.	0.
51516	0.	0.	0.	0.	0.
51517	0.	0.	0.	0.	0.
51518	0.	0.	0.	0.	0.
51519	0.	0.	0.	0.	0.
51520	0.	0.	0.	0.	0.
51521	0.	0.	0.	0.	0.
51522	0.	0.	0.	0.	0.
51523	0.	0.	0.	0.	0.
51524	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE136 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
516 1	0.	0.	0.	0.	0.
516 2	0.	0.	0.	0.	0.
516 3	0.	0.	0.	0.	0.
516 4	0.	0.	0.	0.	0.
516 5	0.	0.	0.	0.	0.
516 6	0.	0.	0.	0.	0.
516 7	0.	0.	0.	0.	0.
516 8	0.	0.	0.	0.	0.
516 9	0.	0.	0.	0.	0.
51610	0.	0.	0.	0.	0.
51611	0.	0.	0.	0.	0.
51612	0.	0.	0.	0.	0.
51613	0.	0.	0.	0.	0.
51614	0.	0.	0.	0.	0.
51615	0.	0.	0.	0.	0.
51616	0.	0.	0.	0.	0.
51617	0.	0.	0.	0.	0.
51618	0.	0.	0.	0.	0.
51619	0.	0.	0.	0.	0.
51620	0.	0.	0.	0.	0.
51621	0.	0.	0.	0.	0.
51622	0.	0.	0.	0.	0.
51623	0.	0.	0.	0.	0.
51624	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE137 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
517 1	0.	0.	0.	0.	0.
517 2	0.	0.	0.	0.	0.
517 3	0.	0.	0.	0.	0.
517 4	0.	0.	0.	0.	0.
517 5	0.	0.	0.	0.	0.
517 6	0.	0.	0.	0.	0.
517 7	0.	0.	0.	0.	0.
517 8	0.	0.	0.	0.	0.
517 9	0.	0.	0.	0.	0.
51710	0.	0.	0.	0.	0.
51711	0.	0.	0.	0.	0.
51712	0.	0.	0.	0.	0.
51713	0.	0.	0.	0.	0.
51714	0.	0.	0.	0.	0.
51715	0.	0.	0.	0.	0.
51716	0.	0.	0.	0.	0.
51717	0.	0.	0.	0.	0.
51718	0.	0.	0.	0.	0.
51719	0.	0.	0.	0.	0.
51720	0.	0.	0.	0.	0.
51721	0.	0.	0.	0.	0.
51722	0.	0.	0.	0.	0.
51723	0.	0.	0.	0.	0.
51724	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE138 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
518 1	0.	0.	0.	0.	0.
518 2	0.	0.	0.	0.	0.
518 3	0.	0.	0.	0.	0.
518 4	0.	0.	0.	0.	0.
518 5	0.	0.	0.	0.	0.
518 6	0.	0.	0.	0.	0.
518 7	0.	0.	0.	0.	0.
518 8	0.	0.	0.	0.	0.
518 9	0.	0.	0.	0.	0.
51810	0.	0.	0.	0.	0.
51811	0.	0.	0.	0.	0.
51812	0.	0.	0.	0.	0.
51813	0.	0.	0.	0.	0.
51814	0.	0.	0.	0.	0.
51815	0.	0.	0.	0.	0.
51816	0.	0.	0.	0.	0.
51817	0.	0.	0.	0.	0.
51818	0.	0.	0.	0.	0.
51819	0.	0.	0.	0.	0.
51820	0.	0.	0.	0.	0.
51821	0.	0.	0.	0.	0.
51822	0.	0.	0.	0.	0.
51823	0.	0.	0.	0.	0.
51824	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE139 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
519 1	0.	0.	0.	0.	0.
519 2	0.	0.	0.	0.	0.
519 3	0.	0.	0.	0.	0.
519 4	0.	0.	0.	0.	0.
519 5	0.	0.	0.	0.	0.
519 6	0.	0.	0.	0.	0.
519 7	0.	0.	0.	0.	0.
519 8	0.	0.	0.	0.	0.
519 9	0.	0.	0.	0.	0.
51910	0.	0.	0.	0.	0.
51911	0.	0.	0.	0.	0.
51912	0.	0.	0.	0.	0.
51913	0.	0.	0.	0.	0.
51914	0.	0.	0.	0.	0.
51915	0.	0.	0.	0.	0.
51916	0.	0.	0.	0.	0.
51917	0.	0.	0.	0.	0.
51918	0.	0.	0.	0.	0.
51919	0.	0.	0.	0.	0.
51920	0.	0.	0.	0.	0.
51921	0.	0.	0.	0.	0.
51922	0.	0.	0.	0.	0.
51923	0.	0.	0.	0.	0.
51924	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE140 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
520 1	0.	0.	0.	0.	0.
520 2	0.	0.	0.	0.	0.
520 3	0.	0.	0.	0.	0.
520 4	0.	0.	0.	0.	0.
520 5	0.	0.	0.	0.	0.
520 6	0.	0.	0.	0.	0.
520 7	0.	0.	0.	0.	0.
520 8	0.	0.	0.	0.	0.
520 9	0.	0.	0.	0.	0.
52010	0.	0.	0.	0.	0.
52011	0.	0.	0.	0.	0.
52012	0.	0.	0.	0.	0.
52013	0.	0.	0.	0.	0.
52014	0.	0.	0.	0.	0.
52015	0.	0.	0.	0.	0.
52016	0.	0.	0.	0.	0.
52017	0.	0.	0.	0.	0.
52018	0.	0.	0.	0.	0.
52019	0.	0.	0.	0.	0.
52020	0.	0.	0.	0.	0.
52021	0.	0.	0.	0.	0.
52022	0.	0.	0.	0.	0.
52023	0.	0.	0.	0.	0.
52024	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE141 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
521 1	0.	0.	0.	0.	0.
521 2	0.	0.	0.	0.	0.
521 3	0.	0.	0.	0.	0.
521 4	0.	0.	0.	0.	0.
521 5	0.	0.	0.	0.	0.
521 6	0.	0.	0.	0.	0.
521 7	0.	0.	0.	0.	0.
521 8	0.	0.	0.	0.	0.
521 9	0.	0.	0.	0.	0.
52110	0.	0.	0.	0.	0.
52111	0.	0.	0.	0.	0.
52112	0.	0.	0.	0.	0.
52113	0.	0.	0.	0.	0.
52114	0.	0.	0.	0.	0.
52115	0.	0.	0.	0.	0.
52116	0.	0.	0.	0.	0.
52117	0.	0.	0.	0.	0.
52118	0.	0.	0.	0.	0.
52119	0.	0.	0.	0.	0.
52120	0.	0.	0.	0.	0.
52121	0.	0.	0.	0.	0.
52122	0.	0.	0.	0.	0.
52123	0.	0.	0.	0.	0.
52124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE142 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
522 1	0.	0.	0.	0.	0.
522 2	0.	0.	0.	0.	0.
522 3	0.	0.	0.	0.	0.
522 4	0.	0.	0.	0.	0.
522 5	0.	0.	0.	0.	0.
522 6	0.	0.	0.	0.	0.
522 7	0.	0.	0.	0.	0.
522 8	0.	0.	0.	0.	0.
522 9	0.	0.	0.	0.	0.
52210	0.	0.	0.	0.	0.
52211	0.	0.	0.	0.	0.
52212	0.	0.	0.	0.	0.
52213	0.	0.	0.	0.	0.
52214	0.	0.	0.	0.	0.
52215	0.	0.	0.	0.	0.
52216	0.	0.	0.	0.	0.
52217	0.	0.	0.	0.	0.
52218	0.	0.	0.	0.	0.
52219	0.	0.	0.	0.	0.
52220	0.	0.	0.	0.	0.
52221	0.	0.	0.	0.	0.
52222	0.	0.	0.	0.	0.
52223	0.	0.	0.	0.	0.
52224	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE143 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
523 1	0.	0.	0.	0.	0.
523 2	0.	0.	0.	0.	0.
523 3	0.	0.	0.	0.	0.
523 4	0.	0.	0.	0.	0.
523 5	0.	0.	0.	0.	0.
523 6	0.	0.	0.	0.	0.
523 7	0.	0.	0.	0.	0.
523 8	0.	0.	0.	0.	0.
523 9	0.	0.	0.	0.	0.
52310	0.	0.	0.	0.	0.
52311	0.	0.	0.	0.	0.
52312	0.	0.	0.	0.	0.
52313	0.	0.	0.	0.	0.
52314	0.	0.	0.	0.	0.
52315	0.	0.	0.	0.	0.
52316	0.	0.	0.	0.	0.
52317	0.	0.	0.	0.	0.
52318	0.	0.	0.	0.	0.
52319	0.	0.	0.	0.	0.
52320	0.	0.	0.	0.	0.
52321	0.	0.	0.	0.	0.
52322	0.	0.	0.	0.	0.
52323	0.	0.	0.	0.	0.
52324	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE144 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
524 1	0.	0.	0.	0.	0.
524 2	0.	0.	0.	0.	0.
524 3	0.	0.	0.	0.	0.
524 4	0.	0.	0.	0.	0.
524 5	0.	0.	0.	0.	0.
524 6	0.	0.	0.	0.	0.
524 7	0.	0.	0.	0.	0.
524 8	0.	0.	0.	0.	0.
524 9	0.	0.	0.	0.	0.
52410	0.	0.	0.	0.	0.
52411	0.	0.	0.	0.	0.
52412	0.	0.	0.	0.	0.
52413	0.	0.	0.	0.	0.
52414	0.	0.	0.	0.	0.
52415	0.	0.	0.	0.	0.
52416	0.	0.	0.	0.	0.
52417	0.	0.	0.	0.	0.
52418	0.	0.	0.	0.	0.
52419	0.	0.	0.	0.	0.
52420	0.	0.	0.	0.	0.
52421	0.	0.	0.	0.	0.
52422	0.	0.	0.	0.	0.
52423	0.	0.	0.	0.	0.
52424	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE145 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
525 1	0.	0.	0.	0.	0.
525 2	0.	0.	0.	0.	0.
525 3	0.	0.	0.	0.	0.
525 4	0.	0.	0.	0.	0.
525 5	0.	0.	0.	0.	0.
525 6	0.	0.	0.	0.	0.
525 7	0.	0.	0.	0.	0.
525 8	0.	0.	0.	0.	0.
525 9	0.	0.	0.	0.	0.
52510	0.	0.	0.	0.	0.
52511	0.	0.	0.	0.	0.
52512	0.	0.	0.	0.	0.
52513	0.	0.	0.	0.	0.
52514	0.	0.	0.	0.	0.
52515	0.	0.	0.	0.	0.
52516	0.	0.	0.	0.	0.
52517	0.	0.	0.	0.	0.
52518	0.	0.	0.	0.	0.
52519	0.	0.	0.	0.	0.
52520	0.	0.	0.	0.	0.
52521	0.	0.	0.	0.	0.
52522	0.	0.	0.	0.	0.
52523	0.	0.	0.	0.	0.
52524	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE146 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
526 1	0.	0.	0.	0.	0.
526 2	0.	0.	0.	0.	0.
526 3	0.	0.	0.	0.	0.
526 4	0.	0.	0.	0.	0.
526 5	0.	0.	0.	0.	0.
526 6	0.	0.	0.	0.	0.
526 7	0.	0.	0.	0.	0.
526 8	0.	0.	0.	0.	0.
526 9	0.	0.	0.	0.	0.
52610	0.	0.	0.	0.	0.
52611	0.	0.	0.	0.	0.
52612	0.	0.	0.	0.	0.
52613	0.	0.	0.	0.	0.
52614	0.	0.	0.	0.	0.
52615	0.	0.	0.	0.	0.
52616	0.	0.	0.	0.	0.
52617	0.	0.	0.	0.	0.
52618	0.	0.	0.	0.	0.
52619	0.	0.	0.	0.	0.
52620	0.	0.	0.	0.	0.
52621	0.	0.	0.	0.	0.
52622	0.	0.	0.	0.	0.
52623	0.	0.	0.	0.	0.
52624	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE147 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
527 1	0.	0.	0.	0.	0.
527 2	0.	0.	0.	0.	0.
527 3	0.	0.	0.	0.	0.
527 4	0.	0.	0.	0.	0.
527 5	0.	0.	0.	0.	0.
527 6	0.	0.	0.	0.	0.
527 7	0.	0.	0.	0.	0.
527 8	0.	0.	0.	0.	0.
527 9	0.	0.	0.	0.	0.
52710	0.	0.	0.	0.	0.
52711	0.	0.	0.	0.	0.
52712	0.	0.	0.	0.	0.
52713	0.	0.	0.	0.	0.
52714	0.	0.	0.	0.	0.
52715	0.	0.	0.	0.	0.
52716	0.	0.	0.	0.	0.
52717	0.	0.	0.	0.	0.
52718	0.	0.	0.	0.	0.
52719	0.	0.	0.	0.	0.
52720	0.	0.	0.	0.	0.
52721	0.	0.	0.	0.	0.
52722	0.	0.	0.	0.	0.
52723	0.	0.	0.	0.	0.
52724	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE148 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
528 1	0.	0.	0.	0.	0.
528 2	0.	0.	0.	0.	0.
528 3	0.	0.	0.	0.	0.
528 4	0.	0.	0.	0.	0.
528 5	0.	0.	0.	0.	0.
528 6	0.	0.	0.	0.	0.
528 7	0.	0.	0.	0.	0.
528 8	0.	0.	0.	0.	0.
528 9	0.	0.	0.	0.	0.
52810	0.	0.	0.	0.	0.
52811	0.	0.	0.	0.	0.
52812	0.	0.	0.	0.	0.
52813	0.	0.	0.	0.	0.
52814	0.	0.	0.	0.	0.
52815	0.	0.	0.	0.	0.
52816	0.	0.	0.	0.	0.
52817	0.	0.	0.	0.	0.
52818	0.	0.	0.	0.	0.
52819	0.	0.	0.	0.	0.
52820	0.	0.	0.	0.	0.
52821	0.	0.	0.	0.	0.
52822	0.	0.	0.	0.	0.
52823	0.	0.	0.	0.	0.
52824	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE149 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
529 1	0.	0.	0.	0.	0.
529 2	0.	0.	0.	0.	0.
529 3	0.	0.	0.	0.	0.
529 4	0.	0.	0.	0.	0.
529 5	0.	0.	0.	0.	0.
529 6	0.	0.	0.	0.	0.
529 7	0.	0.	0.	0.	0.
529 8	0.	0.	0.	0.	0.
529 9	0.	0.	0.	0.	0.
52910	0.	0.	0.	0.	0.
52911	0.	0.	0.	0.	0.
52912	0.	0.	0.	0.	0.
52913	0.	0.	0.	0.	0.
52914	0.	0.	0.	0.	0.
52915	0.	0.	0.	0.	0.
52916	0.	0.	0.	0.	0.
52917	0.	0.	0.	0.	0.
52918	0.	0.	0.	0.	0.
52919	0.	0.	0.	0.	0.
52920	0.	0.	0.	0.	0.
52921	0.	0.	0.	0.	0.
52922	0.	0.	0.	0.	0.
52923	0.	0.	0.	0.	0.
52924	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE150 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
530 1	0.	0.	0.	0.	0.
530 2	0.	0.	0.	0.	0.
530 3	0.	0.	0.	0.	0.
530 4	0.	0.	0.	0.	0.
530 5	0.	0.	0.	0.	0.
530 6	0.	0.	0.	0.	0.
530 7	0.	0.	0.	0.	0.
530 8	0.	0.	0.	0.	0.
530 9	0.	0.	0.	0.	0.
53010	0.	0.	0.	0.	0.
53011	0.	0.	0.	0.	0.
53012	0.	0.	0.	0.	0.
53013	0.	0.	0.	0.	0.
53014	0.	0.	0.	0.	0.
53015	0.	0.	0.	0.	0.
53016	0.	0.	0.	0.	0.
53017	0.	0.	0.	0.	0.
53018	0.	0.	0.	0.	0.
53019	0.	0.	0.	0.	0.
53020	0.	0.	0.	0.	0.
53021	0.	0.	0.	0.	0.
53022	0.	0.	0.	0.	0.
53023	0.	0.	0.	0.	0.
53024	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE151 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
531 1	0.	0.	0.	0.	0.
531 2	0.	0.	0.	0.	0.
531 3	0.	0.	0.	0.	0.
531 4	0.	0.	0.	0.	0.
531 5	0.	0.	0.	0.	0.
531 6	0.	0.	0.	0.	0.
531 7	0.	0.	0.	0.	0.
531 8	0.	0.	0.	0.	0.
531 9	0.	0.	0.	0.	0.
53110	0.	0.	0.	0.	0.
53111	0.	0.	0.	0.	0.
53112	0.	0.	0.	0.	0.
53113	0.	0.	0.	0.	0.
53114	0.	0.	0.	0.	0.
53115	0.	0.	0.	0.	0.
53116	0.	0.	0.	0.	0.
53117	0.	0.	0.	0.	0.
53118	0.	0.	0.	0.	0.
53119	0.	0.	0.	0.	0.
53120	0.	0.	0.	0.	0.
53121	0.	0.	0.	0.	0.
53122	0.	0.	0.	0.	0.
53123	0.	0.	0.	0.	0.
53124	0.	0.	0.	0.	0.
DAILY SUMMARY (MAY 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (MAY)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE152 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 1 1	0.	0.	0.	0.	0.
6 1 2	0.	0.	0.	0.	0.
6 1 3	0.	0.	0.	0.	0.
6 1 4	0.	0.	0.	0.	0.
6 1 5	0.	0.	0.	0.	0.
6 1 6	0.	0.	0.	0.	0.
6 1 7	0.	0.	0.	0.	0.
6 1 8	0.	0.	0.	0.	0.
6 1 9	0.	0.	0.	0.	0.
6 110	0.	0.	0.	0.	0.
6 111	0.	0.	0.	0.	0.
6 112	0.	0.	0.	0.	0.
6 113	0.	0.	0.	0.	0.
6 114	0.	0.	0.	0.	0.
6 115	0.	0.	0.	0.	0.
6 116	0.	0.	0.	0.	0.
6 117	0.	0.	0.	0.	0.
6 118	0.	0.	0.	0.	0.
6 119	0.	0.	0.	0.	0.
6 120	0.	0.	0.	0.	0.
6 121	0.	0.	0.	0.	0.
6 122	0.	0.	0.	0.	0.
6 123	0.	0.	0.	0.	0.
6 124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE153 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 2 1	0.	0.	0.	0.	0.
6 2 2	0.	0.	0.	0.	0.
6 2 3	0.	0.	0.	0.	0.
6 2 4	0.	0.	0.	0.	0.
6 2 5	0.	0.	0.	0.	0.
6 2 6	0.	0.	0.	0.	0.
6 2 7	0.	0.	0.	0.	0.
6 2 8	0.	0.	0.	0.	0.
6 2 9	0.	0.	0.	0.	0.
6 210	0.	0.	0.	0.	0.
6 211	0.	0.	0.	0.	0.
6 212	0.	0.	0.	0.	0.
6 213	0.	0.	0.	0.	0.
6 214	0.	0.	0.	0.	0.
6 215	0.	0.	0.	0.	0.
6 216	0.	0.	0.	0.	0.
6 217	0.	0.	0.	0.	0.
6 218	0.	0.	0.	0.	0.
6 219	0.	0.	0.	0.	0.
6 220	0.	0.	0.	0.	0.
6 221	0.	0.	0.	0.	0.
6 222	0.	0.	0.	0.	0.
6 223	0.	0.	0.	0.	0.
6 224	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE154 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 3 1	0.	0.	0.	0.	0.
6 3 2	0.	0.	0.	0.	0.
6 3 3	0.	0.	0.	0.	0.
6 3 4	0.	0.	0.	0.	0.
6 3 5	0.	0.	0.	0.	0.
6 3 6	0.	0.	0.	0.	0.
6 3 7	0.	0.	0.	0.	0.
6 3 8	0.	0.	0.	0.	0.
6 3 9	0.	0.	0.	0.	0.
6 310	0.	0.	0.	0.	0.
6 311	0.	0.	0.	0.	0.
6 312	0.	0.	0.	0.	0.
6 313	0.	0.	0.	0.	0.
6 314	0.	0.	0.	0.	0.
6 315	0.	0.	0.	0.	0.
6 316	0.	0.	0.	0.	0.
6 317	0.	0.	0.	0.	0.
6 318	0.	0.	0.	0.	0.
6 319	0.	0.	0.	0.	0.
6 320	0.	0.	0.	0.	0.
6 321	0.	0.	0.	0.	0.
6 322	0.	0.	0.	0.	0.
6 323	0.	0.	0.	0.	0.
6 324	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE155 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 4 1	0.	0.	0.	0.	0.
6 4 2	0.	0.	0.	0.	0.
6 4 3	0.	0.	0.	0.	0.
6 4 4	0.	0.	0.	0.	0.
6 4 5	0.	0.	0.	0.	0.
6 4 6	0.	0.	0.	0.	0.
6 4 7	0.	0.	0.	0.	0.
6 4 8	0.	0.	0.	0.	0.
6 4 9	0.	0.	0.	0.	0.
6 410	0.	0.	0.	0.	0.
6 411	0.	0.	0.	0.	0.
6 412	0.	0.	0.	0.	0.
6 413	0.	0.	0.	0.	0.
6 414	0.	0.	0.	0.	0.
6 415	0.	0.	0.	0.	0.
6 416	0.	0.	0.	0.	0.
6 417	0.	0.	0.	0.	0.
6 418	0.	0.	0.	0.	0.
6 419	0.	0.	0.	0.	0.
6 420	0.	0.	0.	0.	0.
6 421	0.	0.	0.	0.	0.
6 422	0.	0.	0.	0.	0.
6 423	0.	0.	0.	0.	0.
6 424	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE156 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 5 1	0.	0.	0.	0.	0.
6 5 2	0.	0.	0.	0.	0.
6 5 3	0.	0.	0.	0.	0.
6 5 4	0.	0.	0.	0.	0.
6 5 5	0.	0.	0.	0.	0.
6 5 6	0.	0.	0.	0.	0.
6 5 7	0.	0.	0.	0.	0.
6 5 8	0.	0.	0.	0.	0.
6 5 9	0.	0.	0.	0.	0.
6 510	0.	0.	0.	0.	0.
6 511	0.	0.	0.	0.	0.
6 512	0.	0.	0.	0.	0.
6 513	0.	0.	0.	0.	0.
6 514	0.	0.	0.	0.	0.
6 515	0.	0.	0.	0.	0.
6 516	0.	0.	0.	0.	0.
6 517	0.	0.	0.	0.	0.
6 518	0.	0.	0.	0.	0.
6 519	0.	0.	0.	0.	0.
6 520	0.	0.	0.	0.	0.
6 521	0.	0.	0.	0.	0.
6 522	0.	0.	0.	0.	0.
6 523	0.	0.	0.	0.	0.
6 524	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE157 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 6 1	0.	0.	0.	0.	0.
6 6 2	0.	0.	0.	0.	0.
6 6 3	0.	0.	0.	0.	0.
6 6 4	0.	0.	0.	0.	0.
6 6 5	0.	0.	0.	0.	0.
6 6 6	0.	0.	0.	0.	0.
6 6 7	0.	0.	0.	0.	0.
6 6 8	0.	0.	0.	0.	0.
6 6 9	0.	0.	0.	0.	0.
6 610	0.	0.	0.	0.	0.
6 611	0.	0.	0.	0.	0.
6 612	0.	0.	0.	0.	0.
6 613	0.	0.	0.	0.	0.
6 614	0.	0.	0.	0.	0.
6 615	0.	0.	0.	0.	0.
6 616	0.	0.	0.	0.	0.
6 617	0.	0.	0.	0.	0.
6 618	0.	0.	0.	0.	0.
6 619	0.	0.	0.	0.	0.
6 620	0.	0.	0.	0.	0.
6 621	0.	0.	0.	0.	0.
6 622	0.	0.	0.	0.	0.
6 623	0.	0.	0.	0.	0.
6 624	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE158 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 7 1	0.	0.	0.	0.	0.
6 7 2	0.	0.	0.	0.	0.
6 7 3	0.	0.	0.	0.	0.
6 7 4	0.	0.	0.	0.	0.
6 7 5	0.	0.	0.	0.	0.
6 7 6	0.	0.	0.	0.	0.
6 7 7	0.	0.	0.	0.	0.
6 7 8	0.	0.	0.	0.	0.
6 7 9	0.	0.	0.	0.	0.
6 710	0.	0.	0.	0.	0.
6 711	0.	0.	0.	0.	0.
6 712	0.	0.	0.	0.	0.
6 713	0.	0.	0.	0.	0.
6 714	0.	0.	0.	0.	0.
6 715	0.	0.	0.	0.	0.
6 716	0.	0.	0.	0.	0.
6 717	0.	0.	0.	0.	0.
6 718	0.	0.	0.	0.	0.
6 719	0.	0.	0.	0.	0.
6 720	0.	0.	0.	0.	0.
6 721	0.	0.	0.	0.	0.
6 722	0.	0.	0.	0.	0.
6 723	0.	0.	0.	0.	0.
6 724	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE159 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 8 1	0.	0.	0.	0.	0.
6 8 2	0.	0.	0.	0.	0.
6 8 3	0.	0.	0.	0.	0.
6 8 4	0.	0.	0.	0.	0.
6 8 5	0.	0.	0.	0.	0.
6 8 6	0.	0.	0.	0.	0.
6 8 7	0.	0.	0.	0.	0.
6 8 8	0.	0.	0.	0.	0.
6 8 9	0.	0.	0.	0.	0.
6 810	0.	0.	0.	0.	0.
6 811	0.	0.	0.	0.	0.
6 812	0.	0.	0.	0.	0.
6 813	0.	0.	0.	0.	0.
6 814	0.	0.	0.	0.	0.
6 815	0.	0.	0.	0.	0.
6 816	0.	0.	0.	0.	0.
6 817	0.	0.	0.	0.	0.
6 818	0.	0.	0.	0.	0.
6 819	0.	0.	0.	0.	0.
6 820	0.	0.	0.	0.	0.
6 821	0.	0.	0.	0.	0.
6 822	0.	0.	0.	0.	0.
6 823	0.	0.	0.	0.	0.
6 824	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE160 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
6 9 1	0.	0.	0.	0.	0.
6 9 2	0.	0.	0.	0.	0.
6 9 3	0.	0.	0.	0.	0.
6 9 4	0.	0.	0.	0.	0.
6 9 5	0.	0.	0.	0.	0.
6 9 6	0.	0.	0.	0.	0.
6 9 7	0.	0.	0.	0.	0.
6 9 8	0.	0.	0.	0.	0.
6 9 9	0.	0.	0.	0.	0.
6 910	0.	0.	0.	0.	0.
6 911	0.	0.	0.	0.	0.
6 912	0.	0.	0.	0.	0.
6 913	0.	0.	0.	0.	0.
6 914	0.	0.	0.	0.	0.
6 915	0.	0.	0.	0.	0.
6 916	0.	0.	0.	0.	0.
6 917	0.	0.	0.	0.	0.
6 918	0.	0.	0.	0.	0.
6 919	0.	0.	0.	0.	0.
6 920	0.	0.	0.	0.	0.
6 921	0.	0.	0.	0.	0.
6 922	0.	0.	0.	0.	0.
6 923	0.	0.	0.	0.	0.
6 924	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE161 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
610 1	0.	0.	0.	0.	0.
610 2	0.	0.	0.	0.	0.
610 3	0.	0.	0.	0.	0.
610 4	0.	0.	0.	0.	0.
610 5	0.	0.	0.	0.	0.
610 6	0.	0.	0.	0.	0.
610 7	0.	0.	0.	0.	0.
610 8	0.	0.	0.	0.	0.
610 9	0.	0.	0.	0.	0.
61010	0.	0.	0.	0.	0.
61011	0.	0.	0.	0.	0.
61012	0.	0.	0.	0.	0.
61013	0.	0.	0.	0.	0.
61014	0.	0.	0.	0.	0.
61015	0.	0.	0.	0.	0.
61016	0.	0.	0.	0.	0.
61017	0.	0.	0.	0.	0.
61018	0.	0.	0.	0.	0.
61019	0.	0.	0.	0.	0.
61020	0.	0.	0.	0.	0.
61021	0.	0.	0.	0.	0.
61022	0.	0.	0.	0.	0.
61023	0.	0.	0.	0.	0.
61024	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE162 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
611 1	0.	0.	0.	0.	0.
611 2	0.	0.	0.	0.	0.
611 3	0.	0.	0.	0.	0.
611 4	0.	0.	0.	0.	0.
611 5	0.	0.	0.	0.	0.
611 6	0.	0.	0.	0.	0.
611 7	0.	0.	0.	0.	0.
611 8	0.	0.	0.	0.	0.
611 9	0.	0.	0.	0.	0.
61110	0.	0.	0.	0.	0.
61111	0.	0.	0.	0.	0.
61112	0.	0.	0.	0.	0.
61113	0.	0.	0.	0.	0.
61114	0.	0.	0.	0.	0.
61115	0.	0.	0.	0.	0.
61116	0.	0.	0.	0.	0.
61117	0.	0.	0.	0.	0.
61118	0.	0.	0.	0.	0.
61119	0.	0.	0.	0.	0.
61120	0.	0.	0.	0.	0.
61121	0.	0.	0.	0.	0.
61122	0.	0.	0.	0.	0.
61123	0.	0.	0.	0.	0.
61124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE163 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
612 1	0.	0.	0.	0.	0.
612 2	0.	0.	0.	0.	0.
612 3	0.	0.	0.	0.	0.
612 4	0.	0.	0.	0.	0.
612 5	0.	0.	0.	0.	0.
612 6	0.	0.	0.	0.	0.
612 7	0.	0.	0.	0.	0.
612 8	0.	0.	0.	0.	0.
612 9	0.	0.	0.	0.	0.
61210	0.	0.	0.	0.	0.
61211	0.	0.	0.	0.	0.
61212	0.	0.	0.	0.	0.
61213	0.	0.	0.	0.	0.
61214	0.	0.	0.	0.	0.
61215	0.	0.	0.	0.	0.
61216	0.	0.	0.	0.	0.
61217	0.	0.	0.	0.	0.
61218	0.	0.	0.	0.	0.
61219	0.	0.	0.	0.	0.
61220	0.	0.	0.	0.	0.
61221	0.	0.	0.	0.	0.
61222	0.	0.	0.	0.	0.
61223	0.	0.	0.	0.	0.
61224	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE164 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
613 1	0.	0.	0.	0.	0.
613 2	0.	0.	0.	0.	0.
613 3	0.	0.	0.	0.	0.
613 4	0.	0.	0.	0.	0.
613 5	0.	0.	0.	0.	0.
613 6	0.	0.	0.	0.	0.
613 7	0.	0.	0.	0.	0.
613 8	0.	0.	0.	0.	0.
613 9	0.	0.	0.	0.	0.
61310	0.	0.	0.	0.	0.
61311	0.	0.	0.	0.	0.
61312	0.	0.	0.	0.	0.
61313	0.	0.	0.	0.	0.
61314	0.	0.	0.	0.	0.
61315	0.	0.	0.	0.	0.
61316	0.	0.	0.	0.	0.
61317	0.	0.	0.	0.	0.
61318	0.	0.	0.	0.	0.
61319	0.	0.	0.	0.	0.
61320	0.	0.	0.	0.	0.
61321	0.	0.	0.	0.	0.
61322	0.	0.	0.	0.	0.
61323	0.	0.	0.	0.	0.
61324	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE165 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
614 1	0.	0.	0.	0.	0.
614 2	0.	0.	0.	0.	0.
614 3	0.	0.	0.	0.	0.
614 4	0.	0.	0.	0.	0.
614 5	0.	0.	0.	0.	0.
614 6	0.	0.	0.	0.	0.
614 7	0.	0.	0.	0.	0.
614 8	0.	0.	0.	0.	0.
614 9	0.	0.	0.	0.	0.
61410	0.	0.	0.	0.	0.
61411	0.	0.	0.	0.	0.
61412	0.	0.	0.	0.	0.
61413	0.	0.	0.	0.	0.
61414	0.	0.	0.	0.	0.
61415	0.	0.	0.	0.	0.
61416	0.	0.	0.	0.	0.
61417	0.	0.	0.	0.	0.
61418	0.	0.	0.	0.	0.
61419	0.	0.	0.	0.	0.
61420	0.	0.	0.	0.	0.
61421	0.	0.	0.	0.	0.
61422	0.	0.	0.	0.	0.
61423	0.	0.	0.	0.	0.
61424	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE166 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
615 1	0.	0.	0.	0.	0.
615 2	0.	0.	0.	0.	0.
615 3	0.	0.	0.	0.	0.
615 4	0.	0.	0.	0.	0.
615 5	0.	0.	0.	0.	0.
615 6	0.	0.	0.	0.	0.
615 7	0.	0.	0.	0.	0.
615 8	0.	0.	0.	0.	0.
615 9	0.	0.	0.	0.	0.
61510	0.	0.	0.	0.	0.
61511	0.	0.	0.	0.	0.
61512	0.	0.	0.	0.	0.
61513	0.	0.	0.	0.	0.
61514	0.	0.	0.	0.	0.
61515	0.	0.	0.	0.	0.
61516	0.	0.	0.	0.	0.
61517	0.	0.	0.	0.	0.
61518	0.	0.	0.	0.	0.
61519	0.	0.	0.	0.	0.
61520	0.	0.	0.	0.	0.
61521	0.	0.	0.	0.	0.
61522	0.	0.	0.	0.	0.
61523	0.	0.	0.	0.	0.
61524	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE167 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
616 1	0.	0.	0.	0.	0.
616 2	0.	0.	0.	0.	0.
616 3	0.	0.	0.	0.	0.
616 4	0.	0.	0.	0.	0.
616 5	0.	0.	0.	0.	0.
616 6	0.	0.	0.	0.	0.
616 7	0.	0.	0.	0.	0.
616 8	0.	0.	0.	0.	0.
616 9	0.	0.	0.	0.	0.
61610	0.	0.	0.	0.	0.
61611	0.	0.	0.	0.	0.
61612	0.	0.	0.	0.	0.
61613	0.	0.	0.	0.	0.
61614	0.	0.	0.	0.	0.
61615	0.	0.	0.	0.	0.
61616	0.	0.	0.	0.	0.
61617	0.	0.	0.	0.	0.
61618	0.	0.	0.	0.	0.
61619	0.	0.	0.	0.	0.
61620	0.	0.	0.	0.	0.
61621	0.	0.	0.	0.	0.
61622	0.	0.	0.	0.	0.
61623	0.	0.	0.	0.	0.
61624	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE168 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
617 1	0.	0.	0.	0.	0.
617 2	0.	0.	0.	0.	0.
617 3	0.	0.	0.	0.	0.
617 4	0.	0.	0.	0.	0.
617 5	0.	0.	0.	0.	0.
617 6	0.	0.	0.	0.	0.
617 7	0.	0.	0.	0.	0.
617 8	0.	0.	0.	0.	0.
617 9	0.	0.	0.	0.	0.
61710	0.	0.	0.	0.	0.
61711	0.	0.	0.	0.	0.
61712	0.	0.	0.	0.	0.
61713	0.	0.	0.	0.	0.
61714	0.	0.	0.	0.	0.
61715	0.	0.	0.	0.	0.
61716	0.	0.	0.	0.	0.
61717	0.	0.	0.	0.	0.
61718	0.	0.	0.	0.	0.
61719	0.	0.	0.	0.	0.
61720	0.	0.	0.	0.	0.
61721	0.	0.	0.	0.	0.
61722	0.	0.	0.	0.	0.
61723	0.	0.	0.	0.	0.
61724	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE169 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
618 1	0.	0.	0.	0.	0.
618 2	0.	0.	0.	0.	0.
618 3	0.	0.	0.	0.	0.
618 4	0.	0.	0.	0.	0.
618 5	0.	0.	0.	0.	0.
618 6	0.	0.	0.	0.	0.
618 7	0.	0.	0.	0.	0.
618 8	0.	0.	0.	0.	0.
618 9	0.	0.	0.	0.	0.
61810	0.	0.	0.	0.	0.
61811	0.	0.	0.	0.	0.
61812	0.	0.	0.	0.	0.
61813	0.	0.	0.	0.	0.
61814	0.	0.	0.	0.	0.
61815	0.	0.	0.	0.	0.
61816	0.	0.	0.	0.	0.
61817	0.	0.	0.	0.	0.
61818	0.	0.	0.	0.	0.
61819	0.	0.	0.	0.	0.
61820	0.	0.	0.	0.	0.
61821	0.	0.	0.	0.	0.
61822	0.	0.	0.	0.	0.
61823	0.	0.	0.	0.	0.
61824	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE170 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
619 1	0.	0.	0.	0.	0.
619 2	0.	0.	0.	0.	0.
619 3	0.	0.	0.	0.	0.
619 4	0.	0.	0.	0.	0.
619 5	0.	0.	0.	0.	0.
619 6	0.	0.	0.	0.	0.
619 7	0.	0.	0.	0.	0.
619 8	0.	0.	0.	0.	0.
619 9	0.	0.	0.	0.	0.
61910	0.	0.	0.	0.	0.
61911	0.	0.	0.	0.	0.
61912	0.	0.	0.	0.	0.
61913	0.	0.	0.	0.	0.
61914	0.	0.	0.	0.	0.
61915	0.	0.	0.	0.	0.
61916	0.	0.	0.	0.	0.
61917	0.	0.	0.	0.	0.
61918	0.	0.	0.	0.	0.
61919	0.	0.	0.	0.	0.
61920	0.	0.	0.	0.	0.
61921	0.	0.	0.	0.	0.
61922	0.	0.	0.	0.	0.
61923	0.	0.	0.	0.	0.
61924	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE171 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
620 1	0.	0.	0.	0.	0.
620 2	0.	0.	0.	0.	0.
620 3	0.	0.	0.	0.	0.
620 4	0.	0.	0.	0.	0.
620 5	0.	0.	0.	0.	0.
620 6	0.	0.	0.	0.	0.
620 7	0.	0.	0.	0.	0.
620 8	0.	0.	0.	0.	0.
620 9	0.	0.	0.	0.	0.
62010	0.	0.	0.	0.	0.
62011	0.	0.	0.	0.	0.
62012	0.	0.	0.	0.	0.
62013	0.	0.	0.	0.	0.
62014	0.	0.	0.	0.	0.
62015	0.	0.	0.	0.	0.
62016	0.	0.	0.	0.	0.
62017	0.	0.	0.	0.	0.
62018	0.	0.	0.	0.	0.
62019	0.	0.	0.	0.	0.
62020	0.	0.	0.	0.	0.
62021	0.	0.	0.	0.	0.
62022	0.	0.	0.	0.	0.
62023	0.	0.	0.	0.	0.
62024	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE172 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
621 1	0.	0.	0.	0.	0.
621 2	0.	0.	0.	0.	0.
621 3	0.	0.	0.	0.	0.
621 4	0.	0.	0.	0.	0.
621 5	0.	0.	0.	0.	0.
621 6	0.	0.	0.	0.	0.
621 7	0.	0.	0.	0.	0.
621 8	0.	0.	0.	0.	0.
621 9	0.	0.	0.	0.	0.
62110	0.	0.	0.	0.	0.
62111	0.	0.	0.	0.	0.
62112	0.	0.	0.	0.	0.
62113	0.	0.	0.	0.	0.
62114	0.	0.	0.	0.	0.
62115	0.	0.	0.	0.	0.
62116	0.	0.	0.	0.	0.
62117	0.	0.	0.	0.	0.
62118	0.	0.	0.	0.	0.
62119	0.	0.	0.	0.	0.
62120	0.	0.	0.	0.	0.
62121	0.	0.	0.	0.	0.
62122	0.	0.	0.	0.	0.
62123	0.	0.	0.	0.	0.
62124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE173 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
622 1	0.	0.	0.	0.	0.
622 2	0.	0.	0.	0.	0.
622 3	0.	0.	0.	0.	0.
622 4	0.	0.	0.	0.	0.
622 5	0.	0.	0.	0.	0.
622 6	0.	0.	0.	0.	0.
622 7	0.	0.	0.	0.	0.
622 8	0.	0.	0.	0.	0.
622 9	0.	0.	0.	0.	0.
62210	0.	0.	0.	0.	0.
62211	0.	0.	0.	0.	0.
62212	0.	0.	0.	0.	0.
62213	0.	0.	0.	0.	0.
62214	0.	0.	0.	0.	0.
62215	0.	0.	0.	0.	0.
62216	0.	0.	0.	0.	0.
62217	0.	0.	0.	0.	0.
62218	0.	0.	0.	0.	0.
62219	0.	0.	0.	0.	0.
62220	0.	0.	0.	0.	0.
62221	0.	0.	0.	0.	0.
62222	0.	0.	0.	0.	0.
62223	0.	0.	0.	0.	0.
62224	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE174 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
623 1	0.	0.	0.	0.	0.
623 2	0.	0.	0.	0.	0.
623 3	0.	0.	0.	0.	0.
623 4	0.	0.	0.	0.	0.
623 5	0.	0.	0.	0.	0.
623 6	0.	0.	0.	0.	0.
623 7	0.	0.	0.	0.	0.
623 8	0.	0.	0.	0.	0.
623 9	0.	0.	0.	0.	0.
62310	0.	0.	0.	0.	0.
62311	0.	0.	0.	0.	0.
62312	0.	0.	0.	0.	0.
62313	0.	0.	0.	0.	0.
62314	0.	0.	0.	0.	0.
62315	0.	0.	0.	0.	0.
62316	0.	0.	0.	0.	0.
62317	0.	0.	0.	0.	0.
62318	0.	0.	0.	0.	0.
62319	0.	0.	0.	0.	0.
62320	0.	0.	0.	0.	0.
62321	0.	0.	0.	0.	0.
62322	0.	0.	0.	0.	0.
62323	0.	0.	0.	0.	0.
62324	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE175 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
624 1	0.	0.	0.	0.	0.
624 2	0.	0.	0.	0.	0.
624 3	0.	0.	0.	0.	0.
624 4	0.	0.	0.	0.	0.
624 5	0.	0.	0.	0.	0.
624 6	0.	0.	0.	0.	0.
624 7	0.	0.	0.	0.	0.
624 8	0.	0.	0.	0.	0.
624 9	0.	0.	0.	0.	0.
62410	0.	0.	0.	0.	0.
62411	0.	0.	0.	0.	0.
62412	0.	0.	0.	0.	0.
62413	0.	0.	0.	0.	0.
62414	0.	0.	0.	0.	0.
62415	0.	0.	0.	0.	0.
62416	0.	0.	0.	0.	0.
62417	0.	0.	0.	0.	0.
62418	0.	0.	0.	0.	0.
62419	0.	0.	0.	0.	0.
62420	0.	0.	0.	0.	0.
62421	0.	0.	0.	0.	0.
62422	0.	0.	0.	0.	0.
62423	0.	0.	0.	0.	0.
62424	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE176 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
625 1	0.	0.	0.	0.	0.
625 2	0.	0.	0.	0.	0.
625 3	0.	0.	0.	0.	0.
625 4	0.	0.	0.	0.	0.
625 5	0.	0.	0.	0.	0.
625 6	0.	0.	0.	0.	0.
625 7	0.	0.	0.	0.	0.
625 8	0.	0.	0.	0.	0.
625 9	0.	0.	0.	0.	0.
62510	0.	0.	0.	0.	0.
62511	0.	0.	0.	0.	0.
62512	0.	0.	0.	0.	0.
62513	0.	0.	0.	0.	0.
62514	0.	0.	0.	0.	0.
62515	0.	0.	0.	0.	0.
62516	0.	0.	0.	0.	0.
62517	0.	0.	0.	0.	0.
62518	0.	0.	0.	0.	0.
62519	0.	0.	0.	0.	0.
62520	0.	0.	0.	0.	0.
62521	0.	0.	0.	0.	0.
62522	0.	0.	0.	0.	0.
62523	0.	0.	0.	0.	0.
62524	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE177 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
626 1	0.	0.	0.	0.	0.
626 2	0.	0.	0.	0.	0.
626 3	0.	0.	0.	0.	0.
626 4	0.	0.	0.	0.	0.
626 5	0.	0.	0.	0.	0.
626 6	0.	0.	0.	0.	0.
626 7	0.	0.	0.	0.	0.
626 8	0.	0.	0.	0.	0.
626 9	0.	0.	0.	0.	0.
62610	0.	0.	0.	0.	0.
62611	0.	0.	0.	0.	0.
62612	0.	0.	0.	0.	0.
62613	0.	0.	0.	0.	0.
62614	0.	0.	0.	0.	0.
62615	0.	0.	0.	0.	0.
62616	0.	0.	0.	0.	0.
62617	0.	0.	0.	0.	0.
62618	0.	0.	0.	0.	0.
62619	0.	0.	0.	0.	0.
62620	0.	0.	0.	0.	0.
62621	0.	0.	0.	0.	0.
62622	0.	0.	0.	0.	0.
62623	0.	0.	0.	0.	0.
62624	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE178 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
627 1	0.	0.	0.	0.	0.
627 2	0.	0.	0.	0.	0.
627 3	0.	0.	0.	0.	0.
627 4	0.	0.	0.	0.	0.
627 5	0.	0.	0.	0.	0.
627 6	0.	0.	0.	0.	0.
627 7	0.	0.	0.	0.	0.
627 8	0.	0.	0.	0.	0.
627 9	0.	0.	0.	0.	0.
62710	0.	0.	0.	0.	0.
62711	0.	0.	0.	0.	0.
62712	0.	0.	0.	0.	0.
62713	0.	0.	0.	0.	0.
62714	0.	0.	0.	0.	0.
62715	0.	0.	0.	0.	0.
62716	0.	0.	0.	0.	0.
62717	0.	0.	0.	0.	0.
62718	0.	0.	0.	0.	0.
62719	0.	0.	0.	0.	0.
62720	0.	0.	0.	0.	0.
62721	0.	0.	0.	0.	0.
62722	0.	0.	0.	0.	0.
62723	0.	0.	0.	0.	0.
62724	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE179 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
628 1	0.	0.	0.	0.	0.
628 2	0.	0.	0.	0.	0.
628 3	0.	0.	0.	0.	0.
628 4	0.	0.	0.	0.	0.
628 5	0.	0.	0.	0.	0.
628 6	0.	0.	0.	0.	0.
628 7	0.	0.	0.	0.	0.
628 8	0.	0.	0.	0.	0.
628 9	0.	0.	0.	0.	0.
62810	0.	0.	0.	0.	0.
62811	0.	0.	0.	0.	0.
62812	0.	0.	0.	0.	0.
62813	0.	0.	0.	0.	0.
62814	0.	0.	0.	0.	0.
62815	0.	0.	0.	0.	0.
62816	0.	0.	0.	0.	0.
62817	0.	0.	0.	0.	0.
62818	0.	0.	0.	0.	0.
62819	0.	0.	0.	0.	0.
62820	0.	0.	0.	0.	0.
62821	0.	0.	0.	0.	0.
62822	0.	0.	0.	0.	0.
62823	0.	0.	0.	0.	0.
62824	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE180 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
629 1	0.	0.	0.	0.	0.
629 2	0.	0.	0.	0.	0.
629 3	0.	0.	0.	0.	0.
629 4	0.	0.	0.	0.	0.
629 5	0.	0.	0.	0.	0.
629 6	0.	0.	0.	0.	0.
629 7	0.	0.	0.	0.	0.
629 8	0.	0.	0.	0.	0.
629 9	0.	0.	0.	0.	0.
62910	0.	0.	0.	0.	0.
62911	0.	0.	0.	0.	0.
62912	0.	0.	0.	0.	0.
62913	0.	0.	0.	0.	0.
62914	0.	0.	0.	0.	0.
62915	0.	0.	0.	0.	0.
62916	0.	0.	0.	0.	0.
62917	0.	0.	0.	0.	0.
62918	0.	0.	0.	0.	0.
62919	0.	0.	0.	0.	0.
62920	0.	0.	0.	0.	0.
62921	0.	0.	0.	0.	0.
62922	0.	0.	0.	0.	0.
62923	0.	0.	0.	0.	0.
62924	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE181 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
630 1	0.	0.	0.	0.	0.
630 2	0.	0.	0.	0.	0.
630 3	0.	0.	0.	0.	0.
630 4	0.	0.	0.	0.	0.
630 5	0.	0.	0.	0.	0.
630 6	0.	0.	0.	0.	0.
630 7	0.	0.	0.	0.	0.
630 8	0.	0.	0.	0.	0.
630 9	0.	0.	0.	0.	0.
63010	0.	0.	0.	0.	0.
63011	0.	0.	0.	0.	0.
63012	0.	0.	0.	0.	0.
63013	0.	0.	0.	0.	0.
63014	0.	0.	0.	0.	0.
63015	0.	0.	0.	0.	0.
63016	0.	0.	0.	0.	0.
63017	0.	0.	0.	0.	0.
63018	0.	0.	0.	0.	0.
63019	0.	0.	0.	0.	0.
63020	0.	0.	0.	0.	0.
63021	0.	0.	0.	0.	0.
63022	0.	0.	0.	0.	0.
63023	0.	0.	0.	0.	0.
63024	0.	0.	0.	0.	0.
DAILY SUMMARY (JUN 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (JUN)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE182 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 1 1	0.	0.	0.	0.	0.
7 1 2	0.	0.	0.	0.	0.
7 1 3	0.	0.	0.	0.	0.
7 1 4	0.	0.	0.	0.	0.
7 1 5	0.	0.	0.	0.	0.
7 1 6	0.	0.	0.	0.	0.
7 1 7	0.	0.	0.	0.	0.
7 1 8	0.	0.	0.	0.	0.
7 1 9	0.	0.	0.	0.	0.
7 110	0.	0.	0.	0.	0.
7 111	0.	0.	0.	0.	0.
7 112	0.	0.	0.	0.	0.
7 113	0.	0.	0.	0.	0.
7 114	0.	0.	0.	0.	0.
7 115	0.	0.	0.	0.	0.
7 116	0.	0.	0.	0.	0.
7 117	0.	0.	0.	0.	0.
7 118	0.	0.	0.	0.	0.
7 119	0.	0.	0.	0.	0.
7 120	0.	0.	0.	0.	0.
7 121	0.	0.	0.	0.	0.
7 122	0.	0.	0.	0.	0.
7 123	0.	0.	0.	0.	0.
7 124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE183 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 2 1	0.	0.	0.	0.	0.
7 2 2	0.	0.	0.	0.	0.
7 2 3	0.	0.	0.	0.	0.
7 2 4	0.	0.	0.	0.	0.
7 2 5	0.	0.	0.	0.	0.
7 2 6	0.	0.	0.	0.	0.
7 2 7	0.	0.	0.	0.	0.
7 2 8	0.	0.	0.	0.	0.
7 2 9	0.	0.	0.	0.	0.
7 210	0.	0.	0.	0.	0.
7 211	0.	0.	0.	0.	0.
7 212	0.	0.	0.	0.	0.
7 213	0.	0.	0.	0.	0.
7 214	0.	0.	0.	0.	0.
7 215	0.	0.	0.	0.	0.
7 216	0.	0.	0.	0.	0.
7 217	0.	0.	0.	0.	0.
7 218	0.	0.	0.	0.	0.
7 219	0.	0.	0.	0.	0.
7 220	0.	0.	0.	0.	0.
7 221	0.	0.	0.	0.	0.
7 222	0.	0.	0.	0.	0.
7 223	0.	0.	0.	0.	0.
7 224	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE184 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 3 1	0.	0.	0.	0.	0.
7 3 2	0.	0.	0.	0.	0.
7 3 3	0.	0.	0.	0.	0.
7 3 4	0.	0.	0.	0.	0.
7 3 5	0.	0.	0.	0.	0.
7 3 6	0.	0.	0.	0.	0.
7 3 7	0.	0.	0.	0.	0.
7 3 8	0.	0.	0.	0.	0.
7 3 9	0.	0.	0.	0.	0.
7 310	0.	0.	0.	0.	0.
7 311	0.	0.	0.	0.	0.
7 312	0.	0.	0.	0.	0.
7 313	0.	0.	0.	0.	0.
7 314	0.	0.	0.	0.	0.
7 315	0.	0.	0.	0.	0.
7 316	0.	0.	0.	0.	0.
7 317	0.	0.	0.	0.	0.
7 318	0.	0.	0.	0.	0.
7 319	0.	0.	0.	0.	0.
7 320	0.	0.	0.	0.	0.
7 321	0.	0.	0.	0.	0.
7 322	0.	0.	0.	0.	0.
7 323	0.	0.	0.	0.	0.
7 324	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE185 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 4 1	0.	0.	0.	0.	0.
7 4 2	0.	0.	0.	0.	0.
7 4 3	0.	0.	0.	0.	0.
7 4 4	0.	0.	0.	0.	0.
7 4 5	0.	0.	0.	0.	0.
7 4 6	0.	0.	0.	0.	0.
7 4 7	0.	0.	0.	0.	0.
7 4 8	0.	0.	0.	0.	0.
7 4 9	0.	0.	0.	0.	0.
7 410	0.	0.	0.	0.	0.
7 411	0.	0.	0.	0.	0.
7 412	0.	0.	0.	0.	0.
7 413	0.	0.	0.	0.	0.
7 414	0.	0.	0.	0.	0.
7 415	0.	0.	0.	0.	0.
7 416	0.	0.	0.	0.	0.
7 417	0.	0.	0.	0.	0.
7 418	0.	0.	0.	0.	0.
7 419	0.	0.	0.	0.	0.
7 420	0.	0.	0.	0.	0.
7 421	0.	0.	0.	0.	0.
7 422	0.	0.	0.	0.	0.
7 423	0.	0.	0.	0.	0.
7 424	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE186 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 5 1	0.	0.	0.	0.	0.
7 5 2	0.	0.	0.	0.	0.
7 5 3	0.	0.	0.	0.	0.
7 5 4	0.	0.	0.	0.	0.
7 5 5	0.	0.	0.	0.	0.
7 5 6	0.	0.	0.	0.	0.
7 5 7	0.	0.	0.	0.	0.
7 5 8	0.	0.	0.	0.	0.
7 5 9	0.	0.	0.	0.	0.
7 510	0.	0.	0.	0.	0.
7 511	0.	0.	0.	0.	0.
7 512	0.	0.	0.	0.	0.
7 513	0.	0.	0.	0.	0.
7 514	0.	0.	0.	0.	0.
7 515	0.	0.	0.	0.	0.
7 516	0.	0.	0.	0.	0.
7 517	0.	0.	0.	0.	0.
7 518	0.	0.	0.	0.	0.
7 519	0.	0.	0.	0.	0.
7 520	0.	0.	0.	0.	0.
7 521	0.	0.	0.	0.	0.
7 522	0.	0.	0.	0.	0.
7 523	0.	0.	0.	0.	0.
7 524	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE187 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 6 1	0.	0.	0.	0.	0.
7 6 2	0.	0.	0.	0.	0.
7 6 3	0.	0.	0.	0.	0.
7 6 4	0.	0.	0.	0.	0.
7 6 5	0.	0.	0.	0.	0.
7 6 6	0.	0.	0.	0.	0.
7 6 7	0.	0.	0.	0.	0.
7 6 8	0.	0.	0.	0.	0.
7 6 9	0.	0.	0.	0.	0.
7 610	0.	0.	0.	0.	0.
7 611	0.	0.	0.	0.	0.
7 612	0.	0.	0.	0.	0.
7 613	0.	0.	0.	0.	0.
7 614	0.	0.	0.	0.	0.
7 615	0.	0.	0.	0.	0.
7 616	0.	0.	0.	0.	0.
7 617	0.	0.	0.	0.	0.
7 618	0.	0.	0.	0.	0.
7 619	0.	0.	0.	0.	0.
7 620	0.	0.	0.	0.	0.
7 621	0.	0.	0.	0.	0.
7 622	0.	0.	0.	0.	0.
7 623	0.	0.	0.	0.	0.
7 624	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE188 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 7 1	0.	0.	0.	0.	0.
7 7 2	0.	0.	0.	0.	0.
7 7 3	0.	0.	0.	0.	0.
7 7 4	0.	0.	0.	0.	0.
7 7 5	0.	0.	0.	0.	0.
7 7 6	0.	0.	0.	0.	0.
7 7 7	0.	0.	0.	0.	0.
7 7 8	0.	0.	0.	0.	0.
7 7 9	0.	0.	0.	0.	0.
7 710	0.	0.	0.	0.	0.
7 711	0.	0.	0.	0.	0.
7 712	0.	0.	0.	0.	0.
7 713	0.	0.	0.	0.	0.
7 714	0.	0.	0.	0.	0.
7 715	0.	0.	0.	0.	0.
7 716	0.	0.	0.	0.	0.
7 717	0.	0.	0.	0.	0.
7 718	0.	0.	0.	0.	0.
7 719	0.	0.	0.	0.	0.
7 720	0.	0.	0.	0.	0.
7 721	0.	0.	0.	0.	0.
7 722	0.	0.	0.	0.	0.
7 723	0.	0.	0.	0.	0.
7 724	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE189 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 8 1	0.	0.	0.	0.	0.
7 8 2	0.	0.	0.	0.	0.
7 8 3	0.	0.	0.	0.	0.
7 8 4	0.	0.	0.	0.	0.
7 8 5	0.	0.	0.	0.	0.
7 8 6	0.	0.	0.	0.	0.
7 8 7	0.	0.	0.	0.	0.
7 8 8	0.	0.	0.	0.	0.
7 8 9	0.	0.	0.	0.	0.
7 810	0.	0.	0.	0.	0.
7 811	0.	0.	0.	0.	0.
7 812	0.	0.	0.	0.	0.
7 813	0.	0.	0.	0.	0.
7 814	0.	0.	0.	0.	0.
7 815	0.	0.	0.	0.	0.
7 816	0.	0.	0.	0.	0.
7 817	0.	0.	0.	0.	0.
7 818	0.	0.	0.	0.	0.
7 819	0.	0.	0.	0.	0.
7 820	0.	0.	0.	0.	0.
7 821	0.	0.	0.	0.	0.
7 822	0.	0.	0.	0.	0.
7 823	0.	0.	0.	0.	0.
7 824	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE190 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
7 9 1	0.	0.	0.	0.	0.
7 9 2	0.	0.	0.	0.	0.
7 9 3	0.	0.	0.	0.	0.
7 9 4	0.	0.	0.	0.	0.
7 9 5	0.	0.	0.	0.	0.
7 9 6	0.	0.	0.	0.	0.
7 9 7	0.	0.	0.	0.	0.
7 9 8	0.	0.	0.	0.	0.
7 9 9	0.	0.	0.	0.	0.
7 910	0.	0.	0.	0.	0.
7 911	0.	0.	0.	0.	0.
7 912	0.	0.	0.	0.	0.
7 913	0.	0.	0.	0.	0.
7 914	0.	0.	0.	0.	0.
7 915	0.	0.	0.	0.	0.
7 916	0.	0.	0.	0.	0.
7 917	0.	0.	0.	0.	0.
7 918	0.	0.	0.	0.	0.
7 919	0.	0.	0.	0.	0.
7 920	0.	0.	0.	0.	0.
7 921	0.	0.	0.	0.	0.
7 922	0.	0.	0.	0.	0.
7 923	0.	0.	0.	0.	0.
7 924	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE191 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
710 1	0.	0.	0.	0.	0.
710 2	0.	0.	0.	0.	0.
710 3	0.	0.	0.	0.	0.
710 4	0.	0.	0.	0.	0.
710 5	0.	0.	0.	0.	0.
710 6	0.	0.	0.	0.	0.
710 7	0.	0.	0.	0.	0.
710 8	0.	0.	0.	0.	0.
710 9	0.	0.	0.	0.	0.
71010	0.	0.	0.	0.	0.
71011	0.	0.	0.	0.	0.
71012	0.	0.	0.	0.	0.
71013	0.	0.	0.	0.	0.
71014	0.	0.	0.	0.	0.
71015	0.	0.	0.	0.	0.
71016	0.	0.	0.	0.	0.
71017	0.	0.	0.	0.	0.
71018	0.	0.	0.	0.	0.
71019	0.	0.	0.	0.	0.
71020	0.	0.	0.	0.	0.
71021	0.	0.	0.	0.	0.
71022	0.	0.	0.	0.	0.
71023	0.	0.	0.	0.	0.
71024	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE192 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
711 1	0.	0.	0.	0.	0.
711 2	0.	0.	0.	0.	0.
711 3	0.	0.	0.	0.	0.
711 4	0.	0.	0.	0.	0.
711 5	0.	0.	0.	0.	0.
711 6	0.	0.	0.	0.	0.
711 7	0.	0.	0.	0.	0.
711 8	0.	0.	0.	0.	0.
711 9	0.	0.	0.	0.	0.
71110	0.	0.	0.	0.	0.
71111	0.	0.	0.	0.	0.
71112	0.	0.	0.	0.	0.
71113	0.	0.	0.	0.	0.
71114	0.	0.	0.	0.	0.
71115	0.	0.	0.	0.	0.
71116	0.	0.	0.	0.	0.
71117	0.	0.	0.	0.	0.
71118	0.	0.	0.	0.	0.
71119	0.	0.	0.	0.	0.
71120	0.	0.	0.	0.	0.
71121	0.	0.	0.	0.	0.
71122	0.	0.	0.	0.	0.
71123	0.	0.	0.	0.	0.
71124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE193 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
712 1	0.	0.	0.	0.	0.
712 2	0.	0.	0.	0.	0.
712 3	0.	0.	0.	0.	0.
712 4	0.	0.	0.	0.	0.
712 5	0.	0.	0.	0.	0.
712 6	0.	0.	0.	0.	0.
712 7	0.	0.	0.	0.	0.
712 8	0.	0.	0.	0.	0.
712 9	0.	0.	0.	0.	0.
71210	0.	0.	0.	0.	0.
71211	0.	0.	0.	0.	0.
71212	0.	0.	0.	0.	0.
71213	0.	0.	0.	0.	0.
71214	0.	0.	0.	0.	0.
71215	0.	0.	0.	0.	0.
71216	0.	0.	0.	0.	0.
71217	0.	0.	0.	0.	0.
71218	0.	0.	0.	0.	0.
71219	0.	0.	0.	0.	0.
71220	0.	0.	0.	0.	0.
71221	0.	0.	0.	0.	0.
71222	0.	0.	0.	0.	0.
71223	0.	0.	0.	0.	0.
71224	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE194 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
713 1	0.	0.	0.	0.	0.
713 2	0.	0.	0.	0.	0.
713 3	0.	0.	0.	0.	0.
713 4	0.	0.	0.	0.	0.
713 5	0.	0.	0.	0.	0.
713 6	0.	0.	0.	0.	0.
713 7	0.	0.	0.	0.	0.
713 8	0.	0.	0.	0.	0.
713 9	0.	0.	0.	0.	0.
71310	0.	0.	0.	0.	0.
71311	0.	0.	0.	0.	0.
71312	0.	0.	0.	0.	0.
71313	0.	0.	0.	0.	0.
71314	0.	0.	0.	0.	0.
71315	0.	0.	0.	0.	0.
71316	0.	0.	0.	0.	0.
71317	0.	0.	0.	0.	0.
71318	0.	0.	0.	0.	0.
71319	0.	0.	0.	0.	0.
71320	0.	0.	0.	0.	0.
71321	0.	0.	0.	0.	0.
71322	0.	0.	0.	0.	0.
71323	0.	0.	0.	0.	0.
71324	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE195 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
714 1	0.	0.	0.	0.	0.
714 2	0.	0.	0.	0.	0.
714 3	0.	0.	0.	0.	0.
714 4	0.	0.	0.	0.	0.
714 5	0.	0.	0.	0.	0.
714 6	0.	0.	0.	0.	0.
714 7	0.	0.	0.	0.	0.
714 8	0.	0.	0.	0.	0.
714 9	0.	0.	0.	0.	0.
71410	0.	0.	0.	0.	0.
71411	0.	0.	0.	0.	0.
71412	0.	0.	0.	0.	0.
71413	0.	0.	0.	0.	0.
71414	0.	0.	0.	0.	0.
71415	0.	0.	0.	0.	0.
71416	0.	0.	0.	0.	0.
71417	0.	0.	0.	0.	0.
71418	0.	0.	0.	0.	0.
71419	0.	0.	0.	0.	0.
71420	0.	0.	0.	0.	0.
71421	0.	0.	0.	0.	0.
71422	0.	0.	0.	0.	0.
71423	0.	0.	0.	0.	0.
71424	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE196 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
715 1	0.	0.	0.	0.	0.
715 2	0.	0.	0.	0.	0.
715 3	0.	0.	0.	0.	0.
715 4	0.	0.	0.	0.	0.
715 5	0.	0.	0.	0.	0.
715 6	0.	0.	0.	0.	0.
715 7	0.	0.	0.	0.	0.
715 8	0.	0.	0.	0.	0.
715 9	0.	0.	0.	0.	0.
71510	0.	0.	0.	0.	0.
71511	0.	0.	0.	0.	0.
71512	0.	0.	0.	0.	0.
71513	0.	0.	0.	0.	0.
71514	0.	0.	0.	0.	0.
71515	0.	0.	0.	0.	0.
71516	0.	0.	0.	0.	0.
71517	0.	0.	0.	0.	0.
71518	0.	0.	0.	0.	0.
71519	0.	0.	0.	0.	0.
71520	0.	0.	0.	0.	0.
71521	0.	0.	0.	0.	0.
71522	0.	0.	0.	0.	0.
71523	0.	0.	0.	0.	0.
71524	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE197 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
716 1	0.	0.	0.	0.	0.
716 2	0.	0.	0.	0.	0.
716 3	0.	0.	0.	0.	0.
716 4	0.	0.	0.	0.	0.
716 5	0.	0.	0.	0.	0.
716 6	0.	0.	0.	0.	0.
716 7	0.	0.	0.	0.	0.
716 8	0.	0.	0.	0.	0.
716 9	0.	0.	0.	0.	0.
71610	0.	0.	0.	0.	0.
71611	0.	0.	0.	0.	0.
71612	0.	0.	0.	0.	0.
71613	0.	0.	0.	0.	0.
71614	0.	0.	0.	0.	0.
71615	0.	0.	0.	0.	0.
71616	0.	0.	0.	0.	0.
71617	0.	0.	0.	0.	0.
71618	0.	0.	0.	0.	0.
71619	0.	0.	0.	0.	0.
71620	0.	0.	0.	0.	0.
71621	0.	0.	0.	0.	0.
71622	0.	0.	0.	0.	0.
71623	0.	0.	0.	0.	0.
71624	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE198 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
717 1	0.	0.	0.	0.	0.
717 2	0.	0.	0.	0.	0.
717 3	0.	0.	0.	0.	0.
717 4	0.	0.	0.	0.	0.
717 5	0.	0.	0.	0.	0.
717 6	0.	0.	0.	0.	0.
717 7	0.	0.	0.	0.	0.
717 8	0.	0.	0.	0.	0.
717 9	0.	0.	0.	0.	0.
71710	0.	0.	0.	0.	0.
71711	0.	0.	0.	0.	0.
71712	0.	0.	0.	0.	0.
71713	0.	0.	0.	0.	0.
71714	0.	0.	0.	0.	0.
71715	0.	0.	0.	0.	0.
71716	0.	0.	0.	0.	0.
71717	0.	0.	0.	0.	0.
71718	0.	0.	0.	0.	0.
71719	0.	0.	0.	0.	0.
71720	0.	0.	0.	0.	0.
71721	0.	0.	0.	0.	0.
71722	0.	0.	0.	0.	0.
71723	0.	0.	0.	0.	0.
71724	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE199 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
718 1	0.	0.	0.	0.	0.
718 2	0.	0.	0.	0.	0.
718 3	0.	0.	0.	0.	0.
718 4	0.	0.	0.	0.	0.
718 5	0.	0.	0.	0.	0.
718 6	0.	0.	0.	0.	0.
718 7	0.	0.	0.	0.	0.
718 8	0.	0.	0.	0.	0.
718 9	0.	0.	0.	0.	0.
71810	0.	0.	0.	0.	0.
71811	0.	0.	0.	0.	0.
71812	0.	0.	0.	0.	0.
71813	0.	0.	0.	0.	0.
71814	0.	0.	0.	0.	0.
71815	0.	0.	0.	0.	0.
71816	0.	0.	0.	0.	0.
71817	0.	0.	0.	0.	0.
71818	0.	0.	0.	0.	0.
71819	0.	0.	0.	0.	0.
71820	0.	0.	0.	0.	0.
71821	0.	0.	0.	0.	0.
71822	0.	0.	0.	0.	0.
71823	0.	0.	0.	0.	0.
71824	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE200 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
719 1	0.	0.	0.	0.	0.
719 2	0.	0.	0.	0.	0.
719 3	0.	0.	0.	0.	0.
719 4	0.	0.	0.	0.	0.
719 5	0.	0.	0.	0.	0.
719 6	0.	0.	0.	0.	0.
719 7	0.	0.	0.	0.	0.
719 8	0.	0.	0.	0.	0.
719 9	0.	0.	0.	0.	0.
71910	0.	0.	0.	0.	0.
71911	0.	0.	0.	0.	0.
71912	0.	0.	0.	0.	0.
71913	0.	0.	0.	0.	0.
71914	0.	0.	0.	0.	0.
71915	0.	0.	0.	0.	0.
71916	0.	0.	0.	0.	0.
71917	0.	0.	0.	0.	0.
71918	0.	0.	0.	0.	0.
71919	0.	0.	0.	0.	0.
71920	0.	0.	0.	0.	0.
71921	0.	0.	0.	0.	0.
71922	0.	0.	0.	0.	0.
71923	0.	0.	0.	0.	0.
71924	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE201 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
720 1	0.	0.	0.	0.	0.
720 2	0.	0.	0.	0.	0.
720 3	0.	0.	0.	0.	0.
720 4	0.	0.	0.	0.	0.
720 5	0.	0.	0.	0.	0.
720 6	0.	0.	0.	0.	0.
720 7	0.	0.	0.	0.	0.
720 8	0.	0.	0.	0.	0.
720 9	0.	0.	0.	0.	0.
72010	0.	0.	0.	0.	0.
72011	0.	0.	0.	0.	0.
72012	0.	0.	0.	0.	0.
72013	0.	0.	0.	0.	0.
72014	0.	0.	0.	0.	0.
72015	0.	0.	0.	0.	0.
72016	0.	0.	0.	0.	0.
72017	0.	0.	0.	0.	0.
72018	0.	0.	0.	0.	0.
72019	0.	0.	0.	0.	0.
72020	0.	0.	0.	0.	0.
72021	0.	0.	0.	0.	0.
72022	0.	0.	0.	0.	0.
72023	0.	0.	0.	0.	0.
72024	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE202 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
721 1	0.	0.	0.	0.	0.
721 2	0.	0.	0.	0.	0.
721 3	0.	0.	0.	0.	0.
721 4	0.	0.	0.	0.	0.
721 5	0.	0.	0.	0.	0.
721 6	0.	0.	0.	0.	0.
721 7	0.	0.	0.	0.	0.
721 8	0.	0.	0.	0.	0.
721 9	0.	0.	0.	0.	0.
72110	0.	0.	0.	0.	0.
72111	0.	0.	0.	0.	0.
72112	0.	0.	0.	0.	0.
72113	0.	0.	0.	0.	0.
72114	0.	0.	0.	0.	0.
72115	0.	0.	0.	0.	0.
72116	0.	0.	0.	0.	0.
72117	0.	0.	0.	0.	0.
72118	0.	0.	0.	0.	0.
72119	0.	0.	0.	0.	0.
72120	0.	0.	0.	0.	0.
72121	0.	0.	0.	0.	0.
72122	0.	0.	0.	0.	0.
72123	0.	0.	0.	0.	0.
72124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE203 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
722 1	0.	0.	0.	0.	0.
722 2	0.	0.	0.	0.	0.
722 3	0.	0.	0.	0.	0.
722 4	0.	0.	0.	0.	0.
722 5	0.	0.	0.	0.	0.
722 6	0.	0.	0.	0.	0.
722 7	0.	0.	0.	0.	0.
722 8	0.	0.	0.	0.	0.
722 9	0.	0.	0.	0.	0.
72210	0.	0.	0.	0.	0.
72211	0.	0.	0.	0.	0.
72212	0.	0.	0.	0.	0.
72213	0.	0.	0.	0.	0.
72214	0.	0.	0.	0.	0.
72215	0.	0.	0.	0.	0.
72216	0.	0.	0.	0.	0.
72217	0.	0.	0.	0.	0.
72218	0.	0.	0.	0.	0.
72219	0.	0.	0.	0.	0.
72220	0.	0.	0.	0.	0.
72221	0.	0.	0.	0.	0.
72222	0.	0.	0.	0.	0.
72223	0.	0.	0.	0.	0.
72224	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE204 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
723 1	0.	0.	0.	0.	0.
723 2	0.	0.	0.	0.	0.
723 3	0.	0.	0.	0.	0.
723 4	0.	0.	0.	0.	0.
723 5	0.	0.	0.	0.	0.
723 6	0.	0.	0.	0.	0.
723 7	0.	0.	0.	0.	0.
723 8	0.	0.	0.	0.	0.
723 9	0.	0.	0.	0.	0.
72310	0.	0.	0.	0.	0.
72311	0.	0.	0.	0.	0.
72312	0.	0.	0.	0.	0.
72313	0.	0.	0.	0.	0.
72314	0.	0.	0.	0.	0.
72315	0.	0.	0.	0.	0.
72316	0.	0.	0.	0.	0.
72317	0.	0.	0.	0.	0.
72318	0.	0.	0.	0.	0.
72319	0.	0.	0.	0.	0.
72320	0.	0.	0.	0.	0.
72321	0.	0.	0.	0.	0.
72322	0.	0.	0.	0.	0.
72323	0.	0.	0.	0.	0.
72324	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE205 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
724 1	0.	0.	0.	0.	0.
724 2	0.	0.	0.	0.	0.
724 3	0.	0.	0.	0.	0.
724 4	0.	0.	0.	0.	0.
724 5	0.	0.	0.	0.	0.
724 6	0.	0.	0.	0.	0.
724 7	0.	0.	0.	0.	0.
724 8	0.	0.	0.	0.	0.
724 9	0.	0.	0.	0.	0.
72410	0.	0.	0.	0.	0.
72411	0.	0.	0.	0.	0.
72412	0.	0.	0.	0.	0.
72413	0.	0.	0.	0.	0.
72414	0.	0.	0.	0.	0.
72415	0.	0.	0.	0.	0.
72416	0.	0.	0.	0.	0.
72417	0.	0.	0.	0.	0.
72418	0.	0.	0.	0.	0.
72419	0.	0.	0.	0.	0.
72420	0.	0.	0.	0.	0.
72421	0.	0.	0.	0.	0.
72422	0.	0.	0.	0.	0.
72423	0.	0.	0.	0.	0.
72424	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE206 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
725 1	0.	0.	0.	0.	0.
725 2	0.	0.	0.	0.	0.
725 3	0.	0.	0.	0.	0.
725 4	0.	0.	0.	0.	0.
725 5	0.	0.	0.	0.	0.
725 6	0.	0.	0.	0.	0.
725 7	0.	0.	0.	0.	0.
725 8	0.	0.	0.	0.	0.
725 9	0.	0.	0.	0.	0.
72510	0.	0.	0.	0.	0.
72511	0.	0.	0.	0.	0.
72512	0.	0.	0.	0.	0.
72513	0.	0.	0.	0.	0.
72514	0.	0.	0.	0.	0.
72515	0.	0.	0.	0.	0.
72516	0.	0.	0.	0.	0.
72517	0.	0.	0.	0.	0.
72518	0.	0.	0.	0.	0.
72519	0.	0.	0.	0.	0.
72520	0.	0.	0.	0.	0.
72521	0.	0.	0.	0.	0.
72522	0.	0.	0.	0.	0.
72523	0.	0.	0.	0.	0.
72524	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE207 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
726 1	0.	0.	0.	0.	0.
726 2	0.	0.	0.	0.	0.
726 3	0.	0.	0.	0.	0.
726 4	0.	0.	0.	0.	0.
726 5	0.	0.	0.	0.	0.
726 6	0.	0.	0.	0.	0.
726 7	0.	0.	0.	0.	0.
726 8	0.	0.	0.	0.	0.
726 9	0.	0.	0.	0.	0.
72610	0.	0.	0.	0.	0.
72611	0.	0.	0.	0.	0.
72612	0.	0.	0.	0.	0.
72613	0.	0.	0.	0.	0.
72614	0.	0.	0.	0.	0.
72615	0.	0.	0.	0.	0.
72616	0.	0.	0.	0.	0.
72617	0.	0.	0.	0.	0.
72618	0.	0.	0.	0.	0.
72619	0.	0.	0.	0.	0.
72620	0.	0.	0.	0.	0.
72621	0.	0.	0.	0.	0.
72622	0.	0.	0.	0.	0.
72623	0.	0.	0.	0.	0.
72624	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE208 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
727 1	0.	0.	0.	0.	0.
727 2	0.	0.	0.	0.	0.
727 3	0.	0.	0.	0.	0.
727 4	0.	0.	0.	0.	0.
727 5	0.	0.	0.	0.	0.
727 6	0.	0.	0.	0.	0.
727 7	0.	0.	0.	0.	0.
727 8	0.	0.	0.	0.	0.
727 9	0.	0.	0.	0.	0.
72710	0.	0.	0.	0.	0.
72711	0.	0.	0.	0.	0.
72712	0.	0.	0.	0.	0.
72713	0.	0.	0.	0.	0.
72714	0.	0.	0.	0.	0.
72715	0.	0.	0.	0.	0.
72716	0.	0.	0.	0.	0.
72717	0.	0.	0.	0.	0.
72718	0.	0.	0.	0.	0.
72719	0.	0.	0.	0.	0.
72720	0.	0.	0.	0.	0.
72721	0.	0.	0.	0.	0.
72722	0.	0.	0.	0.	0.
72723	0.	0.	0.	0.	0.
72724	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE209 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
728 1	0.	0.	0.	0.	0.
728 2	0.	0.	0.	0.	0.
728 3	0.	0.	0.	0.	0.
728 4	0.	0.	0.	0.	0.
728 5	0.	0.	0.	0.	0.
728 6	0.	0.	0.	0.	0.
728 7	0.	0.	0.	0.	0.
728 8	0.	0.	0.	0.	0.
728 9	0.	0.	0.	0.	0.
72810	0.	0.	0.	0.	0.
72811	0.	0.	0.	0.	0.
72812	0.	0.	0.	0.	0.
72813	0.	0.	0.	0.	0.
72814	0.	0.	0.	0.	0.
72815	0.	0.	0.	0.	0.
72816	0.	0.	0.	0.	0.
72817	0.	0.	0.	0.	0.
72818	0.	0.	0.	0.	0.
72819	0.	0.	0.	0.	0.
72820	0.	0.	0.	0.	0.
72821	0.	0.	0.	0.	0.
72822	0.	0.	0.	0.	0.
72823	0.	0.	0.	0.	0.
72824	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE210 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
729 1	0.	0.	0.	0.	0.
729 2	0.	0.	0.	0.	0.
729 3	0.	0.	0.	0.	0.
729 4	0.	0.	0.	0.	0.
729 5	0.	0.	0.	0.	0.
729 6	0.	0.	0.	0.	0.
729 7	0.	0.	0.	0.	0.
729 8	0.	0.	0.	0.	0.
729 9	0.	0.	0.	0.	0.
72910	0.	0.	0.	0.	0.
72911	0.	0.	0.	0.	0.
72912	0.	0.	0.	0.	0.
72913	0.	0.	0.	0.	0.
72914	0.	0.	0.	0.	0.
72915	0.	0.	0.	0.	0.
72916	0.	0.	0.	0.	0.
72917	0.	0.	0.	0.	0.
72918	0.	0.	0.	0.	0.
72919	0.	0.	0.	0.	0.
72920	0.	0.	0.	0.	0.
72921	0.	0.	0.	0.	0.
72922	0.	0.	0.	0.	0.
72923	0.	0.	0.	0.	0.
72924	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE211 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
730 1	0.	0.	0.	0.	0.
730 2	0.	0.	0.	0.	0.
730 3	0.	0.	0.	0.	0.
730 4	0.	0.	0.	0.	0.
730 5	0.	0.	0.	0.	0.
730 6	0.	0.	0.	0.	0.
730 7	0.	0.	0.	0.	0.
730 8	0.	0.	0.	0.	0.
730 9	0.	0.	0.	0.	0.
73010	0.	0.	0.	0.	0.
73011	0.	0.	0.	0.	0.
73012	0.	0.	0.	0.	0.
73013	0.	0.	0.	0.	0.
73014	0.	0.	0.	0.	0.
73015	0.	0.	0.	0.	0.
73016	0.	0.	0.	0.	0.
73017	0.	0.	0.	0.	0.
73018	0.	0.	0.	0.	0.
73019	0.	0.	0.	0.	0.
73020	0.	0.	0.	0.	0.
73021	0.	0.	0.	0.	0.
73022	0.	0.	0.	0.	0.
73023	0.	0.	0.	0.	0.
73024	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE212 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
731 1	0.	0.	0.	0.	0.
731 2	0.	0.	0.	0.	0.
731 3	0.	0.	0.	0.	0.
731 4	0.	0.	0.	0.	0.
731 5	0.	0.	0.	0.	0.
731 6	0.	0.	0.	0.	0.
731 7	0.	0.	0.	0.	0.
731 8	0.	0.	0.	0.	0.
731 9	0.	0.	0.	0.	0.
73110	0.	0.	0.	0.	0.
73111	0.	0.	0.	0.	0.
73112	0.	0.	0.	0.	0.
73113	0.	0.	0.	0.	0.
73114	0.	0.	0.	0.	0.
73115	0.	0.	0.	0.	0.
73116	0.	0.	0.	0.	0.
73117	0.	0.	0.	0.	0.
73118	0.	0.	0.	0.	0.
73119	0.	0.	0.	0.	0.
73120	0.	0.	0.	0.	0.
73121	0.	0.	0.	0.	0.
73122	0.	0.	0.	0.	0.
73123	0.	0.	0.	0.	0.
73124	0.	0.	0.	0.	0.
DAILY SUMMARY (JUL 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (JUL)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE213 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 1 1	0.	0.	0.	0.	0.
8 1 2	0.	0.	0.	0.	0.
8 1 3	0.	0.	0.	0.	0.
8 1 4	0.	0.	0.	0.	0.
8 1 5	0.	0.	0.	0.	0.
8 1 6	0.	0.	0.	0.	0.
8 1 7	0.	0.	0.	0.	0.
8 1 8	0.	0.	0.	0.	0.
8 1 9	0.	0.	0.	0.	0.
8 110	0.	0.	0.	0.	0.
8 111	0.	0.	0.	0.	0.
8 112	0.	0.	0.	0.	0.
8 113	0.	0.	0.	0.	0.
8 114	0.	0.	0.	0.	0.
8 115	0.	0.	0.	0.	0.
8 116	0.	0.	0.	0.	0.
8 117	0.	0.	0.	0.	0.
8 118	0.	0.	0.	0.	0.
8 119	0.	0.	0.	0.	0.
8 120	0.	0.	0.	0.	0.
8 121	0.	0.	0.	0.	0.
8 122	0.	0.	0.	0.	0.
8 123	0.	0.	0.	0.	0.
8 124	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE214 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 2 1	0.	0.	0.	0.	0.
8 2 2	0.	0.	0.	0.	0.
8 2 3	0.	0.	0.	0.	0.
8 2 4	0.	0.	0.	0.	0.
8 2 5	0.	0.	0.	0.	0.
8 2 6	0.	0.	0.	0.	0.
8 2 7	0.	0.	0.	0.	0.
8 2 8	0.	0.	0.	0.	0.
8 2 9	0.	0.	0.	0.	0.
8 210	0.	0.	0.	0.	0.
8 211	0.	0.	0.	0.	0.
8 212	0.	0.	0.	0.	0.
8 213	0.	0.	0.	0.	0.
8 214	0.	0.	0.	0.	0.
8 215	0.	0.	0.	0.	0.
8 216	0.	0.	0.	0.	0.
8 217	0.	0.	0.	0.	0.
8 218	0.	0.	0.	0.	0.
8 219	0.	0.	0.	0.	0.
8 220	0.	0.	0.	0.	0.
8 221	0.	0.	0.	0.	0.
8 222	0.	0.	0.	0.	0.
8 223	0.	0.	0.	0.	0.
8 224	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE215 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 3 1	0.	0.	0.	0.	0.
8 3 2	0.	0.	0.	0.	0.
8 3 3	0.	0.	0.	0.	0.
8 3 4	0.	0.	0.	0.	0.
8 3 5	0.	0.	0.	0.	0.
8 3 6	0.	0.	0.	0.	0.
8 3 7	0.	0.	0.	0.	0.
8 3 8	0.	0.	0.	0.	0.
8 3 9	0.	0.	0.	0.	0.
8 310	0.	0.	0.	0.	0.
8 311	0.	0.	0.	0.	0.
8 312	0.	0.	0.	0.	0.
8 313	0.	0.	0.	0.	0.
8 314	0.	0.	0.	0.	0.
8 315	0.	0.	0.	0.	0.
8 316	0.	0.	0.	0.	0.
8 317	0.	0.	0.	0.	0.
8 318	0.	0.	0.	0.	0.
8 319	0.	0.	0.	0.	0.
8 320	0.	0.	0.	0.	0.
8 321	0.	0.	0.	0.	0.
8 322	0.	0.	0.	0.	0.
8 323	0.	0.	0.	0.	0.
8 324	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE216 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 4 1	0.	0.	0.	0.	0.
8 4 2	0.	0.	0.	0.	0.
8 4 3	0.	0.	0.	0.	0.
8 4 4	0.	0.	0.	0.	0.
8 4 5	0.	0.	0.	0.	0.
8 4 6	0.	0.	0.	0.	0.
8 4 7	0.	0.	0.	0.	0.
8 4 8	0.	0.	0.	0.	0.
8 4 9	0.	0.	0.	0.	0.
8 410	0.	0.	0.	0.	0.
8 411	0.	0.	0.	0.	0.
8 412	0.	0.	0.	0.	0.
8 413	0.	0.	0.	0.	0.
8 414	0.	0.	0.	0.	0.
8 415	0.	0.	0.	0.	0.
8 416	0.	0.	0.	0.	0.
8 417	0.	0.	0.	0.	0.
8 418	0.	0.	0.	0.	0.
8 419	0.	0.	0.	0.	0.
8 420	0.	0.	0.	0.	0.
8 421	0.	0.	0.	0.	0.
8 422	0.	0.	0.	0.	0.
8 423	0.	0.	0.	0.	0.
8 424	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE217 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 5 1	0.	0.	0.	0.	0.
8 5 2	0.	0.	0.	0.	0.
8 5 3	0.	0.	0.	0.	0.
8 5 4	0.	0.	0.	0.	0.
8 5 5	0.	0.	0.	0.	0.
8 5 6	0.	0.	0.	0.	0.
8 5 7	0.	0.	0.	0.	0.
8 5 8	0.	0.	0.	0.	0.
8 5 9	0.	0.	0.	0.	0.
8 510	0.	0.	0.	0.	0.
8 511	0.	0.	0.	0.	0.
8 512	0.	0.	0.	0.	0.
8 513	0.	0.	0.	0.	0.
8 514	0.	0.	0.	0.	0.
8 515	0.	0.	0.	0.	0.
8 516	0.	0.	0.	0.	0.
8 517	0.	0.	0.	0.	0.
8 518	0.	0.	0.	0.	0.
8 519	0.	0.	0.	0.	0.
8 520	0.	0.	0.	0.	0.
8 521	0.	0.	0.	0.	0.
8 522	0.	0.	0.	0.	0.
8 523	0.	0.	0.	0.	0.
8 524	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE218 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 6 1	0.	0.	0.	0.	0.
8 6 2	0.	0.	0.	0.	0.
8 6 3	0.	0.	0.	0.	0.
8 6 4	0.	0.	0.	0.	0.
8 6 5	0.	0.	0.	0.	0.
8 6 6	0.	0.	0.	0.	0.
8 6 7	0.	0.	0.	0.	0.
8 6 8	0.	0.	0.	0.	0.
8 6 9	0.	0.	0.	0.	0.
8 610	0.	0.	0.	0.	0.
8 611	0.	0.	0.	0.	0.
8 612	0.	0.	0.	0.	0.
8 613	0.	0.	0.	0.	0.
8 614	0.	0.	0.	0.	0.
8 615	0.	0.	0.	0.	0.
8 616	0.	0.	0.	0.	0.
8 617	0.	0.	0.	0.	0.
8 618	0.	0.	0.	0.	0.
8 619	0.	0.	0.	0.	0.
8 620	0.	0.	0.	0.	0.
8 621	0.	0.	0.	0.	0.
8 622	0.	0.	0.	0.	0.
8 623	0.	0.	0.	0.	0.
8 624	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE219 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 7 1	0.	0.	0.	0.	0.
8 7 2	0.	0.	0.	0.	0.
8 7 3	0.	0.	0.	0.	0.
8 7 4	0.	0.	0.	0.	0.
8 7 5	0.	0.	0.	0.	0.
8 7 6	0.	0.	0.	0.	0.
8 7 7	0.	0.	0.	0.	0.
8 7 8	0.	0.	0.	0.	0.
8 7 9	0.	0.	0.	0.	0.
8 710	0.	0.	0.	0.	0.
8 711	0.	0.	0.	0.	0.
8 712	0.	0.	0.	0.	0.
8 713	0.	0.	0.	0.	0.
8 714	0.	0.	0.	0.	0.
8 715	0.	0.	0.	0.	0.
8 716	0.	0.	0.	0.	0.
8 717	0.	0.	0.	0.	0.
8 718	0.	0.	0.	0.	0.
8 719	0.	0.	0.	0.	0.
8 720	0.	0.	0.	0.	0.
8 721	0.	0.	0.	0.	0.
8 722	0.	0.	0.	0.	0.
8 723	0.	0.	0.	0.	0.
8 724	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE220 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 8 1	0.	0.	0.	0.	0.
8 8 2	0.	0.	0.	0.	0.
8 8 3	0.	0.	0.	0.	0.
8 8 4	0.	0.	0.	0.	0.
8 8 5	0.	0.	0.	0.	0.
8 8 6	0.	0.	0.	0.	0.
8 8 7	0.	0.	0.	0.	0.
8 8 8	0.	0.	0.	0.	0.
8 8 9	0.	0.	0.	0.	0.
8 810	0.	0.	0.	0.	0.
8 811	0.	0.	0.	0.	0.
8 812	0.	0.	0.	0.	0.
8 813	0.	0.	0.	0.	0.
8 814	0.	0.	0.	0.	0.
8 815	0.	0.	0.	0.	0.
8 816	0.	0.	0.	0.	0.
8 817	0.	0.	0.	0.	0.
8 818	0.	0.	0.	0.	0.
8 819	0.	0.	0.	0.	0.
8 820	0.	0.	0.	0.	0.
8 821	0.	0.	0.	0.	0.
8 822	0.	0.	0.	0.	0.
8 823	0.	0.	0.	0.	0.
8 824	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE221 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
8 9 1	0.	0.	0.	0.	0.
8 9 2	0.	0.	0.	0.	0.
8 9 3	0.	0.	0.	0.	0.
8 9 4	0.	0.	0.	0.	0.
8 9 5	0.	0.	0.	0.	0.
8 9 6	0.	0.	0.	0.	0.
8 9 7	0.	0.	0.	0.	0.
8 9 8	0.	0.	0.	0.	0.
8 9 9	0.	0.	0.	0.	0.
8 910	0.	0.	0.	0.	0.
8 911	0.	0.	0.	0.	0.
8 912	0.	0.	0.	0.	0.
8 913	0.	0.	0.	0.	0.
8 914	0.	0.	0.	0.	0.
8 915	0.	0.	0.	0.	0.
8 916	0.	0.	0.	0.	0.
8 917	0.	0.	0.	0.	0.
8 918	0.	0.	0.	0.	0.
8 919	0.	0.	0.	0.	0.
8 920	0.	0.	0.	0.	0.
8 921	0.	0.	0.	0.	0.
8 922	0.	0.	0.	0.	0.
8 923	0.	0.	0.	0.	0.
8 924	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE222 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
810 1	0.	0.	0.	0.	0.
810 2	0.	0.	0.	0.	0.
810 3	0.	0.	0.	0.	0.
810 4	0.	0.	0.	0.	0.
810 5	0.	0.	0.	0.	0.
810 6	0.	0.	0.	0.	0.
810 7	0.	0.	0.	0.	0.
810 8	0.	0.	0.	0.	0.
810 9	0.	0.	0.	0.	0.
81010	0.	0.	0.	0.	0.
81011	0.	0.	0.	0.	0.
81012	0.	0.	0.	0.	0.
81013	0.	0.	0.	0.	0.
81014	0.	0.	0.	0.	0.
81015	0.	0.	0.	0.	0.
81016	0.	0.	0.	0.	0.
81017	0.	0.	0.	0.	0.
81018	0.	0.	0.	0.	0.
81019	0.	0.	0.	0.	0.
81020	0.	0.	0.	0.	0.
81021	0.	0.	0.	0.	0.
81022	0.	0.	0.	0.	0.
81023	0.	0.	0.	0.	0.
81024	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE223 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
811 1	0.	0.	0.	0.	0.
811 2	0.	0.	0.	0.	0.
811 3	0.	0.	0.	0.	0.
811 4	0.	0.	0.	0.	0.
811 5	0.	0.	0.	0.	0.
811 6	0.	0.	0.	0.	0.
811 7	0.	0.	0.	0.	0.
811 8	0.	0.	0.	0.	0.
811 9	0.	0.	0.	0.	0.
81110	0.	0.	0.	0.	0.
81111	0.	0.	0.	0.	0.
81112	0.	0.	0.	0.	0.
81113	0.	0.	0.	0.	0.
81114	0.	0.	0.	0.	0.
81115	0.	0.	0.	0.	0.
81116	0.	0.	0.	0.	0.
81117	0.	0.	0.	0.	0.
81118	0.	0.	0.	0.	0.
81119	0.	0.	0.	0.	0.
81120	0.	0.	0.	0.	0.
81121	0.	0.	0.	0.	0.
81122	0.	0.	0.	0.	0.
81123	0.	0.	0.	0.	0.
81124	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE224 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
812 1	0.	0.	0.	0.	0.
812 2	0.	0.	0.	0.	0.
812 3	0.	0.	0.	0.	0.
812 4	0.	0.	0.	0.	0.
812 5	0.	0.	0.	0.	0.
812 6	0.	0.	0.	0.	0.
812 7	0.	0.	0.	0.	0.
812 8	0.	0.	0.	0.	0.
812 9	0.	0.	0.	0.	0.
81210	0.	0.	0.	0.	0.
81211	0.	0.	0.	0.	0.
81212	0.	0.	0.	0.	0.
81213	0.	0.	0.	0.	0.
81214	0.	0.	0.	0.	0.
81215	0.	0.	0.	0.	0.
81216	0.	0.	0.	0.	0.
81217	0.	0.	0.	0.	0.
81218	0.	0.	0.	0.	0.
81219	0.	0.	0.	0.	0.
81220	0.	0.	0.	0.	0.
81221	0.	0.	0.	0.	0.
81222	0.	0.	0.	0.	0.
81223	0.	0.	0.	0.	0.
81224	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE225 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
813 1	0.	0.	0.	0.	0.
813 2	0.	0.	0.	0.	0.
813 3	0.	0.	0.	0.	0.
813 4	0.	0.	0.	0.	0.
813 5	0.	0.	0.	0.	0.
813 6	0.	0.	0.	0.	0.
813 7	0.	0.	0.	0.	0.
813 8	0.	0.	0.	0.	0.
813 9	0.	0.	0.	0.	0.
81310	0.	0.	0.	0.	0.
81311	0.	0.	0.	0.	0.
81312	0.	0.	0.	0.	0.
81313	0.	0.	0.	0.	0.
81314	0.	0.	0.	0.	0.
81315	0.	0.	0.	0.	0.
81316	0.	0.	0.	0.	0.
81317	0.	0.	0.	0.	0.
81318	0.	0.	0.	0.	0.
81319	0.	0.	0.	0.	0.
81320	0.	0.	0.	0.	0.
81321	0.	0.	0.	0.	0.
81322	0.	0.	0.	0.	0.
81323	0.	0.	0.	0.	0.
81324	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE226 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
814 1	0.	0.	0.	0.	0.
814 2	0.	0.	0.	0.	0.
814 3	0.	0.	0.	0.	0.
814 4	0.	0.	0.	0.	0.
814 5	0.	0.	0.	0.	0.
814 6	0.	0.	0.	0.	0.
814 7	0.	0.	0.	0.	0.
814 8	0.	0.	0.	0.	0.
814 9	0.	0.	0.	0.	0.
81410	0.	0.	0.	0.	0.
81411	0.	0.	0.	0.	0.
81412	0.	0.	0.	0.	0.
81413	0.	0.	0.	0.	0.
81414	0.	0.	0.	0.	0.
81415	0.	0.	0.	0.	0.
81416	0.	0.	0.	0.	0.
81417	0.	0.	0.	0.	0.
81418	0.	0.	0.	0.	0.
81419	0.	0.	0.	0.	0.
81420	0.	0.	0.	0.	0.
81421	0.	0.	0.	0.	0.
81422	0.	0.	0.	0.	0.
81423	0.	0.	0.	0.	0.
81424	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE227 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
815 1	0.	0.	0.	0.	0.
815 2	0.	0.	0.	0.	0.
815 3	0.	0.	0.	0.	0.
815 4	0.	0.	0.	0.	0.
815 5	0.	0.	0.	0.	0.
815 6	0.	0.	0.	0.	0.
815 7	0.	0.	0.	0.	0.
815 8	0.	0.	0.	0.	0.
815 9	0.	0.	0.	0.	0.
81510	0.	0.	0.	0.	0.
81511	0.	0.	0.	0.	0.
81512	0.	0.	0.	0.	0.
81513	0.	0.	0.	0.	0.
81514	0.	0.	0.	0.	0.
81515	0.	0.	0.	0.	0.
81516	0.	0.	0.	0.	0.
81517	0.	0.	0.	0.	0.
81518	0.	0.	0.	0.	0.
81519	0.	0.	0.	0.	0.
81520	0.	0.	0.	0.	0.
81521	0.	0.	0.	0.	0.
81522	0.	0.	0.	0.	0.
81523	0.	0.	0.	0.	0.
81524	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE228 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
816 1	0.	0.	0.	0.	0.
816 2	0.	0.	0.	0.	0.
816 3	0.	0.	0.	0.	0.
816 4	0.	0.	0.	0.	0.
816 5	0.	0.	0.	0.	0.
816 6	0.	0.	0.	0.	0.
816 7	0.	0.	0.	0.	0.
816 8	0.	0.	0.	0.	0.
816 9	0.	0.	0.	0.	0.
81610	0.	0.	0.	0.	0.
81611	0.	0.	0.	0.	0.
81612	0.	0.	0.	0.	0.
81613	0.	0.	0.	0.	0.
81614	0.	0.	0.	0.	0.
81615	0.	0.	0.	0.	0.
81616	0.	0.	0.	0.	0.
81617	0.	0.	0.	0.	0.
81618	0.	0.	0.	0.	0.
81619	0.	0.	0.	0.	0.
81620	0.	0.	0.	0.	0.
81621	0.	0.	0.	0.	0.
81622	0.	0.	0.	0.	0.
81623	0.	0.	0.	0.	0.
81624	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE229 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
817 1	0.	0.	0.	0.	0.
817 2	0.	0.	0.	0.	0.
817 3	0.	0.	0.	0.	0.
817 4	0.	0.	0.	0.	0.
817 5	0.	0.	0.	0.	0.
817 6	0.	0.	0.	0.	0.
817 7	0.	0.	0.	0.	0.
817 8	0.	0.	0.	0.	0.
817 9	0.	0.	0.	0.	0.
81710	0.	0.	0.	0.	0.
81711	0.	0.	0.	0.	0.
81712	0.	0.	0.	0.	0.
81713	0.	0.	0.	0.	0.
81714	0.	0.	0.	0.	0.
81715	0.	0.	0.	0.	0.
81716	0.	0.	0.	0.	0.
81717	0.	0.	0.	0.	0.
81718	0.	0.	0.	0.	0.
81719	0.	0.	0.	0.	0.
81720	0.	0.	0.	0.	0.
81721	0.	0.	0.	0.	0.
81722	0.	0.	0.	0.	0.
81723	0.	0.	0.	0.	0.
81724	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE230 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
818 1	0.	0.	0.	0.	0.
818 2	0.	0.	0.	0.	0.
818 3	0.	0.	0.	0.	0.
818 4	0.	0.	0.	0.	0.
818 5	0.	0.	0.	0.	0.
818 6	0.	0.	0.	0.	0.
818 7	0.	0.	0.	0.	0.
818 8	0.	0.	0.	0.	0.
818 9	0.	0.	0.	0.	0.
81810	0.	0.	0.	0.	0.
81811	0.	0.	0.	0.	0.
81812	0.	0.	0.	0.	0.
81813	0.	0.	0.	0.	0.
81814	0.	0.	0.	0.	0.
81815	0.	0.	0.	0.	0.
81816	0.	0.	0.	0.	0.
81817	0.	0.	0.	0.	0.
81818	0.	0.	0.	0.	0.
81819	0.	0.	0.	0.	0.
81820	0.	0.	0.	0.	0.
81821	0.	0.	0.	0.	0.
81822	0.	0.	0.	0.	0.
81823	0.	0.	0.	0.	0.
81824	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE231 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
819 1	0.	0.	0.	0.	0.
819 2	0.	0.	0.	0.	0.
819 3	0.	0.	0.	0.	0.
819 4	0.	0.	0.	0.	0.
819 5	0.	0.	0.	0.	0.
819 6	0.	0.	0.	0.	0.
819 7	0.	0.	0.	0.	0.
819 8	0.	0.	0.	0.	0.
819 9	0.	0.	0.	0.	0.
81910	0.	0.	0.	0.	0.
81911	0.	0.	0.	0.	0.
81912	0.	0.	0.	0.	0.
81913	0.	0.	0.	0.	0.
81914	0.	0.	0.	0.	0.
81915	0.	0.	0.	0.	0.
81916	0.	0.	0.	0.	0.
81917	0.	0.	0.	0.	0.
81918	0.	0.	0.	0.	0.
81919	0.	0.	0.	0.	0.
81920	0.	0.	0.	0.	0.
81921	0.	0.	0.	0.	0.
81922	0.	0.	0.	0.	0.
81923	0.	0.	0.	0.	0.
81924	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE232 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
820 1	0.	0.	0.	0.	0.
820 2	0.	0.	0.	0.	0.
820 3	0.	0.	0.	0.	0.
820 4	0.	0.	0.	0.	0.
820 5	0.	0.	0.	0.	0.
820 6	0.	0.	0.	0.	0.
820 7	0.	0.	0.	0.	0.
820 8	0.	0.	0.	0.	0.
820 9	0.	0.	0.	0.	0.
82010	0.	0.	0.	0.	0.
82011	0.	0.	0.	0.	0.
82012	0.	0.	0.	0.	0.
82013	0.	0.	0.	0.	0.
82014	0.	0.	0.	0.	0.
82015	0.	0.	0.	0.	0.
82016	0.	0.	0.	0.	0.
82017	0.	0.	0.	0.	0.
82018	0.	0.	0.	0.	0.
82019	0.	0.	0.	0.	0.
82020	0.	0.	0.	0.	0.
82021	0.	0.	0.	0.	0.
82022	0.	0.	0.	0.	0.
82023	0.	0.	0.	0.	0.
82024	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE233 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
821 1	0.	0.	0.	0.	0.
821 2	0.	0.	0.	0.	0.
821 3	0.	0.	0.	0.	0.
821 4	0.	0.	0.	0.	0.
821 5	0.	0.	0.	0.	0.
821 6	0.	0.	0.	0.	0.
821 7	0.	0.	0.	0.	0.
821 8	0.	0.	0.	0.	0.
821 9	0.	0.	0.	0.	0.
82110	0.	0.	0.	0.	0.
82111	0.	0.	0.	0.	0.
82112	0.	0.	0.	0.	0.
82113	0.	0.	0.	0.	0.
82114	0.	0.	0.	0.	0.
82115	0.	0.	0.	0.	0.
82116	0.	0.	0.	0.	0.
82117	0.	0.	0.	0.	0.
82118	0.	0.	0.	0.	0.
82119	0.	0.	0.	0.	0.
82120	0.	0.	0.	0.	0.
82121	0.	0.	0.	0.	0.
82122	0.	0.	0.	0.	0.
82123	0.	0.	0.	0.	0.
82124	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE234 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
822 1	0.	0.	0.	0.	0.
822 2	0.	0.	0.	0.	0.
822 3	0.	0.	0.	0.	0.
822 4	0.	0.	0.	0.	0.
822 5	0.	0.	0.	0.	0.
822 6	0.	0.	0.	0.	0.
822 7	0.	0.	0.	0.	0.
822 8	0.	0.	0.	0.	0.
822 9	0.	0.	0.	0.	0.
82210	0.	0.	0.	0.	0.
82211	0.	0.	0.	0.	0.
82212	0.	0.	0.	0.	0.
82213	0.	0.	0.	0.	0.
82214	0.	0.	0.	0.	0.
82215	0.	0.	0.	0.	0.
82216	0.	0.	0.	0.	0.
82217	0.	0.	0.	0.	0.
82218	0.	0.	0.	0.	0.
82219	0.	0.	0.	0.	0.
82220	0.	0.	0.	0.	0.
82221	0.	0.	0.	0.	0.
82222	0.	0.	0.	0.	0.
82223	0.	0.	0.	0.	0.
82224	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE235 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
823 1	0.	0.	0.	0.	0.
823 2	0.	0.	0.	0.	0.
823 3	0.	0.	0.	0.	0.
823 4	0.	0.	0.	0.	0.
823 5	0.	0.	0.	0.	0.
823 6	0.	0.	0.	0.	0.
823 7	0.	0.	0.	0.	0.
823 8	0.	0.	0.	0.	0.
823 9	0.	0.	0.	0.	0.
82310	0.	0.	0.	0.	0.
82311	0.	0.	0.	0.	0.
82312	0.	0.	0.	0.	0.
82313	0.	0.	0.	0.	0.
82314	0.	0.	0.	0.	0.
82315	0.	0.	0.	0.	0.
82316	0.	0.	0.	0.	0.
82317	0.	0.	0.	0.	0.
82318	0.	0.	0.	0.	0.
82319	0.	0.	0.	0.	0.
82320	0.	0.	0.	0.	0.
82321	0.	0.	0.	0.	0.
82322	0.	0.	0.	0.	0.
82323	0.	0.	0.	0.	0.
82324	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE236 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
824 1	0.	0.	0.	0.	0.
824 2	0.	0.	0.	0.	0.
824 3	0.	0.	0.	0.	0.
824 4	0.	0.	0.	0.	0.
824 5	0.	0.	0.	0.	0.
824 6	0.	0.	0.	0.	0.
824 7	0.	0.	0.	0.	0.
824 8	0.	0.	0.	0.	0.
824 9	0.	0.	0.	0.	0.
82410	0.	0.	0.	0.	0.
82411	0.	0.	0.	0.	0.
82412	0.	0.	0.	0.	0.
82413	0.	0.	0.	0.	0.
82414	0.	0.	0.	0.	0.
82415	0.	0.	0.	0.	0.
82416	0.	0.	0.	0.	0.
82417	0.	0.	0.	0.	0.
82418	0.	0.	0.	0.	0.
82419	0.	0.	0.	0.	0.
82420	0.	0.	0.	0.	0.
82421	0.	0.	0.	0.	0.
82422	0.	0.	0.	0.	0.
82423	0.	0.	0.	0.	0.
82424	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE237 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
825 1	0.	0.	0.	0.	0.
825 2	0.	0.	0.	0.	0.
825 3	0.	0.	0.	0.	0.
825 4	0.	0.	0.	0.	0.
825 5	0.	0.	0.	0.	0.
825 6	0.	0.	0.	0.	0.
825 7	0.	0.	0.	0.	0.
825 8	0.	0.	0.	0.	0.
825 9	0.	0.	0.	0.	0.
82510	0.	0.	0.	0.	0.
82511	0.	0.	0.	0.	0.
82512	0.	0.	0.	0.	0.
82513	0.	0.	0.	0.	0.
82514	0.	0.	0.	0.	0.
82515	0.	0.	0.	0.	0.
82516	0.	0.	0.	0.	0.
82517	0.	0.	0.	0.	0.
82518	0.	0.	0.	0.	0.
82519	0.	0.	0.	0.	0.
82520	0.	0.	0.	0.	0.
82521	0.	0.	0.	0.	0.
82522	0.	0.	0.	0.	0.
82523	0.	0.	0.	0.	0.
82524	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE238 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
826 1	0.	0.	0.	0.	0.
826 2	0.	0.	0.	0.	0.
826 3	0.	0.	0.	0.	0.
826 4	0.	0.	0.	0.	0.
826 5	0.	0.	0.	0.	0.
826 6	0.	0.	0.	0.	0.
826 7	0.	0.	0.	0.	0.
826 8	0.	0.	0.	0.	0.
826 9	0.	0.	0.	0.	0.
82610	0.	0.	0.	0.	0.
82611	0.	0.	0.	0.	0.
82612	0.	0.	0.	0.	0.
82613	0.	0.	0.	0.	0.
82614	0.	0.	0.	0.	0.
82615	0.	0.	0.	0.	0.
82616	0.	0.	0.	0.	0.
82617	0.	0.	0.	0.	0.
82618	0.	0.	0.	0.	0.
82619	0.	0.	0.	0.	0.
82620	0.	0.	0.	0.	0.
82621	0.	0.	0.	0.	0.
82622	0.	0.	0.	0.	0.
82623	0.	0.	0.	0.	0.
82624	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE239 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
827 1	0.	0.	0.	0.	0.
827 2	0.	0.	0.	0.	0.
827 3	0.	0.	0.	0.	0.
827 4	0.	0.	0.	0.	0.
827 5	0.	0.	0.	0.	0.
827 6	0.	0.	0.	0.	0.
827 7	0.	0.	0.	0.	0.
827 8	0.	0.	0.	0.	0.
827 9	0.	0.	0.	0.	0.
82710	0.	0.	0.	0.	0.
82711	0.	0.	0.	0.	0.
82712	0.	0.	0.	0.	0.
82713	0.	0.	0.	0.	0.
82714	0.	0.	0.	0.	0.
82715	0.	0.	0.	0.	0.
82716	0.	0.	0.	0.	0.
82717	0.	0.	0.	0.	0.
82718	0.	0.	0.	0.	0.
82719	0.	0.	0.	0.	0.
82720	0.	0.	0.	0.	0.
82721	0.	0.	0.	0.	0.
82722	0.	0.	0.	0.	0.
82723	0.	0.	0.	0.	0.
82724	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE240 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
828 1	0.	0.	0.	0.	0.
828 2	0.	0.	0.	0.	0.
828 3	0.	0.	0.	0.	0.
828 4	0.	0.	0.	0.	0.
828 5	0.	0.	0.	0.	0.
828 6	0.	0.	0.	0.	0.
828 7	0.	0.	0.	0.	0.
828 8	0.	0.	0.	0.	0.
828 9	0.	0.	0.	0.	0.
82810	0.	0.	0.	0.	0.
82811	0.	0.	0.	0.	0.
82812	0.	0.	0.	0.	0.
82813	0.	0.	0.	0.	0.
82814	0.	0.	0.	0.	0.
82815	0.	0.	0.	0.	0.
82816	0.	0.	0.	0.	0.
82817	0.	0.	0.	0.	0.
82818	0.	0.	0.	0.	0.
82819	0.	0.	0.	0.	0.
82820	0.	0.	0.	0.	0.
82821	0.	0.	0.	0.	0.
82822	0.	0.	0.	0.	0.
82823	0.	0.	0.	0.	0.
82824	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE241 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
829 1	0.	0.	0.	0.	0.
829 2	0.	0.	0.	0.	0.
829 3	0.	0.	0.	0.	0.
829 4	0.	0.	0.	0.	0.
829 5	0.	0.	0.	0.	0.
829 6	0.	0.	0.	0.	0.
829 7	0.	0.	0.	0.	0.
829 8	0.	0.	0.	0.	0.
829 9	0.	0.	0.	0.	0.
82910	0.	0.	0.	0.	0.
82911	0.	0.	0.	0.	0.
82912	0.	0.	0.	0.	0.
82913	0.	0.	0.	0.	0.
82914	0.	0.	0.	0.	0.
82915	0.	0.	0.	0.	0.
82916	0.	0.	0.	0.	0.
82917	0.	0.	0.	0.	0.
82918	0.	0.	0.	0.	0.
82919	0.	0.	0.	0.	0.
82920	0.	0.	0.	0.	0.
82921	0.	0.	0.	0.	0.
82922	0.	0.	0.	0.	0.
82923	0.	0.	0.	0.	0.
82924	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE242 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
830 1	0.	0.	0.	0.	0.
830 2	0.	0.	0.	0.	0.
830 3	0.	0.	0.	0.	0.
830 4	0.	0.	0.	0.	0.
830 5	0.	0.	0.	0.	0.
830 6	0.	0.	0.	0.	0.
830 7	0.	0.	0.	0.	0.
830 8	0.	0.	0.	0.	0.
830 9	0.	0.	0.	0.	0.
83010	0.	0.	0.	0.	0.
83011	0.	0.	0.	0.	0.
83012	0.	0.	0.	0.	0.
83013	0.	0.	0.	0.	0.
83014	0.	0.	0.	0.	0.
83015	0.	0.	0.	0.	0.
83016	0.	0.	0.	0.	0.
83017	0.	0.	0.	0.	0.
83018	0.	0.	0.	0.	0.
83019	0.	0.	0.	0.	0.
83020	0.	0.	0.	0.	0.
83021	0.	0.	0.	0.	0.
83022	0.	0.	0.	0.	0.
83023	0.	0.	0.	0.	0.
83024	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE243 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
831 1	0.	0.	0.	0.	0.
831 2	0.	0.	0.	0.	0.
831 3	0.	0.	0.	0.	0.
831 4	0.	0.	0.	0.	0.
831 5	0.	0.	0.	0.	0.
831 6	0.	0.	0.	0.	0.
831 7	0.	0.	0.	0.	0.
831 8	0.	0.	0.	0.	0.
831 9	0.	0.	0.	0.	0.
83110	0.	0.	0.	0.	0.
83111	0.	0.	0.	0.	0.
83112	0.	0.	0.	0.	0.
83113	0.	0.	0.	0.	0.
83114	0.	0.	0.	0.	0.
83115	0.	0.	0.	0.	0.
83116	0.	0.	0.	0.	0.
83117	0.	0.	0.	0.	0.
83118	0.	0.	0.	0.	0.
83119	0.	0.	0.	0.	0.
83120	0.	0.	0.	0.	0.
83121	0.	0.	0.	0.	0.
83122	0.	0.	0.	0.	0.
83123	0.	0.	0.	0.	0.
83124	0.	0.	0.	0.	0.
DAILY SUMMARY (AUG 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (AUG)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE244 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 1 1	0.	0.	0.	0.	0.
9 1 2	0.	0.	0.	0.	0.
9 1 3	0.	0.	0.	0.	0.
9 1 4	0.	0.	0.	0.	0.
9 1 5	0.	0.	0.	0.	0.
9 1 6	0.	0.	0.	0.	0.
9 1 7	0.	0.	0.	0.	0.
9 1 8	0.	0.	0.	0.	0.
9 1 9	0.	0.	0.	0.	0.
9 110	0.	0.	0.	0.	0.
9 111	0.	0.	0.	0.	0.
9 112	0.	0.	0.	0.	0.
9 113	0.	0.	0.	0.	0.
9 114	0.	0.	0.	0.	0.
9 115	0.	0.	0.	0.	0.
9 116	0.	0.	0.	0.	0.
9 117	0.	0.	0.	0.	0.
9 118	0.	0.	0.	0.	0.
9 119	0.	0.	0.	0.	0.
9 120	0.	0.	0.	0.	0.
9 121	0.	0.	0.	0.	0.
9 122	0.	0.	0.	0.	0.
9 123	0.	0.	0.	0.	0.
9 124	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE245 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 2 1	0.	0.	0.	0.	0.
9 2 2	0.	0.	0.	0.	0.
9 2 3	0.	0.	0.	0.	0.
9 2 4	0.	0.	0.	0.	0.
9 2 5	0.	0.	0.	0.	0.
9 2 6	0.	0.	0.	0.	0.
9 2 7	0.	0.	0.	0.	0.
9 2 8	0.	0.	0.	0.	0.
9 2 9	0.	0.	0.	0.	0.
9 210	0.	0.	0.	0.	0.
9 211	0.	0.	0.	0.	0.
9 212	0.	0.	0.	0.	0.
9 213	0.	0.	0.	0.	0.
9 214	0.	0.	0.	0.	0.
9 215	0.	0.	0.	0.	0.
9 216	0.	0.	0.	0.	0.
9 217	0.	0.	0.	0.	0.
9 218	0.	0.	0.	0.	0.
9 219	0.	0.	0.	0.	0.
9 220	0.	0.	0.	0.	0.
9 221	0.	0.	0.	0.	0.
9 222	0.	0.	0.	0.	0.
9 223	0.	0.	0.	0.	0.
9 224	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE246 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 3 1	0.	0.	0.	0.	0.
9 3 2	0.	0.	0.	0.	0.
9 3 3	0.	0.	0.	0.	0.
9 3 4	0.	0.	0.	0.	0.
9 3 5	0.	0.	0.	0.	0.
9 3 6	0.	0.	0.	0.	0.
9 3 7	0.	0.	0.	0.	0.
9 3 8	0.	0.	0.	0.	0.
9 3 9	0.	0.	0.	0.	0.
9 310	0.	0.	0.	0.	0.
9 311	0.	0.	0.	0.	0.
9 312	0.	0.	0.	0.	0.
9 313	0.	0.	0.	0.	0.
9 314	0.	0.	0.	0.	0.
9 315	0.	0.	0.	0.	0.
9 316	0.	0.	0.	0.	0.
9 317	0.	0.	0.	0.	0.
9 318	0.	0.	0.	0.	0.
9 319	0.	0.	0.	0.	0.
9 320	0.	0.	0.	0.	0.
9 321	0.	0.	0.	0.	0.
9 322	0.	0.	0.	0.	0.
9 323	0.	0.	0.	0.	0.
9 324	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE247 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 4 1	0.	0.	0.	0.	0.
9 4 2	0.	0.	0.	0.	0.
9 4 3	0.	0.	0.	0.	0.
9 4 4	0.	0.	0.	0.	0.
9 4 5	0.	0.	0.	0.	0.
9 4 6	0.	0.	0.	0.	0.
9 4 7	0.	0.	0.	0.	0.
9 4 8	0.	0.	0.	0.	0.
9 4 9	0.	0.	0.	0.	0.
9 410	0.	0.	0.	0.	0.
9 411	0.	0.	0.	0.	0.
9 412	0.	0.	0.	0.	0.
9 413	0.	0.	0.	0.	0.
9 414	0.	0.	0.	0.	0.
9 415	0.	0.	0.	0.	0.
9 416	0.	0.	0.	0.	0.
9 417	0.	0.	0.	0.	0.
9 418	0.	0.	0.	0.	0.
9 419	0.	0.	0.	0.	0.
9 420	0.	0.	0.	0.	0.
9 421	0.	0.	0.	0.	0.
9 422	0.	0.	0.	0.	0.
9 423	0.	0.	0.	0.	0.
9 424	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE248 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 5 1	0.	0.	0.	0.	0.
9 5 2	0.	0.	0.	0.	0.
9 5 3	0.	0.	0.	0.	0.
9 5 4	0.	0.	0.	0.	0.
9 5 5	0.	0.	0.	0.	0.
9 5 6	0.	0.	0.	0.	0.
9 5 7	0.	0.	0.	0.	0.
9 5 8	0.	0.	0.	0.	0.
9 5 9	0.	0.	0.	0.	0.
9 510	0.	0.	0.	0.	0.
9 511	0.	0.	0.	0.	0.
9 512	0.	0.	0.	0.	0.
9 513	0.	0.	0.	0.	0.
9 514	0.	0.	0.	0.	0.
9 515	0.	0.	0.	0.	0.
9 516	0.	0.	0.	0.	0.
9 517	0.	0.	0.	0.	0.
9 518	0.	0.	0.	0.	0.
9 519	0.	0.	0.	0.	0.
9 520	0.	0.	0.	0.	0.
9 521	0.	0.	0.	0.	0.
9 522	0.	0.	0.	0.	0.
9 523	0.	0.	0.	0.	0.
9 524	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE249 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 6 1	0.	0.	0.	0.	0.
9 6 2	0.	0.	0.	0.	0.
9 6 3	0.	0.	0.	0.	0.
9 6 4	0.	0.	0.	0.	0.
9 6 5	0.	0.	0.	0.	0.
9 6 6	0.	0.	0.	0.	0.
9 6 7	0.	0.	0.	0.	0.
9 6 8	0.	0.	0.	0.	0.
9 6 9	0.	0.	0.	0.	0.
9 610	0.	0.	0.	0.	0.
9 611	0.	0.	0.	0.	0.
9 612	0.	0.	0.	0.	0.
9 613	0.	0.	0.	0.	0.
9 614	0.	0.	0.	0.	0.
9 615	0.	0.	0.	0.	0.
9 616	0.	0.	0.	0.	0.
9 617	0.	0.	0.	0.	0.
9 618	0.	0.	0.	0.	0.
9 619	0.	0.	0.	0.	0.
9 620	0.	0.	0.	0.	0.
9 621	0.	0.	0.	0.	0.
9 622	0.	0.	0.	0.	0.
9 623	0.	0.	0.	0.	0.
9 624	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE250 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 7 1	0.	0.	0.	0.	0.
9 7 2	0.	0.	0.	0.	0.
9 7 3	0.	0.	0.	0.	0.
9 7 4	0.	0.	0.	0.	0.
9 7 5	0.	0.	0.	0.	0.
9 7 6	0.	0.	0.	0.	0.
9 7 7	0.	0.	0.	0.	0.
9 7 8	0.	0.	0.	0.	0.
9 7 9	0.	0.	0.	0.	0.
9 710	0.	0.	0.	0.	0.
9 711	0.	0.	0.	0.	0.
9 712	0.	0.	0.	0.	0.
9 713	0.	0.	0.	0.	0.
9 714	0.	0.	0.	0.	0.
9 715	0.	0.	0.	0.	0.
9 716	0.	0.	0.	0.	0.
9 717	0.	0.	0.	0.	0.
9 718	0.	0.	0.	0.	0.
9 719	0.	0.	0.	0.	0.
9 720	0.	0.	0.	0.	0.
9 721	0.	0.	0.	0.	0.
9 722	0.	0.	0.	0.	0.
9 723	0.	0.	0.	0.	0.
9 724	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE251 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 8 1	0.	0.	0.	0.	0.
9 8 2	0.	0.	0.	0.	0.
9 8 3	0.	0.	0.	0.	0.
9 8 4	0.	0.	0.	0.	0.
9 8 5	0.	0.	0.	0.	0.
9 8 6	0.	0.	0.	0.	0.
9 8 7	0.	0.	0.	0.	0.
9 8 8	0.	0.	0.	0.	0.
9 8 9	0.	0.	0.	0.	0.
9 810	0.	0.	0.	0.	0.
9 811	0.	0.	0.	0.	0.
9 812	0.	0.	0.	0.	0.
9 813	0.	0.	0.	0.	0.
9 814	0.	0.	0.	0.	0.
9 815	0.	0.	0.	0.	0.
9 816	0.	0.	0.	0.	0.
9 817	0.	0.	0.	0.	0.
9 818	0.	0.	0.	0.	0.
9 819	0.	0.	0.	0.	0.
9 820	0.	0.	0.	0.	0.
9 821	0.	0.	0.	0.	0.
9 822	0.	0.	0.	0.	0.
9 823	0.	0.	0.	0.	0.
9 824	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE252 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
9 9 1	0.	0.	0.	0.	0.
9 9 2	0.	0.	0.	0.	0.
9 9 3	0.	0.	0.	0.	0.
9 9 4	0.	0.	0.	0.	0.
9 9 5	0.	0.	0.	0.	0.
9 9 6	0.	0.	0.	0.	0.
9 9 7	0.	0.	0.	0.	0.
9 9 8	0.	0.	0.	0.	0.
9 9 9	0.	0.	0.	0.	0.
9 910	0.	0.	0.	0.	0.
9 911	0.	0.	0.	0.	0.
9 912	0.	0.	0.	0.	0.
9 913	0.	0.	0.	0.	0.
9 914	0.	0.	0.	0.	0.
9 915	0.	0.	0.	0.	0.
9 916	0.	0.	0.	0.	0.
9 917	0.	0.	0.	0.	0.
9 918	0.	0.	0.	0.	0.
9 919	0.	0.	0.	0.	0.
9 920	0.	0.	0.	0.	0.
9 921	0.	0.	0.	0.	0.
9 922	0.	0.	0.	0.	0.
9 923	0.	0.	0.	0.	0.
9 924	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE253 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
910 1	0.	0.	0.	0.	0.
910 2	0.	0.	0.	0.	0.
910 3	0.	0.	0.	0.	0.
910 4	0.	0.	0.	0.	0.
910 5	0.	0.	0.	0.	0.
910 6	0.	0.	0.	0.	0.
910 7	0.	0.	0.	0.	0.
910 8	0.	0.	0.	0.	0.
910 9	0.	0.	0.	0.	0.
91010	0.	0.	0.	0.	0.
91011	0.	0.	0.	0.	0.
91012	0.	0.	0.	0.	0.
91013	0.	0.	0.	0.	0.
91014	0.	0.	0.	0.	0.
91015	0.	0.	0.	0.	0.
91016	0.	0.	0.	0.	0.
91017	0.	0.	0.	0.	0.
91018	0.	0.	0.	0.	0.
91019	0.	0.	0.	0.	0.
91020	0.	0.	0.	0.	0.
91021	0.	0.	0.	0.	0.
91022	0.	0.	0.	0.	0.
91023	0.	0.	0.	0.	0.
91024	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE254 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
911 1	0.	0.	0.	0.	0.
911 2	0.	0.	0.	0.	0.
911 3	0.	0.	0.	0.	0.
911 4	0.	0.	0.	0.	0.
911 5	0.	0.	0.	0.	0.
911 6	0.	0.	0.	0.	0.
911 7	0.	0.	0.	0.	0.
911 8	0.	0.	0.	0.	0.
911 9	0.	0.	0.	0.	0.
91110	0.	0.	0.	0.	0.
91111	0.	0.	0.	0.	0.
91112	0.	0.	0.	0.	0.
91113	0.	0.	0.	0.	0.
91114	0.	0.	0.	0.	0.
91115	0.	0.	0.	0.	0.
91116	0.	0.	0.	0.	0.
91117	0.	0.	0.	0.	0.
91118	0.	0.	0.	0.	0.
91119	0.	0.	0.	0.	0.
91120	0.	0.	0.	0.	0.
91121	0.	0.	0.	0.	0.
91122	0.	0.	0.	0.	0.
91123	0.	0.	0.	0.	0.
91124	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE255 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
912 1	0.	0.	0.	0.	0.
912 2	0.	0.	0.	0.	0.
912 3	0.	0.	0.	0.	0.
912 4	0.	0.	0.	0.	0.
912 5	0.	0.	0.	0.	0.
912 6	0.	0.	0.	0.	0.
912 7	0.	0.	0.	0.	0.
912 8	0.	0.	0.	0.	0.
912 9	0.	0.	0.	0.	0.
91210	0.	0.	0.	0.	0.
91211	0.	0.	0.	0.	0.
91212	0.	0.	0.	0.	0.
91213	0.	0.	0.	0.	0.
91214	0.	0.	0.	0.	0.
91215	0.	0.	0.	0.	0.
91216	0.	0.	0.	0.	0.
91217	0.	0.	0.	0.	0.
91218	0.	0.	0.	0.	0.
91219	0.	0.	0.	0.	0.
91220	0.	0.	0.	0.	0.
91221	0.	0.	0.	0.	0.
91222	0.	0.	0.	0.	0.
91223	0.	0.	0.	0.	0.
91224	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE256 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
913 1	0.	0.	0.	0.	0.
913 2	0.	0.	0.	0.	0.
913 3	0.	0.	0.	0.	0.
913 4	0.	0.	0.	0.	0.
913 5	0.	0.	0.	0.	0.
913 6	0.	0.	0.	0.	0.
913 7	0.	0.	0.	0.	0.
913 8	0.	0.	0.	0.	0.
913 9	0.	0.	0.	0.	0.
91310	0.	0.	0.	0.	0.
91311	0.	0.	0.	0.	0.
91312	0.	0.	0.	0.	0.
91313	0.	0.	0.	0.	0.
91314	0.	0.	0.	0.	0.
91315	0.	0.	0.	0.	0.
91316	0.	0.	0.	0.	0.
91317	0.	0.	0.	0.	0.
91318	0.	0.	0.	0.	0.
91319	0.	0.	0.	0.	0.
91320	0.	0.	0.	0.	0.
91321	0.	0.	0.	0.	0.
91322	0.	0.	0.	0.	0.
91323	0.	0.	0.	0.	0.
91324	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE257 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
914 1	0.	0.	0.	0.	0.
914 2	0.	0.	0.	0.	0.
914 3	0.	0.	0.	0.	0.
914 4	0.	0.	0.	0.	0.
914 5	0.	0.	0.	0.	0.
914 6	0.	0.	0.	0.	0.
914 7	0.	0.	0.	0.	0.
914 8	0.	0.	0.	0.	0.
914 9	0.	0.	0.	0.	0.
91410	0.	0.	0.	0.	0.
91411	0.	0.	0.	0.	0.
91412	0.	0.	0.	0.	0.
91413	0.	0.	0.	0.	0.
91414	0.	0.	0.	0.	0.
91415	0.	0.	0.	0.	0.
91416	0.	0.	0.	0.	0.
91417	0.	0.	0.	0.	0.
91418	0.	0.	0.	0.	0.
91419	0.	0.	0.	0.	0.
91420	0.	0.	0.	0.	0.
91421	0.	0.	0.	0.	0.
91422	0.	0.	0.	0.	0.
91423	0.	0.	0.	0.	0.
91424	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE258 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
915 1	0.	0.	0.	0.	0.
915 2	0.	0.	0.	0.	0.
915 3	0.	0.	0.	0.	0.
915 4	0.	0.	0.	0.	0.
915 5	0.	0.	0.	0.	0.
915 6	0.	0.	0.	0.	0.
915 7	0.	0.	0.	0.	0.
915 8	0.	0.	0.	0.	0.
915 9	0.	0.	0.	0.	0.
91510	0.	0.	0.	0.	0.
91511	0.	0.	0.	0.	0.
91512	0.	0.	0.	0.	0.
91513	0.	0.	0.	0.	0.
91514	0.	0.	0.	0.	0.
91515	0.	0.	0.	0.	0.
91516	0.	0.	0.	0.	0.
91517	0.	0.	0.	0.	0.
91518	0.	0.	0.	0.	0.
91519	0.	0.	0.	0.	0.
91520	0.	0.	0.	0.	0.
91521	0.	0.	0.	0.	0.
91522	0.	0.	0.	0.	0.
91523	0.	0.	0.	0.	0.
91524	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE259 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
916 1	0.	0.	0.	0.	0.
916 2	0.	0.	0.	0.	0.
916 3	0.	0.	0.	0.	0.
916 4	0.	0.	0.	0.	0.
916 5	0.	0.	0.	0.	0.
916 6	0.	0.	0.	0.	0.
916 7	0.	0.	0.	0.	0.
916 8	0.	0.	0.	0.	0.
916 9	0.	0.	0.	0.	0.
91610	0.	0.	0.	0.	0.
91611	0.	0.	0.	0.	0.
91612	0.	0.	0.	0.	0.
91613	0.	0.	0.	0.	0.
91614	0.	0.	0.	0.	0.
91615	0.	0.	0.	0.	0.
91616	0.	0.	0.	0.	0.
91617	0.	0.	0.	0.	0.
91618	0.	0.	0.	0.	0.
91619	0.	0.	0.	0.	0.
91620	0.	0.	0.	0.	0.
91621	0.	0.	0.	0.	0.
91622	0.	0.	0.	0.	0.
91623	0.	0.	0.	0.	0.
91624	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE260 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
917 1	0.	0.	0.	0.	0.
917 2	0.	0.	0.	0.	0.
917 3	0.	0.	0.	0.	0.
917 4	0.	0.	0.	0.	0.
917 5	0.	0.	0.	0.	0.
917 6	0.	0.	0.	0.	0.
917 7	0.	0.	0.	0.	0.
917 8	0.	0.	0.	0.	0.
917 9	0.	0.	0.	0.	0.
91710	0.	0.	0.	0.	0.
91711	0.	0.	0.	0.	0.
91712	0.	0.	0.	0.	0.
91713	0.	0.	0.	0.	0.
91714	0.	0.	0.	0.	0.
91715	0.	0.	0.	0.	0.
91716	0.	0.	0.	0.	0.
91717	0.	0.	0.	0.	0.
91718	0.	0.	0.	0.	0.
91719	0.	0.	0.	0.	0.
91720	0.	0.	0.	0.	0.
91721	0.	0.	0.	0.	0.
91722	0.	0.	0.	0.	0.
91723	0.	0.	0.	0.	0.
91724	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE261 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
918 1	0.	0.	0.	0.	0.
918 2	0.	0.	0.	0.	0.
918 3	0.	0.	0.	0.	0.
918 4	0.	0.	0.	0.	0.
918 5	0.	0.	0.	0.	0.
918 6	0.	0.	0.	0.	0.
918 7	0.	0.	0.	0.	0.
918 8	0.	0.	0.	0.	0.
918 9	0.	0.	0.	0.	0.
91810	0.	0.	0.	0.	0.
91811	0.	0.	0.	0.	0.
91812	0.	0.	0.	0.	0.
91813	0.	0.	0.	0.	0.
91814	0.	0.	0.	0.	0.
91815	0.	0.	0.	0.	0.
91816	0.	0.	0.	0.	0.
91817	0.	0.	0.	0.	0.
91818	0.	0.	0.	0.	0.
91819	0.	0.	0.	0.	0.
91820	0.	0.	0.	0.	0.
91821	0.	0.	0.	0.	0.
91822	0.	0.	0.	0.	0.
91823	0.	0.	0.	0.	0.
91824	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE262 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
919 1	0.	0.	0.	0.	0.
919 2	0.	0.	0.	0.	0.
919 3	0.	0.	0.	0.	0.
919 4	0.	0.	0.	0.	0.
919 5	0.	0.	0.	0.	0.
919 6	0.	0.	0.	0.	0.
919 7	0.	0.	0.	0.	0.
919 8	0.	0.	0.	0.	0.
919 9	0.	0.	0.	0.	0.
91910	0.	0.	0.	0.	0.
91911	0.	0.	0.	0.	0.
91912	0.	0.	0.	0.	0.
91913	0.	0.	0.	0.	0.
91914	0.	0.	0.	0.	0.
91915	0.	0.	0.	0.	0.
91916	0.	0.	0.	0.	0.
91917	0.	0.	0.	0.	0.
91918	0.	0.	0.	0.	0.
91919	0.	0.	0.	0.	0.
91920	0.	0.	0.	0.	0.
91921	0.	0.	0.	0.	0.
91922	0.	0.	0.	0.	0.
91923	0.	0.	0.	0.	0.
91924	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE263 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
920 1	0.	0.	0.	0.	0.
920 2	0.	0.	0.	0.	0.
920 3	0.	0.	0.	0.	0.
920 4	0.	0.	0.	0.	0.
920 5	0.	0.	0.	0.	0.
920 6	0.	0.	0.	0.	0.
920 7	0.	0.	0.	0.	0.
920 8	0.	0.	0.	0.	0.
920 9	0.	0.	0.	0.	0.
92010	0.	0.	0.	0.	0.
92011	0.	0.	0.	0.	0.
92012	0.	0.	0.	0.	0.
92013	0.	0.	0.	0.	0.
92014	0.	0.	0.	0.	0.
92015	0.	0.	0.	0.	0.
92016	0.	0.	0.	0.	0.
92017	0.	0.	0.	0.	0.
92018	0.	0.	0.	0.	0.
92019	0.	0.	0.	0.	0.
92020	0.	0.	0.	0.	0.
92021	0.	0.	0.	0.	0.
92022	0.	0.	0.	0.	0.
92023	0.	0.	0.	0.	0.
92024	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE264 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
921 1	0.	0.	0.	0.	0.
921 2	0.	0.	0.	0.	0.
921 3	0.	0.	0.	0.	0.
921 4	0.	0.	0.	0.	0.
921 5	0.	0.	0.	0.	0.
921 6	0.	0.	0.	0.	0.
921 7	0.	0.	0.	0.	0.
921 8	0.	0.	0.	0.	0.
921 9	0.	0.	0.	0.	0.
92110	0.	0.	0.	0.	0.
92111	0.	0.	0.	0.	0.
92112	0.	0.	0.	0.	0.
92113	0.	0.	0.	0.	0.
92114	0.	0.	0.	0.	0.
92115	0.	0.	0.	0.	0.
92116	0.	0.	0.	0.	0.
92117	0.	0.	0.	0.	0.
92118	0.	0.	0.	0.	0.
92119	0.	0.	0.	0.	0.
92120	0.	0.	0.	0.	0.
92121	0.	0.	0.	0.	0.
92122	0.	0.	0.	0.	0.
92123	0.	0.	0.	0.	0.
92124	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE265 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
922 1	0.	0.	0.	0.	0.
922 2	0.	0.	0.	0.	0.
922 3	0.	0.	0.	0.	0.
922 4	0.	0.	0.	0.	0.
922 5	0.	0.	0.	0.	0.
922 6	0.	0.	0.	0.	0.
922 7	0.	0.	0.	0.	0.
922 8	0.	0.	0.	0.	0.
922 9	0.	0.	0.	0.	0.
92210	0.	0.	0.	0.	0.
92211	0.	0.	0.	0.	0.
92212	0.	0.	0.	0.	0.
92213	0.	0.	0.	0.	0.
92214	0.	0.	0.	0.	0.
92215	0.	0.	0.	0.	0.
92216	0.	0.	0.	0.	0.
92217	0.	0.	0.	0.	0.
92218	0.	0.	0.	0.	0.
92219	0.	0.	0.	0.	0.
92220	0.	0.	0.	0.	0.
92221	0.	0.	0.	0.	0.
92222	0.	0.	0.	0.	0.
92223	0.	0.	0.	0.	0.
92224	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE266 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
923 1	0.	0.	0.	0.	0.
923 2	0.	0.	0.	0.	0.
923 3	0.	0.	0.	0.	0.
923 4	0.	0.	0.	0.	0.
923 5	0.	0.	0.	0.	0.
923 6	0.	0.	0.	0.	0.
923 7	0.	0.	0.	0.	0.
923 8	0.	0.	0.	0.	0.
923 9	0.	0.	0.	0.	0.
92310	0.	0.	0.	0.	0.
92311	0.	0.	0.	0.	0.
92312	0.	0.	0.	0.	0.
92313	0.	0.	0.	0.	0.
92314	0.	0.	0.	0.	0.
92315	0.	0.	0.	0.	0.
92316	0.	0.	0.	0.	0.
92317	0.	0.	0.	0.	0.
92318	0.	0.	0.	0.	0.
92319	0.	0.	0.	0.	0.
92320	0.	0.	0.	0.	0.
92321	0.	0.	0.	0.	0.
92322	0.	0.	0.	0.	0.
92323	0.	0.	0.	0.	0.
92324	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE267 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
924 1	0.	0.	0.	0.	0.
924 2	0.	0.	0.	0.	0.
924 3	0.	0.	0.	0.	0.
924 4	0.	0.	0.	0.	0.
924 5	0.	0.	0.	0.	0.
924 6	0.	0.	0.	0.	0.
924 7	0.	0.	0.	0.	0.
924 8	0.	0.	0.	0.	0.
924 9	0.	0.	0.	0.	0.
92410	0.	0.	0.	0.	0.
92411	0.	0.	0.	0.	0.
92412	0.	0.	0.	0.	0.
92413	0.	0.	0.	0.	0.
92414	0.	0.	0.	0.	0.
92415	0.	0.	0.	0.	0.
92416	0.	0.	0.	0.	0.
92417	0.	0.	0.	0.	0.
92418	0.	0.	0.	0.	0.
92419	0.	0.	0.	0.	0.
92420	0.	0.	0.	0.	0.
92421	0.	0.	0.	0.	0.
92422	0.	0.	0.	0.	0.
92423	0.	0.	0.	0.	0.
92424	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE268 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
925 1	0.	0.	0.	0.	0.
925 2	0.	0.	0.	0.	0.
925 3	0.	0.	0.	0.	0.
925 4	0.	0.	0.	0.	0.
925 5	0.	0.	0.	0.	0.
925 6	0.	0.	0.	0.	0.
925 7	0.	0.	0.	0.	0.
925 8	0.	0.	0.	0.	0.
925 9	0.	0.	0.	0.	0.
92510	0.	0.	0.	0.	0.
92511	0.	0.	0.	0.	0.
92512	0.	0.	0.	0.	0.
92513	0.	0.	0.	0.	0.
92514	0.	0.	0.	0.	0.
92515	0.	0.	0.	0.	0.
92516	0.	0.	0.	0.	0.
92517	0.	0.	0.	0.	0.
92518	0.	0.	0.	0.	0.
92519	0.	0.	0.	0.	0.
92520	0.	0.	0.	0.	0.
92521	0.	0.	0.	0.	0.
92522	0.	0.	0.	0.	0.
92523	0.	0.	0.	0.	0.
92524	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE269 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
926 1	0.	0.	0.	0.	0.
926 2	0.	0.	0.	0.	0.
926 3	0.	0.	0.	0.	0.
926 4	0.	0.	0.	0.	0.
926 5	0.	0.	0.	0.	0.
926 6	0.	0.	0.	0.	0.
926 7	0.	0.	0.	0.	0.
926 8	0.	0.	0.	0.	0.
926 9	0.	0.	0.	0.	0.
92610	0.	0.	0.	0.	0.
92611	0.	0.	0.	0.	0.
92612	0.	0.	0.	0.	0.
92613	0.	0.	0.	0.	0.
92614	0.	0.	0.	0.	0.
92615	0.	0.	0.	0.	0.
92616	0.	0.	0.	0.	0.
92617	0.	0.	0.	0.	0.
92618	0.	0.	0.	0.	0.
92619	0.	0.	0.	0.	0.
92620	0.	0.	0.	0.	0.
92621	0.	0.	0.	0.	0.
92622	0.	0.	0.	0.	0.
92623	0.	0.	0.	0.	0.
92624	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE270 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
927 1	0.	0.	0.	0.	0.
927 2	0.	0.	0.	0.	0.
927 3	0.	0.	0.	0.	0.
927 4	0.	0.	0.	0.	0.
927 5	0.	0.	0.	0.	0.
927 6	0.	0.	0.	0.	0.
927 7	0.	0.	0.	0.	0.
927 8	0.	0.	0.	0.	0.
927 9	0.	0.	0.	0.	0.
92710	0.	0.	0.	0.	0.
92711	0.	0.	0.	0.	0.
92712	0.	0.	0.	0.	0.
92713	0.	0.	0.	0.	0.
92714	0.	0.	0.	0.	0.
92715	0.	0.	0.	0.	0.
92716	0.	0.	0.	0.	0.
92717	0.	0.	0.	0.	0.
92718	0.	0.	0.	0.	0.
92719	0.	0.	0.	0.	0.
92720	0.	0.	0.	0.	0.
92721	0.	0.	0.	0.	0.
92722	0.	0.	0.	0.	0.
92723	0.	0.	0.	0.	0.
92724	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE271 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
928 1	0.	0.	0.	0.	0.
928 2	0.	0.	0.	0.	0.
928 3	0.	0.	0.	0.	0.
928 4	0.	0.	0.	0.	0.
928 5	0.	0.	0.	0.	0.
928 6	0.	0.	0.	0.	0.
928 7	0.	0.	0.	0.	0.
928 8	0.	0.	0.	0.	0.
928 9	0.	0.	0.	0.	0.
92810	0.	0.	0.	0.	0.
92811	0.	0.	0.	0.	0.
92812	0.	0.	0.	0.	0.
92813	0.	0.	0.	0.	0.
92814	0.	0.	0.	0.	0.
92815	0.	0.	0.	0.	0.
92816	0.	0.	0.	0.	0.
92817	0.	0.	0.	0.	0.
92818	0.	0.	0.	0.	0.
92819	0.	0.	0.	0.	0.
92820	0.	0.	0.	0.	0.
92821	0.	0.	0.	0.	0.
92822	0.	0.	0.	0.	0.
92823	0.	0.	0.	0.	0.
92824	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE272 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
929 1	0.	0.	0.	0.	0.
929 2	0.	0.	0.	0.	0.
929 3	0.	0.	0.	0.	0.
929 4	0.	0.	0.	0.	0.
929 5	0.	0.	0.	0.	0.
929 6	0.	0.	0.	0.	0.
929 7	0.	0.	0.	0.	0.
929 8	0.	0.	0.	0.	0.
929 9	0.	0.	0.	0.	0.
92910	0.	0.	0.	0.	0.
92911	0.	0.	0.	0.	0.
92912	0.	0.	0.	0.	0.
92913	0.	0.	0.	0.	0.
92914	0.	0.	0.	0.	0.
92915	0.	0.	0.	0.	0.
92916	0.	0.	0.	0.	0.
92917	0.	0.	0.	0.	0.
92918	0.	0.	0.	0.	0.
92919	0.	0.	0.	0.	0.
92920	0.	0.	0.	0.	0.
92921	0.	0.	0.	0.	0.
92922	0.	0.	0.	0.	0.
92923	0.	0.	0.	0.	0.
92924	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE273 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
930 1	0.	0.	0.	0.	0.
930 2	0.	0.	0.	0.	0.
930 3	0.	0.	0.	0.	0.
930 4	0.	0.	0.	0.	0.
930 5	0.	0.	0.	0.	0.
930 6	0.	0.	0.	0.	0.
930 7	0.	0.	0.	0.	0.
930 8	0.	0.	0.	0.	0.
930 9	0.	0.	0.	0.	0.
93010	0.	0.	0.	0.	0.
93011	0.	0.	0.	0.	0.
93012	0.	0.	0.	0.	0.
93013	0.	0.	0.	0.	0.
93014	0.	0.	0.	0.	0.
93015	0.	0.	0.	0.	0.
93016	0.	0.	0.	0.	0.
93017	0.	0.	0.	0.	0.
93018	0.	0.	0.	0.	0.
93019	0.	0.	0.	0.	0.
93020	0.	0.	0.	0.	0.
93021	0.	0.	0.	0.	0.
93022	0.	0.	0.	0.	0.
93023	0.	0.	0.	0.	0.
93024	0.	0.	0.	0.	0.
DAILY SUMMARY (SEP 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (SEP)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE274 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 1 1	0.	0.	0.	0.	0.
10 1 2	0.	0.	0.	0.	0.
10 1 3	0.	0.	0.	0.	0.
10 1 4	0.	0.	0.	0.	0.
10 1 5	0.	0.	0.	0.	0.
10 1 6	0.	0.	0.	0.	0.
10 1 7	0.	0.	0.	0.	0.
10 1 8	0.	0.	0.	0.	0.
10 1 9	0.	0.	0.	0.	0.
10 110	0.	0.	0.	0.	0.
10 111	0.	0.	0.	0.	0.
10 112	0.	0.	0.	0.	0.
10 113	0.	0.	0.	0.	0.
10 114	0.	0.	0.	0.	0.
10 115	0.	0.	0.	0.	0.
10 116	0.	0.	0.	0.	0.
10 117	0.	0.	0.	0.	0.
10 118	0.	0.	0.	0.	0.
10 119	0.	0.	0.	0.	0.
10 120	0.	0.	0.	0.	0.
10 121	0.	0.	0.	0.	0.
10 122	0.	0.	0.	0.	0.
10 123	0.	0.	0.	0.	0.
10 124	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE275 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 2 1	0.	0.	0.	0.	0.
10 2 2	0.	0.	0.	0.	0.
10 2 3	0.	0.	0.	0.	0.
10 2 4	0.	0.	0.	0.	0.
10 2 5	0.	0.	0.	0.	0.
10 2 6	0.	0.	0.	0.	0.
10 2 7	0.	0.	0.	0.	0.
10 2 8	0.	0.	0.	0.	0.
10 2 9	0.	0.	0.	0.	0.
10 210	0.	0.	0.	0.	0.
10 211	0.	0.	0.	0.	0.
10 212	0.	0.	0.	0.	0.
10 213	0.	0.	0.	0.	0.
10 214	0.	0.	0.	0.	0.
10 215	0.	0.	0.	0.	0.
10 216	0.	0.	0.	0.	0.
10 217	0.	0.	0.	0.	0.
10 218	0.	0.	0.	0.	0.
10 219	0.	0.	0.	0.	0.
10 220	0.	0.	0.	0.	0.
10 221	0.	0.	0.	0.	0.
10 222	0.	0.	0.	0.	0.
10 223	0.	0.	0.	0.	0.
10 224	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE276 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 3 1	0.	0.	0.	0.	0.
10 3 2	0.	0.	0.	0.	0.
10 3 3	0.	0.	0.	0.	0.
10 3 4	0.	0.	0.	0.	0.
10 3 5	0.	0.	0.	0.	0.
10 3 6	0.	0.	0.	0.	0.
10 3 7	0.	0.	0.	0.	0.
10 3 8	0.	0.	0.	0.	0.
10 3 9	0.	0.	0.	0.	0.
10 310	0.	0.	0.	0.	0.
10 311	0.	0.	0.	0.	0.
10 312	0.	0.	0.	0.	0.
10 313	0.	0.	0.	0.	0.
10 314	0.	0.	0.	0.	0.
10 315	0.	0.	0.	0.	0.
10 316	0.	0.	0.	0.	0.
10 317	0.	0.	0.	0.	0.
10 318	0.	0.	0.	0.	0.
10 319	0.	0.	0.	0.	0.
10 320	0.	0.	0.	0.	0.
10 321	0.	0.	0.	0.	0.
10 322	0.	0.	0.	0.	0.
10 323	0.	0.	0.	0.	0.
10 324	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE277 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 4 1	0.	0.	0.	0.	0.
10 4 2	0.	0.	0.	0.	0.
10 4 3	0.	0.	0.	0.	0.
10 4 4	0.	0.	0.	0.	0.
10 4 5	0.	0.	0.	0.	0.
10 4 6	0.	0.	0.	0.	0.
10 4 7	0.	0.	0.	0.	0.
10 4 8	0.	0.	0.	0.	0.
10 4 9	0.	0.	0.	0.	0.
10 410	0.	0.	0.	0.	0.
10 411	0.	0.	0.	0.	0.
10 412	0.	0.	0.	0.	0.
10 413	0.	0.	0.	0.	0.
10 414	0.	0.	0.	0.	0.
10 415	0.	0.	0.	0.	0.
10 416	0.	0.	0.	0.	0.
10 417	0.	0.	0.	0.	0.
10 418	0.	0.	0.	0.	0.
10 419	0.	0.	0.	0.	0.
10 420	0.	0.	0.	0.	0.
10 421	0.	0.	0.	0.	0.
10 422	0.	0.	0.	0.	0.
10 423	0.	0.	0.	0.	0.
10 424	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE278 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 5 1	0.	0.	0.	0.	0.
10 5 2	0.	0.	0.	0.	0.
10 5 3	0.	0.	0.	0.	0.
10 5 4	0.	0.	0.	0.	0.
10 5 5	0.	0.	0.	0.	0.
10 5 6	0.	0.	0.	0.	0.
10 5 7	0.	0.	0.	0.	0.
10 5 8	0.	0.	0.	0.	0.
10 5 9	0.	0.	0.	0.	0.
10 510	0.	0.	0.	0.	0.
10 511	0.	0.	0.	0.	0.
10 512	0.	0.	0.	0.	0.
10 513	0.	0.	0.	0.	0.
10 514	0.	0.	0.	0.	0.
10 515	0.	0.	0.	0.	0.
10 516	0.	0.	0.	0.	0.
10 517	0.	0.	0.	0.	0.
10 518	0.	0.	0.	0.	0.
10 519	0.	0.	0.	0.	0.
10 520	0.	0.	0.	0.	0.
10 521	0.	0.	0.	0.	0.
10 522	0.	0.	0.	0.	0.
10 523	0.	0.	0.	0.	0.
10 524	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE279 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 6 1	0.	0.	0.	0.	0.
10 6 2	0.	0.	0.	0.	0.
10 6 3	0.	0.	0.	0.	0.
10 6 4	0.	0.	0.	0.	0.
10 6 5	0.	0.	0.	0.	0.
10 6 6	0.	0.	0.	0.	0.
10 6 7	0.	0.	0.	0.	0.
10 6 8	0.	0.	0.	0.	0.
10 6 9	0.	0.	0.	0.	0.
10 610	0.	0.	0.	0.	0.
10 611	0.	0.	0.	0.	0.
10 612	0.	0.	0.	0.	0.
10 613	0.	0.	0.	0.	0.
10 614	0.	0.	0.	0.	0.
10 615	0.	0.	0.	0.	0.
10 616	0.	0.	0.	0.	0.
10 617	0.	0.	0.	0.	0.
10 618	0.	0.	0.	0.	0.
10 619	0.	0.	0.	0.	0.
10 620	0.	0.	0.	0.	0.
10 621	0.	0.	0.	0.	0.
10 622	0.	0.	0.	0.	0.
10 623	0.	0.	0.	0.	0.
10 624	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE280 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 7 1	0.	0.	0.	0.	0.
10 7 2	0.	0.	0.	0.	0.
10 7 3	0.	0.	0.	0.	0.
10 7 4	0.	0.	0.	0.	0.
10 7 5	0.	0.	0.	0.	0.
10 7 6	0.	0.	0.	0.	0.
10 7 7	0.	0.	0.	0.	0.
10 7 8	0.	0.	0.	0.	0.
10 7 9	0.	0.	0.	0.	0.
10 710	0.	0.	0.	0.	0.
10 711	0.	0.	0.	0.	0.
10 712	0.	0.	0.	0.	0.
10 713	0.	0.	0.	0.	0.
10 714	0.	0.	0.	0.	0.
10 715	0.	0.	0.	0.	0.
10 716	0.	0.	0.	0.	0.
10 717	0.	0.	0.	0.	0.
10 718	0.	0.	0.	0.	0.
10 719	0.	0.	0.	0.	0.
10 720	0.	0.	0.	0.	0.
10 721	0.	0.	0.	0.	0.
10 722	0.	0.	0.	0.	0.
10 723	0.	0.	0.	0.	0.
10 724	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE281 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 8 1	0.	0.	0.	0.	0.
10 8 2	0.	0.	0.	0.	0.
10 8 3	0.	0.	0.	0.	0.
10 8 4	0.	0.	0.	0.	0.
10 8 5	0.	0.	0.	0.	0.
10 8 6	0.	0.	0.	0.	0.
10 8 7	0.	0.	0.	0.	0.
10 8 8	0.	0.	0.	0.	0.
10 8 9	0.	0.	0.	0.	0.
10 810	0.	0.	0.	0.	0.
10 811	0.	0.	0.	0.	0.
10 812	0.	0.	0.	0.	0.
10 813	0.	0.	0.	0.	0.
10 814	0.	0.	0.	0.	0.
10 815	0.	0.	0.	0.	0.
10 816	0.	0.	0.	0.	0.
10 817	0.	0.	0.	0.	0.
10 818	0.	0.	0.	0.	0.
10 819	0.	0.	0.	0.	0.
10 820	0.	0.	0.	0.	0.
10 821	0.	0.	0.	0.	0.
10 822	0.	0.	0.	0.	0.
10 823	0.	0.	0.	0.	0.
10 824	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE282 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
10 9 1	0.	0.	0.	0.	0.
10 9 2	0.	0.	0.	0.	0.
10 9 3	0.	0.	0.	0.	0.
10 9 4	0.	0.	0.	0.	0.
10 9 5	0.	0.	0.	0.	0.
10 9 6	0.	0.	0.	0.	0.
10 9 7	0.	0.	0.	0.	0.
10 9 8	0.	0.	0.	0.	0.
10 9 9	0.	0.	0.	0.	0.
10 910	0.	0.	0.	0.	0.
10 911	0.	0.	0.	0.	0.
10 912	0.	0.	0.	0.	0.
10 913	0.	0.	0.	0.	0.
10 914	0.	0.	0.	0.	0.
10 915	0.	0.	0.	0.	0.
10 916	0.	0.	0.	0.	0.
10 917	0.	0.	0.	0.	0.
10 918	0.	0.	0.	0.	0.
10 919	0.	0.	0.	0.	0.
10 920	0.	0.	0.	0.	0.
10 921	0.	0.	0.	0.	0.
10 922	0.	0.	0.	0.	0.
10 923	0.	0.	0.	0.	0.
10 924	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE283 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1010 1	0.	0.	0.	0.	0.
1010 2	0.	0.	0.	0.	0.
1010 3	0.	0.	0.	0.	0.
1010 4	0.	0.	0.	0.	0.
1010 5	0.	0.	0.	0.	0.
1010 6	0.	0.	0.	0.	0.
1010 7	0.	0.	0.	0.	0.
1010 8	0.	0.	0.	0.	0.
1010 9	0.	0.	0.	0.	0.
101010	0.	0.	0.	0.	0.
101011	0.	0.	0.	0.	0.
101012	0.	0.	0.	0.	0.
101013	0.	0.	0.	0.	0.
101014	0.	0.	0.	0.	0.
101015	0.	0.	0.	0.	0.
101016	0.	0.	0.	0.	0.
101017	0.	0.	0.	0.	0.
101018	0.	0.	0.	0.	0.
101019	0.	0.	0.	0.	0.
101020	0.	0.	0.	0.	0.
101021	0.	0.	0.	0.	0.
101022	0.	0.	0.	0.	0.
101023	0.	0.	0.	0.	0.
101024	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE284 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1011 1	0.	0.	0.	0.	0.
1011 2	0.	0.	0.	0.	0.
1011 3	0.	0.	0.	0.	0.
1011 4	0.	0.	0.	0.	0.
1011 5	0.	0.	0.	0.	0.
1011 6	0.	0.	0.	0.	0.
1011 7	0.	0.	0.	0.	0.
1011 8	0.	0.	0.	0.	0.
1011 9	0.	0.	0.	0.	0.
101110	0.	0.	0.	0.	0.
101111	0.	0.	0.	0.	0.
101112	0.	0.	0.	0.	0.
101113	0.	0.	0.	0.	0.
101114	0.	0.	0.	0.	0.
101115	0.	0.	0.	0.	0.
101116	0.	0.	0.	0.	0.
101117	0.	0.	0.	0.	0.
101118	0.	0.	0.	0.	0.
101119	0.	0.	0.	0.	0.
101120	0.	0.	0.	0.	0.
101121	0.	0.	0.	0.	0.
101122	0.	0.	0.	0.	0.
101123	0.	0.	0.	0.	0.
101124	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE285 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1012 1	0.	0.	0.	0.	0.
1012 2	0.	0.	0.	0.	0.
1012 3	0.	0.	0.	0.	0.
1012 4	0.	0.	0.	0.	0.
1012 5	0.	0.	0.	0.	0.
1012 6	0.	0.	0.	0.	0.
1012 7	0.	0.	0.	0.	0.
1012 8	0.	0.	0.	0.	0.
1012 9	0.	0.	0.	0.	0.
101210	0.	0.	0.	0.	0.
101211	0.	0.	0.	0.	0.
101212	0.	0.	0.	0.	0.
101213	0.	0.	0.	0.	0.
101214	0.	0.	0.	0.	0.
101215	0.	0.	0.	0.	0.
101216	0.	0.	0.	0.	0.
101217	0.	0.	0.	0.	0.
101218	0.	0.	0.	0.	0.
101219	0.	0.	0.	0.	0.
101220	0.	0.	0.	0.	0.
101221	0.	0.	0.	0.	0.
101222	0.	0.	0.	0.	0.
101223	0.	0.	0.	0.	0.
101224	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE286 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1013 1	0.	0.	0.	0.	0.
1013 2	0.	0.	0.	0.	0.
1013 3	0.	0.	0.	0.	0.
1013 4	0.	0.	0.	0.	0.
1013 5	0.	0.	0.	0.	0.
1013 6	0.	0.	0.	0.	0.
1013 7	0.	0.	0.	0.	0.
1013 8	0.	0.	0.	0.	0.
1013 9	0.	0.	0.	0.	0.
101310	0.	0.	0.	0.	0.
101311	0.	0.	0.	0.	0.
101312	0.	0.	0.	0.	0.
101313	0.	0.	0.	0.	0.
101314	0.	0.	0.	0.	0.
101315	0.	0.	0.	0.	0.
101316	0.	0.	0.	0.	0.
101317	0.	0.	0.	0.	0.
101318	0.	0.	0.	0.	0.
101319	0.	0.	0.	0.	0.
101320	0.	0.	0.	0.	0.
101321	0.	0.	0.	0.	0.
101322	0.	0.	0.	0.	0.
101323	0.	0.	0.	0.	0.
101324	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE287 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1014 1	0.	0.	0.	0.	0.
1014 2	0.	0.	0.	0.	0.
1014 3	0.	0.	0.	0.	0.
1014 4	0.	0.	0.	0.	0.
1014 5	0.	0.	0.	0.	0.
1014 6	0.	0.	0.	0.	0.
1014 7	0.	0.	0.	0.	0.
1014 8	0.	0.	0.	0.	0.
1014 9	0.	0.	0.	0.	0.
101410	0.	0.	0.	0.	0.
101411	0.	0.	0.	0.	0.
101412	0.	0.	0.	0.	0.
101413	0.	0.	0.	0.	0.
101414	0.	0.	0.	0.	0.
101415	0.	0.	0.	0.	0.
101416	0.	0.	0.	0.	0.
101417	0.	0.	0.	0.	0.
101418	0.	0.	0.	0.	0.
101419	0.	0.	0.	0.	0.
101420	0.	0.	0.	0.	0.
101421	0.	0.	0.	0.	0.
101422	0.	0.	0.	0.	0.
101423	0.	0.	0.	0.	0.
101424	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE288 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1015 1	0.	0.	0.	0.	0.
1015 2	0.	0.	0.	0.	0.
1015 3	0.	0.	0.	0.	0.
1015 4	0.	0.	0.	0.	0.
1015 5	0.	0.	0.	0.	0.
1015 6	0.	0.	0.	0.	0.
1015 7	0.	0.	0.	0.	0.
1015 8	0.	0.	0.	0.	0.
1015 9	0.	0.	0.	0.	0.
101510	0.	0.	0.	0.	0.
101511	0.	0.	0.	0.	0.
101512	0.	0.	0.	0.	0.
101513	0.	0.	0.	0.	0.
101514	0.	0.	0.	0.	0.
101515	0.	0.	0.	0.	0.
101516	0.	0.	0.	0.	0.
101517	0.	0.	0.	0.	0.
101518	0.	0.	0.	0.	0.
101519	0.	0.	0.	0.	0.
101520	0.	0.	0.	0.	0.
101521	0.	0.	0.	0.	0.
101522	0.	0.	0.	0.	0.
101523	0.	0.	0.	0.	0.
101524	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE289 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1016 1	0.	0.	0.	0.	0.
1016 2	0.	0.	0.	0.	0.
1016 3	0.	0.	0.	0.	0.
1016 4	0.	0.	0.	0.	0.
1016 5	0.	0.	0.	0.	0.
1016 6	0.	0.	0.	0.	0.
1016 7	0.	0.	0.	0.	0.
1016 8	0.	0.	0.	0.	0.
1016 9	0.	0.	0.	0.	0.
101610	0.	0.	0.	0.	0.
101611	0.	0.	0.	0.	0.
101612	0.	0.	0.	0.	0.
101613	0.	0.	0.	0.	0.
101614	0.	0.	0.	0.	0.
101615	0.	0.	0.	0.	0.
101616	0.	0.	0.	0.	0.
101617	0.	0.	0.	0.	0.
101618	0.	0.	0.	0.	0.
101619	0.	0.	0.	0.	0.
101620	0.	0.	0.	0.	0.
101621	0.	0.	0.	0.	0.
101622	0.	0.	0.	0.	0.
101623	0.	0.	0.	0.	0.
101624	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE290 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1017 1	0.	0.	0.	0.	0.
1017 2	0.	0.	0.	0.	0.
1017 3	0.	0.	0.	0.	0.
1017 4	0.	0.	0.	0.	0.
1017 5	0.	0.	0.	0.	0.
1017 6	0.	0.	0.	0.	0.
1017 7	0.	0.	0.	0.	0.
1017 8	0.	0.	0.	0.	0.
1017 9	0.	0.	0.	0.	0.
101710	0.	0.	0.	0.	0.
101711	0.	0.	0.	0.	0.
101712	0.	0.	0.	0.	0.
101713	0.	0.	0.	0.	0.
101714	0.	0.	0.	0.	0.
101715	0.	0.	0.	0.	0.
101716	0.	0.	0.	0.	0.
101717	0.	0.	0.	0.	0.
101718	0.	0.	0.	0.	0.
101719	0.	0.	0.	0.	0.
101720	0.	0.	0.	0.	0.
101721	0.	0.	0.	0.	0.
101722	0.	0.	0.	0.	0.
101723	0.	0.	0.	0.	0.
101724	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE291 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1018 1	0.	0.	0.	0.	0.
1018 2	0.	0.	0.	0.	0.
1018 3	0.	0.	0.	0.	0.
1018 4	0.	0.	0.	0.	0.
1018 5	0.	0.	0.	0.	0.
1018 6	0.	0.	0.	0.	0.
1018 7	0.	0.	0.	0.	0.
1018 8	0.	0.	0.	0.	0.
1018 9	0.	0.	0.	0.	0.
101810	0.	0.	0.	0.	0.
101811	0.	0.	0.	0.	0.
101812	0.	0.	0.	0.	0.
101813	0.	0.	0.	0.	0.
101814	0.	0.	0.	0.	0.
101815	0.	0.	0.	0.	0.
101816	0.	0.	0.	0.	0.
101817	0.	0.	0.	0.	0.
101818	0.	0.	0.	0.	0.
101819	0.	0.	0.	0.	0.
101820	0.	0.	0.	0.	0.
101821	0.	0.	0.	0.	0.
101822	0.	0.	0.	0.	0.
101823	0.	0.	0.	0.	0.
101824	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE292 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1019 1	0.	0.	0.	0.	0.
1019 2	0.	0.	0.	0.	0.
1019 3	0.	0.	0.	0.	0.
1019 4	0.	0.	0.	0.	0.
1019 5	0.	0.	0.	0.	0.
1019 6	0.	0.	0.	0.	0.
1019 7	0.	0.	0.	0.	0.
1019 8	0.	0.	0.	0.	0.
1019 9	0.	0.	0.	0.	0.
101910	0.	0.	0.	0.	0.
101911	0.	0.	0.	0.	0.
101912	0.	0.	0.	0.	0.
101913	0.	0.	0.	0.	0.
101914	0.	0.	0.	0.	0.
101915	0.	0.	0.	0.	0.
101916	0.	0.	0.	0.	0.
101917	0.	0.	0.	0.	0.
101918	0.	0.	0.	0.	0.
101919	0.	0.	0.	0.	0.
101920	0.	0.	0.	0.	0.
101921	0.	0.	0.	0.	0.
101922	0.	0.	0.	0.	0.
101923	0.	0.	0.	0.	0.
101924	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE293 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1020 1	0.	0.	0.	0.	0.
1020 2	0.	0.	0.	0.	0.
1020 3	0.	0.	0.	0.	0.
1020 4	0.	0.	0.	0.	0.
1020 5	0.	0.	0.	0.	0.
1020 6	0.	0.	0.	0.	0.
1020 7	0.	0.	0.	0.	0.
1020 8	0.	0.	0.	0.	0.
1020 9	0.	0.	0.	0.	0.
102010	0.	0.	0.	0.	0.
102011	0.	0.	0.	0.	0.
102012	0.	0.	0.	0.	0.
102013	0.	0.	0.	0.	0.
102014	0.	0.	0.	0.	0.
102015	0.	0.	0.	0.	0.
102016	0.	0.	0.	0.	0.
102017	0.	0.	0.	0.	0.
102018	0.	0.	0.	0.	0.
102019	0.	0.	0.	0.	0.
102020	0.	0.	0.	0.	0.
102021	0.	0.	0.	0.	0.
102022	0.	0.	0.	0.	0.
102023	0.	0.	0.	0.	0.
102024	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE294 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1021 1	0.	0.	0.	0.	0.
1021 2	0.	0.	0.	0.	0.
1021 3	0.	0.	0.	0.	0.
1021 4	0.	0.	0.	0.	0.
1021 5	0.	0.	0.	0.	0.
1021 6	0.	0.	0.	0.	0.
1021 7	0.	0.	0.	0.	0.
1021 8	0.	0.	0.	0.	0.
1021 9	0.	0.	0.	0.	0.
102110	0.	0.	0.	0.	0.
102111	0.	0.	0.	0.	0.
102112	0.	0.	0.	0.	0.
102113	0.	0.	0.	0.	0.
102114	0.	0.	0.	0.	0.
102115	0.	0.	0.	0.	0.
102116	0.	0.	0.	0.	0.
102117	0.	0.	0.	0.	0.
102118	0.	0.	0.	0.	0.
102119	0.	0.	0.	0.	0.
102120	0.	0.	0.	0.	0.
102121	0.	0.	0.	0.	0.
102122	0.	0.	0.	0.	0.
102123	0.	0.	0.	0.	0.
102124	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE295 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1022 1	0.	0.	0.	0.	0.
1022 2	0.	0.	0.	0.	0.
1022 3	0.	0.	0.	0.	0.
1022 4	0.	0.	0.	0.	0.
1022 5	0.	0.	0.	0.	0.
1022 6	0.	0.	0.	0.	0.
1022 7	0.	0.	0.	0.	0.
1022 8	0.	0.	0.	0.	0.
1022 9	0.	0.	0.	0.	0.
102210	0.	0.	0.	0.	0.
102211	0.	0.	0.	0.	0.
102212	0.	0.	0.	0.	0.
102213	0.	0.	0.	0.	0.
102214	0.	0.	0.	0.	0.
102215	0.	0.	0.	0.	0.
102216	0.	0.	0.	0.	0.
102217	0.	0.	0.	0.	0.
102218	0.	0.	0.	0.	0.
102219	0.	0.	0.	0.	0.
102220	0.	0.	0.	0.	0.
102221	0.	0.	0.	0.	0.
102222	0.	0.	0.	0.	0.
102223	0.	0.	0.	0.	0.
102224	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE296 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1023 1	0.	0.	0.	0.	0.
1023 2	0.	0.	0.	0.	0.
1023 3	0.	0.	0.	0.	0.
1023 4	0.	0.	0.	0.	0.
1023 5	0.	0.	0.	0.	0.
1023 6	0.	0.	0.	0.	0.
1023 7	0.	0.	0.	0.	0.
1023 8	0.	0.	0.	0.	0.
1023 9	0.	0.	0.	0.	0.
102310	0.	0.	0.	0.	0.
102311	0.	0.	0.	0.	0.
102312	0.	0.	0.	0.	0.
102313	0.	0.	0.	0.	0.
102314	0.	0.	0.	0.	0.
102315	0.	0.	0.	0.	0.
102316	0.	0.	0.	0.	0.
102317	0.	0.	0.	0.	0.
102318	0.	0.	0.	0.	0.
102319	0.	0.	0.	0.	0.
102320	0.	0.	0.	0.	0.
102321	0.	0.	0.	0.	0.
102322	0.	0.	0.	0.	0.
102323	0.	0.	0.	0.	0.
102324	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE297 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1024 1	0.	0.	0.	0.	0.
1024 2	0.	0.	0.	0.	0.
1024 3	0.	0.	0.	0.	0.
1024 4	0.	0.	0.	0.	0.
1024 5	0.	0.	0.	0.	0.
1024 6	0.	0.	0.	0.	0.
1024 7	0.	0.	0.	0.	0.
1024 8	0.	0.	0.	0.	0.
1024 9	0.	0.	0.	0.	0.
102410	0.	0.	0.	0.	0.
102411	0.	0.	0.	0.	0.
102412	0.	0.	0.	0.	0.
102413	0.	0.	0.	0.	0.
102414	0.	0.	0.	0.	0.
102415	0.	0.	0.	0.	0.
102416	0.	0.	0.	0.	0.
102417	0.	0.	0.	0.	0.
102418	0.	0.	0.	0.	0.
102419	0.	0.	0.	0.	0.
102420	0.	0.	0.	0.	0.
102421	0.	0.	0.	0.	0.
102422	0.	0.	0.	0.	0.
102423	0.	0.	0.	0.	0.
102424	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE298 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1025 1	0.	0.	0.	0.	0.
1025 2	0.	0.	0.	0.	0.
1025 3	0.	0.	0.	0.	0.
1025 4	0.	0.	0.	0.	0.
1025 5	0.	0.	0.	0.	0.
1025 6	0.	0.	0.	0.	0.
1025 7	0.	0.	0.	0.	0.
1025 8	0.	0.	0.	0.	0.
1025 9	0.	0.	0.	0.	0.
102510	0.	0.	0.	0.	0.
102511	0.	0.	0.	0.	0.
102512	0.	0.	0.	0.	0.
102513	0.	0.	0.	0.	0.
102514	0.	0.	0.	0.	0.
102515	0.	0.	0.	0.	0.
102516	0.	0.	0.	0.	0.
102517	0.	0.	0.	0.	0.
102518	0.	0.	0.	0.	0.
102519	0.	0.	0.	0.	0.
102520	0.	0.	0.	0.	0.
102521	0.	0.	0.	0.	0.
102522	0.	0.	0.	0.	0.
102523	0.	0.	0.	0.	0.
102524	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE299 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1026 1	0.	0.	0.	0.	0.
1026 2	0.	0.	0.	0.	0.
1026 3	0.	0.	0.	0.	0.
1026 4	0.	0.	0.	0.	0.
1026 5	0.	0.	0.	0.	0.
1026 6	0.	0.	0.	0.	0.
1026 7	0.	0.	0.	0.	0.
1026 8	0.	0.	0.	0.	0.
1026 9	0.	0.	0.	0.	0.
102610	0.	0.	0.	0.	0.
102611	0.	0.	0.	0.	0.
102612	0.	0.	0.	0.	0.
102613	0.	0.	0.	0.	0.
102614	0.	0.	0.	0.	0.
102615	0.	0.	0.	0.	0.
102616	0.	0.	0.	0.	0.
102617	0.	0.	0.	0.	0.
102618	0.	0.	0.	0.	0.
102619	0.	0.	0.	0.	0.
102620	0.	0.	0.	0.	0.
102621	0.	0.	0.	0.	0.
102622	0.	0.	0.	0.	0.
102623	0.	0.	0.	0.	0.
102624	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE300 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1027 1	0.	0.	0.	0.	0.
1027 2	0.	0.	0.	0.	0.
1027 3	0.	0.	0.	0.	0.
1027 4	0.	0.	0.	0.	0.
1027 5	0.	0.	0.	0.	0.
1027 6	0.	0.	0.	0.	0.
1027 7	0.	0.	0.	0.	0.
1027 8	0.	0.	0.	0.	0.
1027 9	0.	0.	0.	0.	0.
102710	0.	0.	0.	0.	0.
102711	0.	0.	0.	0.	0.
102712	0.	0.	0.	0.	0.
102713	0.	0.	0.	0.	0.
102714	0.	0.	0.	0.	0.
102715	0.	0.	0.	0.	0.
102716	0.	0.	0.	0.	0.
102717	0.	0.	0.	0.	0.
102718	0.	0.	0.	0.	0.
102719	0.	0.	0.	0.	0.
102720	0.	0.	0.	0.	0.
102721	0.	0.	0.	0.	0.
102722	0.	0.	0.	0.	0.
102723	0.	0.	0.	0.	0.
102724	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE301 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1028 1	0.	0.	0.	0.	0.
1028 2	0.	0.	0.	0.	0.
1028 3	0.	0.	0.	0.	0.
1028 4	0.	0.	0.	0.	0.
1028 5	0.	0.	0.	0.	0.
1028 6	0.	0.	0.	0.	0.
1028 7	0.	0.	0.	0.	0.
1028 8	0.	0.	0.	0.	0.
1028 9	0.	0.	0.	0.	0.
102810	0.	0.	0.	0.	0.
102811	0.	0.	0.	0.	0.
102812	0.	0.	0.	0.	0.
102813	0.	0.	0.	0.	0.
102814	0.	0.	0.	0.	0.
102815	0.	0.	0.	0.	0.
102816	0.	0.	0.	0.	0.
102817	0.	0.	0.	0.	0.
102818	0.	0.	0.	0.	0.
102819	0.	0.	0.	0.	0.
102820	0.	0.	0.	0.	0.
102821	0.	0.	0.	0.	0.
102822	0.	0.	0.	0.	0.
102823	0.	0.	0.	0.	0.
102824	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE302 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1029 1	0.	0.	0.	0.	0.
1029 2	0.	0.	0.	0.	0.
1029 3	0.	0.	0.	0.	0.
1029 4	0.	0.	0.	0.	0.
1029 5	0.	0.	0.	0.	0.
1029 6	0.	0.	0.	0.	0.
1029 7	0.	0.	0.	0.	0.
1029 8	0.	0.	0.	0.	0.
1029 9	0.	0.	0.	0.	0.
102910	0.	0.	0.	0.	0.
102911	0.	0.	0.	0.	0.
102912	0.	0.	0.	0.	0.
102913	0.	0.	0.	0.	0.
102914	0.	0.	0.	0.	0.
102915	0.	0.	0.	0.	0.
102916	0.	0.	0.	0.	0.
102917	0.	0.	0.	0.	0.
102918	0.	0.	0.	0.	0.
102919	0.	0.	0.	0.	0.
102920	0.	0.	0.	0.	0.
102921	0.	0.	0.	0.	0.
102922	0.	0.	0.	0.	0.
102923	0.	0.	0.	0.	0.
102924	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE303 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1030 1	0.	0.	0.	0.	0.
1030 2	0.	0.	0.	0.	0.
1030 3	0.	0.	0.	0.	0.
1030 4	0.	0.	0.	0.	0.
1030 5	0.	0.	0.	0.	0.
1030 6	0.	0.	0.	0.	0.
1030 7	0.	0.	0.	0.	0.
1030 8	0.	0.	0.	0.	0.
1030 9	0.	0.	0.	0.	0.
103010	0.	0.	0.	0.	0.
103011	0.	0.	0.	0.	0.
103012	0.	0.	0.	0.	0.
103013	0.	0.	0.	0.	0.
103014	0.	0.	0.	0.	0.
103015	0.	0.	0.	0.	0.
103016	0.	0.	0.	0.	0.
103017	0.	0.	0.	0.	0.
103018	0.	0.	0.	0.	0.
103019	0.	0.	0.	0.	0.
103020	0.	0.	0.	0.	0.
103021	0.	0.	0.	0.	0.
103022	0.	0.	0.	0.	0.
103023	0.	0.	0.	0.	0.
103024	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE304 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1031 1	0.	0.	0.	0.	0.
1031 2	0.	0.	0.	0.	0.
1031 3	0.	0.	0.	0.	0.
1031 4	0.	0.	0.	0.	0.
1031 5	0.	0.	0.	0.	0.
1031 6	0.	0.	0.	0.	0.
1031 7	0.	0.	0.	0.	0.
1031 8	0.	0.	0.	0.	0.
1031 9	0.	0.	0.	0.	0.
103110	0.	0.	0.	0.	0.
103111	0.	0.	0.	0.	0.
103112	0.	0.	0.	0.	0.
103113	0.	0.	0.	0.	0.
103114	0.	0.	0.	0.	0.
103115	0.	0.	0.	0.	0.
103116	0.	0.	0.	0.	0.
103117	0.	0.	0.	0.	0.
103118	0.	0.	0.	0.	0.
103119	0.	0.	0.	0.	0.
103120	0.	0.	0.	0.	0.
103121	0.	0.	0.	0.	0.
103122	0.	0.	0.	0.	0.
103123	0.	0.	0.	0.	0.
103124	0.	0.	0.	0.	0.
DAILY SUMMARY (OCT 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (OCT)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE305 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 1 1	0.	0.	0.	0.	0.
11 1 2	0.	0.	0.	0.	0.
11 1 3	0.	0.	0.	0.	0.
11 1 4	0.	0.	0.	0.	0.
11 1 5	0.	0.	0.	0.	0.
11 1 6	0.	0.	0.	0.	0.
11 1 7	0.	0.	0.	0.	0.
11 1 8	0.	0.	0.	0.	0.
11 1 9	0.	0.	0.	0.	0.
11 110	0.	0.	0.	0.	0.
11 111	0.	0.	0.	0.	0.
11 112	0.	0.	0.	0.	0.
11 113	0.	0.	0.	0.	0.
11 114	0.	0.	0.	0.	0.
11 115	0.	0.	0.	0.	0.
11 116	0.	0.	0.	0.	0.
11 117	0.	0.	0.	0.	0.
11 118	0.	0.	0.	0.	0.
11 119	0.	0.	0.	0.	0.
11 120	0.	0.	0.	0.	0.
11 121	0.	0.	0.	0.	0.
11 122	0.	0.	0.	0.	0.
11 123	0.	0.	0.	0.	0.
11 124	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE306 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 2 1	0.	0.	0.	0.	0.
11 2 2	0.	0.	0.	0.	0.
11 2 3	0.	0.	0.	0.	0.
11 2 4	0.	0.	0.	0.	0.
11 2 5	0.	0.	0.	0.	0.
11 2 6	0.	0.	0.	0.	0.
11 2 7	0.	0.	0.	0.	0.
11 2 8	0.	0.	0.	0.	0.
11 2 9	0.	0.	0.	0.	0.
11 210	0.	0.	0.	0.	0.
11 211	0.	0.	0.	0.	0.
11 212	0.	0.	0.	0.	0.
11 213	0.	0.	0.	0.	0.
11 214	0.	0.	0.	0.	0.
11 215	0.	0.	0.	0.	0.
11 216	0.	0.	0.	0.	0.
11 217	0.	0.	0.	0.	0.
11 218	0.	0.	0.	0.	0.
11 219	0.	0.	0.	0.	0.
11 220	0.	0.	0.	0.	0.
11 221	0.	0.	0.	0.	0.
11 222	0.	0.	0.	0.	0.
11 223	0.	0.	0.	0.	0.
11 224	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE307 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 3 1	0.	0.	0.	0.	0.
11 3 2	0.	0.	0.	0.	0.
11 3 3	0.	0.	0.	0.	0.
11 3 4	0.	0.	0.	0.	0.
11 3 5	0.	0.	0.	0.	0.
11 3 6	0.	0.	0.	0.	0.
11 3 7	0.	0.	0.	0.	0.
11 3 8	0.	0.	0.	0.	0.
11 3 9	0.	0.	0.	0.	0.
11 310	0.	0.	0.	0.	0.
11 311	0.	0.	0.	0.	0.
11 312	0.	0.	0.	0.	0.
11 313	0.	0.	0.	0.	0.
11 314	0.	0.	0.	0.	0.
11 315	0.	0.	0.	0.	0.
11 316	0.	0.	0.	0.	0.
11 317	0.	0.	0.	0.	0.
11 318	0.	0.	0.	0.	0.
11 319	0.	0.	0.	0.	0.
11 320	0.	0.	0.	0.	0.
11 321	0.	0.	0.	0.	0.
11 322	0.	0.	0.	0.	0.
11 323	0.	0.	0.	0.	0.
11 324	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE308 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 4 1	0.	0.	0.	0.	0.
11 4 2	0.	0.	0.	0.	0.
11 4 3	0.	0.	0.	0.	0.
11 4 4	0.	0.	0.	0.	0.
11 4 5	0.	0.	0.	0.	0.
11 4 6	0.	0.	0.	0.	0.
11 4 7	0.	0.	0.	0.	0.
11 4 8	0.	0.	0.	0.	0.
11 4 9	0.	0.	0.	0.	0.
11 410	0.	0.	0.	0.	0.
11 411	0.	0.	0.	0.	0.
11 412	0.	0.	0.	0.	0.
11 413	0.	0.	0.	0.	0.
11 414	0.	0.	0.	0.	0.
11 415	0.	0.	0.	0.	0.
11 416	0.	0.	0.	0.	0.
11 417	0.	0.	0.	0.	0.
11 418	0.	0.	0.	0.	0.
11 419	0.	0.	0.	0.	0.
11 420	0.	0.	0.	0.	0.
11 421	0.	0.	0.	0.	0.
11 422	0.	0.	0.	0.	0.
11 423	0.	0.	0.	0.	0.
11 424	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE309 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 5 1	0.	0.	0.	0.	0.
11 5 2	0.	0.	0.	0.	0.
11 5 3	0.	0.	0.	0.	0.
11 5 4	0.	0.	0.	0.	0.
11 5 5	0.	0.	0.	0.	0.
11 5 6	0.	0.	0.	0.	0.
11 5 7	0.	0.	0.	0.	0.
11 5 8	0.	0.	0.	0.	0.
11 5 9	0.	0.	0.	0.	0.
11 510	0.	0.	0.	0.	0.
11 511	0.	0.	0.	0.	0.
11 512	0.	0.	0.	0.	0.
11 513	0.	0.	0.	0.	0.
11 514	0.	0.	0.	0.	0.
11 515	0.	0.	0.	0.	0.
11 516	0.	0.	0.	0.	0.
11 517	0.	0.	0.	0.	0.
11 518	0.	0.	0.	0.	0.
11 519	0.	0.	0.	0.	0.
11 520	0.	0.	0.	0.	0.
11 521	0.	0.	0.	0.	0.
11 522	0.	0.	0.	0.	0.
11 523	0.	0.	0.	0.	0.
11 524	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE310 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 6 1	0.	0.	0.	0.	0.
11 6 2	0.	0.	0.	0.	0.
11 6 3	0.	0.	0.	0.	0.
11 6 4	0.	0.	0.	0.	0.
11 6 5	0.	0.	0.	0.	0.
11 6 6	0.	0.	0.	0.	0.
11 6 7	0.	0.	0.	0.	0.
11 6 8	0.	0.	0.	0.	0.
11 6 9	0.	0.	0.	0.	0.
11 610	0.	0.	0.	0.	0.
11 611	0.	0.	0.	0.	0.
11 612	0.	0.	0.	0.	0.
11 613	0.	0.	0.	0.	0.
11 614	0.	0.	0.	0.	0.
11 615	0.	0.	0.	0.	0.
11 616	0.	0.	0.	0.	0.
11 617	0.	0.	0.	0.	0.
11 618	0.	0.	0.	0.	0.
11 619	0.	0.	0.	0.	0.
11 620	0.	0.	0.	0.	0.
11 621	0.	0.	0.	0.	0.
11 622	0.	0.	0.	0.	0.
11 623	0.	0.	0.	0.	0.
11 624	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE311 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 7 1	0.	0.	0.	0.	0.
11 7 2	0.	0.	0.	0.	0.
11 7 3	0.	0.	0.	0.	0.
11 7 4	0.	0.	0.	0.	0.
11 7 5	0.	0.	0.	0.	0.
11 7 6	0.	0.	0.	0.	0.
11 7 7	0.	0.	0.	0.	0.
11 7 8	0.	0.	0.	0.	0.
11 7 9	0.	0.	0.	0.	0.
11 710	0.	0.	0.	0.	0.
11 711	0.	0.	0.	0.	0.
11 712	0.	0.	0.	0.	0.
11 713	0.	0.	0.	0.	0.
11 714	0.	0.	0.	0.	0.
11 715	0.	0.	0.	0.	0.
11 716	0.	0.	0.	0.	0.
11 717	0.	0.	0.	0.	0.
11 718	0.	0.	0.	0.	0.
11 719	0.	0.	0.	0.	0.
11 720	0.	0.	0.	0.	0.
11 721	0.	0.	0.	0.	0.
11 722	0.	0.	0.	0.	0.
11 723	0.	0.	0.	0.	0.
11 724	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE312 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 8 1	0.	0.	0.	0.	0.
11 8 2	0.	0.	0.	0.	0.
11 8 3	0.	0.	0.	0.	0.
11 8 4	0.	0.	0.	0.	0.
11 8 5	0.	0.	0.	0.	0.
11 8 6	0.	0.	0.	0.	0.
11 8 7	0.	0.	0.	0.	0.
11 8 8	0.	0.	0.	0.	0.
11 8 9	0.	0.	0.	0.	0.
11 810	0.	0.	0.	0.	0.
11 811	0.	0.	0.	0.	0.
11 812	0.	0.	0.	0.	0.
11 813	0.	0.	0.	0.	0.
11 814	0.	0.	0.	0.	0.
11 815	0.	0.	0.	0.	0.
11 816	0.	0.	0.	0.	0.
11 817	0.	0.	0.	0.	0.
11 818	0.	0.	0.	0.	0.
11 819	0.	0.	0.	0.	0.
11 820	0.	0.	0.	0.	0.
11 821	0.	0.	0.	0.	0.
11 822	0.	0.	0.	0.	0.
11 823	0.	0.	0.	0.	0.
11 824	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE313 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
11 9 1	0.	0.	0.	0.	0.
11 9 2	0.	0.	0.	0.	0.
11 9 3	0.	0.	0.	0.	0.
11 9 4	0.	0.	0.	0.	0.
11 9 5	0.	0.	0.	0.	0.
11 9 6	0.	0.	0.	0.	0.
11 9 7	0.	0.	0.	0.	0.
11 9 8	0.	0.	0.	0.	0.
11 9 9	0.	0.	0.	0.	0.
11 910	0.	0.	0.	0.	0.
11 911	0.	0.	0.	0.	0.
11 912	0.	0.	0.	0.	0.
11 913	0.	0.	0.	0.	0.
11 914	0.	0.	0.	0.	0.
11 915	0.	0.	0.	0.	0.
11 916	0.	0.	0.	0.	0.
11 917	0.	0.	0.	0.	0.
11 918	0.	0.	0.	0.	0.
11 919	0.	0.	0.	0.	0.
11 920	0.	0.	0.	0.	0.
11 921	0.	0.	0.	0.	0.
11 922	0.	0.	0.	0.	0.
11 923	0.	0.	0.	0.	0.
11 924	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE314 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1110 1	0.	0.	0.	0.	0.
1110 2	0.	0.	0.	0.	0.
1110 3	0.	0.	0.	0.	0.
1110 4	0.	0.	0.	0.	0.
1110 5	0.	0.	0.	0.	0.
1110 6	0.	0.	0.	0.	0.
1110 7	0.	0.	0.	0.	0.
1110 8	0.	0.	0.	0.	0.
1110 9	0.	0.	0.	0.	0.
111010	0.	0.	0.	0.	0.
111011	0.	0.	0.	0.	0.
111012	0.	0.	0.	0.	0.
111013	0.	0.	0.	0.	0.
111014	0.	0.	0.	0.	0.
111015	0.	0.	0.	0.	0.
111016	0.	0.	0.	0.	0.
111017	0.	0.	0.	0.	0.
111018	0.	0.	0.	0.	0.
111019	0.	0.	0.	0.	0.
111020	0.	0.	0.	0.	0.
111021	0.	0.	0.	0.	0.
111022	0.	0.	0.	0.	0.
111023	0.	0.	0.	0.	0.
111024	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE315 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1111 1	0.	0.	0.	0.	0.
1111 2	0.	0.	0.	0.	0.
1111 3	0.	0.	0.	0.	0.
1111 4	0.	0.	0.	0.	0.
1111 5	0.	0.	0.	0.	0.
1111 6	0.	0.	0.	0.	0.
1111 7	0.	0.	0.	0.	0.
1111 8	0.	0.	0.	0.	0.
1111 9	0.	0.	0.	0.	0.
111110	0.	0.	0.	0.	0.
111111	0.	0.	0.	0.	0.
111112	0.	0.	0.	0.	0.
111113	0.	0.	0.	0.	0.
111114	0.	0.	0.	0.	0.
111115	0.	0.	0.	0.	0.
111116	0.	0.	0.	0.	0.
111117	0.	0.	0.	0.	0.
111118	0.	0.	0.	0.	0.
111119	0.	0.	0.	0.	0.
111120	0.	0.	0.	0.	0.
111121	0.	0.	0.	0.	0.
111122	0.	0.	0.	0.	0.
111123	0.	0.	0.	0.	0.
111124	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE316 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1112 1	0.	0.	0.	0.	0.
1112 2	0.	0.	0.	0.	0.
1112 3	0.	0.	0.	0.	0.
1112 4	0.	0.	0.	0.	0.
1112 5	0.	0.	0.	0.	0.
1112 6	0.	0.	0.	0.	0.
1112 7	0.	0.	0.	0.	0.
1112 8	0.	0.	0.	0.	0.
1112 9	0.	0.	0.	0.	0.
111210	0.	0.	0.	0.	0.
111211	0.	0.	0.	0.	0.
111212	0.	0.	0.	0.	0.
111213	0.	0.	0.	0.	0.
111214	0.	0.	0.	0.	0.
111215	0.	0.	0.	0.	0.
111216	0.	0.	0.	0.	0.
111217	0.	0.	0.	0.	0.
111218	0.	0.	0.	0.	0.
111219	0.	0.	0.	0.	0.
111220	0.	0.	0.	0.	0.
111221	0.	0.	0.	0.	0.
111222	0.	0.	0.	0.	0.
111223	0.	0.	0.	0.	0.
111224	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE317 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1113 1	0.	0.	0.	0.	0.
1113 2	0.	0.	0.	0.	0.
1113 3	0.	0.	0.	0.	0.
1113 4	0.	0.	0.	0.	0.
1113 5	0.	0.	0.	0.	0.
1113 6	0.	0.	0.	0.	0.
1113 7	0.	0.	0.	0.	0.
1113 8	0.	0.	0.	0.	0.
1113 9	0.	0.	0.	0.	0.
111310	0.	0.	0.	0.	0.
111311	0.	0.	0.	0.	0.
111312	0.	0.	0.	0.	0.
111313	0.	0.	0.	0.	0.
111314	0.	0.	0.	0.	0.
111315	0.	0.	0.	0.	0.
111316	0.	0.	0.	0.	0.
111317	0.	0.	0.	0.	0.
111318	0.	0.	0.	0.	0.
111319	0.	0.	0.	0.	0.
111320	0.	0.	0.	0.	0.
111321	0.	0.	0.	0.	0.
111322	0.	0.	0.	0.	0.
111323	0.	0.	0.	0.	0.
111324	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE318 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1114 1	0.	0.	0.	0.	0.
1114 2	0.	0.	0.	0.	0.
1114 3	0.	0.	0.	0.	0.
1114 4	0.	0.	0.	0.	0.
1114 5	0.	0.	0.	0.	0.
1114 6	0.	0.	0.	0.	0.
1114 7	0.	0.	0.	0.	0.
1114 8	0.	0.	0.	0.	0.
1114 9	0.	0.	0.	0.	0.
111410	0.	0.	0.	0.	0.
111411	0.	0.	0.	0.	0.
111412	0.	0.	0.	0.	0.
111413	0.	0.	0.	0.	0.
111414	0.	0.	0.	0.	0.
111415	0.	0.	0.	0.	0.
111416	0.	0.	0.	0.	0.
111417	0.	0.	0.	0.	0.
111418	0.	0.	0.	0.	0.
111419	0.	0.	0.	0.	0.
111420	0.	0.	0.	0.	0.
111421	0.	0.	0.	0.	0.
111422	0.	0.	0.	0.	0.
111423	0.	0.	0.	0.	0.
111424	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE319 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1115 1	0.	0.	0.	0.	0.
1115 2	0.	0.	0.	0.	0.
1115 3	0.	0.	0.	0.	0.
1115 4	0.	0.	0.	0.	0.
1115 5	0.	0.	0.	0.	0.
1115 6	0.	0.	0.	0.	0.
1115 7	0.	0.	0.	0.	0.
1115 8	0.	0.	0.	0.	0.
1115 9	0.	0.	0.	0.	0.
111510	0.	0.	0.	0.	0.
111511	0.	0.	0.	0.	0.
111512	0.	0.	0.	0.	0.
111513	0.	0.	0.	0.	0.
111514	0.	0.	0.	0.	0.
111515	0.	0.	0.	0.	0.
111516	0.	0.	0.	0.	0.
111517	0.	0.	0.	0.	0.
111518	0.	0.	0.	0.	0.
111519	0.	0.	0.	0.	0.
111520	0.	0.	0.	0.	0.
111521	0.	0.	0.	0.	0.
111522	0.	0.	0.	0.	0.
111523	0.	0.	0.	0.	0.
111524	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE320 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1116 1	0.	0.	0.	0.	0.
1116 2	0.	0.	0.	0.	0.
1116 3	0.	0.	0.	0.	0.
1116 4	0.	0.	0.	0.	0.
1116 5	0.	0.	0.	0.	0.
1116 6	0.	0.	0.	0.	0.
1116 7	0.	0.	0.	0.	0.
1116 8	0.	0.	0.	0.	0.
1116 9	0.	0.	0.	0.	0.
111610	0.	0.	0.	0.	0.
111611	0.	0.	0.	0.	0.
111612	0.	0.	0.	0.	0.
111613	0.	0.	0.	0.	0.
111614	0.	0.	0.	0.	0.
111615	0.	0.	0.	0.	0.
111616	0.	0.	0.	0.	0.
111617	0.	0.	0.	0.	0.
111618	0.	0.	0.	0.	0.
111619	0.	0.	0.	0.	0.
111620	0.	0.	0.	0.	0.
111621	0.	0.	0.	0.	0.
111622	0.	0.	0.	0.	0.
111623	0.	0.	0.	0.	0.
111624	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE321 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1117 1	0.	0.	0.	0.	0.
1117 2	0.	0.	0.	0.	0.
1117 3	0.	0.	0.	0.	0.
1117 4	0.	0.	0.	0.	0.
1117 5	0.	0.	0.	0.	0.
1117 6	0.	0.	0.	0.	0.
1117 7	0.	0.	0.	0.	0.
1117 8	0.	0.	0.	0.	0.
1117 9	0.	0.	0.	0.	0.
111710	0.	0.	0.	0.	0.
111711	0.	0.	0.	0.	0.
111712	0.	0.	0.	0.	0.
111713	0.	0.	0.	0.	0.
111714	0.	0.	0.	0.	0.
111715	0.	0.	0.	0.	0.
111716	0.	0.	0.	0.	0.
111717	0.	0.	0.	0.	0.
111718	0.	0.	0.	0.	0.
111719	0.	0.	0.	0.	0.
111720	0.	0.	0.	0.	0.
111721	0.	0.	0.	0.	0.
111722	0.	0.	0.	0.	0.
111723	0.	0.	0.	0.	0.
111724	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE322 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1118 1	0.	0.	0.	0.	0.
1118 2	0.	0.	0.	0.	0.
1118 3	0.	0.	0.	0.	0.
1118 4	0.	0.	0.	0.	0.
1118 5	0.	0.	0.	0.	0.
1118 6	0.	0.	0.	0.	0.
1118 7	0.	0.	0.	0.	0.
1118 8	0.	0.	0.	0.	0.
1118 9	0.	0.	0.	0.	0.
111810	0.	0.	0.	0.	0.
111811	0.	0.	0.	0.	0.
111812	0.	0.	0.	0.	0.
111813	0.	0.	0.	0.	0.
111814	0.	0.	0.	0.	0.
111815	0.	0.	0.	0.	0.
111816	0.	0.	0.	0.	0.
111817	0.	0.	0.	0.	0.
111818	0.	0.	0.	0.	0.
111819	0.	0.	0.	0.	0.
111820	0.	0.	0.	0.	0.
111821	0.	0.	0.	0.	0.
111822	0.	0.	0.	0.	0.
111823	0.	0.	0.	0.	0.
111824	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE323 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1119 1	0.	0.	0.	0.	0.
1119 2	0.	0.	0.	0.	0.
1119 3	0.	0.	0.	0.	0.
1119 4	0.	0.	0.	0.	0.
1119 5	0.	0.	0.	0.	0.
1119 6	0.	0.	0.	0.	0.
1119 7	0.	0.	0.	0.	0.
1119 8	0.	0.	0.	0.	0.
1119 9	0.	0.	0.	0.	0.
111910	0.	0.	0.	0.	0.
111911	0.	0.	0.	0.	0.
111912	0.	0.	0.	0.	0.
111913	0.	0.	0.	0.	0.
111914	0.	0.	0.	0.	0.
111915	0.	0.	0.	0.	0.
111916	0.	0.	0.	0.	0.
111917	0.	0.	0.	0.	0.
111918	0.	0.	0.	0.	0.
111919	0.	0.	0.	0.	0.
111920	0.	0.	0.	0.	0.
111921	0.	0.	0.	0.	0.
111922	0.	0.	0.	0.	0.
111923	0.	0.	0.	0.	0.
111924	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE324 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1120 1	0.	0.	0.	0.	0.
1120 2	0.	0.	0.	0.	0.
1120 3	0.	0.	0.	0.	0.
1120 4	0.	0.	0.	0.	0.
1120 5	0.	0.	0.	0.	0.
1120 6	0.	0.	0.	0.	0.
1120 7	0.	0.	0.	0.	0.
1120 8	0.	0.	0.	0.	0.
1120 9	0.	0.	0.	0.	0.
112010	0.	0.	0.	0.	0.
112011	0.	0.	0.	0.	0.
112012	0.	0.	0.	0.	0.
112013	0.	0.	0.	0.	0.
112014	0.	0.	0.	0.	0.
112015	0.	0.	0.	0.	0.
112016	0.	0.	0.	0.	0.
112017	0.	0.	0.	0.	0.
112018	0.	0.	0.	0.	0.
112019	0.	0.	0.	0.	0.
112020	0.	0.	0.	0.	0.
112021	0.	0.	0.	0.	0.
112022	0.	0.	0.	0.	0.
112023	0.	0.	0.	0.	0.
112024	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE325 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1121 1	0.	0.	0.	0.	0.
1121 2	0.	0.	0.	0.	0.
1121 3	0.	0.	0.	0.	0.
1121 4	0.	0.	0.	0.	0.
1121 5	0.	0.	0.	0.	0.
1121 6	0.	0.	0.	0.	0.
1121 7	0.	0.	0.	0.	0.
1121 8	0.	0.	0.	0.	0.
1121 9	0.	0.	0.	0.	0.
112110	0.	0.	0.	0.	0.
112111	0.	0.	0.	0.	0.
112112	0.	0.	0.	0.	0.
112113	0.	0.	0.	0.	0.
112114	0.	0.	0.	0.	0.
112115	0.	0.	0.	0.	0.
112116	0.	0.	0.	0.	0.
112117	0.	0.	0.	0.	0.
112118	0.	0.	0.	0.	0.
112119	0.	0.	0.	0.	0.
112120	0.	0.	0.	0.	0.
112121	0.	0.	0.	0.	0.
112122	0.	0.	0.	0.	0.
112123	0.	0.	0.	0.	0.
112124	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE326 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1122 1	0.	0.	0.	0.	0.
1122 2	0.	0.	0.	0.	0.
1122 3	0.	0.	0.	0.	0.
1122 4	0.	0.	0.	0.	0.
1122 5	0.	0.	0.	0.	0.
1122 6	0.	0.	0.	0.	0.
1122 7	0.	0.	0.	0.	0.
1122 8	0.	0.	0.	0.	0.
1122 9	0.	0.	0.	0.	0.
112210	0.	0.	0.	0.	0.
112211	0.	0.	0.	0.	0.
112212	0.	0.	0.	0.	0.
112213	0.	0.	0.	0.	0.
112214	0.	0.	0.	0.	0.
112215	0.	0.	0.	0.	0.
112216	0.	0.	0.	0.	0.
112217	0.	0.	0.	0.	0.
112218	0.	0.	0.	0.	0.
112219	0.	0.	0.	0.	0.
112220	0.	0.	0.	0.	0.
112221	0.	0.	0.	0.	0.
112222	0.	0.	0.	0.	0.
112223	0.	0.	0.	0.	0.
112224	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE327 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1123 1	0.	0.	0.	0.	0.
1123 2	0.	0.	0.	0.	0.
1123 3	0.	0.	0.	0.	0.
1123 4	0.	0.	0.	0.	0.
1123 5	0.	0.	0.	0.	0.
1123 6	0.	0.	0.	0.	0.
1123 7	0.	0.	0.	0.	0.
1123 8	0.	0.	0.	0.	0.
1123 9	0.	0.	0.	0.	0.
112310	0.	0.	0.	0.	0.
112311	0.	0.	0.	0.	0.
112312	0.	0.	0.	0.	0.
112313	0.	0.	0.	0.	0.
112314	0.	0.	0.	0.	0.
112315	0.	0.	0.	0.	0.
112316	0.	0.	0.	0.	0.
112317	0.	0.	0.	0.	0.
112318	0.	0.	0.	0.	0.
112319	0.	0.	0.	0.	0.
112320	0.	0.	0.	0.	0.
112321	0.	0.	0.	0.	0.
112322	0.	0.	0.	0.	0.
112323	0.	0.	0.	0.	0.
112324	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE328 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1124 1	0.	0.	0.	0.	0.
1124 2	0.	0.	0.	0.	0.
1124 3	0.	0.	0.	0.	0.
1124 4	0.	0.	0.	0.	0.
1124 5	0.	0.	0.	0.	0.
1124 6	0.	0.	0.	0.	0.
1124 7	0.	0.	0.	0.	0.
1124 8	0.	0.	0.	0.	0.
1124 9	0.	0.	0.	0.	0.
112410	0.	0.	0.	0.	0.
112411	0.	0.	0.	0.	0.
112412	0.	0.	0.	0.	0.
112413	0.	0.	0.	0.	0.
112414	0.	0.	0.	0.	0.
112415	0.	0.	0.	0.	0.
112416	0.	0.	0.	0.	0.
112417	0.	0.	0.	0.	0.
112418	0.	0.	0.	0.	0.
112419	0.	0.	0.	0.	0.
112420	0.	0.	0.	0.	0.
112421	0.	0.	0.	0.	0.
112422	0.	0.	0.	0.	0.
112423	0.	0.	0.	0.	0.
112424	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE329 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1125 1	0.	0.	0.	0.	0.
1125 2	0.	0.	0.	0.	0.
1125 3	0.	0.	0.	0.	0.
1125 4	0.	0.	0.	0.	0.
1125 5	0.	0.	0.	0.	0.
1125 6	0.	0.	0.	0.	0.
1125 7	0.	0.	0.	0.	0.
1125 8	0.	0.	0.	0.	0.
1125 9	0.	0.	0.	0.	0.
112510	0.	0.	0.	0.	0.
112511	0.	0.	0.	0.	0.
112512	0.	0.	0.	0.	0.
112513	0.	0.	0.	0.	0.
112514	0.	0.	0.	0.	0.
112515	0.	0.	0.	0.	0.
112516	0.	0.	0.	0.	0.
112517	0.	0.	0.	0.	0.
112518	0.	0.	0.	0.	0.
112519	0.	0.	0.	0.	0.
112520	0.	0.	0.	0.	0.
112521	0.	0.	0.	0.	0.
112522	0.	0.	0.	0.	0.
112523	0.	0.	0.	0.	0.
112524	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE330 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1126 1	0.	0.	0.	0.	0.
1126 2	0.	0.	0.	0.	0.
1126 3	0.	0.	0.	0.	0.
1126 4	0.	0.	0.	0.	0.
1126 5	0.	0.	0.	0.	0.
1126 6	0.	0.	0.	0.	0.
1126 7	0.	0.	0.	0.	0.
1126 8	0.	0.	0.	0.	0.
1126 9	0.	0.	0.	0.	0.
112610	0.	0.	0.	0.	0.
112611	0.	0.	0.	0.	0.
112612	0.	0.	0.	0.	0.
112613	0.	0.	0.	0.	0.
112614	0.	0.	0.	0.	0.
112615	0.	0.	0.	0.	0.
112616	0.	0.	0.	0.	0.
112617	0.	0.	0.	0.	0.
112618	0.	0.	0.	0.	0.
112619	0.	0.	0.	0.	0.
112620	0.	0.	0.	0.	0.
112621	0.	0.	0.	0.	0.
112622	0.	0.	0.	0.	0.
112623	0.	0.	0.	0.	0.
112624	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE331 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1127 1	0.	0.	0.	0.	0.
1127 2	0.	0.	0.	0.	0.
1127 3	0.	0.	0.	0.	0.
1127 4	0.	0.	0.	0.	0.
1127 5	0.	0.	0.	0.	0.
1127 6	0.	0.	0.	0.	0.
1127 7	0.	0.	0.	0.	0.
1127 8	0.	0.	0.	0.	0.
1127 9	0.	0.	0.	0.	0.
112710	0.	0.	0.	0.	0.
112711	0.	0.	0.	0.	0.
112712	0.	0.	0.	0.	0.
112713	0.	0.	0.	0.	0.
112714	0.	0.	0.	0.	0.
112715	0.	0.	0.	0.	0.
112716	0.	0.	0.	0.	0.
112717	0.	0.	0.	0.	0.
112718	0.	0.	0.	0.	0.
112719	0.	0.	0.	0.	0.
112720	0.	0.	0.	0.	0.
112721	0.	0.	0.	0.	0.
112722	0.	0.	0.	0.	0.
112723	0.	0.	0.	0.	0.
112724	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE332 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1128 1	0.	0.	0.	0.	0.
1128 2	0.	0.	0.	0.	0.
1128 3	0.	0.	0.	0.	0.
1128 4	0.	0.	0.	0.	0.
1128 5	0.	0.	0.	0.	0.
1128 6	0.	0.	0.	0.	0.
1128 7	0.	0.	0.	0.	0.
1128 8	0.	0.	0.	0.	0.
1128 9	0.	0.	0.	0.	0.
112810	0.	0.	0.	0.	0.
112811	0.	0.	0.	0.	0.
112812	0.	0.	0.	0.	0.
112813	0.	0.	0.	0.	0.
112814	0.	0.	0.	0.	0.
112815	0.	0.	0.	0.	0.
112816	0.	0.	0.	0.	0.
112817	0.	0.	0.	0.	0.
112818	0.	0.	0.	0.	0.
112819	0.	0.	0.	0.	0.
112820	0.	0.	0.	0.	0.
112821	0.	0.	0.	0.	0.
112822	0.	0.	0.	0.	0.
112823	0.	0.	0.	0.	0.
112824	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE333 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1129 1	0.	0.	0.	0.	0.
1129 2	0.	0.	0.	0.	0.
1129 3	0.	0.	0.	0.	0.
1129 4	0.	0.	0.	0.	0.
1129 5	0.	0.	0.	0.	0.
1129 6	0.	0.	0.	0.	0.
1129 7	0.	0.	0.	0.	0.
1129 8	0.	0.	0.	0.	0.
1129 9	0.	0.	0.	0.	0.
112910	0.	0.	0.	0.	0.
112911	0.	0.	0.	0.	0.
112912	0.	0.	0.	0.	0.
112913	0.	0.	0.	0.	0.
112914	0.	0.	0.	0.	0.
112915	0.	0.	0.	0.	0.
112916	0.	0.	0.	0.	0.
112917	0.	0.	0.	0.	0.
112918	0.	0.	0.	0.	0.
112919	0.	0.	0.	0.	0.
112920	0.	0.	0.	0.	0.
112921	0.	0.	0.	0.	0.
112922	0.	0.	0.	0.	0.
112923	0.	0.	0.	0.	0.
112924	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE334 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1130 1	0.	0.	0.	0.	0.
1130 2	0.	0.	0.	0.	0.
1130 3	0.	0.	0.	0.	0.
1130 4	0.	0.	0.	0.	0.
1130 5	0.	0.	0.	0.	0.
1130 6	0.	0.	0.	0.	0.
1130 7	0.	0.	0.	0.	0.
1130 8	0.	0.	0.	0.	0.
1130 9	0.	0.	0.	0.	0.
113010	0.	0.	0.	0.	0.
113011	0.	0.	0.	0.	0.
113012	0.	0.	0.	0.	0.
113013	0.	0.	0.	0.	0.
113014	0.	0.	0.	0.	0.
113015	0.	0.	0.	0.	0.
113016	0.	0.	0.	0.	0.
113017	0.	0.	0.	0.	0.
113018	0.	0.	0.	0.	0.
113019	0.	0.	0.	0.	0.
113020	0.	0.	0.	0.	0.
113021	0.	0.	0.	0.	0.
113022	0.	0.	0.	0.	0.
113023	0.	0.	0.	0.	0.
113024	0.	0.	0.	0.	0.
DAILY SUMMARY (NOV 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (NOV)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE335 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 1 1	0.	0.	0.	0.	0.
12 1 2	0.	0.	0.	0.	0.
12 1 3	0.	0.	0.	0.	0.
12 1 4	0.	0.	0.	0.	0.
12 1 5	0.	0.	0.	0.	0.
12 1 6	0.	0.	0.	0.	0.
12 1 7	0.	0.	0.	0.	0.
12 1 8	0.	0.	0.	0.	0.
12 1 9	0.	0.	0.	0.	0.
12 110	0.	0.	0.	0.	0.
12 111	0.	0.	0.	0.	0.
12 112	0.	0.	0.	0.	0.
12 113	0.	0.	0.	0.	0.
12 114	0.	0.	0.	0.	0.
12 115	0.	0.	0.	0.	0.
12 116	0.	0.	0.	0.	0.
12 117	0.	0.	0.	0.	0.
12 118	0.	0.	0.	0.	0.
12 119	0.	0.	0.	0.	0.
12 120	0.	0.	0.	0.	0.
12 121	0.	0.	0.	0.	0.
12 122	0.	0.	0.	0.	0.
12 123	0.	0.	0.	0.	0.
12 124	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 1)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE336 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 2 1	0.	0.	0.	0.	0.
12 2 2	0.	0.	0.	0.	0.
12 2 3	0.	0.	0.	0.	0.
12 2 4	0.	0.	0.	0.	0.
12 2 5	0.	0.	0.	0.	0.
12 2 6	0.	0.	0.	0.	0.
12 2 7	0.	0.	0.	0.	0.
12 2 8	0.	0.	0.	0.	0.
12 2 9	0.	0.	0.	0.	0.
12 210	0.	0.	0.	0.	0.
12 211	0.	0.	0.	0.	0.
12 212	0.	0.	0.	0.	0.
12 213	0.	0.	0.	0.	0.
12 214	0.	0.	0.	0.	0.
12 215	0.	0.	0.	0.	0.
12 216	0.	0.	0.	0.	0.
12 217	0.	0.	0.	0.	0.
12 218	0.	0.	0.	0.	0.
12 219	0.	0.	0.	0.	0.
12 220	0.	0.	0.	0.	0.
12 221	0.	0.	0.	0.	0.
12 222	0.	0.	0.	0.	0.
12 223	0.	0.	0.	0.	0.
12 224	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 2)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE337 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 3 1	0.	0.	0.	0.	0.
12 3 2	0.	0.	0.	0.	0.
12 3 3	0.	0.	0.	0.	0.
12 3 4	0.	0.	0.	0.	0.
12 3 5	0.	0.	0.	0.	0.
12 3 6	0.	0.	0.	0.	0.
12 3 7	0.	0.	0.	0.	0.
12 3 8	0.	0.	0.	0.	0.
12 3 9	0.	0.	0.	0.	0.
12 310	0.	0.	0.	0.	0.
12 311	0.	0.	0.	0.	0.
12 312	0.	0.	0.	0.	0.
12 313	0.	0.	0.	0.	0.
12 314	0.	0.	0.	0.	0.
12 315	0.	0.	0.	0.	0.
12 316	0.	0.	0.	0.	0.
12 317	0.	0.	0.	0.	0.
12 318	0.	0.	0.	0.	0.
12 319	0.	0.	0.	0.	0.
12 320	0.	0.	0.	0.	0.
12 321	0.	0.	0.	0.	0.
12 322	0.	0.	0.	0.	0.
12 323	0.	0.	0.	0.	0.
12 324	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 3)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE338 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 4 1	0.	0.	0.	0.	0.
12 4 2	0.	0.	0.	0.	0.
12 4 3	0.	0.	0.	0.	0.
12 4 4	0.	0.	0.	0.	0.
12 4 5	0.	0.	0.	0.	0.
12 4 6	0.	0.	0.	0.	0.
12 4 7	0.	0.	0.	0.	0.
12 4 8	0.	0.	0.	0.	0.
12 4 9	0.	0.	0.	0.	0.
12 410	0.	0.	0.	0.	0.
12 411	0.	0.	0.	0.	0.
12 412	0.	0.	0.	0.	0.
12 413	0.	0.	0.	0.	0.
12 414	0.	0.	0.	0.	0.
12 415	0.	0.	0.	0.	0.
12 416	0.	0.	0.	0.	0.
12 417	0.	0.	0.	0.	0.
12 418	0.	0.	0.	0.	0.
12 419	0.	0.	0.	0.	0.
12 420	0.	0.	0.	0.	0.
12 421	0.	0.	0.	0.	0.
12 422	0.	0.	0.	0.	0.
12 423	0.	0.	0.	0.	0.
12 424	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 4)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE339 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 5 1	0.	0.	0.	0.	0.
12 5 2	0.	0.	0.	0.	0.
12 5 3	0.	0.	0.	0.	0.
12 5 4	0.	0.	0.	0.	0.
12 5 5	0.	0.	0.	0.	0.
12 5 6	0.	0.	0.	0.	0.
12 5 7	0.	0.	0.	0.	0.
12 5 8	0.	0.	0.	0.	0.
12 5 9	0.	0.	0.	0.	0.
12 510	0.	0.	0.	0.	0.
12 511	0.	0.	0.	0.	0.
12 512	0.	0.	0.	0.	0.
12 513	0.	0.	0.	0.	0.
12 514	0.	0.	0.	0.	0.
12 515	0.	0.	0.	0.	0.
12 516	0.	0.	0.	0.	0.
12 517	0.	0.	0.	0.	0.
12 518	0.	0.	0.	0.	0.
12 519	0.	0.	0.	0.	0.
12 520	0.	0.	0.	0.	0.
12 521	0.	0.	0.	0.	0.
12 522	0.	0.	0.	0.	0.
12 523	0.	0.	0.	0.	0.
12 524	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 5)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE340 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 6 1	0.	0.	0.	0.	0.
12 6 2	0.	0.	0.	0.	0.
12 6 3	0.	0.	0.	0.	0.
12 6 4	0.	0.	0.	0.	0.
12 6 5	0.	0.	0.	0.	0.
12 6 6	0.	0.	0.	0.	0.
12 6 7	0.	0.	0.	0.	0.
12 6 8	0.	0.	0.	0.	0.
12 6 9	0.	0.	0.	0.	0.
12 610	0.	0.	0.	0.	0.
12 611	0.	0.	0.	0.	0.
12 612	0.	0.	0.	0.	0.
12 613	0.	0.	0.	0.	0.
12 614	0.	0.	0.	0.	0.
12 615	0.	0.	0.	0.	0.
12 616	0.	0.	0.	0.	0.
12 617	0.	0.	0.	0.	0.
12 618	0.	0.	0.	0.	0.
12 619	0.	0.	0.	0.	0.
12 620	0.	0.	0.	0.	0.
12 621	0.	0.	0.	0.	0.
12 622	0.	0.	0.	0.	0.
12 623	0.	0.	0.	0.	0.
12 624	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 6)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE341 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 7 1	0.	0.	0.	0.	0.
12 7 2	0.	0.	0.	0.	0.
12 7 3	0.	0.	0.	0.	0.
12 7 4	0.	0.	0.	0.	0.
12 7 5	0.	0.	0.	0.	0.
12 7 6	0.	0.	0.	0.	0.
12 7 7	0.	0.	0.	0.	0.
12 7 8	0.	0.	0.	0.	0.
12 7 9	0.	0.	0.	0.	0.
12 710	0.	0.	0.	0.	0.
12 711	0.	0.	0.	0.	0.
12 712	0.	0.	0.	0.	0.
12 713	0.	0.	0.	0.	0.
12 714	0.	0.	0.	0.	0.
12 715	0.	0.	0.	0.	0.
12 716	0.	0.	0.	0.	0.
12 717	0.	0.	0.	0.	0.
12 718	0.	0.	0.	0.	0.
12 719	0.	0.	0.	0.	0.
12 720	0.	0.	0.	0.	0.
12 721	0.	0.	0.	0.	0.
12 722	0.	0.	0.	0.	0.
12 723	0.	0.	0.	0.	0.
12 724	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 7)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE342 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 8 1	0.	0.	0.	0.	0.
12 8 2	0.	0.	0.	0.	0.
12 8 3	0.	0.	0.	0.	0.
12 8 4	0.	0.	0.	0.	0.
12 8 5	0.	0.	0.	0.	0.
12 8 6	0.	0.	0.	0.	0.
12 8 7	0.	0.	0.	0.	0.
12 8 8	0.	0.	0.	0.	0.
12 8 9	0.	0.	0.	0.	0.
12 810	0.	0.	0.	0.	0.
12 811	0.	0.	0.	0.	0.
12 812	0.	0.	0.	0.	0.
12 813	0.	0.	0.	0.	0.
12 814	0.	0.	0.	0.	0.
12 815	0.	0.	0.	0.	0.
12 816	0.	0.	0.	0.	0.
12 817	0.	0.	0.	0.	0.
12 818	0.	0.	0.	0.	0.
12 819	0.	0.	0.	0.	0.
12 820	0.	0.	0.	0.	0.
12 821	0.	0.	0.	0.	0.
12 822	0.	0.	0.	0.	0.
12 823	0.	0.	0.	0.	0.
12 824	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 8)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE343 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
12 9 1	0.	0.	0.	0.	0.
12 9 2	0.	0.	0.	0.	0.
12 9 3	0.	0.	0.	0.	0.
12 9 4	0.	0.	0.	0.	0.
12 9 5	0.	0.	0.	0.	0.
12 9 6	0.	0.	0.	0.	0.
12 9 7	0.	0.	0.	0.	0.
12 9 8	0.	0.	0.	0.	0.
12 9 9	0.	0.	0.	0.	0.
12 910	0.	0.	0.	0.	0.
12 911	0.	0.	0.	0.	0.
12 912	0.	0.	0.	0.	0.
12 913	0.	0.	0.	0.	0.
12 914	0.	0.	0.	0.	0.
12 915	0.	0.	0.	0.	0.
12 916	0.	0.	0.	0.	0.
12 917	0.	0.	0.	0.	0.
12 918	0.	0.	0.	0.	0.
12 919	0.	0.	0.	0.	0.
12 920	0.	0.	0.	0.	0.
12 921	0.	0.	0.	0.	0.
12 922	0.	0.	0.	0.	0.
12 923	0.	0.	0.	0.	0.
12 924	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 9)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE344 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1210 1	0.	0.	0.	0.	0.
1210 2	0.	0.	0.	0.	0.
1210 3	0.	0.	0.	0.	0.
1210 4	0.	0.	0.	0.	0.
1210 5	0.	0.	0.	0.	0.
1210 6	0.	0.	0.	0.	0.
1210 7	0.	0.	0.	0.	0.
1210 8	0.	0.	0.	0.	0.
1210 9	0.	0.	0.	0.	0.
121010	0.	0.	0.	0.	0.
121011	0.	0.	0.	0.	0.
121012	0.	0.	0.	0.	0.
121013	0.	0.	0.	0.	0.
121014	0.	0.	0.	0.	0.
121015	0.	0.	0.	0.	0.
121016	0.	0.	0.	0.	0.
121017	0.	0.	0.	0.	0.
121018	0.	0.	0.	0.	0.
121019	0.	0.	0.	0.	0.
121020	0.	0.	0.	0.	0.
121021	0.	0.	0.	0.	0.
121022	0.	0.	0.	0.	0.
121023	0.	0.	0.	0.	0.
121024	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 10)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE345 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1211 1	0.	0.	0.	0.	0.
1211 2	0.	0.	0.	0.	0.
1211 3	0.	0.	0.	0.	0.
1211 4	0.	0.	0.	0.	0.
1211 5	0.	0.	0.	0.	0.
1211 6	0.	0.	0.	0.	0.
1211 7	0.	0.	0.	0.	0.
1211 8	0.	0.	0.	0.	0.
1211 9	0.	0.	0.	0.	0.
121110	0.	0.	0.	0.	0.
121111	0.	0.	0.	0.	0.
121112	0.	0.	0.	0.	0.
121113	0.	0.	0.	0.	0.
121114	0.	0.	0.	0.	0.
121115	0.	0.	0.	0.	0.
121116	0.	0.	0.	0.	0.
121117	0.	0.	0.	0.	0.
121118	0.	0.	0.	0.	0.
121119	0.	0.	0.	0.	0.
121120	0.	0.	0.	0.	0.
121121	0.	0.	0.	0.	0.
121122	0.	0.	0.	0.	0.
121123	0.	0.	0.	0.	0.
121124	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 11)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE346 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1212 1	0.	0.	0.	0.	0.
1212 2	0.	0.	0.	0.	0.
1212 3	0.	0.	0.	0.	0.
1212 4	0.	0.	0.	0.	0.
1212 5	0.	0.	0.	0.	0.
1212 6	0.	0.	0.	0.	0.
1212 7	0.	0.	0.	0.	0.
1212 8	0.	0.	0.	0.	0.
1212 9	0.	0.	0.	0.	0.
121210	0.	0.	0.	0.	0.
121211	0.	0.	0.	0.	0.
121212	0.	0.	0.	0.	0.
121213	0.	0.	0.	0.	0.
121214	0.	0.	0.	0.	0.
121215	0.	0.	0.	0.	0.
121216	0.	0.	0.	0.	0.
121217	0.	0.	0.	0.	0.
121218	0.	0.	0.	0.	0.
121219	0.	0.	0.	0.	0.
121220	0.	0.	0.	0.	0.
121221	0.	0.	0.	0.	0.
121222	0.	0.	0.	0.	0.
121223	0.	0.	0.	0.	0.
121224	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 12)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE347 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1213 1	0.	0.	0.	0.	0.
1213 2	0.	0.	0.	0.	0.
1213 3	0.	0.	0.	0.	0.
1213 4	0.	0.	0.	0.	0.
1213 5	0.	0.	0.	0.	0.
1213 6	0.	0.	0.	0.	0.
1213 7	0.	0.	0.	0.	0.
1213 8	0.	0.	0.	0.	0.
1213 9	0.	0.	0.	0.	0.
121310	0.	0.	0.	0.	0.
121311	0.	0.	0.	0.	0.
121312	0.	0.	0.	0.	0.
121313	0.	0.	0.	0.	0.
121314	0.	0.	0.	0.	0.
121315	0.	0.	0.	0.	0.
121316	0.	0.	0.	0.	0.
121317	0.	0.	0.	0.	0.
121318	0.	0.	0.	0.	0.
121319	0.	0.	0.	0.	0.
121320	0.	0.	0.	0.	0.
121321	0.	0.	0.	0.	0.
121322	0.	0.	0.	0.	0.
121323	0.	0.	0.	0.	0.
121324	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 13)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE348 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1214 1	0.	0.	0.	0.	0.
1214 2	0.	0.	0.	0.	0.
1214 3	0.	0.	0.	0.	0.
1214 4	0.	0.	0.	0.	0.
1214 5	0.	0.	0.	0.	0.
1214 6	0.	0.	0.	0.	0.
1214 7	0.	0.	0.	0.	0.
1214 8	0.	0.	0.	0.	0.
1214 9	0.	0.	0.	0.	0.
121410	0.	0.	0.	0.	0.
121411	0.	0.	0.	0.	0.
121412	0.	0.	0.	0.	0.
121413	0.	0.	0.	0.	0.
121414	0.	0.	0.	0.	0.
121415	0.	0.	0.	0.	0.
121416	0.	0.	0.	0.	0.
121417	0.	0.	0.	0.	0.
121418	0.	0.	0.	0.	0.
121419	0.	0.	0.	0.	0.
121420	0.	0.	0.	0.	0.
121421	0.	0.	0.	0.	0.
121422	0.	0.	0.	0.	0.
121423	0.	0.	0.	0.	0.
121424	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 14)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE349 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1215 1	0.	0.	0.	0.	0.
1215 2	0.	0.	0.	0.	0.
1215 3	0.	0.	0.	0.	0.
1215 4	0.	0.	0.	0.	0.
1215 5	0.	0.	0.	0.	0.
1215 6	0.	0.	0.	0.	0.
1215 7	0.	0.	0.	0.	0.
1215 8	0.	0.	0.	0.	0.
1215 9	0.	0.	0.	0.	0.
121510	0.	0.	0.	0.	0.
121511	0.	0.	0.	0.	0.
121512	0.	0.	0.	0.	0.
121513	0.	0.	0.	0.	0.
121514	0.	0.	0.	0.	0.
121515	0.	0.	0.	0.	0.
121516	0.	0.	0.	0.	0.
121517	0.	0.	0.	0.	0.
121518	0.	0.	0.	0.	0.
121519	0.	0.	0.	0.	0.
121520	0.	0.	0.	0.	0.
121521	0.	0.	0.	0.	0.
121522	0.	0.	0.	0.	0.
121523	0.	0.	0.	0.	0.
121524	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 15)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE350 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1216 1	0.	0.	0.	0.	0.
1216 2	0.	0.	0.	0.	0.
1216 3	0.	0.	0.	0.	0.
1216 4	0.	0.	0.	0.	0.
1216 5	0.	0.	0.	0.	0.
1216 6	0.	0.	0.	0.	0.
1216 7	0.	0.	0.	0.	0.
1216 8	0.	0.	0.	0.	0.
1216 9	0.	0.	0.	0.	0.
121610	0.	0.	0.	0.	0.
121611	0.	0.	0.	0.	0.
121612	0.	0.	0.	0.	0.
121613	0.	0.	0.	0.	0.
121614	0.	0.	0.	0.	0.
121615	0.	0.	0.	0.	0.
121616	0.	0.	0.	0.	0.
121617	0.	0.	0.	0.	0.
121618	0.	0.	0.	0.	0.
121619	0.	0.	0.	0.	0.
121620	0.	0.	0.	0.	0.
121621	0.	0.	0.	0.	0.
121622	0.	0.	0.	0.	0.
121623	0.	0.	0.	0.	0.
121624	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 16)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE351 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1217 1	0.	0.	0.	0.	0.
1217 2	0.	0.	0.	0.	0.
1217 3	0.	0.	0.	0.	0.
1217 4	0.	0.	0.	0.	0.
1217 5	0.	0.	0.	0.	0.
1217 6	0.	0.	0.	0.	0.
1217 7	0.	0.	0.	0.	0.
1217 8	0.	0.	0.	0.	0.
1217 9	0.	0.	0.	0.	0.
121710	0.	0.	0.	0.	0.
121711	0.	0.	0.	0.	0.
121712	0.	0.	0.	0.	0.
121713	0.	0.	0.	0.	0.
121714	0.	0.	0.	0.	0.
121715	0.	0.	0.	0.	0.
121716	0.	0.	0.	0.	0.
121717	0.	0.	0.	0.	0.
121718	0.	0.	0.	0.	0.
121719	0.	0.	0.	0.	0.
121720	0.	0.	0.	0.	0.
121721	0.	0.	0.	0.	0.
121722	0.	0.	0.	0.	0.
121723	0.	0.	0.	0.	0.
121724	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 17)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE352 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1218 1	0.	0.	0.	0.	0.
1218 2	0.	0.	0.	0.	0.
1218 3	0.	0.	0.	0.	0.
1218 4	0.	0.	0.	0.	0.
1218 5	0.	0.	0.	0.	0.
1218 6	0.	0.	0.	0.	0.
1218 7	0.	0.	0.	0.	0.
1218 8	0.	0.	0.	0.	0.
1218 9	0.	0.	0.	0.	0.
121810	0.	0.	0.	0.	0.
121811	0.	0.	0.	0.	0.
121812	0.	0.	0.	0.	0.
121813	0.	0.	0.	0.	0.
121814	0.	0.	0.	0.	0.
121815	0.	0.	0.	0.	0.
121816	0.	0.	0.	0.	0.
121817	0.	0.	0.	0.	0.
121818	0.	0.	0.	0.	0.
121819	0.	0.	0.	0.	0.
121820	0.	0.	0.	0.	0.
121821	0.	0.	0.	0.	0.
121822	0.	0.	0.	0.	0.
121823	0.	0.	0.	0.	0.
121824	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 18)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE353 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1219 1	0.	0.	0.	0.	0.
1219 2	0.	0.	0.	0.	0.
1219 3	0.	0.	0.	0.	0.
1219 4	0.	0.	0.	0.	0.
1219 5	0.	0.	0.	0.	0.
1219 6	0.	0.	0.	0.	0.
1219 7	0.	0.	0.	0.	0.
1219 8	0.	0.	0.	0.	0.
1219 9	0.	0.	0.	0.	0.
121910	0.	0.	0.	0.	0.
121911	0.	0.	0.	0.	0.
121912	0.	0.	0.	0.	0.
121913	0.	0.	0.	0.	0.
121914	0.	0.	0.	0.	0.
121915	0.	0.	0.	0.	0.
121916	0.	0.	0.	0.	0.
121917	0.	0.	0.	0.	0.
121918	0.	0.	0.	0.	0.
121919	0.	0.	0.	0.	0.
121920	0.	0.	0.	0.	0.
121921	0.	0.	0.	0.	0.
121922	0.	0.	0.	0.	0.
121923	0.	0.	0.	0.	0.
121924	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 19)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE354 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1220 1	0.	0.	0.	0.	0.
1220 2	0.	0.	0.	0.	0.
1220 3	0.	0.	0.	0.	0.
1220 4	0.	0.	0.	0.	0.
1220 5	0.	0.	0.	0.	0.
1220 6	0.	0.	0.	0.	0.
1220 7	0.	0.	0.	0.	0.
1220 8	0.	0.	0.	0.	0.
1220 9	0.	0.	0.	0.	0.
122010	0.	0.	0.	0.	0.
122011	0.	0.	0.	0.	0.
122012	0.	0.	0.	0.	0.
122013	0.	0.	0.	0.	0.
122014	0.	0.	0.	0.	0.
122015	0.	0.	0.	0.	0.
122016	0.	0.	0.	0.	0.
122017	0.	0.	0.	0.	0.
122018	0.	0.	0.	0.	0.
122019	0.	0.	0.	0.	0.
122020	0.	0.	0.	0.	0.
122021	0.	0.	0.	0.	0.
122022	0.	0.	0.	0.	0.
122023	0.	0.	0.	0.	0.
122024	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 20)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE355 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1221 1	0.	0.	0.	0.	0.
1221 2	0.	0.	0.	0.	0.
1221 3	0.	0.	0.	0.	0.
1221 4	0.	0.	0.	0.	0.
1221 5	0.	0.	0.	0.	0.
1221 6	0.	0.	0.	0.	0.
1221 7	0.	0.	0.	0.	0.
1221 8	0.	0.	0.	0.	0.
1221 9	0.	0.	0.	0.	0.
122110	0.	0.	0.	0.	0.
122111	0.	0.	0.	0.	0.
122112	0.	0.	0.	0.	0.
122113	0.	0.	0.	0.	0.
122114	0.	0.	0.	0.	0.
122115	0.	0.	0.	0.	0.
122116	0.	0.	0.	0.	0.
122117	0.	0.	0.	0.	0.
122118	0.	0.	0.	0.	0.
122119	0.	0.	0.	0.	0.
122120	0.	0.	0.	0.	0.
122121	0.	0.	0.	0.	0.
122122	0.	0.	0.	0.	0.
122123	0.	0.	0.	0.	0.
122124	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 21)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE356 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1222 1	0.	0.	0.	0.	0.
1222 2	0.	0.	0.	0.	0.
1222 3	0.	0.	0.	0.	0.
1222 4	0.	0.	0.	0.	0.
1222 5	0.	0.	0.	0.	0.
1222 6	0.	0.	0.	0.	0.
1222 7	0.	0.	0.	0.	0.
1222 8	0.	0.	0.	0.	0.
1222 9	0.	0.	0.	0.	0.
122210	0.	0.	0.	0.	0.
122211	0.	0.	0.	0.	0.
122212	0.	0.	0.	0.	0.
122213	0.	0.	0.	0.	0.
122214	0.	0.	0.	0.	0.
122215	0.	0.	0.	0.	0.
122216	0.	0.	0.	0.	0.
122217	0.	0.	0.	0.	0.
122218	0.	0.	0.	0.	0.
122219	0.	0.	0.	0.	0.
122220	0.	0.	0.	0.	0.
122221	0.	0.	0.	0.	0.
122222	0.	0.	0.	0.	0.
122223	0.	0.	0.	0.	0.
122224	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 22)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE357 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1223 1	0.	0.	0.	0.	0.
1223 2	0.	0.	0.	0.	0.
1223 3	0.	0.	0.	0.	0.
1223 4	0.	0.	0.	0.	0.
1223 5	0.	0.	0.	0.	0.
1223 6	0.	0.	0.	0.	0.
1223 7	0.	0.	0.	0.	0.
1223 8	0.	0.	0.	0.	0.
1223 9	0.	0.	0.	0.	0.
122310	0.	0.	0.	0.	0.
122311	0.	0.	0.	0.	0.
122312	0.	0.	0.	0.	0.
122313	0.	0.	0.	0.	0.
122314	0.	0.	0.	0.	0.
122315	0.	0.	0.	0.	0.
122316	0.	0.	0.	0.	0.
122317	0.	0.	0.	0.	0.
122318	0.	0.	0.	0.	0.
122319	0.	0.	0.	0.	0.
122320	0.	0.	0.	0.	0.
122321	0.	0.	0.	0.	0.
122322	0.	0.	0.	0.	0.
122323	0.	0.	0.	0.	0.
122324	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 23)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE358 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1224 1	0.	0.	0.	0.	0.
1224 2	0.	0.	0.	0.	0.
1224 3	0.	0.	0.	0.	0.
1224 4	0.	0.	0.	0.	0.
1224 5	0.	0.	0.	0.	0.
1224 6	0.	0.	0.	0.	0.
1224 7	0.	0.	0.	0.	0.
1224 8	0.	0.	0.	0.	0.
1224 9	0.	0.	0.	0.	0.
122410	0.	0.	0.	0.	0.
122411	0.	0.	0.	0.	0.
122412	0.	0.	0.	0.	0.
122413	0.	0.	0.	0.	0.
122414	0.	0.	0.	0.	0.
122415	0.	0.	0.	0.	0.
122416	0.	0.	0.	0.	0.
122417	0.	0.	0.	0.	0.
122418	0.	0.	0.	0.	0.
122419	0.	0.	0.	0.	0.
122420	0.	0.	0.	0.	0.
122421	0.	0.	0.	0.	0.
122422	0.	0.	0.	0.	0.
122423	0.	0.	0.	0.	0.
122424	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 24)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE359 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1225 1	0.	0.	0.	0.	0.
1225 2	0.	0.	0.	0.	0.
1225 3	0.	0.	0.	0.	0.
1225 4	0.	0.	0.	0.	0.
1225 5	0.	0.	0.	0.	0.
1225 6	0.	0.	0.	0.	0.
1225 7	0.	0.	0.	0.	0.
1225 8	0.	0.	0.	0.	0.
1225 9	0.	0.	0.	0.	0.
122510	0.	0.	0.	0.	0.
122511	0.	0.	0.	0.	0.
122512	0.	0.	0.	0.	0.
122513	0.	0.	0.	0.	0.
122514	0.	0.	0.	0.	0.
122515	0.	0.	0.	0.	0.
122516	0.	0.	0.	0.	0.
122517	0.	0.	0.	0.	0.
122518	0.	0.	0.	0.	0.
122519	0.	0.	0.	0.	0.
122520	0.	0.	0.	0.	0.
122521	0.	0.	0.	0.	0.
122522	0.	0.	0.	0.	0.
122523	0.	0.	0.	0.	0.
122524	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 25)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE360 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1226 1	0.	0.	0.	0.	0.
1226 2	0.	0.	0.	0.	0.
1226 3	0.	0.	0.	0.	0.
1226 4	0.	0.	0.	0.	0.
1226 5	0.	0.	0.	0.	0.
1226 6	0.	0.	0.	0.	0.
1226 7	0.	0.	0.	0.	0.
1226 8	0.	0.	0.	0.	0.
1226 9	0.	0.	0.	0.	0.
122610	0.	0.	0.	0.	0.
122611	0.	0.	0.	0.	0.
122612	0.	0.	0.	0.	0.
122613	0.	0.	0.	0.	0.
122614	0.	0.	0.	0.	0.
122615	0.	0.	0.	0.	0.
122616	0.	0.	0.	0.	0.
122617	0.	0.	0.	0.	0.
122618	0.	0.	0.	0.	0.
122619	0.	0.	0.	0.	0.
122620	0.	0.	0.	0.	0.
122621	0.	0.	0.	0.	0.
122622	0.	0.	0.	0.	0.
122623	0.	0.	0.	0.	0.
122624	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 26)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE361 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1227 1	0.	0.	0.	0.	0.
1227 2	0.	0.	0.	0.	0.
1227 3	0.	0.	0.	0.	0.
1227 4	0.	0.	0.	0.	0.
1227 5	0.	0.	0.	0.	0.
1227 6	0.	0.	0.	0.	0.
1227 7	0.	0.	0.	0.	0.
1227 8	0.	0.	0.	0.	0.
1227 9	0.	0.	0.	0.	0.
122710	0.	0.	0.	0.	0.
122711	0.	0.	0.	0.	0.
122712	0.	0.	0.	0.	0.
122713	0.	0.	0.	0.	0.
122714	0.	0.	0.	0.	0.
122715	0.	0.	0.	0.	0.
122716	0.	0.	0.	0.	0.
122717	0.	0.	0.	0.	0.
122718	0.	0.	0.	0.	0.
122719	0.	0.	0.	0.	0.
122720	0.	0.	0.	0.	0.
122721	0.	0.	0.	0.	0.
122722	0.	0.	0.	0.	0.
122723	0.	0.	0.	0.	0.
122724	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 27)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE362 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1228 1	0.	0.	0.	0.	0.
1228 2	0.	0.	0.	0.	0.
1228 3	0.	0.	0.	0.	0.
1228 4	0.	0.	0.	0.	0.
1228 5	0.	0.	0.	0.	0.
1228 6	0.	0.	0.	0.	0.
1228 7	0.	0.	0.	0.	0.
1228 8	0.	0.	0.	0.	0.
1228 9	0.	0.	0.	0.	0.
122810	0.	0.	0.	0.	0.
122811	0.	0.	0.	0.	0.
122812	0.	0.	0.	0.	0.
122813	0.	0.	0.	0.	0.
122814	0.	0.	0.	0.	0.
122815	0.	0.	0.	0.	0.
122816	0.	0.	0.	0.	0.
122817	0.	0.	0.	0.	0.
122818	0.	0.	0.	0.	0.
122819	0.	0.	0.	0.	0.
122820	0.	0.	0.	0.	0.
122821	0.	0.	0.	0.	0.
122822	0.	0.	0.	0.	0.
122823	0.	0.	0.	0.	0.
122824	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 28)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE363 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1229 1	0.	0.	0.	0.	0.
1229 2	0.	0.	0.	0.	0.
1229 3	0.	0.	0.	0.	0.
1229 4	0.	0.	0.	0.	0.
1229 5	0.	0.	0.	0.	0.
1229 6	0.	0.	0.	0.	0.
1229 7	0.	0.	0.	0.	0.
1229 8	0.	0.	0.	0.	0.
1229 9	0.	0.	0.	0.	0.
122910	0.	0.	0.	0.	0.
122911	0.	0.	0.	0.	0.
122912	0.	0.	0.	0.	0.
122913	0.	0.	0.	0.	0.
122914	0.	0.	0.	0.	0.
122915	0.	0.	0.	0.	0.
122916	0.	0.	0.	0.	0.
122917	0.	0.	0.	0.	0.
122918	0.	0.	0.	0.	0.
122919	0.	0.	0.	0.	0.
122920	0.	0.	0.	0.	0.
122921	0.	0.	0.	0.	0.
122922	0.	0.	0.	0.	0.
122923	0.	0.	0.	0.	0.
122924	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 29)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE364 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1230 1	0.	0.	0.	0.	0.
1230 2	0.	0.	0.	0.	0.
1230 3	0.	0.	0.	0.	0.
1230 4	0.	0.	0.	0.	0.
1230 5	0.	0.	0.	0.	0.
1230 6	0.	0.	0.	0.	0.
1230 7	0.	0.	0.	0.	0.
1230 8	0.	0.	0.	0.	0.
1230 9	0.	0.	0.	0.	0.
123010	0.	0.	0.	0.	0.
123011	0.	0.	0.	0.	0.
123012	0.	0.	0.	0.	0.
123013	0.	0.	0.	0.	0.
123014	0.	0.	0.	0.	0.
123015	0.	0.	0.	0.	0.
123016	0.	0.	0.	0.	0.
123017	0.	0.	0.	0.	0.
123018	0.	0.	0.	0.	0.
123019	0.	0.	0.	0.	0.
123020	0.	0.	0.	0.	0.
123021	0.	0.	0.	0.	0.
123022	0.	0.	0.	0.	0.
123023	0.	0.	0.	0.	0.
123024	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 30)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

HOURLY REPORT- Hourly Report

WEATHER FILE- Los Angeles CA TMY2PAGE365 - 3

	FM1	FM1	FM1	FM1	FM1
	REFG END USE BTU	SUPP END USE BTU	DHW END USE BTU	EXT END USE BTU	TOTAL USAGE BTU
	---- (9)	---- (10)	---- (11)	---- (12)	---- (20)
1231 1	0.	0.	0.	0.	0.
1231 2	0.	0.	0.	0.	0.
1231 3	0.	0.	0.	0.	0.
1231 4	0.	0.	0.	0.	0.
1231 5	0.	0.	0.	0.	0.
1231 6	0.	0.	0.	0.	0.
1231 7	0.	0.	0.	0.	0.
1231 8	0.	0.	0.	0.	0.
1231 9	0.	0.	0.	0.	0.
123110	0.	0.	0.	0.	0.
123111	0.	0.	0.	0.	0.
123112	0.	0.	0.	0.	0.
123113	0.	0.	0.	0.	0.
123114	0.	0.	0.	0.	0.
123115	0.	0.	0.	0.	0.
123116	0.	0.	0.	0.	0.
123117	0.	0.	0.	0.	0.
123118	0.	0.	0.	0.	0.
123119	0.	0.	0.	0.	0.
123120	0.	0.	0.	0.	0.
123121	0.	0.	0.	0.	0.
123122	0.	0.	0.	0.	0.
123123	0.	0.	0.	0.	0.
123124	0.	0.	0.	0.	0.
DAILY SUMMARY (DEC 31)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
MONTHLY SUMMARY (DEC)					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.
YEARLY SUMMARY					
MN	0.	0.	0.	0.	0.
MX	0.	0.	0.	0.	0.
SM	0.	0.	0.	0.	0.
AV	0.	0.	0.	0.	0.

WARNING***
NO ENERGY COSTS, DEMAND COSTS, OR BLOCK-CHARGES HAVE BEEN DEFINED
FOR UTILITY-RATE Custom Elec Rate
DEFAULT OF \$ 0.07 PER KWH ASSUMED.

REPORT- EV-A Life-Cycle Costing Parameters

WEATHER FILE- Los Angeles CA TMY2

LIFE-CYCLE COSTING PARAMETERS

DISCOUNT RATE (PERCENT)	LABOR INFLATION RATE (PERCENT)	MATERIALS INFLATION RATE (PERCENT)	PROJECT LIFE (YEARS)
10.0	0.0	0.0	25.0

BUILDING COMPONENT COST INPUT DATA (CURRENT DOLLARS)

COST NAME	NUMBER OF UNITS	UNIT NAME	LIFE (YEARS)	UNIT FIRST COST (\$)	UNIT INSTALL -ATION COST (\$)	UNIT ANNUAL MAINT COST (\$)	UNIT MINOR OVERHAUL COST (\$)	MINOR OVERHAUL INTERVAL (YEARS)	UNIT MAJOR OVERHAUL COST (\$)	MAJOR OVERHAUL INTERVAL (YEARS)
-----------	--------------------	-----------	-----------------	-------------------------------	---	---	---	--	---	--

NO BUILDING COMPONENT COSTS SPECIFIED

REPORT- ES-A Annual Costs and Savings

WEATHER FILE- Los Angeles CA TMY2

YEAR	E N E R G Y (\$)			O P E R A T I O N S (\$)				TOTAL	
	ENERGY	ENERGY	ENERGY	OPRNS	OPRNS COST -- THIS RUN			OPRNS	SAVINGS-
	COST	COST	COST	COST	-----			COST	ENERGY
-----	BASELINE	THIS RUN	SAVINGS	BASELINE	PLANT	BUILDING	TOTAL	SAVINGS	PLUS
----	-----	-----	-----	-----	-----	-----	-----	-----	OPRNS
----	-----	-----	-----	-----	-----	-----	-----	-----	-----
1	0.	142612.	-142612.	0.	0.	0.	0.	0.	-142612.
2	0.	136130.	-136130.	0.	0.	0.	0.	0.	-136130.
3	0.	129942.	-129942.	0.	0.	0.	0.	0.	-129942.
4	0.	124036.	-124036.	0.	0.	0.	0.	0.	-124036.
5	0.	118398.	-118398.	0.	0.	0.	0.	0.	-118398.
6	0.	113016.	-113016.	0.	0.	0.	0.	0.	-113016.
7	0.	107879.	-107879.	0.	0.	0.	0.	0.	-107879.
8	0.	102975.	-102975.	0.	0.	0.	0.	0.	-102975.
9	0.	98295.	-98295.	0.	0.	0.	0.	0.	-98295.
10	0.	93827.	-93827.	0.	0.	0.	0.	0.	-93827.
11	0.	89562.	-89562.	0.	0.	0.	0.	0.	-89562.
12	0.	85491.	-85491.	0.	0.	0.	0.	0.	-85491.
13	0.	81605.	-81605.	0.	0.	0.	0.	0.	-81605.
14	0.	77896.	-77896.	0.	0.	0.	0.	0.	-77896.
15	0.	74355.	-74355.	0.	0.	0.	0.	0.	-74355.
16	0.	70975.	-70975.	0.	0.	0.	0.	0.	-70975.
17	0.	67749.	-67749.	0.	0.	0.	0.	0.	-67749.
18	0.	64670.	-64670.	0.	0.	0.	0.	0.	-64670.
19	0.	61730.	-61730.	0.	0.	0.	0.	0.	-61730.
20	0.	58924.	-58924.	0.	0.	0.	0.	0.	-58924.
21	0.	56246.	-56246.	0.	0.	0.	0.	0.	-56246.
22	0.	53689.	-53689.	0.	0.	0.	0.	0.	-53689.
23	0.	51249.	-51249.	0.	0.	0.	0.	0.	-51249.
24	0.	48919.	-48919.	0.	0.	0.	0.	0.	-48919.
25	0.	46696.	-46696.	0.	0.	0.	0.	0.	-46696.
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
TOTALS (\$)	0.	2156866.	-2156866.	0.	0.	0.	0.	0.	-2156866.

LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS (\$)

COST NAME	FIRST COST (INCLUDING INSTALLATION)	REPLACEMENTS	OPERATIONS	TOTAL	INVESTMENT (FIRST COST PLUS REPLACEMENTS)
NO BUILDING COMPONENT COSTS SPECIFIED					

ENERGY SAVINGS

	ANNUAL ENERGY USE BASELINE (MBTU)	ANNUAL ENERGY USE THIS RUN (MBTU)	ANNUAL ENERGY SAVINGS (MBTU)	ANNUAL ENERGY SAVINGS (PERCENT)
AT SITE	0.00	6953.31	-6953.31	0.0
AT SOURCE	0.00	20859.96	-20859.96	0.0

INVESTMENT STATISTICS

PROJECT LIFE, 25.0 YEARS

INVESTMENT THIS RUN (\$)	BASELINE REPLACEMENT COSTS (\$)	INCREMENTAL INVESTMENT (\$)	COST SAVINGS (\$)	RATIO OF SAVINGS TO INCREMENTAL INVESTMENT (SIR)	DISCOUNTED PAYBACK PERIOD (YEARS)	RATIO OF LIFE CYCLE ENERGY SAVINGS (AT SITE) TO INCREMENTAL INVESTMENT (MBTU/\$)	RATIO OF LIFE-CYCLE ENERGY SAVINGS (AT SOURCE) TO INCREMENTAL INVESTMENT (MBTU/\$)
0.	0.	0.	-2156866.	0.00	999.00	0.00	0.00

OVERALL LIFE-CYCLE COSTS (\$)

	FIRST COST	OPRNS COST	REPLACEMENTS	ENERGY COST	T O T A L
BASELINE	0.	0.	0.	0.	0.
THIS RUN	0.	0.	0.	2156866.	2156866.
SAVINGS (\$)	0.	0.	0.	-2156866.	-2156866.
(PERCENT)	0.0	0.0	0.0	0.0	0.0

REPORT- ES-D Energy Cost Summary

WEATHER FILE- Los Angeles CA TMY2

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
Custom Elec Rate	ELECTRICITY	EM1	2037321. KWH	142612.	0.0700	YES
				=====		
				142612.		
ENERGY COST/GROSS BLDG AREA:				1.26		
ENERGY COST/NET BLDG AREA:				1.26		

REPORT- ES-E Summary of Utility-Rate: Custom Elec Rate

WEATHER FILE- Los Angeles CA TMY2

RESOURCE: ELECTRICITY DEMAND-INTERVAL 15 3413. BTU/KWH
 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 METERS: EM1
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.75 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS		BLOCK-CHARGES		DEMAND-RATCHETS				MIN-MON-RATCHETS					
MIN-ENERGY:	0.0												
MAX-ENERGY:	0.0												
MIN-DEMAND:	0.0												
MAX-DEMAND:	0.0												
QUALIFY-RATE:	ALL YEAR												
USE-MIN-QUAL:	NO												
MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	143463	143463	658.2	658.2	10042	0	0	0	0	0	0	0.0700	10042
FEB	135110	135110	671.8	671.8	9458	0	0	0	0	0	0	0.0700	9458
MAR	156500	156500	667.6	667.6	10955	0	0	0	0	0	0	0.0700	10955
APR	161089	161089	675.1	675.1	11276	0	0	0	0	0	0	0.0700	11276
MAY	166161	166161	732.0	732.0	11631	0	0	0	0	0	0	0.0700	11631
JUN	184717	184717	718.8	718.8	12930	0	0	0	0	0	0	0.0700	12930
JUL	203335	203335	763.2	763.2	14233	0	0	0	0	0	0	0.0700	14233
AUG	203937	203937	796.1	796.1	14276	0	0	0	0	0	0	0.0700	14276
SEP	192456	192456	762.6	762.6	13472	0	0	0	0	0	0	0.0700	13472
OCT	183495	183495	741.1	741.1	12845	0	0	0	0	0	0	0.0700	12845
NOV	147842	147842	682.0	682.0	10349	0	0	0	0	0	0	0.0700	10349
DEC	159216	159216	653.8	653.8	11145	0	0	0	0	0	0	0.0700	11145
	=====	=====	=====		=====	=====	=====	=====	=====	=====		=====	=====
TOTAL	2037321	2037321	796.1		142612	0	0	0	0	0		0.0700	142612