

REPORT- SS-D Building HVAC Load Summary

WEATHER FILE- Los Angeles CA TMY2

	C O O L I N G						H E A T I N G						E L E C	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	49.55088	26 14	82.F	55.F	1787.487	-0.047	3 8	53.F	42.F	-9.447	94346.	348.911		
FEB	56.09909	12 14	85.F	60.F	1933.199	-0.042	21 12	61.F	51.F	-8.237	88837.	348.118		
MAR	75.47161	31 16	75.F	53.F	1900.508	-0.010	28 8	53.F	52.F	-3.868	102063.	347.241		
APR	105.91557	13 14	77.F	61.F	2101.329	-0.006	25 8	56.F	53.F	-2.896	102421.	353.516		
MAY	233.59656	29 16	74.F	65.F	2969.483	0.000	31 1	61.F	57.F	0.000	94830.	345.754		
JUN	316.91837	30 15	75.F	64.F	2776.791	0.000	30 1	64.F	61.F	0.000	102173.	348.395		
JUL	549.98285	20 16	74.F	67.F	3504.209	0.000	31 1	65.F	60.F	0.000	102613.	349.755		
AUG	612.42670	17 15	75.F	68.F	4119.633	0.000	31 1	62.F	59.F	0.000	99422.	349.232		
SEP	481.32880	8 9	72.F	66.F	3500.041	0.000	30 1	64.F	60.F	0.000	98103.	349.885		
OCT	328.37399	22 15	73.F	68.F	3066.977	0.000	31 1	59.F	55.F	0.000	99010.	350.194		
NOV	131.68567	10 13	73.F	62.F	2012.969	-0.005	28 8	53.F	44.F	-5.089	89454.	348.945		
DEC	92.99192	18 14	76.F	56.F	1756.078	-0.060	12 8	46.F	36.F	-28.268	101730.	345.885		
TOTAL	3034.342					-0.170					1175006.			
MAX					4119.633					-28.268		353.516		
MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY)						0.000 (KBTU)								
MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE)						37170.744 (KBTU)								