


Electric Demand (kW)



Electric Demand (kW)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	232.8	239.9	237.0	247.4	283.4	274.5	308.6	333.8	304.7	286.8	241.8	223.8	3,214.5
Heat Reject.	12.3	16.2	12.4	18.9	28.9	26.3	34.5	39.1	31.8	30.1	18.6	10.6	279.7
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	24.4	26.7	29.2	28.1	30.3	29.1	31.0	33.5	37.1	35.4	32.8	30.3	367.8
Pumps & Aux.	76.5	76.5	76.5	76.5	76.5	76.5	76.5	76.5	76.5	76.5	76.5	76.5	918.1
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	212.4	212.9	212.9	204.2	212.9	212.4	212.9	213.3	212.9	212.9	212.9	212.4	2,545.1
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	99.7	99.4	99.4	99.7	99.4	99.7	99.4	99.7	99.4	99.4	99.4	99.7	1,194.0
Total	658.1	671.6	667.3	674.7	731.5	718.5	763.0	795.9	762.3	741.0	681.9	653.3	8,519.1

Gas Demand (Btu/h)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool													
Heat Reject.													
Refrigeration													
Space Heat													
HP Supp.													
Hot Water													
Vent. Fans													
Pumps & Aux.													
Ext. Usage													
Misc. Equip.													
Task Lights													
Area Lights													
Total													