

Subtype Air to Water Inverter Heat Pump R290 Series 8 kW

| | |
|---------------------|---|
| Certificate Holder | Guangdong Warmhouse Technology Co., Ltd. |
| Address | No. 1, Dejin Road, Xingtan Town, Shunde District |
| ZIP | 528306 |
| City | Xingtan |
| Country | CN |
| Certification Body | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH |
| Subtype title | Air to Water Inverter Heat Pump R290 Series 8 kW |
| Registration number | 011-1W0908 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R290 |
| Mass of Refrigerant | 0.75 kg |
| Certification Date | 09.10.2024 |
| Testing basis | HP KEYMARK certification scheme rules V14 |

Model HL8HG

| | |
|-------------------------------------|-----------------------|
| Model name | HL8HG |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 8.06 kW | 7.65 kW |
| El input | 1.65 kW | 2.38 kW |
| COP | 4.88 | 3.21 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 56 dB(A) | 56 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 199 % | 152 % |
| Prated | 8.00 kW | 7.00 kW |
| SCOP | 5.05 | 3.87 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 6.80 kW | 6.60 kW |
| COP Tj = -7°C | 3.26 | 2.36 |
| Cdh Tj = -7 °C | 0.980 | 0.980 |
| Pdh Tj = +2°C | 4.20 kW | 4.10 kW |
| COP Tj = +2°C | 4.93 | 3.78 |
| Cdh Tj = +2 °C | 0.980 | 0.980 |
| Pdh Tj = +7°C | 3.00 kW | 2.90 kW |

| | | |
|---|-------------|-------------|
| COP Tj = +7°C | 6.49 | 5.09 |
| Cdh Tj = +7 °C | 0.980 | 0.980 |
| Pdh Tj = 12°C | 3.50 kW | 3.40 kW |
| COP Tj = 12°C | 8.47 | 6.92 |
| Cdh Tj = +12 °C | 0.980 | 0.980 |
| Pdh Tj = Tbiv | 6.80 kW | 6.60 kW |
| COP Tj = Tbiv | 3.26 | 2.36 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 7.50 kW | 7.20 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.77 | 2.04 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.980 | 0.980 |
| WTOL | 75 °C | 75 °C |
| Poff | 10 W | 10 W |
| PTO | 12 W | 12 W |
| PSB | 10 W | 10 W |
| PCK | 49 W | 49 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.50 kW | 0.00 kW |
| Annual energy consumption Qhe | 3140 kWh | 3974 kWh |