

## Subtype Alféa Extensa A.I. 6 R32 / Alféa Extensa S 6

Certificate Holder	Groupe Atlantic
Address	Rue des Fondeurs BP 64
ZIP	59660
City	Merville
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Extensa A.I. 6 R32 / Alféa Extensa S 6
Registration number	012-SC0367-19
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.97 kg
Certification Date	03.12.2021
Testing basis	EN 14511:2018, EN 14825:2016, EN 16147:2017, EN 12102:2017
Testing laboratory	CETIAT, FR

## Model Alf a Extensa A.I. 6 R32

Model name	Alf�a Extensa A.I. 6 R32
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.18 kW	2.06 kW
COP	4.65	2.67

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	125 %
Prated	5.60 kW	5.30 kW
SCOP	4.46	3.21
Tbiv	-7 �C	-7 �C
TOL	-10 �C	-10 �C
Pdh Tj = -7�C	5.00 kW	4.70 kW
COP Tj = -7�C	2.74	1.97
Cdh Tj = -7 �C	0.960	0.970
Pdh Tj = +2�C	3.00 kW	2.90 kW
COP Tj = +2�C	4.38	3.11
Cdh Tj = +2 �C	0.960	0.970
Pdh Tj = +7�C	2.10 kW	1.80 kW

COP Tj = +7�C	6.04	4.29
Cdh Tj = +7 �C	0.960	0.970
Pdh Tj = 12�C	2.40 kW	2.30 kW
COP Tj = 12�C	7.43	6.06
Cdh Tj = +12 �C	0.960	0.970
Pdh Tj = Tbiv	5.00 kW	4.70 kW
COP Tj = Tbiv	2.74	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.50 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 �C	55 �C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	2594 kWh	3411 kWh

## Model Alf a Extensa A.I. Duo 6 R32

Model name	Alf�a Extensa A.I. Duo 6 R32
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	No

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	130 %
COP	3.10
Heating up time	1:35 h:min
Standby power input	30.0 W
Reference hot water temperature	54.0 �C
Mixed water at 40�C	245 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.18 kW	2.06 kW
COP	4.65	2.67

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	125 %
Prated	5.60 kW	5.30 kW

SCOP	4.46	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	4.70 kW
COP Tj = -7°C	2.74	1.97
Cdh Tj = -7 °C	0.960	0.970
Pdh Tj = +2°C	3.00 kW	2.90 kW
COP Tj = +2°C	4.38	3.11
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.10 kW	1.80 kW
COP Tj = +7°C	6.04	4.29
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	7.43	6.06
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	5.00 kW	4.70 kW
COP Tj = Tbiv	2.74	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.50 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	2594 kWh	3411 kWh

## Model Alf a Extensa S 6

Model name	Alf�a Extensa S 6
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.18 kW	2.06 kW
COP	4.65	2.67

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	125 %
Prated	5.60 kW	5.30 kW
SCOP	4.46	3.21
Tbiv	-7 �C	-7 �C
TOL	-10 �C	-10 �C
Pdh Tj = -7�C	5.00 kW	4.70 kW
COP Tj = -7�C	2.74	1.97
Cdh Tj = -7 �C	0.960	0.970
Pdh Tj = +2�C	3.00 kW	2.90 kW
COP Tj = +2�C	4.38	3.11
Cdh Tj = +2 �C	0.960	0.970
Pdh Tj = +7�C	2.10 kW	1.80 kW

COP Tj = +7�C	6.04	4.29
Cdh Tj = +7 �C	0.960	0.970
Pdh Tj = 12�C	2.40 kW	2.30 kW
COP Tj = 12�C	7.43	6.06
Cdh Tj = +12 �C	0.960	0.970
Pdh Tj = Tbiv	5.00 kW	4.70 kW
COP Tj = Tbiv	2.74	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.50 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 �C	55 �C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	2594 kWh	3411 kWh

## Model Alféa Extensa S Duo 6

Model name	Alféa Extensa S Duo 6
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	130 %
COP	3.10
Heating up time	1:35 h:min
Standby power input	30.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	245 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.50 kW	5.50 kW
El input	1.18 kW	2.06 kW
COP	4.65	2.67

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	125 %
Prated	5.60 kW	5.30 kW



SCOP	4.46	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	4.70 kW
COP Tj = -7°C	2.74	1.97
Cdh Tj = -7 °C	0.960	0.970
Pdh Tj = +2°C	3.00 kW	2.90 kW
COP Tj = +2°C	4.38	3.11
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.10 kW	1.80 kW
COP Tj = +7°C	6.04	4.29
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	7.43	6.06
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	5.00 kW	4.70 kW
COP Tj = Tbiv	2.74	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.50 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	2594 kWh	3411 kWh