

Subtype Bosch Compress 7000iAW 5 OR, Compress 6000 AW-5, Bosch CS7001iAW 5

Certificate Holder	Bosch Thermotechnik GmbH
Address	Junkersstraße 20 - 24
ZIP	73249
City	Wernau
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Bosch Compress 7000iAW 5 OR, Compress 6000 AW-5, Bosch CS7001iAW 5
Registration number	011-1W0122
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	1.7 kg
Certification Date	18.07.2017
Testing basis	HP KEYMARK certification scheme rules rev. 8

Model Bosch CS7000iAW 5 ORMS-S

Model name	Bosch CS7000iAW 5 ORMS-S
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.25
Heating up time	03:30 h:min
Standby power input	55.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	272 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	81 %
COP	1.90
Heating up time	04:18 h:min
Standby power input	65.0 W
Reference hot water temperature	52.4 °C
Mixed water at 40°C	275 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	119 %
COP	2.80
Heating up time	03:00 h:min
Standby power input	47.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	272 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	1955 kWh	2533 kWh
---	----------	----------

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
T _{biv}	-17 °C	-16 °C
TOL	-20 °C	-18 °C
P _{dh} T _j = -7°C	2.46 kW	2.32 kW
COP T _j = -7°C	3.56	2.57
P _{dh} T _j = +2°C	1.48 kW	1.79 kW
COP T _j = +2°C	4.86	3.66
P _{dh} T _j = +7°C	1.13 kW	2.13 kW
COP T _j = +7°C	5.53	4.54
P _{dh} T _j = 12°C	1.21 kW	2.55 kW
COP T _j = 12°C	5.75	5.82
P _{dh} T _j = T _{biv}	3.43 kW	3.37 kW
COP T _j = T _{biv}	2.36	1.78
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.08 kW	3.11 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.16	1.61
WTOL	60 °C	60 °C
P _{off}	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Q _{he}	2378 kWh	3287 kWh
P _{dh} T _j = -15°C (if TOL	3.27	1.88
COP T _j = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch CS7000iAW 5 ORM-S

Model name	Bosch CS7000iAW 5 ORM-S
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.25
Heating up time	03:30 h:min
Standby power input	55.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	272 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	81 %
COP	1.90
Heating up time	04:18 h:min
Standby power input	65.0 W
Reference hot water temperature	52.4 °C
Mixed water at 40°C	275 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	119 %
COP	2.80
Heating up time	03:00 h:min
Standby power input	47.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	272 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	1955 kWh	2533 kWh
---	----------	----------

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
T _{biv}	-17 °C	-16 °C
TOL	-20 °C	-18 °C
P _{dh} T _j = -7°C	2.46 kW	2.32 kW
COP T _j = -7°C	3.56	2.57
P _{dh} T _j = +2°C	1.48 kW	1.79 kW
COP T _j = +2°C	4.86	3.66
P _{dh} T _j = +7°C	1.13 kW	2.13 kW
COP T _j = +7°C	5.53	4.54
P _{dh} T _j = 12°C	1.21 kW	2.55 kW
COP T _j = 12°C	5.75	5.82
P _{dh} T _j = T _{biv}	3.43 kW	3.37 kW
COP T _j = T _{biv}	2.36	1.78
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.08 kW	3.11 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.16	1.61
WTOL	60 °C	60 °C
P _{off}	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Q _{he}	2378 kWh	3287 kWh
P _{dh} T _j = -15°C (if TOL	3.27	1.88
COP T _j = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch CS7000iAW 5 ORB-S

Model name	Bosch CS7000iAW 5 ORB-S
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29

Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1245 kWh	1823 kWh

Model Bosch CS7000iAW 5 ORE-S

Model name	Bosch CS7000iAW 5 ORE-S
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW

COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61

WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Q _{he}	2378 kWh	3287 kWh
P _{dh} T _j = -15°C (if TOL	3.27	1.88
COP T _j = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	5.28 kW	5.65 kW
COP T _j = +2°C	3.08	2.22
P _{dh} T _j = +7°C	3.22 kW	3.92 kW
COP T _j = +7°C	5.31	3.54
P _{dh} T _j = 12°C	1.50 kW	2.49 kW
COP T _j = 12°C	6.79	5.35
P _{dh} T _j = T _{biv}	5.28 kW	5.65 kW
COP T _j = T _{biv}	3.08	2.22
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	5.28 kW	5.65 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1245 kWh	1823 kWh

Model Bosch Compress 6000 AW-5 AWE

Model name	Bosch Compress 6000 AW-5 AWE
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW

COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61

WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch Compress 6000 AW-5 AWB

Model name	Bosch Compress 6000 AW-5 AWB
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW

COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61

WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch Compress 6000 AW-5 AWM

Model name	Bosch Compress 6000 AW-5 AWM
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.25
Heating up time	03:30 h:min
Standby power input	55.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	272 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	81 %
COP	1.90
Heating up time	04:18 h:min
Standby power input	65.0 W
Reference hot water temperature	52.4 °C
Mixed water at 40°C	275 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	119 %
COP	2.80
Heating up time	03:00 h:min
Standby power input	47.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	272 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	1955 kWh	2533 kWh
---	----------	----------

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
T _{biv}	-17 °C	-16 °C
TOL	-20 °C	-18 °C
P _{dh} T _j = -7°C	2.46 kW	2.32 kW
COP T _j = -7°C	3.56	2.57
P _{dh} T _j = +2°C	1.48 kW	1.79 kW
COP T _j = +2°C	4.86	3.66
P _{dh} T _j = +7°C	1.13 kW	2.13 kW
COP T _j = +7°C	5.53	4.54
P _{dh} T _j = 12°C	1.21 kW	2.55 kW
COP T _j = 12°C	5.75	5.82
P _{dh} T _j = T _{biv}	3.43 kW	3.37 kW
COP T _j = T _{biv}	2.36	1.78
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.08 kW	3.11 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.16	1.61
WTOL	60 °C	60 °C
P _{off}	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Q _{he}	2378 kWh	3287 kWh
P _{dh} T _j = -15°C (if TOL	3.27	1.88
COP T _j = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch Compress 6000 AW-5 AWMS

Model name	Bosch Compress 6000 AW-5 AWMS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.25
Heating up time	03:30 h:min
Standby power input	55.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	272 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	81 %
COP	1.90
Heating up time	04:18 h:min
Standby power input	65.0 W
Reference hot water temperature	52.4 °C
Mixed water at 40°C	275 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	119 %
COP	2.80
Heating up time	03:00 h:min
Standby power input	47.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	272 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	1955 kWh	2533 kWh
EN 12102-1 Colder Climate		
	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)
EN 14825 Colder Climate		
	Low temperature	Medium temperature
η _s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
T _{biv}	-17 °C	-16 °C
TOL	-20 °C	-18 °C
P _{dh} T _j = -7°C	2.46 kW	2.32 kW
COP T _j = -7°C	3.56	2.57
P _{dh} T _j = +2°C	1.48 kW	1.79 kW
COP T _j = +2°C	4.86	3.66
P _{dh} T _j = +7°C	1.13 kW	2.13 kW
COP T _j = +7°C	5.53	4.54
P _{dh} T _j = 12°C	1.21 kW	2.55 kW
COP T _j = 12°C	5.75	5.82
P _{dh} T _j = T _{biv}	3.43 kW	3.37 kW
COP T _j = T _{biv}	2.36	1.78
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.08 kW	3.11 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.16	1.61
WTOL	60 °C	60 °C
P _{off}	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Q _{he}	2378 kWh	3287 kWh
P _{dh} T _j = -15°C (if TOL	3.27	1.88
COP T _j = -15°C (if TOL	2.55	1.88
EN 12102-1 Warmer Climate		
	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)
EN 14825 Warmer Climate		

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch CS7001iAW 5 ORE-S

Model name	Bosch CS7001iAW 5 ORE-S
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29

Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61
WTOL	60 °C	60 °C

Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch CS7001iAW 5 ORB-S

Model name	Bosch CS7001iAW 5 ORB-S
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Cdh Tj = +2 °C	1.00	1.00

Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1245 kWh	1823 kWh

Model Bosch CS7001iAW 5 ORM-S

Model name	Bosch CS7001iAW 5 ORM-S
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.25
Heating up time	03:30 h:min
Standby power input	55.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	272 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	81 %
COP	1.90
Heating up time	04:18 h:min
Standby power input	65.0 W
Reference hot water temperature	52.4 °C
Mixed water at 40°C	275 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	119 %
COP	2.80
Heating up time	03:00 h:min
Standby power input	47.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	272 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW

SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch CS7001iAW 5 ORMS-S

Model name	Bosch CS7001iAW 5 ORMS-S
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.25
Heating up time	03:30 h:min
Standby power input	55.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	272 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	81 %
COP	1.90
Heating up time	04:18 h:min
Standby power input	65.0 W
Reference hot water temperature	52.4 °C
Mixed water at 40°C	275 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	119 %
COP	2.80
Heating up time	03:00 h:min
Standby power input	47.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	272 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW
COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Qhe	2378 kWh	3287 kWh
Pdh Tj = -15°C (if TOL	3.27	1.88
COP Tj = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	161 %
Prated	5.30 kW	5.60 kW

SCOP	5.69	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.28 kW	5.65 kW
COP Tj = +2°C	3.08	2.22
Pdh Tj = +7°C	3.22 kW	3.92 kW
COP Tj = +7°C	5.31	3.54
Pdh Tj = 12°C	1.50 kW	2.49 kW
COP Tj = 12°C	6.79	5.35
Pdh Tj = Tbiv	5.28 kW	5.65 kW
COP Tj = Tbiv	3.08	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.28 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.08	2.22
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1245 kWh	1823 kWh

Model Bosch CSH7000iAW 5 OR

Model name	Bosch CSH7000iAW 5 OR
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.46 kW	0.72 kW
COP	4.68	2.60

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	131 %
Prated	4.40 kW	4.10 kW
SCOP	4.65	3.34
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	3.07	2.16
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.69	3.29
Pdh Tj = +7°C	1.50 kW	2.13 kW

COP Tj = +7°C	5.78	4.29
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	6.13	5.53
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.76	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.85
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1955 kWh	2533 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	117 %
Prated	3.90 kW	4.00 kW
SCOP	4.04	3.00
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.56	2.57
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.86	3.66
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.53	4.54
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.75	5.82
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.36	1.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.61
WTOL	60 °C	60 °C
Poff	17 W	17 W

PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2378 kWh	3287 kWh
P _{dh} T _j = -15°C (if TOL	3.27	1.88
COP T _j = -15°C (if TOL	2.55	1.88

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	161 %
Prated	5.30 kW	5.60 kW
SCOP	5.69	4.10
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	5.28 kW	5.65 kW
COP T _j = +2°C	3.08	2.22
P _{dh} T _j = +7°C	3.22 kW	3.92 kW
COP T _j = +7°C	5.31	3.54
P _{dh} T _j = 12°C	1.50 kW	2.49 kW
COP T _j = 12°C	6.79	5.35
P _{dh} T _j = T _{biv}	5.28 kW	5.65 kW
COP T _j = T _{biv}	3.08	2.22
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	5.28 kW	5.65 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.08	2.22
WTOL	60 °C	60 °C
P _{off}	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1245 kWh	1823 kWh

Model Bosch CS7001iAW 5 ORMB-S

Model name	Bosch CS7001iAW 5 ORMB-S
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.14 kW	1.88 kW
El input	0.48 kW	0.75 kW
COP	4.44	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.10 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.88 kW	3.57 kW
COP Tj = -7°C	2.99	2.13
Pdh Tj = +2°C	2.51 kW	2.34 kW
COP Tj = +2°C	4.50	3.20
Pdh Tj = +7°C	1.50 kW	2.13 kW

COP Tj = +7°C	5.32	4.08
Pdh Tj = 12°C	1.23 kW	2.52 kW
COP Tj = 12°C	5.57	5.22
Pdh Tj = Tbiv	4.37 kW	4.05 kW
COP Tj = Tbiv	2.70	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.37 kW	4.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.83
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2072 kWh	2647 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	150 %	112 %
Prated	3.90 kW	4.00 kW
SCOP	3.83	2.87
Tbiv	-17 °C	-16 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.46 kW	2.32 kW
COP Tj = -7°C	3.43	2.52
Pdh Tj = +2°C	1.48 kW	1.79 kW
COP Tj = +2°C	4.59	3.51
Pdh Tj = +7°C	1.13 kW	2.13 kW
COP Tj = +7°C	5.13	4.33
Pdh Tj = 12°C	1.21 kW	2.55 kW
COP Tj = 12°C	5.24	5.51
Pdh Tj = Tbiv	3.43 kW	3.37 kW
COP Tj = Tbiv	2.31	1.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	3.11 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.12	1.59
WTOL	60 °C	60 °C
Poff	22 W	22 W

PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.90 kW	4.00 kW
Annual energy consumption Q _{he}	2511 kWh	3430 kWh
P _{dh} T _j = -15°C (if TOL	3.27	3.29
COP T _j = -15°C (if TOL	2.49	1.85

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	208 %	153 %
Prated	5.30 kW	5.60 kW
SCOP	5.28	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	5.28 kW	5.65 kW
COP T _j = +2°C	2.98	2.19
P _{dh} T _j = +7°C	3.22 kW	3.92 kW
COP T _j = +7°C	5.01	3.45
P _{dh} T _j = 12°C	1.50 kW	2.49 kW
COP T _j = 12°C	6.19	5.05
P _{dh} T _j = T _{biv}	5.28 kW	5.65 kW
COP T _j = T _{biv}	2.98	2.19
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	5.28 kW	5.65 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.98	2.19
WTOL	60 °C	60 °C
P _{off}	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1341 kWh	1918 kWh