

## Subtype VIESSMANN Vitocal 060-A R290-180l

Certificate Holder	Viessmann Climate Solutions GmbH & Co. KG
Address	Viessmannstr. 1
ZIP	35107
City	Allendorf/Eder
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	VIESSMANN Vitocal 060-A R290-180l
Registration number	011-1W1004
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R290
Mass of Refrigerant	0.13 kg
Certification Date	10.03.2025
Testing basis	HP KEYMARK certification scheme rules V14

**Model VIESSMANN Vitocal 060-A T0E-R290-180I**

Model name	VIESSMANN Vitocal 060-A T0E-R290-180I
Application	n/a
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	Yes

**Heat Pump for Domestic Hot Water (DHW)****EN 16147 | Operating test**

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

**EN 12102-2 | Average Climate**

Sound power level indoor	52 dB(A)
--------------------------	----------

**EN 16147 | Average Climate**

Declared load profile	L
Efficiency $\eta_{DHW}$	123 %
COP	2.98
Heating up time	6:49 h:min
Standby power input	22.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	235 l