

## Subtype COMBO RSJA2-16/190S

Certificate Holder	Frigicoll
Address	Blasco de Garay, 4 6
ZIP	08960
City	Sant Just Desvern
Country	ES
Certification Body	ICIM S.p.A.
Subtype title	COMBO RSJA2-16/190S
Registration number	ICIM-PDC-000153
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R134a
Mass of Refrigerant	1.1 kg
Certification Date	12.04.2022
Testing basis	HP KEYMARK certification scheme rules rev. no. 4

**Model RSJA2-16/190S**

Model name	RSJA2-16/190S
Application	Heating + DHW
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	No

**Heat Pump for Domestic Hot Water (DHW)****EN 16147 | Operating test**

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

**EN 12102-2 | Average Climate**

Sound power level indoor	51 dB(A)
--------------------------	----------

**EN 16147 | Average Climate**

Declared load profile	L
Efficiency $\eta_{DHW}$	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l