

Subtype F1345-40

Certificate Holder	Nibe AB
Address	Box 14
ZIP	S-28521
City	Markaryd
Country	SE
Certification Body	RISE CERT
Subtype title	F1345-40
Registration number	012-052
Heat Pump Type	Brine/Water
Refrigerant	R407c
Mass of Refrigerant	3.4 kg
Certification Date	15.06.2017
Testing laboratory	Austrian Institute of Technology (AIT)

Model F1345-40

Model name	F1345-40
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	39.94 kW	37.80 kW
El input	8.90 kW	11.90 kW
COP	4.49	3.18

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	143 %
Prated	46.00 kW	46.00 kW
SCOP	4.75	3.78
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7 °C	40.10 kW	38.20 kW
COP Tj = -7 °C	4.62	3.33
Cdh Tj = -7 °C		
Pdh Tj = +2 °C	40.30 kW	39.10 kW
COP Tj = +2 °C	4.78	3.79
Cdh Tj = +2 °C		
Pdh Tj = +7 °C	20.30 kW	19.90 kW
COP Tj = +7 °C	5.11	4.21
Cdh Tj = +7 °C		
Pdh Tj = 12°C	20.40 kW	20.10 kW

COP Tj = 12°C	5.09	4.51
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	40.10 kW	38.40 kW
COP Tj = Tbiv	4.63	3.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	40.00 kW	37.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	3.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.980	0.990
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	100 W	100 W
PSB	7 W	7 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	8.20 kW
Annual energy consumption Qhe	19996 kWh	25093 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	190 %	149 %
Prated	46.00 kW	46.00 kW
SCOP	4.95	3.93
Tbiv	-17 °C	-16 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	40.40 kW	39.00 kW
COP Tj = -7°C	4.86	3.70
Pdh Tj = +2°C	20.30 kW	19.80 kW
COP Tj = +2°C	5.16	4.19
Pdh Tj = +7°C	20.40 kW	20.00 kW
COP Tj = +7°C	5.22	4.50
Pdh Tj = 12°C	20.40 kW	20.20 kW
COP Tj = 12°C	4.95	4.65
Pdh Tj = Tbiv	40.20 kW	38.40 kW
COP Tj = Tbiv	4.67	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	40.00 kW	37.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	3.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99

WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	100 W	100 W
PSB	7 W	7 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	8.20 kW
Annual energy consumption Qhe	22939 kWh	28857 kWh