

## Subtype Air to Water Heat Pump- R290- 6kW

Certificate Holder	Aira Group AB
Address	Norra Stationsgatan 93C
ZIP	11364
City	Stockholm
Country	SE
Certification Body	BRE Global Limited
Subtype title	Air to Water Heat Pump- R290- 6kW
Registration number	041-K087-06
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.7 kg
Certification Date	11.03.2024
Testing basis	Heat Pump Keymark Scheme Rules Rev 13
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

## Model HPO-AW-6-230V-1.0

Model name	HPO-AW-6-230V-1.0
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.70 kW	5.56 kW
El input	1.16 kW	1.69 kW
COP	4.93	3.29

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	61 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	185 %	144 %
Prated	6.76 kW	6.70 kW
SCOP	4.71	3.66
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.98 kW	5.92 kW
COP Tj = -7°C	3.13	2.50
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.81 kW	3.79 kW
COP Tj = +2°C	4.64	3.69
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.13 kW	2.82 kW

COP Tj = +7°C	6.30	4.52
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.82 kW	3.66 kW
COP Tj = 12°C	8.48	6.40
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.98 kW	5.92 kW
COP Tj = Tbiv	3.13	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.32 kW	5.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	12 W	12 W
PTO	41 W	41 W
PSB	12 W	12 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.44 kW	1.35 kW
Annual energy consumption Qhe	2970 kWh	3774 kWh