

Subtype Buderus Logatherm WPS 6K-1

Certificate Holder	Bosch Thermotechnik GmbH (Buderus)
Address	Sophienstraße 30-32
ZIP	35576
City	Wetzlar
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Buderus Logatherm WPS 6K-1
Registration number	011-1W0177
Heat Pump Type	Brine/Water
Refrigerant	R410A
Mass of Refrigerant	1.55 kg
Certification Date	17.11.2017
Testing basis	HP KEYMARK certification scheme rules rev. 14
Testing laboratory	Universität Stuttgart, Prüfstelle HLK am Institut für Gebäudeenergetik, Thermotechnik und Energiespeicherung (IGTE), DE

Model Buderus Logatherm WPS 6K-1

Model name	Buderus Logatherm WPS 6K-1
Application	Heating + DHW + low temp
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water**EN 16147 | Average Climate**

Declared load profile	L
Efficiency η_{DHW}	92 %
COP	2.21
Heating up time	1:45 h:min
Standby power input	37.5 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	209 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	92 %
COP	2.21
Heating up time	114.7 h:min
Standby power input	37.5 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	209 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	92 %
COP	2.21
Heating up time	114.7 h:min
Standby power input	37.5 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	209 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Starting and operating test	passed	
EN 14511-2 Heating		
Heat output	Low temperature	Medium temperature
5.52 kW	4.94 kW	
El input	1.34 kW	1.88 kW
COP	4.12	2.63
EN 12102-1 Average Climate		
Sound power level indoor	Low temperature	Medium temperature
48 dB(A)	48 dB(A)	
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	167 %	123 %
Prated	7 kW	6 kW
SCOP	4.38	3.27
Tbiv	-4 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.54 kW	5.02 kW
COP Tj = -7°C	4.22	2.79
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	5.60 kW	5.19 kW
COP Tj = +2°C	4.46	3.27
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.64 kW	5.29 kW
COP Tj = +7°C	4.67	3.62
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.69 kW	5.39 kW
COP Tj = 12°C	4.91	4.02
Cdh Tj = +12 °C	0.99	1.00
Pdh Tj = Tbiv	5.57 kW	5.06 kW
COP Tj = Tbiv	4.33	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.12	2.63
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Supplementary Heater: PSUP	1.48 kW	1.06 kW
Annual energy consumption Qhe	3305 kWh	3790 kWh
EN 12102-1 Colder Climate		
Sound power level indoor	Low temperature 48 dB(A)	Medium temperature 48 dB(A)
EN 14825 Colder Climate		
ηs	Low temperature 172 %	Medium temperature 126 %
Prated	7.00 kW	6.00 kW
SCOP	4.49	3.35
Tbiv	-14 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.61 kW	5.15 kW
COP Tj = -7°C	4.51	3.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	5.65 kW	5.27 kW
COP Tj = +2°C	4.69	3.55
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.68 kW	5.36 kW
COP Tj = +7°C	4.84	3.90
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.68 kW	5.43 kW
COP Tj = 12°C	4.87	4.18
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.58 kW	5.06 kW
COP Tj = Tbiv	4.38	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.12	2.63
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.48 kW	1.06 kW
Annual energy consumption Qhe	3841 kWh	4411 kWh
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
EN 14825 Warmer Climate		
	Low temperature	Medium temperature
ηs	167 %	123 %
Prated	7.00 kW	6.00 kW
SCOP	4.39	3.27
Tbiv	5 °C	5 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.52 kW	4.94 kW
COP Tj = +2°C	4.12	2.63
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.59 kW	5.11 kW
COP Tj = +7°C	4.42	3.05
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.66 kW	5.32 kW
COP Tj = 12°C	4.75	3.75
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.57 kW	5.06 kW
COP Tj = Tbiv	4.35	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.12	2.63
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.48 kW	1.06 kW
Annual energy consumption Qhe	2132 kWh	2450 kWh