

Subtype HYBEA 6

Certificate Holder	Groupe Atlantic
Address	Rue des Fondeurs BP 64
ZIP	59660
City	Merville
Country	FR
Certification Body	RISE CERT
Subtype title	HYBEA 6
Registration number	012-C700245
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.88 kg
Certification Date	24.05.2024
Testing basis	EN 14511:2022, EN 14825:2022, EN 12102:2022
Testing laboratory	ACTA INDUSTRIE - Laboratoire Acoustique et Climatique

Model HYBEA 6 - 30

Model name	HYBEA 6 - 30
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	0.97 kW	1.64 kW
COP	5.15	3.04

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	187 %	138 %
Prated	5.80 kW	5.50 kW
SCOP	4.74	3.51
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.10 kW	4.90 kW
COP Tj = -7°C	3.20	2.26
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	4.98	3.59
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.00 kW	1.90 kW
COP Tj = +7°C	6.76	4.76

Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.78	6.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.10 kW	4.90 kW
COP Tj = Tbiv	3.20	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.10 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.20	2.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	5 W	5 W
PTO	13 W	13 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	5.80 kW	5.50 kW
Annual energy consumption Qhe	2530 kWh	3234 kWh

Model HYBEA 6 - 35		
Model name	HYBEA 6 - 35	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	n/a	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	0.97 kW	1.64 kW
COP	5.15	3.04
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	187 %	138 %
Prated	5.80 kW	5.50 kW
SCOP	4.74	3.51
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.10 kW	4.90 kW
COP Tj = -7°C	3.20	2.26
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	4.98	3.59
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.00 kW	1.90 kW
COP Tj = +7°C	6.76	4.76

Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.78	6.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.10 kW	4.90 kW
COP Tj = Tbiv	3.20	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.10 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.20	2.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	5 W	5 W
PTO	13 W	13 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	5.80 kW	5.50 kW
Annual energy consumption Qhe	2530 kWh	3234 kWh

Model HYBEA 6 - 20

Model name	HYBEA 6 - 20
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	0.97 kW	1.64 kW
COP	5.15	3.04

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	187 %	138 %
Prated	5.80 kW	5.50 kW
SCOP	4.74	3.51
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.10 kW	4.90 kW
COP Tj = -7°C	3.20	2.26
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	4.98	3.59
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.00 kW	1.90 kW
COP Tj = +7°C	6.76	4.76

Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.78	6.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.10 kW	4.90 kW
COP Tj = Tbiv	3.20	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.10 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.20	2.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	5 W	5 W
PTO	13 W	13 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	5.80 kW	5.50 kW
Annual energy consumption Qhe	2530 kWh	3234 kWh

Model HYBEA 6 Micro 30

Model name	HYBEA 6 Micro 30
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	0.97 kW	1.64 kW
COP	5.15	3.04

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	187 %	138 %
Prated	5.80 kW	5.50 kW
SCOP	4.74	3.51
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.10 kW	4.90 kW
COP Tj = -7°C	3.20	2.26
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	4.98	3.59
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.00 kW	1.90 kW
COP Tj = +7°C	6.76	4.76

Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.78	6.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.10 kW	4.90 kW
COP Tj = Tbiv	3.20	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.10 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.20	2.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	5 W	5 W
PTO	13 W	13 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	5.80 kW	5.50 kW
Annual energy consumption Qhe	2530 kWh	3234 kWh

Model HYBEA 6 Duo 25

Model name	HYBEA 6 Duo 25
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.00 kW	5.00 kW
El input	0.97 kW	1.64 kW
COP	5.15	3.04

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	187 %	138 %
Prated	5.80 kW	5.50 kW
SCOP	4.74	3.51
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.10 kW	4.90 kW
COP Tj = -7°C	3.20	2.26
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	4.98	3.59
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.00 kW	1.90 kW
COP Tj = +7°C	6.76	4.76

Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.78	6.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.10 kW	4.90 kW
COP Tj = Tbiv	3.20	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.10 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.20	2.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	5 W	5 W
PTO	13 W	13 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	5.80 kW	5.50 kW
Annual energy consumption Qhe	2530 kWh	3234 kWh