

Subtype Compak KHP 15/190 ACS1

| | |
|---------------------|--|
| Certificate Holder | Frigicoll |
| Address | Blasco de Garay, 4 6 |
| ZIP | 08960 |
| City | Sant Just Desvern |
| Country | ES |
| Certification Body | BRE Global Limited |
| Subtype title | Compak KHP 15/190 ACS1 |
| Registration number | 041-K009-04 |
| Heat Pump Type | Heat Pump for Domestic Hot Water (DHW) |
| Refrigerant | R134a |
| Mass of Refrigerant | 1.1 kg |
| Certification Date | 30.04.2021 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 08 |

Model Compak KHP 15/190 ACS1

| | |
|-------------------------------------|------------------------|
| Model name | Compak KHP 15/190 ACS1 |
| Application | n/a |
| Units | Indoor |
| Climate zone (for heating) | n/a |
| Heat Source | Outdoor Air |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | No |

Heat Pump for Domestic Hot Water (DHW)**EN 16147 | Operating test**

| | |
|------------------------------|---|
| Temperature operating range | 2 |
| Safety devices checking test | 2 |
| Condensate draining | 2 |

EN 12102-2 | Average Climate

| | |
|--------------------------|----------|
| Sound power level indoor | 58 dB(A) |
|--------------------------|----------|

EN 16147 | Average Climate

| | |
|---------------------------------|------------|
| Declared load profile | L |
| Efficiency η_{DHW} | 104 % |
| COP | 2.55 |
| Heating up time | 7:05 h:min |
| Standby power input | 20.8 W |
| Reference hot water temperature | 53.3 °C |
| Mixed water at 40°C | 234 l |