

Subtype WPT200

Certificate Holder	Bosch Thermotechnik GmbH (Buderus)
Address	Sophienstraße 30-32
ZIP	35576
City	Wetzlar
Country	DE
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	WPT200
Registration number	037-0080-22
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R513A
Mass of Refrigerant	1.1 kg
Certification Date	26.08.2022
Testing basis	HP Keymark scheme rules rev. no. 9

Model Logatherm WPT200.4 AS

Model name	Logatherm WPT200.4 AS
Application	n/a
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	Outdoor Air

General data

Power supply	1x230V 50Hz
Off-peak product	No

Heat Pump for Domestic Hot Water (DHW)

EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	56 dB(A)
--------------------------	----------

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	3.00
Heating up time	7:45 h:min
Standby power input	35.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l

Model Logatherm WPT200.4 A

Model name	Logatherm WPT200.4 A
Application	n/a
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	Outdoor Air

General data

Power supply	1x230V 50Hz
Off-peak product	No

Heat Pump for Domestic Hot Water (DHW)

EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	56 dB(A)
--------------------------	----------

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	3.00
Heating up time	7:45 h:min
Standby power input	35.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	283 l