

Subtype F1345-60

Certificate Holder	Nibe AB
Address	Box 14
ZIP	S-28521
City	Markaryd
Country	SE
Certification Body	RISE CERT
Subtype title	F1345-60
Registration number	012-053
Heat Pump Type	Brine/Water
Refrigerant	R407c
Mass of Refrigerant	3.4 kg
Certification Date	15.06.2017
Testing laboratory	Austrian Institute of Technology (AIT)

Model F1345-60

Model name	F1345-60
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	59.22 kW	54.20 kW
El input	13.72 kW	17.90 kW
COP	4.32	3.02

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	138 %
Prated	67.00 kW	67.00 kW
SCOP	4.60	3.65
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7 °C	59.50 kW	54.80 kW
COP Tj = -7 °C	4.42	3.17
Cdh Tj = -7 °C		
Pdh Tj = +2 °C	60.10 kW	56.60 kW
COP Tj = +2 °C	4.59	3.62
Cdh Tj = +2 °C		
Pdh Tj = +7 °C	30.50 kW	29.20 kW
COP Tj = +7 °C	4.87	4.06
Cdh Tj = +7 °C		
Pdh Tj = 12°C	30.80 kW	29.80 kW

COP Tj = 12°C	4.91	4.31
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	59.50 kW	55.20 kW
COP Tj = Tbiv	4.42	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	59.20 kW	54.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.31	3.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	120 W	120 W
PSB	7 W	7 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.80 kW	12.90 kW
Annual energy consumption Qhe	30169 kWh	38048 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	181 %	142 %
Prated	67.00 kW	67.00 kW
SCOP	4.73	3.75
Tbiv	-18 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	60.30 kW	56.20 kW
COP Tj = -7°C	4.62	3.53
Pdh Tj = +2°C	30.60 kW	29.10 kW
COP Tj = +2°C	4.90	4.01
Pdh Tj = +7°C	30.80 kW	29.70 kW
COP Tj = +7°C	5.00	4.29
Pdh Tj = 12°C	30.80 kW	30.10 kW
COP Tj = 12°C	4.80	4.46
Pdh Tj = Tbiv	59.60 kW	55.30 kW
COP Tj = Tbiv	4.45	3.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	59.20 kW	54.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.31	3.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99

WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	100 W	100 W
PSB	7 W	7 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.80 kW	12.90 kW
Annual energy consumption Qhe	34918 kWh	43924 kWh