

Subtype Atlantic Ixtra M 15 Tri

Certificate Holder	Groupe Atlantic
Address	Rue des Fondeurs BP 64
ZIP	59660
City	Merville
Country	FR
Certification Body	RISE CERT
Subtype title	Atlantic Ixtra M 15 Tri
Registration number	012-C700149
Heat Pump Type	Outdoor Air/Water
Refrigerant	R452B
Mass of Refrigerant	2.75 kg
Certification Date	30.06.2022
Testing basis	EN 14511:2018, EN 14825:2016, EN 12102:2017
Testing laboratory	CETIAT, FR

**Model Atlantic Ixtra M 15 Tri**

Model name	Atlantic Ixtra M 15 Tri
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

**General data**

Power supply	3x400V 50Hz
Off-peak product	n/a

**Outdoor Air/Water****EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

**EN 14511-2 | Heating**

	Low temperature	Medium temperature
Heat output	8.50 kW	12.90 kW
EI input	1.77 kW	4.31 kW
COP	4.79	2.99

**EN 12102-1 | Average Climate**

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

**EN 14825 | Average Climate**

	Low temperature	Medium temperature
$\eta_s$	177 %	131 %
Prated	13.50 kW	13.30 kW
SCOP	4.51	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.90 kW	11.80 kW
COP Tj = -7°C	3.04	2.24
Cdh Tj = -7 °C	0.970	0.980
Pdh Tj = +2°C	7.30 kW	7.20 kW
COP Tj = +2°C	4.70	3.38
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	8.60 kW	8.30 kW
COP Tj = +7°C	5.55	4.24

Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	10.10 kW	9.80 kW
COP Tj = 12°C	6.53	5.06
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	11.90 kW	11.80 kW
COP Tj = Tbiv	3.09	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.10 kW	11.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.07
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	48 W	32 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	2.10 kW
Annual energy consumption Qhe	6187 kWh	8179 kWh