

## Subtype DC Inverter Air to Water Heat Pump Unit-R32-XC 09

Certificate Holder	Zhongshan Amitime Electric Co., Ltd
Address	5th Yandong Rd
ZIP	
City	Zhongshan City - Guangdong
Country	CN
Certification Body	BRE Global Limited
Subtype title	DC Inverter Air to Water Heat Pump Unit-R32-XC 09
Registration number	041-K027-02
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.15 kg
Certification Date	10.05.2024
Testing basis	Heat Pump Keymark Scheme Rules Rev 13
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

## Model PAVH-09V1FXC

Model name	PAVH-09V1FXC
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.82 kW	7.91 kW
El input	2.05 kW	2.87 kW
COP	4.30	2.76

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	61 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	178 %	129 %
Prated	8.49 kW	7.45 kW
SCOP	4.53	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.51 kW	6.59 kW
COP Tj = -7°C	2.99	1.93
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.60 kW	4.13 kW
COP Tj = +2°C	4.44	3.35
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.59 kW	4.32 kW

COP Tj = +7°C	6.27	4.64
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.20 kW	5.14 kW
COP Tj = 12°C	8.10	6.24
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.51 kW	6.59 kW
COP Tj = Tbiv	2.99	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	6.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	58 °C	58 °C
Poff	8 W	8 W
PTO	32 W	32 W
PSB	8 W	8 W
PCK	41 W	41 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.59 kW	1.22 kW
Annual energy consumption Qhe	3874 kWh	4675 kWh