

Subtype RSJ-16/190

| | |
|---------------------|--|
| Certificate Holder | GD Midea Heating & Ventilating Equipment Co., Ltd. |
| Address | Penglai Industry Road |
| ZIP | 528311 |
| City | Beijiao, Shunde, Foshan |
| Country | CN |
| Certification Body | ICIM S.p.A. |
| Subtype title | RSJ-16/190 |
| Registration number | ICIM-PDC-000039 |
| Heat Pump Type | Heat Pump for Domestic Hot Water (DHW) |
| Refrigerant | R134a |
| Mass of Refrigerant | 1.1 kg |
| Certification Date | 25.06.2019 |

Model RSJ-16/190

| | |
|-------------------------------------|---------------|
| Model name | RSJ-16/190 |
| Application | Heating + DHW |
| Units | Indoor |
| Climate zone (for heating) | n/a |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | No |

Heat Pump for Domestic Hot Water (DHW)

EN 12102-2 | Average Climate

| | |
|--------------------------|----------|
| Sound power level indoor | 51 dB(A) |
|--------------------------|----------|

EN 16147 | Average Climate

| | |
|---------------------------------|------------|
| Declared load profile | L |
| Efficiency η_{DHW} | 115 % |
| COP | 2.76 |
| Heating up time | 7:01 h:min |
| Standby power input | 26.3 W |
| Reference hot water temperature | 53.8 °C |
| Mixed water at 40°C | 234 l |