

## Subtype Monobloc Heat Pump Inverter-14

Certificate Holder	Arçelik A.S.
Address	Karaağaç Cad No.2-6, Sötlüce
ZIP	34445
City	Istanbul
Country	TR
Certification Body	BRE Global Limited
Subtype title	Monobloc Heat Pump Inverter-14
Registration number	041-K089-04
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.1 kg
Certification Date	03.06.2024
Testing basis	HP KEYMARK certification scheme rules rev. no.14
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

## Model GHPH-MM14

Model name	GHPH-MM14
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.34 kW	14.13 kW
El input	3.05 kW	4.69 kW
COP	4.71	3.01

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	65 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	177 %	125 %
Prated	13.54 kW	13.34 kW
SCOP	4.50	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.98 kW	11.80 kW
COP Tj = -7°C	2.56	2.05
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	7.30 kW	7.53 kW
COP Tj = +2°C	4.54	3.08
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.19 kW	4.73 kW

COP Tj = +7°C	5.77	4.10
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	5.30 kW	5.53 kW
COP Tj = 12°C	7.86	5.93
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.98 kW	11.80 kW
COP Tj = Tbiv	2.56	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.06 kW	11.85 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.38	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	20 W	20 W
PSB	7 W	7 W
PCK	28 W	28 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.48 kW	1.49 kW
Annual energy consumption Qhe	6220 kWh	8584 kWh